

Graph revision AD - internals01: Purchased-module envelopes per plan rule 6: 2 RO modules (120 dia x 500, one per train), 2 EDI stacks (150 x 150 x 400), UV
Graph revision AD - internals01: Potable bypass run DN25 Sch 40 at y 470, z 260 with risers - the potable share bypasses RO/EDI (node internals row; bypass
Graph revision AD - internals01: Module and pump envelope sizes and the piping layout are the layout choice (WO

Aqueous Solutions (owner) AQS-MFG-BMED_UPW_POLISH-INTERNALS01
BMED_UPW_POLISH fabrication drawing INTERNALS01 (AQS-PLAN-00
Type: fabrication drawing (GA / nozzle orientation / part sheet) Rev 86864657 Issued
Created: flow graph pipeline Approved: not approved (study)
Sheet 1 of 1 AQS-DWG-001