

Graph revision AD - insul01: Insulation jacket: OD 194.3 x 980 over the duct run; the isolating-flange end stays bare
Graph revision AD - insul01: Duty section 3: insulated to hold the wall above the acid dew point (M7; dew point held)
Graph revision AD - insul01: Thickness 40 mm is a study value; AQS-THM-003 states no thickness for this line (hold

Aqueous Solutions (owner) AQS-MFG-AFTERBURNER_FLUE-INSUL01
AFTERBURNER_FLUE fabrication drawing INSUL01 (AQS-PLAN-006 M
Type: fabrication drawing (GA / nozzle orientation / part sheet) Rev b26a2959 Issued
Created: flow graph pipeline Approved: not approved (study)
Sheet 1 of 1 AQS-DWG-001