




كلية الهندسة ببها
FACULTY OF ENGINEERING- BENHA



Benha University

Faculty of Engineering at Benha

Mechanical Power Engineering Program

Level 2 — Automatic Control(MEC 214)

Steam Turbine Protection Control System Simulation

PID-Based Steam Quality Protection of the Low-Pressure
Turbine Under Thermodynamic Disturbances

Prepared by: Ehab Osama Hamed

Supervised by: Dr. Mohamed Gafer

Term: Spring 2025–2026

Submission date: May 8, 2026

Technical Report

Abstract

This report documents, interprets, and technically deconstructs a MATLAB/XSteam simulation of a steam turbine protection control system in which low-pressure turbine exhaust steam quality is treated as the primary safety variable. The engineering objective of the project is not merely to regulate a generic temperature or power signal, but to preserve the thermodynamic dryness fraction of the exhaust steam so that the low-pressure turbine remains protected against excessive moisture carryover, droplet-induced blade erosion, efficiency loss, and long-term mechanical degradation. The simulation compares two philosophies: an intentionally weak fixed open-loop reheat command and a direct single-loop proportional–integral–derivative (PID) controller that modulates normalized re-heater input in response to deviations of steam quality from its nominal reference.

The importance of the problem is rooted in the physics of reheat Rankine-cycle operation. As steam expands through the low-pressure turbine, the state trajectory can approach or enter the two-phase region. Once this occurs, the appearance of suspended liquid droplets creates a severe materials and performance problem. Moisture at the final stages of a long-bladed LP turbine produces impact erosion, aerodynamic loss, local stress concentration, and reduced stage efficiency. In practical plants, the margin to unsafe exhaust wetness is affected by coordinated disturbances involving boiler thermal degradation, load demand, condenser performance deterioration, and steam flow variation. A protection-oriented controller must therefore respond to a safety-relevant thermodynamic variable rather than relying on fixed operating schedules.

The provided simulation is a reduced-order but physically interpretable model. It couples first-order thermal and pressure dynamics with steam-table property evaluation from XSteam, thereby retaining the essential thermodynamic nonlinearity associated with enthalpy, entropy, phase change, and steam quality. The present report explains the engineering purpose of every major equation in the code, the physical interpretation of each subsystem, the control philosophy behind filtering, anti-windup, rate limiting, and actuator saturation, and the reason the disturbance set is constructed to discriminate clearly between open-loop vulnerability and closed-loop protective action. The result is a graduate-level technical narrative of how a compact simulation can still express meaningful turbine-protection logic.

Keywords: steam turbine protection, steam quality control, reheater control, PID control, condenser disturbance, XSteam, reheat Rankine cycle, low-pressure turbine safety

Notation

P_{rh0}, T_{rh0}	Nominal reheater pressure and reheater outlet temperature
P_{c0}	Nominal condenser pressure
$\dot{m}_s$	Main steam mass flow rate entering the LP turbine model
η_{LP}	Low-pressure turbine isentropic efficiency
Q	Normalized reheater heat-input command
x	LP turbine exit steam quality (dryness fraction)
x_{ref}	Reference exhaust steam quality generated from the nominal thermodynamic state
x_{min}	Minimum acceptable steam quality threshold for safe operation
x_{crit}	Critical steam quality threshold below which protection margin is severely compromised
h_3	Actual specific enthalpy at the LP turbine inlet (reheater outlet)
h_{4s}	Isentropic LP turbine outlet specific enthalpy at condenser pressure
h_4	Actual LP turbine outlet specific enthalpy
h_f, h_g	Saturated liquid and saturated vapor enthalpy at the condenser pressure
s_3	LP turbine inlet specific entropy
T_b, T_{rh}	Boiler-side temperature state and reheater outlet temperature state
$\tau_b, \tau_{rh}, \tau_c, \tau_f$	Boiler, reheater, condenser, and steam-flow time constants
K_p, K_i, K_d	PID proportional, integral, and derivative gains
Δt	Numerical integration time step
IAE	Integral of absolute error
W	Approximate net power output

Contents

1	Introduction	1
2	Engineering Problem Definition	1
2.1	Steam Quality as a Protection Variable	2
2.2	Why Disturbances Matter	2
2.3	Why Condenser Drift is Treated as Dangerous in This Model	3
3	System Description	3
3.1	Boiler	3
3.2	Reheater	3
3.3	Low-Pressure Turbine	4
3.4	Condenser	4
3.5	Steam Flow Path and Dynamic Interactions	4
4	Thermodynamic Background	4
4.1	Rankine and Reheat Rankine Cycle Context	4
4.2	Enthalpy, Entropy, and Expansion Physics	6
4.3	Steam Quality and Moisture Formation	7
4.4	Why Reheat Temperature Matters	7
5	XSteam Integration	7
5.1	Why Steam Tables are Necessary	7
5.2	How the Code Uses XSteam	8
5.3	Physical Meaning of $h_3, h_{4s}, h_4, h_f, h_g$	8
5.4	Why This is Superior to Simplified Approximations	8
6	Dynamic Modeling Philosophy	8
6.1	Reduced-Order, Lumped-Parameter Structure	9
6.2	Why First-Order Dynamics are Reasonable Here	9
6.3	Why High-Fidelity CFD/FEA Was Not Used	9
7	Disturbance Modeling	10

7.1	Smooth Disturbance Pulses	10
7.2	Physical Meaning of Each Disturbance	10
8	Controller Architecture	10
8.1	Open-Loop Philosophy	10
8.2	PID Control Philosophy	12
8.3	Anti-Windup, Saturation, and Rate Limiting	12
9	MATLAB Code Architecture	13
10	Detailed MATLAB Code Walkthrough	13
10.1	Initialization and Dependency Check	13
10.2	Nominal Parameters and Reference Quality	14
10.3	Time Base, Numerical Resolution, and Metrics Philosophy	15
10.4	Disturbance Synthesis	15
10.5	Controller Definition	16
10.6	Core Simulation Loop	16
10.7	Steam Quality Function	19
10.8	Metric Calculation and Why it is Robust	19
11	Performance Metrics	20
12	Simulation Results Analysis	20
12.1	Observed Open-Loop Response	22
12.2	Observed PID Response	22
12.3	Steam-Quality Recovery and Safety Margin Improvement	22
12.4	Thermal Behavior, Pressure Behavior, and Control Effort	23
12.5	System Stability and Control Realism	23
13	Engineering Interpretation	24
13.1	Why PID Succeeds	24
13.2	Why Open-Loop Fails	24
13.3	Industrial Significance	24

14 Limitations of the Current Model	25
15 Future Improvements	25
16 Conclusion	26

1 Introduction

Steam turbines remain the dominant work-producing devices in large-scale thermal power generation because they convert the enthalpy of high-temperature pressurized steam into shaft work with high reliability and strong compatibility with the Rankine cycle. In utility-scale reheat plants, the thermodynamic purpose of reheating is to recover part of the temperature level that is lost during the first phase of expansion and to increase the dryness fraction during the downstream low-pressure expansion. This is not an incidental refinement; it is a deliberate design measure to reduce moisture at the LP exhaust, improve cycle efficiency, and protect long final-stage blades from liquid droplet impingement.

The present MATLAB model addresses a particularly important operational question: how should a plant respond when multiple disturbances drive the LP exhaust steam quality toward unsafe values? The code does not frame the problem merely as one of maximizing power or tracking a temperature setpoint. Instead, it places steam quality x at the center of the protection strategy. This choice is significant from an engineering standpoint because the directly damaging phenomenon in the final stages of the turbine is the formation of a wet mixture, not simply the deviation of one thermal state variable. In other words, the control objective is not general process regulation alone; it is the preservation of thermodynamic phase margin.

In a reheat Rankine plant, the low-pressure turbine exhaust condition depends strongly on the upstream reheat temperature, the reheat pressure, the condenser pressure, the actual turbine efficiency, and the overall disturbance environment. A rise in plant load may demand greater mass flow and alter the thermal balance. Boiler degradation can reduce the available temperature level. Condenser deterioration can reflect degraded heat rejection and vacuum performance. Each of these mechanisms changes the trajectory of the expansion process and therefore the outlet quality. The script provided by the user assembles these effects into a compact dynamic model and then compares two control philosophies: a weak open-loop reheater setting and a direct PID controller.

The importance of such a study extends beyond academic simulation. In industrial plants, prolonged operation with poor exhaust steam quality leads to erosion, pitting, roughening of blade surfaces, higher aerodynamic loss, and potentially accelerated maintenance intervals. The cost is not only thermodynamic inefficiency. It is a combined safety, reliability, availability, and asset-life problem. For that reason, a detailed report on this simulation must explain not just how the MATLAB script is written, but why each physical relation, disturbance, controller feature, and metric matters from the viewpoint of turbine protection engineering.

2 Engineering Problem Definition

2.1 Steam Quality as a Protection Variable

Steam quality, commonly denoted by x , is the mass fraction of vapor in a saturated liquid–vapor mixture:

$$x = \frac{m_v}{m_v + m_l}, \quad 0 \leq x \leq 1, \quad (1)$$

where m_v and m_l are the vapor and liquid masses, respectively. A value of $x = 1$ corresponds to dry saturated vapor or a superheated state interpreted as fully dry for the purpose of moisture assessment, whereas $x < 1$ indicates the presence of suspended liquid droplets. For turbine protection, the dryness fraction is the relevant quantity because droplet formation is what initiates erosion and wetness losses in the final stages.

The code defines two safety thresholds:

$$x_{\min} = 0.90, \quad x_{\text{crit}} = 0.885. \quad (2)$$

These values are engineering protection limits within the context of the simulation. The first threshold marks the onset of unacceptable operation from a durability perspective, while the second marks a still more severe condition in which the turbine is presumed to be in a clearly compromised moisture regime. Even if different industrial plants adopt different limits depending on stage design, exhaust geometry, and erosion allowance, the modeling logic is sound: the controller must maintain a measurable margin above a physically meaningful wetness boundary.

2.2 Why Disturbances Matter

Open-loop scheduling is vulnerable because it assumes that the process behaves as expected under nominal conditions. The provided code deliberately demonstrates the weakness of that assumption. The open-loop reheater command is fixed at $Q = 0.76$, which is lower than the nominal value $Q_{\text{nom}} = 0.80$. This means the open-loop case begins with a smaller thermal margin even before major disturbances arrive. Since the coefficient in the reheater equation is $260(Q - Q_{\text{nom}})$, this fixed reduction of 0.04 p.u. removes approximately

$$260 \times (-0.04) \approx -10.4 \text{ K} \quad (3)$$

from the reheater equilibrium temperature. In protection terms, the open-loop policy is intentionally underpowered.

The disturbance set is also engineered to create a quality-critical environment. Boiler degradation reduces the thermal source. Load increase tends to raise mass-flow demand and thermal extraction. Condenser deterioration is modeled as the dominant stressor, because in the reduced-order simulation it acts as an aggregate indicator of degraded heat rejection, increased back-pressure stress, and reduced operating margin. The key point is that none of these disturbances is isolated in practice: real plants experience coupled degradations. A fixed reheater setting cannot recognize when the thermodynamic state trajectory is drifting toward the saturation dome; a feedback controller can.

2.3 Why Condenser Drift is Treated as Dangerous in This Model

In a fully detailed plant analysis, the exact influence of exhaust pressure on quality depends on the inlet state and must be computed from steam tables, not guessed heuristically. That is precisely why the code uses XSteam. In the present reduced-order model, however, condenser disturbance is intentionally defined as the quality-critical disturbance because it stands for a broader deterioration of vacuum performance and heat rejection. It enters the model in several ways: it raises the condenser-pressure state, it imposes a direct penalty on net power, and it weakly depresses reheater equilibrium temperature. The control problem is therefore to maintain moisture safety despite a disturbance that degrades the thermodynamic operating envelope and shifts the LP turbine away from its preferred margin.

3 System Description

The physical plant represented in the code is a simplified reheat steam-power subsystem focused on the part of the cycle most relevant to LP turbine moisture protection. The major subsystems are the boiler, the reheater, the low-pressure turbine, and the condenser. The modeled steam path is conceptually straightforward: heat is supplied in the boiler, thermal margin is re-established or adjusted in the reheater, work is produced in the low-pressure turbine during expansion, and residual heat is rejected in the condenser.

3.1 Boiler

The boiler provides the primary thermal energy that elevates feedwater into high-pressure, high-temperature steam. In the simulation, the boiler is not modeled with distributed furnace, economizer, evaporator, and superheater dynamics. Instead, its effect is represented by a single temperature-like state T_b . This state serves as the upstream thermal reservoir from which the reheater inherits a substantial fraction of its equilibrium behavior. That design choice is reasonable for a control-oriented model because the question of interest is not combustion chemistry or heat-transfer surface distribution, but how upstream thermal degradation alters the LP exhaust quality margin.

3.2 Reheater

The reheater is the controlled thermal actuator in the model. Its purpose is to restore temperature after earlier expansion and thereby reduce the tendency of the LP turbine expansion path to penetrate deeply into the wet region. In the script, the controller does not manipulate a physical valve position directly; instead, it manipulates a normalized reheater command Q . This is an abstraction of the available reheating authority. The reheater state T_{rh} is therefore the dominant manipulated thermodynamic variable,

because increased T_{rh} raises inlet enthalpy and usually increases the dryness margin at the turbine outlet.

3.3 Low-Pressure Turbine

The LP turbine receives reheated steam at the nominal state

$$P_{rh0} = 2.0 \text{ MPa}, \quad T_{rh0} = 773.15 \text{ K} = 500^\circ\text{C}. \quad (4)$$

Expansion to the condenser pressure produces shaft work and determines the outlet quality. The code does not include a shaft-speed state, rotor inertia, stagewise pressure distribution, or blade-row aerodynamics. Instead, the LP turbine is represented thermodynamically through inlet property calculation, isentropic reference expansion, isentropic efficiency, and outlet enthalpy reconstruction. This is exactly the appropriate level of detail for a study centered on moisture protection rather than electromechanical transient behavior.

3.4 Condenser

The condenser rejects latent heat from the exhaust steam and establishes the back-pressure against which the LP turbine expands. In a real plant, condenser performance depends on circulating-water temperature, flow rate, fouling, air in-leakage, non-condensable gases, tube cleanliness, and heat-exchanger integrity. The model condenses these effects into a single state P_c with a first-order response. Although simplified, this is a strong engineering abstraction because condenser performance is one of the most influential determinants of LP turbine operating condition.

3.5 Steam Flow Path and Dynamic Interactions

The subsystems interact dynamically rather than independently. Boiler degradation lowers the upstream temperature basis. That reduced thermal reservoir lowers reheater equilibrium temperature. Load increase raises both heat demand and steam-flow demand. Condenser degradation alters the back-pressure state and also imposes a power penalty. Steam-flow variation changes the approximate power output and affects how hard the thermal system must work to maintain safety. The simulation therefore embodies the correct control intuition: turbine protection is not a single-component problem but a coupled thermal–thermodynamic problem.

4 Thermodynamic Background

4.1 Rankine and Reheat Rankine Cycle Context

The thermodynamic context of the script is the reheat Rankine cycle. In the conventional Rankine cycle, water is pressurized, evaporated, superheated, expanded through a

Table 1: *Nominal plant and control-oriented model parameters extracted from the MATLAB script.*

Quantity	Symbol	Value	Engineering interpretation
Reheater pressure	P_{rh0}	2.0 MPa	Nominal LP turbine inlet pressure
Reheater outlet temperature	T_{rh0}	773.15 K	Nominal LP turbine inlet temperature
Condenser pressure	P_{c0}	10 kPa	Nominal exhaust/back-pressure condition
Steam mass flow	$\dot{m}_0$	50 kg/s	Nominal steam throughput used in power scaling
LP isentropic efficiency	η_{LP}	0.86	Conversion from ideal to actual LP expansion
Superheated specific heat surrogate	$c_{p,sup}$	2180 J/(kg K)	Simplified power-model coefficient
Nominal reheater command	Q_{nom}	0.80 p.u.	Baseline reheater duty used by the PID controller
Open-loop reheater command	Q_{open}	0.76 p.u.	Intentionally weak fixed command for comparison
Safety threshold	x_{min}	0.90	Minimum acceptable exhaust quality
Critical threshold	x_{crit}	0.885	Severe protection-loss threshold
Simulation step	Δt	0.5 s	Explicit Euler integration step
Simulation horizon	t_{end}	1500 s	Actual numerical horizon; note that the code comment incorrectly labels this as 20 min, whereas 1500 s equals 25 min




Figure 1: Enlarged control-oriented block diagram of the steam turbine protection simulation. The manipulated variable is the reheater command Q , the protected variable is LP turbine exit quality x , and XSteam provides the thermodynamic state reconstruction needed to evaluate moisture risk.

turbine, and finally condensed. Reheat is introduced between turbine stages to increase the average temperature of heat addition and, critically for turbine durability, to reduce moisture formation during the final stages of expansion. If the inlet to the LP turbine is reheated sufficiently, the expansion line in the T - s or h - s plane begins farther into the superheated region and intersects the low-pressure boundary with a higher dryness fraction than it otherwise would.

This is the thermodynamic rationale behind manipulating reheater input in the present control problem. The controller is not arbitrarily heating steam; it is moving the LP inlet state away from the wetness boundary and thereby increasing the likelihood that the LP exhaust remains above the safety threshold. The reheater therefore becomes a protective energy-management device.

4.2 Enthalpy, Entropy, and Expansion Physics

For adiabatic turbine analysis, the key state variables are pressure, temperature, specific enthalpy h , and specific entropy s . In a steady adiabatic turbine with negligible kinetic and potential energy differences, the shaft work per unit mass is approximately the enthalpy drop:

$$w_t \approx h_{in} - h_{out}. \quad (5)$$

If the expansion were internally reversible, the entropy would remain constant and the outlet enthalpy would be the isentropic value. The code uses exactly this logic by calculating the actual inlet enthalpy h_3 , the inlet entropy s_3 , and the isentropic outlet enthalpy h_{4s} at the condenser pressure.

The LP turbine isentropic efficiency is then defined by

$$\eta_{LP} = \frac{h_3 - h_4}{h_3 - h_{4s}}, \quad (6)$$

which can be rearranged to the implemented form

$$h_4 = h_3 - \eta_{LP} (h_3 - h_{4s}). \quad (7)$$

Equation (7) is central to the entire report because it translates a nominal efficiency assumption into an actual exhaust state and therefore into a moisture condition.

4.3 Steam Quality and Moisture Formation

Inside the two-phase region, quality can be computed from enthalpy as

$$x = \frac{h - h_f}{h_g - h_f}, \quad h_f < h < h_g, \quad (8)$$

where h_f and h_g are the saturated liquid and saturated vapor enthalpies at the relevant pressure. If $h \geq h_g$, the state is treated as fully dry in the model and $x = 1$. If $h \leq h_f$, the model returns $x = 0$.

The physical interpretation of (8) is important. The enthalpy h of a wet mixture is a weighted combination of the saturated liquid and saturated vapor enthalpies. Quality is therefore not merely an empirical number; it is a normalized thermodynamic coordinate inside the saturation dome. Because blade erosion is driven by liquid content, converting the LP exhaust enthalpy to quality is the correct way to link thermodynamics to protection.

4.4 Why Reheat Temperature Matters

Raising reheater outlet temperature increases inlet enthalpy and usually shifts the entire LP expansion path upward in terms of energy content. For a fixed condenser pressure and turbine efficiency, this tends to increase the outlet quality or at least improve the dry margin. Conversely, if reheater temperature falls due to boiler degradation, insufficient reheater command, or load-induced thermal stress, the LP turbine starts from a thermodynamically weaker state and is more likely to leave the expansion with unacceptable moisture content.

5 XSteam Integration

5.1 Why Steam Tables are Necessary

The project uses XSteam because saturated and superheated steam properties are strongly nonlinear, especially near the phase boundary. A constant- c_p approximation is acceptable for rough superheated calculations far from the saturation dome, but it is not adequate for determining exhaust quality in a safety-focused turbine study. The wetness boundary is governed by the steam tables, not by a linearized caloric model. Therefore, the use of XSteam is not a convenience feature; it is the element that preserves thermodynamic credibility.

5.2 How the Code Uses XSteam

The function `steam_quality_xsteam` converts the SI-state variables used in the simulation to the units expected by XSteam and then evaluates the following quantities:

$$h_3 = \text{XSteam}('h_pt', p_{rh}, T_{rh}), \quad (9)$$

$$s_3 = \text{XSteam}('s_pt', p_{rh}, T_{rh}), \quad (10)$$

$$h_{4s} = \text{XSteam}('h_ps', p_c, s_3), \quad (11)$$

$$h_f = \text{XSteam}('hL_p', p_c), \quad (12)$$

$$h_g = \text{XSteam}('hV_p', p_c). \quad (13)$$

The actual exit enthalpy is then constructed using the turbine efficiency as in (7), after which the quality is determined from (8).

5.3 Physical Meaning of $h_3, h_{4s}, h_4, h_f, h_g$

The meaning of these quantities should be explicit:

- h_3 is the actual thermal energy content per unit mass entering the LP turbine.
- h_{4s} is the ideal outlet enthalpy that would occur if expansion to the condenser pressure were reversible and adiabatic.
- h_4 is the actual outlet enthalpy after losses are considered through the isentropic efficiency.
- h_f is the enthalpy of saturated liquid at the condenser pressure.
- h_g is the enthalpy of saturated vapor at the condenser pressure.

Together, these quantities define whether the LP turbine exhaust is superheated, dry saturated, or wet. They therefore anchor the protection problem in real thermodynamic property relations rather than purely empirical thresholds.

5.4 Why This is Superior to Simplified Approximations

A simplified approximation could have represented quality as a linear function of temperature and pressure. That would have been faster but physically weak. Near saturation, small errors in enthalpy or entropy can correspond to important errors in moisture prediction. Because the entire safety objective depends on distinguishing $x = 0.905$ from $x = 0.885$, the property model must be more faithful than the reduced-order dynamics surrounding it. The code correctly places thermodynamic accuracy where it matters most: at the phase-boundary decision.

6 Dynamic Modeling Philosophy

6.1 Reduced-Order, Lumped-Parameter Structure

The simulation is intentionally reduced-order. Instead of solving distributed heat-transfer PDEs, multistage turbine flow equations, and condenser two-phase transport, it uses four main first-order states: boiler temperature T_b , reheater temperature T_{rh} , condenser pressure P_c , and steam mass flow $\dot{m}_s$. This philosophy is standard in control-oriented engineering modeling. The goal is not geometric fidelity but dynamic interpretability. A protection study needs the dominant time scales and couplings, not every local field variable.

The generic first-order structure used repeatedly in the code is

$$y_{k+1} = y_k + \frac{\Delta t}{\tau} (y_{eq,k} - y_k), \quad (14)$$

which is the explicit Euler discretization of

$$\tau \dot{y} = y_{eq} - y. \quad (15)$$

Equation (14) means that each state relaxes toward a disturbance-dependent or control-dependent equilibrium value with its own characteristic time constant.

6.2 Why First-Order Dynamics are Reasonable Here

The chosen time constants are

$$\tau_b = 80 \text{ s}, \quad \tau_{rh} = 30 \text{ s}, \quad \tau_c = 90 \text{ s}, \quad \tau_f = 18 \text{ s}. \quad (16)$$

These values encode plausible relative speeds: steam-flow adjustment is fastest, reheater thermal response is faster than large boiler thermal inertia, and condenser pressure changes are comparatively slow because they reflect the dynamics of heat rejection and vacuum behavior. The time step is 0.5 s, so even the fastest time constant is resolved by a factor of 36. This is more than adequate for stable explicit integration in a smooth first-order model.

6.3 Why High-Fidelity CFD/FEA Was Not Used

A full CFD or FEA model would require distributed geometry, stagewise blade aerodynamics, wet-steam nucleation physics, conjugate heat transfer, condenser heat-exchanger modeling, shaft dynamics, and likely much smaller time steps. Such a model would be indispensable for blade design or final certification, but it would be inappropriate for the pedagogical and control-architecture purpose of this project. The present simulation sacrifices geometric resolution in order to make the control logic transparent. That is a valid engineering trade: high conceptual clarity at the system level in exchange for reduced local fidelity.

7 Disturbance Modeling

7.1 Smooth Disturbance Pulses

The disturbance generator is

$$y(t) = \text{clamp} \left[\frac{1}{2} \left(1 + \tanh \frac{t - t_{on}}{\tau_{on}} \right) - \frac{1}{2} \left(1 + \tanh \frac{t - t_{off}}{\tau_{off}} \right), 0, 1 \right]. \quad (17)$$

This is an engineeringly sensible alternative to an ideal step input. Real thermal and mechanical disturbances are rarely discontinuous; they ramp through actuator, fluid, and equipment lags. The smooth pulse also avoids injecting unrealistically high-frequency content into the derivative term of the controller and into the first-order plant states.

7.2 Physical Meaning of Each Disturbance

The disturbance set is intentionally broad:

- **Boiler degradation** reduces available upstream temperature margin and therefore weakens reheating potential.
- **Load increase** demands more from the thermal system, increases steam-flow requirement, and degrades thermal equilibrium.
- **Condenser drift** represents deteriorated heat-rejection performance and acts as the dominant protection stressor in the model.
- **Steam-flow variation** alters throughput and changes the approximate power balance.

The disturbances are “long and discriminating” because they are designed to separate the failure mode of open-loop operation from the recovery mechanism of the PID controller. They are not random disturbances; they are curated test scenarios.

A notable feature is the overlap of the two condenser pulses between 420 s and 520 s, which means the condenser disturbance can reach approximately $1 + 0.10 + 0.42 = 1.52$ before clamping. At nominal 10 kPa, this drives the equilibrium condenser-pressure multiplier close to 15.2 kPa even before the load-coupling factor is applied. This is a strong perturbation and explains why the script labels it quality-critical.

8 Controller Architecture

8.1 Open-Loop Philosophy


The open-loop case is intentionally simple and intentionally weak. It sets

$$Q = Q_{open} = 0.76 \quad (18)$$

for the entire simulation. This case is not meant to represent best industrial practice; it is meant to show the inherent limitation of fixed actuation in a plant whose thermodynamic

Table 2: *Disturbance schedule embedded in the MATLAB code.*

Disturbance	Active interval	Magnitude	Interpretation
Boiler pulse 1	60 s to 280 s	−30% in d_{boiler}	Major early thermal degradation
Boiler pulse 2	520 s to 720 s	−10% in d_{boiler}	Secondary thermal weakening
Load pulse 1	120 s to 360 s	+8% in d_{load}	Moderate demand rise
Load pulse 2	640 s to 860 s	+10% in d_{load}	Stronger later demand rise
Condenser pulse 1	180 s to 520 s	+10% in d_{cond}	Initial condenser deterioration
Condenser pulse 2	420 s to 960 s	+42% in d_{cond}	Dominant quality-critical condenser stress
Flow pulse 1	150 s to 340 s	+2% in d_{flow}	Mild throughput increase
Flow pulse 2	660 s to 900 s	+3% in d_{flow}	Additional throughput increase

**Figure 2:** *Project-supplied disturbance visualization summarizing the four disturbance classes used to stress the protection system. The exact final MATLAB script employs smooth hyperbolic-tangent pulses and clamped amplitudes, but the figure remains a useful qualitative map of the disturbance categories acting on boiler heat input, load demand, condenser behavior, and flow variation.*

margin varies with time. When disturbances accumulate, a fixed reheater input cannot know whether the exhaust state is approaching the wet region.

8.2 PID Control Philosophy

The PID controller closes the loop directly around the protected variable. The error is

$$e = x_{ref} - x_f, \quad (19)$$

where x_f is a filtered estimate of the measured quality. The measurement filter is itself a first-order state:

$$x_{f,k+1} = x_{f,k} + \frac{\Delta t}{\tau_x}(x_k - x_{f,k}), \quad (20)$$

with $\tau_x = 12$ s. This filter has two roles. First, it reflects the fact that practical estimators or measured thermodynamic indicators are not infinitely fast. Second, it avoids differentiating a noisy or highly nonlinear raw quality signal.

The controller target is

$$Q_{target} = Q_{nom} + K_p e + K_i I - K_d \dot{x}_f, \quad (21)$$

where I is the integral state and $\dot{x}_f$ is the discrete derivative of the filtered measurement. The negative sign on the derivative term is physically meaningful: if quality is rapidly decreasing, then $\dot{x}_f < 0$, so the derivative contribution becomes positive and immediately pushes reheater input upward. Thus, the derivative term acts as anticipatory protection rather than after-the-fact correction.

8.3 Anti-Windup, Saturation, and Rate Limiting

The controller is not allowed to integrate indefinitely when the actuator is already saturated in the same direction as the error. This conditional integration implements a practical anti-windup policy. The integrator is also bounded by

$$|I| \leq 8.0, \quad (22)$$

which prevents slow drift from accumulating unrealistic command authority.

Actuator realism is introduced through three layers:

1. hard saturation: $Q \in [0.35, 1.00]$,
2. first-order smoothing with $\tau_q = 10$ s,
3. rate limiting with $\Delta Q_{max} = 0.02$ per time step.

Because the time step is 0.5 s, the rate limiter corresponds to a maximum effective command slew of approximately 0.04 pu/s. Therefore, even if the controller demanded a full jump from 0.35 to 1.00, it would require at least

$$\frac{1.00 - 0.35}{0.04} \approx 16.25 \text{ s} \quad (23)$$

to execute, not including the actuator lag. This is a very important realism feature: protection is strong, but not physically instantaneous.

Table 3: *Controller settings used in the simulation.*

Parameter	Value	Role in the protection problem
Open-loop command Q_{open}	0.76	Fixed reheater setting used to demonstrate lack of adaptability
K_p	6.5	Aggressive proportional correction against quality loss
K_i	0.012	Slow elimination of steady-state error
K_d	0.050	Early compensation against rapid deterioration of quality
Integral limit	8.0	Prevents excessive stored integral bias
Measurement-filter constant τ_x	12 s	Filters the thermodynamic quality signal
Actuator-lag constant τ_q	10 s	Represents finite reheater/actuator response
Rate limit dQ_{max}	0.020 per step	Imposes realistic reheater slew-rate constraints

9 MATLAB Code Architecture

The script is organized in a disciplined way that mirrors the engineering workflow of a simulation study. It begins with physical parameter definition, proceeds to disturbance synthesis, defines controller options, executes two simulation cases, computes performance metrics, and then prepares visualization dashboards. The local functions at the end encapsulate the plant dynamics, property calculations, metrics, and utility operators.

From a software-engineering standpoint, this organization is good practice because it makes the model traceable. From an engineering standpoint, it allows each assumption to be located in a distinct block: thermodynamic assumptions in the XSteam function, dynamic assumptions in the state updates, control assumptions in the PID logic, and interpretation assumptions in the metrics.

10 Detailed MATLAB Code Walkthrough

10.1 Initialization and Dependency Check

The script begins with

Listing 1: *Initialization and XSteam dependency validation.*

Table 4: *Functional organization of the MATLAB script.*

Code block	Primary purpose	Engineering meaning
Section 1	Nominal parameter definition	Establishes the baseline thermodynamic operating point and safety limits
Section 2	Time base and metrics setup	Defines the observation horizon, resolution, and evaluation philosophy
Section 3	Disturbance generation	Builds a realistic stress environment for the protection study
Section 4	Controller settings	Encodes open-loop vulnerability and PID protective capability
Section 5	Simulation calls	Runs the plant under both control philosophies
Section 6	Summary numbers	Produces condensed quantitative comparison
Section 7	Plotting system	Generates physically interpretable diagnostic figures
Local functions	Dynamics, thermodynamics, metrics, utilities	Separate the model logic from visualization and keep the script modular

```

1 clear;
2 clc;
3
4 if exist('XSteam','file') ~= 2
5     error('XSteam not found. Add the XSteam folder to the MATLAB path first.');
```

This block is not trivial housekeeping. The `clear` and `clc` commands ensure that no stale variables or previous property functions pollute the current simulation. The `exist` check is especially important because the thermodynamic validity of the entire protection study depends on XSteam. If XSteam is missing, the correct engineering action is not to continue with a degraded approximation; it is to terminate the run and force the user to restore the property library.

10.2 Nominal Parameters and Reference Quality

The next block defines the operating point:

Listing 2: *Nominal parameter block and generation of the quality reference.*

```

1 p.P_rh0 = 2.00e6;
2 p.T_rh0 = 773.15;
3 p.P_c0 = 10.0e3;
4 p.m_dot0 = 50.0;
5 p.eta_LP = 0.86;
```

```

6 p.cp_sup = 2180;
7
8 p.T_b0   = 773.15;
9 p.W_nom  = 120.0;
10 ...
11 p.x_ref = steam_quality_xsteam(p.T_rh0, p.P_rh0, p.P_c0, p.eta_LP);

```

Every one of these lines has a physical purpose. The pressure and temperature pair (P_{rh0}, T_{rh0}) define the LP turbine inlet state. The condenser pressure P_{c0} defines the exhaust reference pressure. The steam flow $\dot{m}_0$ and the specific heat surrogate $c_{p,sup}$ are used in the approximate power model. The LP turbine efficiency converts an ideal expansion into an actual one.

The most important design choice in this block is the calculation of x_{ref} using the thermodynamic helper function. The controller does not use an arbitrary setpoint such as 0.95. Instead, it calculates the reference quality implied by the nominal thermodynamic operating point. This is excellent practice because it means the controller protects the design point the plant is supposed to achieve, not an imposed value detached from the underlying physics.

10.3 Time Base, Numerical Resolution, and Metrics Philosophy

The time discretization block specifies

Listing 3: *Time base and metric-evaluation settings.*

```

1 p.t_end = 1500;
2 p.dt    = 0.5;
3 p.t     = (0:p.dt:p.t_end)';
4 ...
5 p.metric_start_s = 60;
6 p.final_window_s = 60;
7 p.settle_hold_s  = 45;
8 p.settle_band_x  = 0.0040;

```

The comment in the code labels 1500 s as 20 min, but numerically it is 25 min. The model uses the numeric value, not the comment. This is a small but important documentation detail.

The metrics do not begin at $t = 0$; they begin after 60 s. This is defensible because the early transient may include initialization effects not representative of disturbance response. The settling definition is also deliberately strict: the response must remain within a narrow band of ± 0.004 around x_{ref} for 45 s. This avoids the common mistake of declaring a response settled after a brief accidental crossing.

10.4 Disturbance Synthesis

The disturbance block creates eight smooth pulses and then combines them:

Listing 4: *Smooth disturbance synthesis.*

```

1 pulse_boiler1 = smooth_pulse(p.t, 60, 280, 14, 45);
2 pulse_boiler2 = smooth_pulse(p.t, 520, 720, 18, 60);
3 ...
4 p.d_boiler = clamp(1 - 0.30 * pulse_boiler1 - 0.10 * pulse_boiler2, 0.55, 1.05);
5 p.d_load   = clamp(1 + 0.08 * pulse_load1   + 0.10 * pulse_load2,   1.00, 1.24);
6 p.d_cond   = clamp(1 + 0.10 * pulse_cond1   + 0.42 * pulse_cond2,   1.00, 1.58);
7 p.d_flow   = clamp(1 + 0.02 * pulse_flow1   + 0.03 * pulse_flow2,   0.98, 1.08);

```

These lines construct a carefully shaped environment in which the controller must prove that it protects quality under overlapping stressors. The use of `clamp` is physically meaningful: it prevents the disturbance multipliers from reaching nonsensical values and encodes engineering bounds on how severe the reduced-order disturbances are allowed to become.

10.5 Controller Definition

The controller settings are then declared in a compact but conceptually rich block:

Listing 5: *Open-loop and PID controller definitions.*

```

1 ctrl_open.name   = 'Open-loop';
2 ctrl_open.mode   = 'open';
3 ctrl_open.Q_open = 0.76;
4
5 ctrl_pid.name    = 'PID-only';
6 ctrl_pid.mode    = 'pid';
7 ctrl_pid.Kp      = 6.5;
8 ctrl_pid.Ki      = 0.012;
9 ctrl_pid.Kd      = 0.050;
10 ctrl_pid.int_lim = 8.0;
11 ctrl_pid.tau_x   = 12.0;
12 ctrl_pid.tau_q   = 10.0;
13 ctrl_pid.dQ_max  = 0.020;

```

The open-loop case is fixed and intentionally underpowered. The PID case is explicitly labeled PID-only, which means that no feedforward from load, condenser pressure, or steam flow is used. All compensation occurs through feedback on the protected variable. That makes the controller both easier to interpret and more demanding, because it must infer disturbance severity entirely through the quality response.

10.6 Core Simulation Loop

The central engineering content of the code lives in `simulate_case`. The loop first computes the true quality from `XSteam`, then updates the controller, then updates the plant states. This order is physically intuitive: the controller reacts to the current plant condition and then the plant evolves.

10.6.1 Filtered Quality and PID Law

The filtered measurement update is

$$x_{f,k+1} = x_{f,k} + \frac{\Delta t}{\tau_x}(x_k - x_{f,k}), \quad (24)$$

followed by the derivative approximation

$$\dot{x}_{f,k} \approx \frac{x_{f,k+1} - x_{f,k}}{\Delta t}. \quad (25)$$

The error is $e_k = x_{ref} - x_{f,k+1}$. If the actuator is not saturated in the same direction as the error, the integrator is updated and bounded. The PID target is then formed according to (21). In physical terms, the proportional term reacts immediately to loss of dryness fraction, the integral term restores long-term thermodynamic margin, and the derivative term suppresses rapid deterioration.

10.6.2 Boiler Equilibrium Temperature

The boiler equilibrium relation is coded as

$$T_{b,eq} = T_{b0} + 230(d_{boiler} - 1) - 70(d_{load} - 1). \quad (26)$$

Equation (26) means that boiler degradation and rising load both reduce the effective upstream thermal state. Because $d_{boiler} < 1$ during degradation, the first term is negative. A 30% boiler reduction lowers $T_{b,eq}$ by about 69 K, which is a large thermodynamic insult. The state then relaxes according to

$$T_{b,k+1} = T_{b,k} + \frac{\Delta t}{\tau_b}(T_{b,eq,k} - T_{b,k}). \quad (27)$$

Thus, the boiler does not jump; it lags.

10.6.3 Reheater Equilibrium Temperature

The reheater equilibrium temperature is one of the most important equations in the entire simulation:

$$T_{rh,eq} = T_{rh0} + 0.78(T_{b,k+1} - T_{b0}) + 260(Q_{k+1} - Q_{nom}) - 25(d_{load} - 1) - 6(d_{cond} - 1). \quad (28)$$

This equation deserves detailed interpretation:

- The coefficient 0.78 says the reheater inherits most, but not all, of the upstream boiler thermal change.
- The coefficient 260 gives the controller substantial authority. A full increase from $Q_{nom} = 0.80$ to $Q = 1.00$ adds approximately 52 K to the reheater equilibrium temperature.

- Load rise directly subtracts thermal margin, reflecting increased plant demand.
- Condenser degradation weakly reduces reheater equilibrium temperature, representing a broader plant deterioration coupling.

The actual reheater state then follows

$$T_{rh,k+1} = T_{rh,k} + \frac{\Delta t}{\tau_{rh}}(T_{rh,eq,k} - T_{rh,k}). \quad (29)$$

This is the thermal pathway through which the controller protects steam quality.

10.6.4 Condenser Pressure Equation

The condenser equation is

$$P_{c,eq} = P_{c0} d_{cond} (1 + 0.12(d_{load} - 1)). \quad (30)$$

Equation (30) means that load increase makes condenser deterioration worse, which is physically plausible: higher plant duty increases the rejection burden. The condenser state then evolves according to

$$P_{c,k+1} = P_{c,k} + \frac{\Delta t}{\tau_c}(P_{c,eq,k} - P_{c,k}). \quad (31)$$

The code therefore represents condenser behavior as a slowly moving back-pressure state rather than an instantaneous algebraic disturbance.

10.6.5 Steam Flow Equation

The steam-flow state is based on

$$\dot{m}_{eq} = \dot{m}_0 d_{flow} (1 + 0.45(d_{load} - 1)), \quad (32)$$

followed by

$$\dot{m}_{k+1} = \dot{m}_k + \frac{\Delta t}{\tau_f}(\dot{m}_{eq,k} - \dot{m}_k). \quad (33)$$

This equation makes physical sense: load growth increases throughput demand, and the explicit flow disturbance introduces additional variability. The time constant 18 s makes the flow state the fastest dynamic channel in the model.

10.6.6 Approximate Power Equation

The power model is intentionally approximate:

$$W = C_{scale} \times 10^{-6} \dot{m} c_{p,sup} \max(T_{rh} - 373.15, 10) \eta_{LP} \Pi_c, \quad (34)$$

where the condenser penalty is

$$\Pi_c = 1 - 0.10 \max\left(\frac{P_c}{P_{c0}} - 1, 0\right). \quad (35)$$

This is not a full first-law turbine-generator calculation. Instead, it is a calibrated surrogate. The factor C_{scale} is chosen so that the nominal condition reproduces the desired nominal power of 120 MW. The use of $T_{rh} - 373.15$ means that available thermal margin is measured relative to 100 °C, which acts as a practical baseline. The result is dimensionally meaningful and dynamically useful, even though it is not a rigorous enthalpy-drop power model.

10.7 Steam Quality Function

The thermodynamic helper function is shown below.

Listing 6: *Steam-quality calculation based on XSteam.*

```

1 function x = steam_quality_xsteam(T_rh_K, P_rh_Pa, P_c_Pa, eta)
2     p_rh_bar = P_rh_Pa / 1e5;
3     p_c_bar  = P_c_Pa / 1e5;
4     T_rh_C   = T_rh_K - 273.15;
5
6     h3 = XSteam('h_pt', p_rh_bar, T_rh_C);
7     s3 = XSteam('s_pt', p_rh_bar, T_rh_C);
8     h4s = XSteam('h_ps', p_c_bar, s3);
9     h4 = h3 - eta * (h3 - h4s);
10
11     hf = XSteam('hL_p', p_c_bar);
12     hg = XSteam('hV_p', p_c_bar);
13
14     if h4 >= hg
15         x = 1.0;
16     elseif h4 <= hf
17         x = 0.0;
18     else
19         x = (h4 - hf) / (hg - hf);
20     end
21 end

```

This function is the thermodynamic heart of the model. All protection logic eventually reduces to this question: given the current reheater outlet temperature and condenser pressure, what is the LP exhaust quality implied by turbine efficiency and steam tables? The function answers exactly that.

10.8 Metric Calculation and Why it is Robust

The post-processing function `compute_metrics` evaluates settling time, IAE, unsafe time, critical time, minimum quality, and final-window averages. The settling-time helper deserves particular praise because it first waits for the response to depart from the

reference band and then requires sustained return for a hold window. This is much more meaningful than a single-threshold crossing. In turbine protection, temporary re-entry into the safe band is not enough; the controller must establish persistent recovery.

11 Performance Metrics

The script evaluates the following quantities:

$$\text{IAE}_x = \int_{t_{start}}^{t_{end}} |x(t) - x_{ref}| dt, \quad (36)$$

$$t_{unsafe} = \int_{t_{start}}^{t_{end}} \mathbf{1}_{x < x_{min}} dt, \quad (37)$$

$$t_{critical} = \int_{t_{start}}^{t_{end}} \mathbf{1}_{x < x_{crit}} dt, \quad (38)$$

$$e_{x,final} = |\bar{x}_{final} - x_{ref}|. \quad (39)$$

Settling time is defined algorithmically rather than with a closed-form equation, but the principle is clear: after a departure from the reference band, the response must return to and remain within a tolerance of ± 0.004 for a hold interval of 45 s.

These metrics matter physically because they distinguish different kinds of success and failure:

- **Settling time** measures how quickly the protection system re-establishes normal thermodynamic margin.
- **IAE** measures accumulated thermodynamic stress even when the signal is technically safe.
- **Unsafe time** directly estimates how long the turbine is exposed to unacceptable moisture risk.
- **Critical time** quantifies the duration of especially severe exposure.
- **Final quality error** indicates whether the controller restores the plant to its nominal target rather than merely surviving the disturbance.

From a protection standpoint, unsafe and critical time are arguably the most important because they connect directly to accumulated blade damage potential.

12 Simulation Results Analysis

The project now includes exported MATLAB results, so the discussion in this section is based on actual simulation outputs rather than placeholders. Figure 3 gives the direct steam-quality comparison, Fig. 4 shows the multivariable plant response, and Fig. 2 earlier in the report provides a qualitative disturbance overview.




Figure 3: Uploaded MATLAB result comparing open-loop and PID steam-quality protection performance. The figure reports the reference quality, the safety limit, minimum quality attained by each case, and the final operating-point recovery.




Figure 4: Uploaded MATLAB result showing the commanded reheater duty, reheater temperature, condenser pressure, and net power for the open-loop and PID cases.

Table 5: *Key values read directly from the uploaded steam-quality response figure.*

Metric	Open-loop	PID-only
Reference quality x_0	0.9697	
Minimum quality $x_{min,obs}$	0.9432	0.9582
Final quality x_{final}	0.9651	0.9697
Unsafe time below $x_{min} = 0.90$	0.0 s	0.0 s

12.1 Observed Open-Loop Response

The uploaded steam-quality plot shows that the open-loop case remains above the hard safety threshold of $x_{min} = 0.90$, but it does so with a significantly smaller protection margin than the PID case. The minimum reported open-loop quality is approximately $x = 0.9432$, which means the plant stays nominally safe yet undergoes a deeper excursion away from the reference quality $x_0 = 0.9697$. The final open-loop value, reported as $x = 0.9651$, also indicates that the fixed reheater setting does not fully restore the nominal thermodynamic state by the end of the simulation horizon.

This is a subtle but important engineering result. The open-loop strategy does not catastrophically fail in the uploaded run, but it fails to preserve margin. In turbine protection work, reduced margin is still meaningful because it leaves less tolerance for unmodeled disturbances, efficiency deterioration, or more severe condenser degradation than the one already imposed.

12.2 Observed PID Response

The PID-controlled case exhibits a visibly shallower quality dip and a superior final recovery. The uploaded figure reports a minimum quality of about $x = 0.9582$ and a final quality of $x = 0.9697$, essentially equal to the stated reference. Thus, even though both controllers remain above the formal safety limit in this specific scenario, the PID loop materially reduces the depth of the thermodynamic excursion and eliminates the residual steady-state offset seen in the open-loop case.

The advantage is consistent with the controller structure analyzed earlier. As quality begins to fall, the PID loop increases reheater command above its nominal baseline, thereby injecting additional thermal margin into the LP turbine inlet state. Because the derivative and filtering terms temper the response, the controller does not overreact violently; instead, it supplies a smooth but purposeful protective correction.

12.3 Steam-Quality Recovery and Safety Margin Improvement

The numerical values in Table 5 allow a more precise interpretation of protection benefit. The PID controller improves the minimum quality by approximately

$$0.9582 - 0.9432 = 0.0150, \quad (40)$$

which is a nontrivial increase for a variable confined to the interval $0 \leq x \leq 1$. Measured as margin above the safety threshold, the open-loop case retains about 0.0432 of margin, whereas the PID case retains about 0.0582. This corresponds to roughly a 35% increase in available safety margin relative to the threshold.

Equally important is the final-state recovery. The open-loop final quality remains below the nominal reference by approximately 0.0046, whereas the PID case returns essentially to the reference value. Therefore, the protection benefit is not only transient. It also appears as improved long-term thermodynamic restoration.

12.4 Thermal Behavior, Pressure Behavior, and Control Effort

The multivariable dashboard in Fig. 4 clarifies how the PID controller achieves the improved moisture margin. In the controller-action panel, the PID reheater command rises above the fixed open-loop value of 0.76 and reaches approximately the high-0.8 range during the early disturbance interval. This increased actuation is directly reflected in the reheater-temperature panel, where the PID case maintains a substantially higher temperature level during the most stressed period.

The reheater-temperature comparison is particularly revealing. The open-loop curve undergoes a much deeper depression, while the PID curve remains elevated by several tens of degrees Celsius during the worst part of the transient. That temperature preservation is the physical mechanism behind the improved quality response: higher reheater outlet temperature means higher turbine-inlet enthalpy and a more favorable outlet dryness fraction after expansion.

The condenser-pressure panel also carries an important message. The condenser disturbance is effectively common to both control cases because neither strategy directly manipulates condenser hardware. In other words, the PID controller does not remove the external disturbance; it improves turbine protection despite the disturbance. The benefit therefore comes from better use of reheater authority, not from unrealistically canceling the back-pressure excursion.

Finally, the net-power panel shows that better protection does not come at the expense of degraded gross operating quality. On the contrary, the PID case retains noticeably higher power through most of the transient. The visual separation between the blue and red power traces indicates that the same reheater action that protects steam quality also helps preserve useful work output.

12.5 System Stability and Control Realism

The uploaded results show smooth trajectories rather than aggressive oscillations. This is consistent with the filtered-measurement and rate-limited controller design used in the script. The PID loop produces meaningful corrective action without chattering, actuator banging, or obvious numerical instability. That behavior is especially important in thermal systems, where physical actuators and heat-transfer processes cannot support

arbitrarily fast command swings. The results therefore support not only the effectiveness but also the practical plausibility of the implemented protection logic.

13 Engineering Interpretation

13.1 Why PID Succeeds

PID succeeds in this application because it acts on the variable that actually matters. Many industrial control loops regulate temperature, pressure, or valve position because those variables are easy to measure and actuate. But the physically damaging variable for LP turbine moisture protection is exhaust quality. By computing quality directly from steam properties and then closing the loop around it, the controller aligns the control objective with the asset-protection objective.

A second reason PID succeeds is that the manipulated variable is physically meaningful. Reheater duty is one of the few levers that can materially shift the LP inlet thermodynamic state without redesigning the turbine. Increasing reheater input increases the dryness margin. The model captures this in a compact but clear form through the 260 coefficient in the reheater equilibrium equation.

A third reason PID succeeds is its practical implementation detail. The controller is not an ideal textbook PID. It uses filtered measurement, anti-windup, saturation, smoothing, and rate limiting. These features make it look less mathematically elegant than a simple continuous-time transfer function, but more physically plausible as a plant-side protection mechanism.

13.2 Why Open-Loop Fails

Open-loop fails because it assumes that the plant remains close to its nominal state despite major disturbances. That assumption is thermodynamically untenable in this simulation. Boiler temperature, reheater temperature, condenser pressure, and steam flow all move during the scenario. Since the open-loop reheater command is fixed below nominal, the plant loses the very margin it most needs during the disturbance interval. This is the essential weakness of fixed scheduling in safety-critical thermal systems: it cannot respond to changing phase-boundary risk.

13.3 Industrial Significance

From an industrial perspective, the report's significance is not limited to the numerical comparison of two simulation cases. The broader lesson is that direct thermodynamic protection variables can and should be brought into the feedback structure when plant safety depends on them. Exhaust wetness is not a secondary diagnostic. It is a primary indicator of turbine health. Therefore, using a control architecture that explicitly protects quality is a rational asset-management decision, not merely an academic

control exercise.

14 Limitations of the Current Model

The present model is informative but intentionally simplified. Its limitations should be stated clearly.

- **Reduced-order thermodynamics:** The model computes quality with steam tables, which is excellent, but the surrounding temperature and power dynamics are simplified first-order relationships rather than full energy balances.
- **No shaft dynamics:** Rotor speed, inertia, torsional coupling, and generator dynamics are not modeled.
- **No valve or servo dynamics beyond reheater lag:** Real actuators include deadband, hysteresis, and nonlinear stroke limitations.
- **No transport delay:** Steam transport and sensor delay are lumped into first-order filtering rather than explicit delay blocks.
- **Approximate power equation:** Equation (34) is calibrated and useful but not a full turbine power calculation based on actual enthalpy drop across all components.
- **Simplified condenser disturbance interpretation:** The variable d_{cond} acts as an aggregate condenser-degradation indicator. In a more rigorous plant model, separate mechanisms such as cooling-water fouling, vacuum loss, and exhaust pressure change would be modeled individually.
- **Fixed LP efficiency:** The model assumes $\eta_{LP} = 0.86$ throughout, whereas real turbine efficiency depends on load, flow coefficient, wetness, Reynolds number, and stage condition.
- **No moisture separator or drain dynamics:** Some industrial configurations include more elaborate moisture management than the present model represents.

These limitations do not invalidate the study. Rather, they define its scope: the model is a control-oriented thermodynamic protection simulator, not a plant-grade digital twin.

15 Future Improvements

Several meaningful research and industrial extensions can be built on the present framework.

- **Nonlinear state-space modeling:** Replace empirical equilibrium equations with a thermodynamically derived nonlinear state-space model that includes explicit energy storage terms.

- **Model predictive control (MPC):** Since the disturbance environment is multi-variable and constrained, MPC would be a natural next step for supervisory moisture protection.
- **Linear-quadratic regulation (LQR):** If a linearized state model around the nominal point is developed, LQR could provide structured multi-state feedback and optimal penalty weighting.
- **Digital-twin development:** Online plant data could be fused with the reduced-order model to create a predictive LP turbine protection twin.
- **Simulink integration:** The MATLAB script could be translated into Simulink for easier controller prototyping, block-diagram analysis, and hardware-in-the-loop studies.
- **CFD or meanline coupling:** The LP turbine model could be upgraded by coupling the thermodynamic simulation to a stagewise meanline or CFD-informed wetness-loss correlation.
- **State estimation:** A Kalman filter or moving-horizon estimator could be used to infer unmeasured thermodynamic states and reduce reliance on directly computed quality alone.
- **Fault-aware disturbance decomposition:** Instead of using one aggregated condenser disturbance factor, the model could separate cooling-water degradation, air in-leakage, fouling, and condenser load.

The current script is therefore best seen as the foundation of a richer research platform rather than an endpoint.

16 Conclusion

This report has analyzed a MATLAB/XSteam simulation of a steam turbine protection control system with a focus on LP turbine exhaust steam quality. The engineering contribution of the project lies in treating steam quality as the central protection variable and in constructing a reduced-order dynamic model that is simple enough for control design yet sufficiently thermodynamic to remain meaningful. By using XSteam to compute enthalpy, entropy, and dryness fraction, the model avoids one of the most common failures of simplified protection studies: the use of overly crude property approximations near the saturation boundary.

The control contribution lies in the comparison between a deliberately weak open-loop reheater setting and a direct PID controller with filtered measurement, anti-windup, actuator saturation, smoothing, and rate limiting. The report has shown why the PID structure is well suited to this problem: it adds reheater authority only when the thermodynamic safety variable begins to deteriorate and thereby converts available thermal headroom into turbine protection.

The turbine-protection achievement of the model is conceptual but important. It demonstrates that feedback control centered on steam quality can materially improve protection against the combined effects of boiler degradation, load rise, condenser drift, and flow variation. Even though the model is simplified, it captures the most important engineering truth of the problem: feedback control is essential whenever thermodynamic safety margin is time-varying and moisture-related damage risk cannot be reliably bounded by fixed operating schedules.

References

- [1] M. J. Moran, H. N. Shapiro, D. D. Boettner, and M. B. Bailey, *Fundamentals of Engineering Thermodynamics*, 8th ed., Wiley, 2014.
- [2] Y. A. Cengel and M. A. Boles, *Thermodynamics: An Engineering Approach*, 8th ed., McGraw–Hill, 2015.
- [3] S. L. Dixon and C. A. Hall, *Fluid Mechanics and Thermodynamics of Turbomachinery*, 7th ed., Butterworth–Heinemann, 2014.
- [4] R. Kehlhofer, B. Rukes, F. Hannemann, and F. Stirnimann, *Combined-Cycle Gas & Steam Turbine Power Plants*, 3rd ed., PennWell, 2009.
- [5] K. Ogata, *Modern Control Engineering*, 5th ed., Prentice Hall, 2010.
- [6] K. J. Åström and T. Hägglund, *PID Controllers: Theory, Design, and Tuning*, 2nd ed., ISA, 1995.
- [7] D. E. Seborg, T. F. Edgar, D. A. Mellichamp, and F. J. Doyle, *Process Dynamics and Control*, 3rd ed., Wiley, 2010.
- [8] The International Association for the Properties of Water and Steam, *Revised Release on the IAPWS Industrial Formulation 1997 for the Thermodynamic Properties of Water and Steam*, 2007.
- [9] M. Holmgren, *XSteam for MATLAB: Thermodynamic Properties of Water and Steam Based on IAPWS IF-97*, technical documentation, 2006.
- [10] I. K. Smith, N. Stosic, and A. Kovacevic, *Power Recovery Systems*, Elsevier, 2014.
- [11] E. O. Hamed, *MATLAB Script for Steam Turbine Protection Control System: Open-Loop vs PID on Steam Quality*, user-provided project code, 2026.