Panduan Hafalan Presentasi Sidang

Data-based Numerical Simulation of Buoyant Jet Flow – 16 slide, sekitar 17 menit


Mochamad Bukhori Zainun – Johannes Kepler University Linz

Cara memakai

1. Lihat gambar slide dulu, lalu baca kotak Alur cerita. Gambar dan alur adalah gantungan hafalan.
2. Ucapkan naskah per kalimat. Garis miring (/) adalah jeda napas.
3. Jangan menghafal kata per kata. Ingat urutan kata kunci, lalu ceritakan dengan kalimat sendiri.
4. Total 2262 kata. Dengan tempo tenang dan jeda, sekitar 15 menit.

Kalimat inti yang menghubungkan semuanya: *The correction can improve the replay, but it cannot create physical motion that is missing from the database.*

Slide 1 – Introduction *0:40*



Alur cerita


Salam → nama, supervisor, judul → topik → peta talk.

Naskah. Good morning, and thank you for being here. My name is Mochamad Bukhori Zainun, and today I will present my master's thesis, supervised by Professor Stefan Pirker: Data-based Numerical Simulation of Buoyant Jet Flow. / This thesis studies whether a recorded flow can carry a temperature that pushes back on the flow. / I will follow the work step by step: the problem and the method, the closed configuration with an adiabatic and a cooled lid, a laboratory vessel, and finally the cost and the main findings.

Kata kunci

1. Greeting, name, supervisor, title.
2. Topic: a recorded flow carrying a temperature that pushes back.
3. Route: problem, method, two lids, vessel, cost, findings.

Slide 2 – The central problem *1:00*



Alur cerita


Suhu dan kecepatan terkopel → air hangat ringan, naik → suku buoyancy menutup loop → rCFD pakai ulang aliran terekam, cocok untuk passive scalar → kasus saya non-passive → tiga pertanyaan.

Naskah. In conventional CFD, temperature and velocity affect each other. / Warm water is lighter, so it rises. This buoyancy changes the velocity, and the new velocity transports the temperature again. The buoyancy term in the momentum equation closes this loop. / To make the simulation faster, Recurrence CFD, or rCFD, skips the momentum equations and reuses a recorded flow. This works well when the temperature is a passive scalar, so when it does not act back on the flow. In my cases, it is not passive. The temperature drives the flow, and the recorded motion may no longer represent it. / Therefore, my thesis looks at three things: where rCFD works well, where it fails, and how it can be improved.

Kata kunci

1. Coupling: temperature and velocity affect each other.
2. Warm is light, rises, changes velocity, carries T again.
3. Buoyancy term closes the loop.
4. rCFD: recorded flow, fine for a passive scalar.
5. My cases: non-passive, T drives the flow.
6. Thesis: where it works, where it fails, how to improve.

Slide 3 – The rCFD method *1:00*



Alur cerita


Rekam peta antarsel → replay tanpa persamaan momentum → standard: face exchange (f_sd) + konservasi global → langkah saya: tahap koreksi, dirancang dari diagnosis.

Naskah. Let me briefly explain the method. First, we run a normal CFD simulation and record how the fluid moves between cells. This motion is stored as cell-to-cell maps, one per second of flow. / During the replay, these maps transport the temperature without solving the momentum equations again. The maps do not capture all of the mixing, so the standard replay adds face exchange between neighbouring cells, with one free strength, f s d. A global conservation constraint then corrects the total energy. / In my thesis, I add one more step between face exchange and the constraint: a correction stage. What this step must do follows from a diagnosis of the errors.

Kata kunci

1. Record: CFD → cell-to-cell maps, one per second.
2. Replay: maps transport T, no momentum equations.
3. Standard: face exchange (f_sd) + global conservation.
4. My step: a correction stage, designed from a diagnosis.

Slide 4 – Study design *1:00*



Alur cerita


Konfigurasi kecil, laminar → lid adiabatik: galat murni numerik → lid didinginkan: ada gerak sendiri → memisahkan galat numerik dari gerak yang hilang → bejana.

Naskah. I started with a small closed configuration: 75 by 75 by 15 millimetres with an inlet and an outlet channel, and 85,625 cubic cells of one millimetre. A warm jet at 333 kelvin enters fluid at 293 kelvin for 315 seconds. The Reynolds number is about 100, so the flow is laminar, and the reference simulation needs 569 minutes on a laptop. / I used two conditions on the lid. With an adiabatic lid, the recording and the reference represent the same flow, so any deviation of the replay is numerical. With a cooled lid, the cooled liquid sinks and creates motion of its own. Comparing the two separates numerical errors from missing motion. Finally, I applied the method to a laboratory vessel.

Kata kunci

1. 75 × 75 × 15 mm, 85 625 cells of 1 mm.
2. Jet 333 K into 293 K for 315 s, Re ≈ 100, laminar, 569 min.
3. Adiabatic lid: same flow, errors are numerical.
4. Cooled lid: motion of its own.
5. Then: laboratory vessel.

Slide 5 – The standard replay *1:20*



Alur cerita


Tujuh nilai f_sd → mean T terbaik tanpa mixing (1,07 K), z_cog terbaik 0,5 → sebabnya outlet di bawah termoklin → tidak ada satu nilai terbaik → lanjut diagnosis.

Naskah. Let us start with the adiabatic case and the standard replay. Its only free parameter is the face-exchange strength. I tested seven values, from zero, which means recorded advection alone, up to three. / The two integral measures disagree. The mean temperature is most accurate with little or no added mixing, with a root mean square error of 1.07 kelvin. The height of the heat, the centre of gravity, is best near 0.5. / The reason is the outlet, just below the thermocline. During the warm inflow, numerical diffusion moves heat from the warm current into the cold fluid below, so the outflow is too cold and the configuration keeps too much heat. After the inflow, the outlet draws warm fluid that diffusion has pushed across the thermocline, so the configuration loses too much heat. / So no single mixing strength serves both measures. This answers my first research question, and it leads to a diagnosis of the smearing.

Kata kunci

1. Seven strengths, from 0 (advection alone) to 3.
2. Mean T best with little mixing: 1.07 K.
3. Centre of gravity best near 0.5.
4. Outlet below the thermocline: too cold in, too warm out.
5. No single strength serves both (Q1).

Slide 6 – Diagnosis: where the smearing comes from *1:20*



Alur cerita


Maps saja tetap tipis → bukan gerak terekam → tanpa face exchange ada kantong tak tercampur → standard 15,7 mm → face exchange 10× difusivitas molekuler → stratifikasi N = 5,8/s → jet perlu mixing, termoklin tidak → koreksi.

Naskah. The montage shows the diagnosis at four instants. The top row is the reference. With the recorded maps alone, in the second row, the thermocline stays as thin as in the reference, between about two and four millimetres. So the recorded motion is not the problem. Without face exchange, however, the upper layer keeps unmixed pockets, so face exchange cannot simply be removed. / The standard replay, in the third row, ends with a thermocline of 15.7 millimetres, about three times the reference. The source is face exchange. At a strength of 0.5 it acts like a diffusivity ten times the molecular value, and a sharp interface under such a diffusivity grows to about 20 millimetres in two minutes. / In the reference, stable stratification suppresses vertical motion across the thermocline, with a buoyancy frequency of 5.8 per second. Face exchange ignores this and mixes equally in all directions. The jet needs this mixing, but the thermocline does not. The last row shows the answer: the extended replay keeps face exchange and adds a correction.

Kata kunci

1. Maps only: 2 to 4 mm, motion is not the problem.
2. No face exchange: unmixed pockets.
3. Standard: 15.7 mm, three times the reference.
4. Face exchange ≈ 10 × molecular, 20 mm in 2 min.
5. Reference stratified, N = 5.8 per s; jet needs mixing, thermocline does not.

Slide 7 – The correction *1:25*



Alur cerita


Koreksi konservatif naik gradien → limiter Zalesak, tanpa ekstrem baru ($s \leq 1/2$) → bobot vertikal → arah lebih penting dari kekuatan → 5,3/4,0 mm mengapit 5,0 mm → trace error turun.

Naskah. The correction moves heat back up the local gradient, across the thermocline. It is conservative: each exchange moves the same energy out of one cell and into its neighbour. A local-bounds limiter of the Zalesak type keeps every cell within the range of its neighbours, so no new extremes appear, as long as the strength stays within its bound of one half. And it is weighted towards the vertical, because the thermocline is nearly horizontal. The animation shows the idea on a model front: plain negative diffusion leaves the data range, while the limited correction sharpens the front and stays inside it. / The direction matters more than the strength. Without a weight, the correction reaches the reference thickness only at s equal to 0.9, with grid-scale oscillations. The gradient-weighted form steepens perturbations along the interface. The vertical weight works within its guaranteed range: 5.3 millimetres at s equal to 0.40 and 4.0 at 0.50, which brackets the reference of 5.0 millimetres. The trace error falls from 1.46 to between 0.70 and 0.59 kelvin. This answers my second research question.

Kata kunci

1. Conservative exchange, up the local gradient.
2. Zalesak-type limiter, no new extremes within $s \leq 1/2$.
3. Vertical weight: the thermocline is horizontal.
4. Unweighted: $s = 0.9$, oscillations; gradient form steepens perturbations.
5. Vertical: 5.3 / 4.0 mm brackets 5.0 mm; 1.46 → 0.70–0.59 K (Q2).

Slide 8 – Result in the adiabatic case *1:10*



Alur cerita


CFD lawan extended: 5,0 vs 5,3 mm → outlet dalam 0,1 K → deviasi akhir 1,69 → 0,35 K → mid-plane 4,00 → 0,85 K → jembatan ke lid didinginkan.

Naskah. Here is the result, the CFD on the left and the extended replay on the right. At the end of the run, the thermocline is 5.0 millimetres in the CFD and 5.3 millimetres in the replay. / The correction also fixes the heat content, because a sharp thermocline puts the right fluid at the outlet. Over the last twenty seconds, the outlet temperature agrees with the reference within 0.1 kelvin, and the final deviation of the mean temperature drops from 1.69 to 0.35 kelvin. At s equal to 0.5, the mean absolute difference on the mid-plane falls from 4.00 to 0.85 kelvin, and the buoyancy frequency returns to within 0.5 per second of the reference. / So when the database holds the right motion, a bounded correction repairs the numerical error. The next question is what happens when it does not.

Kata kunci

1. CFD left, extended right: 5.0 against 5.3 mm.
2. Outlet within 0.1 K; end deviation 1.69 → 0.35 K.
3. Mid-plane 4.00 → 0.85 K at $s = 0.5$; N within 0.5 per s.
4. Bridge: what if the database lacks the motion.

Slide 9 – The cooling regime *1:20*



Alur cerita


Lid didinginkan → database adiabatik: 63 %, 2,08 K terlalu hangat → suku dinding self-limiting, film dingin → matriks recurrence 10× → konveksi Rayleigh–Bénard terbalik → database milik rezim → rekam ulang.

Naskah. Now the lid is cooled. The cooled liquid becomes denser and sinks, and warmer liquid rises to replace it. Since the replay applies the wall heat loss on its own, one database could in principle serve both lids. With the adiabatic database, however, the lid removes only 63 per cent of the reference heat loss, and the run ends 2.08 kelvin too warm. Stronger mixing or the correction raise this only to 64 to 67 per cent. / The reason is physical. The wall term removes heat in proportion to the temperature difference to the surroundings. Without recorded sinking motion, nothing carries the cooled fluid away, a cold film forms under the lid, and the heat loss limits itself. / The recurrence matrices confirm it. Under cooling, frames one second apart differ about ten times more, because the lid drives an inverted Rayleigh–Bénard convection with a Rayleigh number of 1.5 to 2.5 times ten to the seven. A recording without cooling cannot contain this motion. So a database belongs to a cooling regime, and I recorded it again under cooling.

Kata kunci

1. Adiabatic database: 63 %, 2.08 K too warm; 64–67 % with mixing or correction.
2. Wall term □ ΔT: cold film, self-limiting.
3. Recurrence: 10 × faster renewal under cooling.
4. Inverted Rayleigh–Bénard, Ra 1.5–2.5 × 10^7.
5. Database belongs to a regime → record again.

Slide 10 – Result with the cooled database *1:15*



Alur cerita


Database didinginkan → standard 98 % tapi panas salah tempat → koreksi s ≈ 0,55: 0,06 K dan 0,41 K → di atas batas 1/2 → plume 9/1/3 → koreksi menampakkan kembali yang sudah terekam.

Naskah. With the database recorded under cooling, the standard replay removes 98 per cent of the lid heat loss and ends only 0.66 kelvin too cold. But the heat is in the wrong place: the bulk is too warm, the thermocline and the top layer too cold, and the thermocline is three times too thick during the inflow. / The same correction, with a static-stability criterion, improves every measure. At its working strength of about 0.55, the run ends within 0.06 kelvin of the reference, and the end-profile error drops from 2.79 to 0.41 kelvin. This strength lies just above the bound of one half, so the final clamp can become active. / The montage compares the CFD with both databases at the stored states. With the cooled database, the replay follows the CFD. The correction even restores part of the plume structure, three plumes under the lid instead of one, against nine in the reference. The plumes are already in the recorded transport; the correction makes them visible again.

Kata kunci

1. Standard: 98 %, 0.66 K too cold, heat in the wrong place.
2. Correction s ≈ 0.55: within 0.06 K, profile 2.79 → 0.41 K.
3. s above the bound 1/2: clamp can act.
4. Plumes: 9 reference, 1 standard, 3 corrected.

Slide 11 – The limit of local corrections *1:10*



Alur cerita


Sisa galat: filling lag 2,25 K → empat varian gagal → galat transport → uji fluks 0,45 K tapi 0,86 K terlalu dingin → hanya diagnostik.

Naskah. One error remains after every local correction. During filling, the heterogeneity of the replay lags behind the reference by 2.25 kelvin, and the traces meet only after the inflow. I tested four variants: a joint study of the wall multiplier and the strength, a Richardson-number weight, several passes, and a reversed diffusivity weight. None reduced this error. / Rules that move heat only between neighbouring cells cannot recover heat that is in the wrong layer at the wrong time. So this is a transport error. As a test, I applied the recorded vertical convective flux. It reduces the error from 2.25 to 0.45 kelvin, which supports the diagnosis. But the run then ends 0.86 kelvin too cold, through the single-compartment conservation constraint, and the flux belongs to one run only. So it remains a diagnostic, not part of the method.

Kata kunci

1. Filling lag: 2.25 K, traces meet after the inflow.
2. Four variants fail.
3. Wrong layer, wrong time → transport error.
4. Flux test: 2.25 → 0.45 K, ends 0.86 K too cold; diagnostic only.

Slide 12 – Application to a through-flow vessel *2:10*



Alur cerita

Bejana → satu database umpan tutup → operator per umpan (lid: koreksi lemah + down-gradient; floor: convective adjustment, tidak bounded) → 1,28 → 0,77 dan 1,61 → 0,68 K → standard f_sd 160 terlalu mencampur → kurva cocok, jalur salah.

Naskah. Finally, I applied the operators to a second buoyant flow, the through-flow vessel of the laboratory rig. It is 195 millimetres wide and 250 millimetres high, fed through eight openings at two heights and drained at half height. The reference simulations use the k-omega SST turbulence model. I recorded one database in the lid-fed case and replayed both cases with it. / The two cases need different operators. With the lid feed, a warm layer forms, so a weak vertically weighted correction keeps it thin, with down-gradient mixing below the lid after the pulse. With the floor feed, warm water enters below cold water, and the column becomes statically unstable. The lid-fed recording does not overturn it, so a convective adjustment sorts the column instead. This adjustment is not bounded by construction. / Against each reference simulation, the mean error over the seven sensor heights falls from 1.28 to 0.77 kelvin with the lid feed, and from 1.61 to 0.68 kelvin with the floor feed. The best standard replay of the floor feed needs a face-exchange strength of 160, which mixes 12 to 17 times more strongly than the turbulence in the reference and removes almost all structure. / The curves and the montage show what transfers and what does not. On the sensor curves, CFD and the extended replay agree, because each sensor gives one temperature per height and the adjustment keeps warm water above cold water. In the port plane, the reference carries the warm floor feed up the wall in two plumes, while the replay carries it along the floor and up the axis, the path of the neutral floor jet in the lid-fed recording. So the replay gets the layering right, but not the path.

Kata kunci

1. Vessel 195 × 250 mm, 8 openings, drain at half height, SST.
2. One lid-fed database for both feeds.
3. Lid: weak vertical correction + down-gradient mixing.
4. Floor: unstable column → convective adjustment, not bounded.
5. 1.28 → 0.77 K and 1.61 → 0.68 K; standard f_sd = 160 is 12–17 × turbulent mixing.
6. Layering right, path wrong.

Slide 13 – Computational cost *0:50*



Alur cerita


Referensi sangat lama → replay jauh lebih cepat → koreksi tetap mempertahankan kecepatan → pembuatan database tetap butuh CFD biasa.

Naskah. Besides accuracy, computational cost is also important. / In the adiabatic closed case, the reference simulation took 569 minutes. The standard replay took only 2.16 minutes. The extended replay took about 1.9 minutes. / This means that the standard replay is about 260 times faster. The extended replay is about 300 times faster. / So, the correction keeps the main speed advantage of recurrence CFD. In the vessel, a replay took about eight and a half minutes, against 7.4 and 4.7 days for the reference simulations. These reference times include rendering at every step, so the vessel ratios are upper estimates. / However, this advantage applies to repeated replays. We still need one conventional CFD simulation to create the database.

Kata kunci

1. Computational cost: selain akurasi, waktu penting.
2. Reference: 569 min.
3. Standard replay: 2.16 min, about 260×.
4. Vessel: 8.5 min against 7.4 and 4.7 days, upper estimates.
5. Extended replay: 1.9 min, about 300×.
6. Conclusion: still fast, database needs one CFD run.

Slide 14 – Contributions *0:35*



Alur cerita


Lima kata: Trade-off – Diagnosis/Correction – Database regime – Transport limit – Transfer.

Naskah. To summarise, this thesis has five main findings. / First, the standard replay has a trade-off between energy retention and temperature stratification. / Second, my correction reduces numerical diffusion while keeping the temperature within local limits. / Third, the database must represent the correct flow regime. / Fourth, local corrections cannot replace motion that is missing from the database. / Fifth, the correction methods can be used in other configurations, but their settings must be adjusted.

Kata kunci

1. Trade-off: energy retention vs stratification.
2. Correction: less diffusion, local limits respected.
3. Database: must match the flow regime.
4. Missing motion: not replaced by local correction.
5. Transfer: works elsewhere, settings change.

Slide 15 – Limitations and next steps *1:05*



Alur cerita


Batasan → langkah: database per rezim, fluks kinematik, jaringan kecil di dalam limiter → referensi adalah simulasi (6,2 K di sensor atas) → tujuan: CFD dipakai ulang.

Naskah. These results have clear limits, and each one points to a next step. The accuracy depends on how well the database covers the flow, so databases for several regimes, switched according to the flow state, are a natural next step. / Flow structures absent from the database cannot be reconstructed. Recording only the kinematic part of the convective flux could make the missing transport transferable to other cases. / The correction strength is still selected per case. A small network could predict it from the replayed field and act inside the limiter, so that conservation and the local bounds are kept. / Finally, the references are simulations. With the lid feed, the reference itself departs from the rig by up to 6.2 kelvin at the top sensors, and the replays inherit this gap. The goal is not to replace CFD, but to make existing CFD knowledge more reusable.

Kata kunci

1. Coverage → databases per regime, switched by flow state.
2. Missing structures → kinematic part of the flux.
3. Settings per case → small network inside the limiter.
4. References are simulations; lid reference up to 6.2 K off the rig.
5. Goal: reuse CFD knowledge.

Slide 16 – Conclusion *0:40*



Alur cerita

Jawaban: ya, dengan syarat → koreksi menangani bagian numerik → database menentukan bagian fisik → pesan akhir → terima kasih.

Naskah. So, a recorded flow can carry a temperature that also changes the flow, but only under certain conditions. / The correction removes the numerical part of the error. The recorded database decides the physical part. / This is the main finding of my thesis. The accuracy of recurrence CFD depends not only on how we correct the replay, but also on what physical information we record. / Thank you for your attention. I will be happy to answer your questions.

Kata kunci

1. Answer: yes, under certain conditions.
2. Correction: the numerical part.
3. Database: the physical part.
4. Final message: what we record matters as much as how we correct.
5. Thank you, questions.

Angka penting

Slide	Parameter	Angka
4	Ukuran domain, sel	$75 \times 75 \times 15$ mm, 85 625 sel 1 mm
4	Reynolds number inlet	≈ 100, laminar
5	Jumlah mixing strength yang diuji	7
5	RMSE suhu rata-rata terendah	1.07 K
5	Mixing strength terbaik untuk centre of gravity	≈ 0.5
6	Difusivitas efektif face exchange di 0.5	sepuluh kali molekuler
7	Tebal termoklin: referensi, standar, koreksi	5.0, 15.7, 5.3 mm ($s = 0.40$) dan 4.0 mm ($s = 0.50$)
7	Trace error sebelum dan sesudah koreksi	1.46 K $\rightarrow$ 0.70 dan 0.59 K
6	Frekuensi buoyancy referensi	5.8 s^{-1}
9	Heat loss, database adiabatik	63 %, 64–67 % dengan mixing atau koreksi
10	Heat loss, replay standar, database didinginkan	98 %
10	Galat profil akhir, standar $\rightarrow$ koreksi	2.79 K $\rightarrow$ 0.41 K, $s \approx 0.55$ (di atas batas 1/2)
11	Uji diagnostik fluks	2.25 $\rightarrow$ 0.45 K, akhir 0.86 K terlalu dingin
12	Galat rata-rata tujuh tinggi, tutup dan dasar	1.28 $\rightarrow$ 0.77 K, 1.61 $\rightarrow$ 0.68 K
13	Waktu: referensi, standar, koreksi	569 min, 2.16 min ($\approx 260\times$), 1.9 min ($\approx 300\times$)
13	Bejana: referensi dan replay	7.4 dan 4.7 hari, 8.5 dan 8.6 min (batas atas, termasuk render)

Pemeriksaan naskah terhadap tesis (14 November 2026)

Semua angka di atas ada di tesis dengan nilai yang sama: 1.07 K dan 0.5 (Tabel 5.1), 5.3 dan 4.0 mm, 0.70/0.64/0.59 K (Tabel A3, Bagian 9.1), sepuluh kali difusivitas molekuler dan 5.8 s^{-1} (Bab 5), 98 %, 2.79 K, 0.41 K, $s = 0.55$ (Tabel 6.1), 63 % dan 64–67 % (Bab 6), 2.25 $\rightarrow$ 0.45 K dan 0.86 K (Tabel 6.1, Bagian 6.5.2), 1.28/0.77 dan 1.61/0.68 K (Tabel 7.2), 569 min, 2.16 min, 1.9 min, 260 dan 300 kali (Bagian 8.4).

- Slide 11 sudah benar: uji kedua (fluks) memakai database yang direkam saat didinginkan, uji pertama database adiabatik. Kelebihan pendinginan muncul di tempat fluks bertemu batasan energi global, sesuai Bagian 6.5.2.
- Slide 12: “eight inlets” diganti “eight feed openings”, karena tesis menulis *eight feed openings at two heights* (Bagian 8.3). Menurut Tabel 7.1, umpan tutup memakai koreksi anti-difusi lemah berbobot vertikal ($s = 0.05$) ditambah down-gradient mixing di bawah tutup, umpan dasar memakai convective adjustment ditambah down-gradient mixing. Kalimat naskah tetap benar.
- Slide 15: “the reference itself departs from the rig” sesuai Bagian 7.6. Referensi umpan tutup sendiri menyimpang 6.20 dan 5.36 K dari rig di dua sensor atas. Siapkan angka ini kalau ditanya.
- Slide 7: rentang kerja $s = 0.40$ sampai 0.50 mengapit tebal referensi (5.3 dan 4.0 mm), trace error 0.70, 0.64 dan 0.59 K.
- Naskah bercerita tanpa kalimat tanya. Pertanyaan riset tetap tertulis di slide 2.
- Slide 10 dan 12 menyebut dua pengecualian sifat bounded: $s = 0.55$ di atas batas 1/2 sehingga final clamp bisa aktif dan energinya tidak dicatat (Bab 6), dan convective adjustment tidak bounded by construction (Bab 9).
- Slide 12: judul mengikuti Bab 8, operatornya berpindah, setelannya tidak. Kurva sensor cocok karena satu suhu per ketinggian dan kolom dijaga stabil, tetapi medannya beda: lapisan benar, jalur salah (Bab 7).
- Slide 6 memakai figur tesis dengan $s = 0.45$ (4.4 mm), slide 8 memakai animasi $s = 0.40$ (5.3 mm). Keduanya di dalam rentang kerja 0.40–0.50.

- Yang mungkin ditanya: referensi adalah simulasi, bukan pengukuran; satu konfigurasi, satu mesh, satu bejana.
- Figur kurva bejana (slide 12): panel b adalah rentang max − min tujuh sensor. H di teks tesis (1.14, 0.61, 0.05 K) adalah rata-rata deviasi absolut (Bab 4). Keduanya diturunkan dari cache yang sama. Di tesis, sumbu panel b ditulis “heterogeneity”, jadi bila ditanya jelaskan perbedaannya.

Pesan satu kalimat dan tiga poin pendukung

Pesan. A recorded flow can carry a non-passive temperature as long as the database holds the motion, and a bounded correction removes the numerical part of the error.

1. Standard replay: one mixing parameter cannot serve both errors (1.07 K at little mixing, layer height best near $f_{sd} = 0.5$).
2. Correction: the thermocline goes from 15.7 mm back to 5.3 mm (reference 5.0 mm) without leaving the data range.
3. Database: without the cooling motion only 63 % of the lid heat is removed, with it 98 %. In the vessel one lid-fed database serves both feeds (0.77 and 0.68 K), but not the wall plumes.

Ringkasan 60 detik

My thesis asks whether a recorded flow can carry a temperature that changes the flow. Recurrence CFD replays recorded motion instead of solving the momentum equations, so it is about 260 to 300 times faster than the reference. In the adiabatic jet the standard replay smears the thermocline to 15.7 mm, and no single mixing strength fixes both the heat content and the layer height. My bounded correction brings the thermocline back to 5.3 mm. Under a cooled lid, the adiabatic database removes only 63 % of the lid heat, because the sinking motion was never recorded. With a database recorded under cooling, the replay removes 98 %, and with the correction the end profile error drops to 0.41 K. In a laboratory vessel, one database serves both feeds, but the wall plumes of the floor feed cannot be created. So the correction handles the numerical part, and the database decides the physical part.

- Semua angka di dua bagian ini sama dengan tabel Angka penting di atas.