

 PT. MNA SERANG	WORKING INSTRUCTION	WI/MNASRG-E&I-19-017	
	EFR TESTING	Dept.	ENGINEERING
		Section	E&I
		Revision	0
		Effective Date	01-Sep-19
		Page	1 of 1

PSU Checking / *PSU Checking*

									
Uukur nominal tegangan pada GFCI (<i>Measure the nominal voltage on GFCI</i>)	hubungkan output test ke terminal injector (<i>Connect the output test to injector terminal</i>)								
	<table><tr><th>System Power Supply</th><th>12 VDC Local I/O Bus Power</th></tr><tr><td>AC/DC</td><td>2.1 Amps @ 60 °C (Load Sharing)</td></tr><tr><td>Dual DC/DC – 12 VDC</td><td>13 Amps @ 60 °C (Load Sharing)</td></tr><tr><td>Dual DC/DC – 24 VDC</td><td>8 Amps @ 60 °C (Load Sharing)</td></tr></table>	System Power Supply	12 VDC Local I/O Bus Power	AC/DC	2.1 Amps @ 60 °C (Load Sharing)	Dual DC/DC – 12 VDC	13 Amps @ 60 °C (Load Sharing)	Dual DC/DC – 24 VDC	8 Amps @ 60 °C (Load Sharing)
System Power Supply	12 VDC Local I/O Bus Power								
AC/DC	2.1 Amps @ 60 °C (Load Sharing)								
Dual DC/DC – 12 VDC	13 Amps @ 60 °C (Load Sharing)								
Dual DC/DC – 24 VDC	8 Amps @ 60 °C (Load Sharing)								
Naikkan nominal arus, hingga EFR Trip (<i>raise the EFR nominal current until it trip</i>)	catat nominal arus & waktu trip (<i>Note the Current nominal & trip Time</i>)								

System Power Supply	12 VDC Local I/O Bus Power
AC/DC	2.1 Amps @ 60 °C (Load Sharing)
Dual DC/DC – 12 VDC	13 Amps @ 60 °C (Load Sharing)
Dual DC/DC – 24 VDC	8 Amps @ 60 °C (Load Sharing)

bandingkan & analisa deviasi terhadap arus & waktu yang diatur (<i>Compare & Analyze the deviation of current & time set</i>)
