

 PT. MNA SERANG	WORKING INSTRUCTION CT & VT PREVENTIVE MAINTENANCE	WI/MNASRG-E&I-19-020	
		Dept.	ENGINEERING
		Section	E&I
		Revision	0
		Effective Date	01-Sep-19
		Page	1 of 2

Identifikasi / Identification



Identifikasi power meter yang akan dicek (*Identify the power meter which will be checked*)

Pengecekan / Checking



Cek arus yang terbaca pada power meter lakukan juga pengukuran arus pada koneksi CT ke power meter (*check the measurent current on power meter, also measure the current on CT connection to power meter*)

Cek rasio pada current trafo, apabila hasil perkalian arus yang terukur pada jalur CT dengan rasionya sesuai dengan pembacaan pada power meter, CT masih baik, apabila buruk, ajukan pergantian Current Trafo (*Check current ration on current trafo, if the multiplication result between measurement current on CT connection with it ratio fit with measurement on power meter, then it's good, if it's bad, ask for the Current Trafo Replacement*)

 PT. MNA SERANG	WORKING INSTRUCTION	WI/MNASRG-E&I-19-020	
	DELTA V DCS I/O MODULE RM	Dept.	ENGINEERING
		Section	E&I
		Revision	0
		Effective Date	
		Page	2 of 2

Identifikasi / Identification	
Identifikasi power meter pada panel, apakah parameter pembacaannya tegangan perfasanya membaca semua, apabila tidak, pastikan seluruh koneksi yang menuju ke PT power meter terhubung (<i>identify power meter on panel, is the voltage per phase measuring well, if not, make sure all connection to PT on power meter connected</i>)	Jika pembacaan tegangan pada jalur koneksi ke power meter terbaca namun di power meter tidak terbaca, dipastikan PT pada power meter rusak, segera ajukan pergantian power meter (<i>if the voltage measurement on connection to power meter measure well but not on power meter, PT on power meter must be broken, ask for power meter replacement soon</i>)