





 PT. MNA SERANG	WORKING INSTRUCTION Temperature Switch Reactive Maintenance	WI/MNASRG-E&I-19-108	
		Dept.	ENGINEERING
		Section	E&I
		Revision	0
		Effective Date	
		Page	1 of 1 page

Instruksi / <i>Instruction</i>	
Persiapan Alignment / <i>Prepare of Alignment Process</i>	
	
Siapkan peralatan dan APD (<i>Prepare equipment and APD</i>)	Identification: Kealahan pada pembacaan temperature switch (<i>Incorrectly Switch</i>)
Pengecekan Elemen Sensor/ <i>Sensor Element Checking</i>	
 1. Thermal switch 2. Cool water 3. Thermometer	 1 2 3
1. Check continuity for sanpping with tester	2. Check the connection terminals
 1 2 3	 1 2 3
3. Check the circuit of thermocouple & v compensating	4. Check for an open circuit
	
5. Change the grounding method or shield	6. If cant work, replace the new temperature switch