



 PT. MNA SERANG	WORKING INSTRUCTION DELTA V DCS MEDIA CONVERTER RM	WI/MNASRG-E&I-19-204	
		Dept.	ENGINEERING
		Section	E&I
		Revision	0
		Effective Date	01-Sep-19
		Page	1 of 2

Identifikasi / Identification	
	
LED Integrity pada layer Diagnostic berwarna merah (<i>Integrity LED on Diagnostic screen turns red</i>)	LED dari Media converter tidak menyala (<i>No Media Converter LED lit</i>)
Reset Modul / Modul Reset	
 	 
Lepaskan relay fuse & turunkan breaker DC (<i>Disconnect The fuse relay and lower the DC Breaker.</i>)	Lepaskan kabel fiber optic & kabel media yang terhubung ke media converter, sambungkan kembali sekitar 10 detik kemudian (<i>Unplug the Fiber optic & Media cable which connected to the Media Converter, re-Plug it after approximately 10 seconds</i>)
 	
Sambungkan relay fuse & naikan breaker DC (<i>Re-connect the fuse relay and rise the DC Breaker.</i>)	Check modul HMI(<i>Check the HMI Modul</i>)