BD Central Control Room

Field Site

HIS0263 BD5 | HIS0262 BD5 | HIS0261 BD4 | HIS0260 BD4 | HIS0257 PME

Note : Actual connection is go through KVM switch, where CPU place in CPU Panel at BD CCR

CPU Panel 5 units CPU

CCR Room

HP Color Laserjet 2600n

<S64> 2.64 — HIS0264 EWS

Enet — BD-ETHERNET03 — Enet — BD-ETHERNET01 — F.O Patch Box

BD4 PDP 1

YNT #7 — master

Vnet Cable Length = 8 m

Vnet from panel to BD Console = 30 m

slave — ABC — slave

Vnet Cable Length = 8 m

Domain 2

Vnet Cable Length = 20 m

Modbus TCP link to Westfalia Separator PLC

Vnet Cable Length = 8 m

Modbus TCP link to Westfalia Separator PLC

Vnet Cable Length = 8 m

UPS 15 KVA Redundant | PDP & FOP | FCU1 ANB x2 | ANB x4 | ANB x2 ANR x2 | ANR x2 | ABC ANR x1

System/ Marshalling Panel (Non-Exi) | System/ Marshalling Panel (Exi-area) | System/ Marshalling Panel (Non-Exi)

BD4 +BD4/5 Offsite

FCU2 ANB x2 | ANB x2

System/ Marshalling Panel (Exi-area) | System/ Marshalling Panel (Non-Exi)

PME / SOD MIX

FCU3 ANB x2 | ANB x4 | ANB x1 ANR x2 | ANR x2

System/ Marshalling Panel (Exi-area) | System/ Marshalling Panel (Non-Exi)

BD5

PME&SOD MIX DCS PANEL 1

BD5-ERBUS 01 | BD5-ERBUS 01

BD4 PDP 1

BD4-ERBUS 01 | BD4-ERBUS 02 | PME-ERBUS 01 | PME-ERBUS 02 | BD-ETHERNET 02 | F.O Patch Box

YNT #8

F.O 350m (ER Bus1 /Vnet Bus1)

F.O 350m (ER Bus2 /Vnet Bus2 / Ethernet)

ME-ERBUS 01 | ME-ERBUS 02 | ME-ETHERNET | F.O Patch Box

ME PDP1

YNT #9

Vnet cable Length = 20m (Dual Redundant)

UPS 10 KVA Redundant | PDP & FOP | ANR x2 | ANR x2

Domain 2

<S58> 2.58 — HIS0258 ME

<S59> 2.59 — HIS0259 ME

ME – Fract + Offsite

Fiber Optic (Vnet) from YNT#7 to YNT#10 (BD to FA) = 300m

Note* connect to BD/ME Plant Domain 02/YNT#7

Vnet Cable from HYD CCR to FA CCR = 140m (Dual Redundant)

Fiber Optic Cable (Vnet) = 550m (Dual Redundant)

Main FA Control Room

Enet — Switch — SW4

Fiber Optic (Enet) = 550m

HIS 151 | HIS 154 | HIS 159 | HIS 160 | HIS 161 | HIS 162 | HIS 163 | HIS 164 EWS

<S51> 1.51 | <S54> 1.54 | <S59> 1.59 | <S60> 1.60 | <S61> 1.61 | <S62> 1.62 | <S63> 1.63 | <S64> 1.64

HP Color Laserjet (CP1515N)

Note: Remote HIS at Manager Room

Under FA3 Scope Of Work

From FCU1 to Console (Vnet)= 30m (Dual Redundant)

YNT #10

Vnet Cable Length = 5 m

YNT #1

Vnet Cable Length = 10 m

FO1&2 | FO1&2 | ENET SW/SW1&3

UPS 15 KVA Redundant | PDP & FOP | FCU1 ANB x1 FA-MC1 | ANR x2 FA-MC2 | ANR x2 FA-MC3 | ANR x1 FA-MC4 | ANR x1 FA#1

Domain 1

System/ Marshalling Panel (Non-Exi)

Fiber Optic (ER Bus) = 200m (Dual Redundant)

FO3&4 | SW5&6

Tank Farm FA Control Room

Domain 1 — For FA 2 & FA 3

UPS 10 KVA Redundant | ANR x3 TF-MC1 | ANR x2 OSBL | PDP & FOP TF-MC2

System/ Marshalling Panel (Non-Exi)

Under FA3 Scope Of Work

Fiber Optic (Enet) = 550m

Coal Fired/HP Boiler Control Room

MOXA SW — SW12

Fiber Optic (Enet) = 700m

Switch

Enet

HIS 158 | HIS 157 | HIS 156 | HIS 155

<S58> 1.58 | <S57> 1.57 | <S56> 1.56 | <S55> 1.55

From FCU3 to HIS (Vnet) = 30 m (Dual Redundant)

YNT #2

Vnet Cable Length = 5 m

YNT #3

Domain 1

Fiber Optic (Vnet) = 700m (Dual Redundant)

Vnet Cable Length = 8 m

FO7&8 | FO7&8 | SW13&14

UPS 10 KVA Redundant | PDP & FOP | FCU3 ANB x1 CF-MC1 | ANR x2 CF-MC2 | ANR x1 CF-MC3

System/ Marshalling Panel (Non-Exi)

UPS 6 KVA Redundant | ANR x2 CF-MC4

Under FA2 Scope Of Work

Fiber Optics (ER Bus) = 700m (Redundant)

Soap & Beading Control Room

SW2 — Enet — Switch

HIS 153 | HIS 152 | HIS 150

<S53> 1.53 | <S52> 1.52 | <S50> 1.50

Under FA2 Scope Of Work

YNT #4

Vnet Cable Length = 30 m

Domain 1

UPS 10 KVA Redundant | PDP & FOP | ANR x2 SN-MC1 | ANR x1 SN-MC2 | ANR x1 SN-MC3 | ANR x1 SN-MC4

System/ Marshalling Panel (Non-Exi)

UPS 6 KVA Redundant | ANR x3 SN-MC5

Under FA2 Scope Of Work

FO5&6 | SW10&11

Relay Panel at Field

Legend

HIS : Operator Workstation
FCS : Field Control Station
EWS : Engineering Workstation
FOP : Fiber Optic Panel
PDP : Power Distribution Panel
*P : 800(W)x800(D)x2100(H)

Hydrogenation Control Room

Domain 1

From FCU1 to FCU4 (Vnet) = 20m (Dual Redundant)

PDP & FOP | FCU2 ANB x1 HYD-MC1 | ANR x2 HYD-MC2 | ANR x2 HYD-MC3 | ANR x2 HYD-MC4 | ANR x2 HYD-MC5 | ANR x2 HYD-MC6

System/ Marshalling Panel (Non-Exi) | System/ Marshalling Panel (Exi-area)

UPS 10 KVA Redundant | PDP & FOP | FCU4 ANB x1 H2-MC1 | ANB x3 H2-MC3 | ANR x2 FA3-MC1

Supply for HYD/H2/FA3 Panel (Non-Exi) (Exi-area)

Under FA3 Scope Of Work

UPS 15 KVA Redundant | FCU5 ANB x1 FA2-MC1 | ANR x3 FA2-MC2

Under FA2 Scope Of Work

PDP & FOP | UPS 15 KVA Redundant

Under FA3 Scope Of Work

					First Issue		*Rev 0*	Project Name : **WSH2 & SN Project**
						By	*Date*	
3	FA2 And FA3 Expansion	Hafiz Idrus	WP Yong	11 April 2011				
2	Cable rewiring and new panel layout	Rashida Azhar	Jenny Heng	17 June 2009	*Drawn*	LOY TK	23 April 2011	Title : **SYSTEM CONFIGURATION**
1	Cable rewiring and new panel layout	Rashida Azhar	Jenny Heng	26 May 2009	*Checked*	KH SHEE	23 April 2011	Doc no : **WSH2SN-C11-001** — Page : 1 / 1
Rev.	*Description*	*Revised By*	*Approved By*	*Date*	*Approved*	KH SHEE	23 April 2011	

File Name : form09Hform.dat
Eff. Date : 15-03-03
Form No.: EGD-STD-F008
Rev. No.: 0

YOKOGAWA