

Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks
														LOer	Upper		LL	L	H	HH		
		0104	ADV151-P	1-3-1	1	3	1	FN220101STI	FN220101	ID FAN RUN STATUS	ID FAN RUN	STATUS	DI	NIS								
		0104	ADV151-P	1-3-2	1	3	2	FN220101TRI	FN220101	ID FAN TRIP STATUS	ID FAN TRIP	STATUS	DI	NIS								
		0104	ADV151-P	1-3-3	1	3	3	FN220101FFI	FN220101	ID FAN FF? STATUS	ID FAN FF?	STATUS	DI	NIS								
		0104	ADV151-P	1-3-4	1	3	4	FN220101RLI	FN220101	ID FAN REM /LOC STATUS	ID FAN REM /	LOC STATUS	DI	NIS								
		0104	ADV151-P	1-3-5	1	3	5	FN220102STI	FN220102	FD FAN RUN STATUS	FD FAN RUN	STATUS	DI	NIS								
		0104	ADV151-P	1-3-6	1	3	6	FN220102TRI	FN220102	FD FAN TRIP STATUS	FD FAN TRIP	STATUS	DI	NIS								
		0104	ADV151-P	1-3-7	1	3	7	FN220102FFI	FN220102	FD FAN FF? STATUS	FD FAN FF?	STATUS	DI	NIS								
		0104	ADV151-P	1-3-8	1	3	8	FN220102RLI	FN220102	FD FAN REM /LOC STATUS	FD FAN REM /	LOC STATUS	DI	NIS								
		0104	ADV151-P	1-3-9	1	3	9	PU220101ASTI	PU220101A	BFW PUMP RUN STATUS	BFW PUMP	RUN STATUS	DI	NIS								
		0104	ADV151-P	1-3-10	1	3	10	PU220101ATRI	PU220101A	BFW PUMP TRIP STATUS	BFW PUMP	TRIP STATUS	DI	NIS								
		0104	ADV151-P	1-3-11	1	3	11	PU220101AFFI	PU220101A	BFW PUMP FF? STATUS	BFW PUMP	FF? STATUS	DI	NIS								
		0104	ADV151-P	1-3-12	1	3	12	PU220101ARLI	PU220101A	BFW PUMP REM/LOC STATUS	BFW PUMP REM	/LOC STATUS	DI	NIS								
		0104	ADV151-P	1-3-13	1	3	13	PU220101BSTI	PU220101B	BFW PUMP RUN STATUS	BFW PUMP	RUN STATUS	DI	NIS								
		0104	ADV151-P	1-3-14	1	3	14	PU220101BTRI	PU220101B	BFW PUMP TRIP STATUS	BFW PUMP	TRIP STATUS	DI	NIS								
		0104	ADV151-P	1-3-15	1	3	15	PU220101BFFI	PU220101B	BFW PUMP FF? STATUS	BFW PUMP	FF? STATUS	DI	NIS								
		0104	ADV151-P	1-3-16	1	3	16	PU220101BRLI	PU220101B	BFW PUMP REM/LOC STATUS	BFW PUMP REM	/LOC STATUS	DI	NIS								
		0104	ADV151-P	1-3-17	1	3	17	PU220DZ1STI	PU220DZ1				DI	NIS								
		0104	ADV151-P	1-3-18	1	3	18	PU220DZ1TRI	PU220DZ1				DI	NIS								
		0104	ADV151-P	1-3-19	1	3	19	PU220DZ2STI	PU220DZ2				DI	NIS								
		0104	ADV151-P	1-3-20	1	3	20	PU220DZ2TRI	PU220DZ2				DI	NIS								
		0104	ADV151-P	1-3-21	1	3	21	FN150CT05STI	FN150CT05				DI	NIS								
		0104	ADV151-P	1-3-22	1	3	22	FN150CT05TRI	FN150CT05				DI	NIS								
		0104	ADV151-P	1-3-23	1	3	23	PU150CCW11STI	PU150CCW11				DI	NIS								
		0104	ADV151-P	1-3-24	1	3	24	PU150CCW11TRI	PU150CCW11				DI	NIS								
		0104	ADV151-P	1-3-25	1	3	25	CP2201STI	CP2201				DI	NIS							NG	
		0104	ADV151-P	1-3-26	1	3	26	CP2201TRI	CP2201				DI	NIS							NG	
		0104	ADV151-P	1-3-27	1	3	27	PU2201STI	PU2201				DI	NIS							NG	
		0104	ADV151-P	1-3-28	1	3	28	PU2201TRI	PU2201				DI	NIS							NG	
		0104	ADV151-P	1-3-29	1	3	29	CP2202STI	CP2202				DI	NIS							NG	
		0104	ADV151-P	1-3-30	1	3	30	CP2202TRI	CP2202				DI	NIS							NG	
		0104	ADV151-P	1-3-31	1	3	31	PU2202STI	PU2202				DI	NIS							NG	
		0104	ADV151-P	1-3-32	1	3	32	PU2202TRI	PU2202				DI	NIS							NG	
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks
														LOer	Upper		LL	L	H	HH		
		0104	ADV151-P	1-4-1	1	4	1	FLS220202S	FLS220202	IMPORT H2	IMPORT H2		DI	NIS								
		0104	ADV151-P	1-4-2	1	4	2	FLS220231S	FLS220231	N2 FLOW SWITCH LOW	N2 FLOW	SWITCH LOW	DI	NIS								
		0104	ADV151-P	1-4-3	1	4	3	LSHH220405S	LSHH220405	220V104 LVL SWITCH HH	220V104 LVL	SWITCH HH	DI	NIS								
		0104	ADV151-P	1-4-4	1	4	4	LSLL220401S	LSLL220401	FUEL GAS STEAM GEN.	FUEL GAS	STEAM GEN.	DI	NIS								
		0104	ADV151-P	1-4-5	1	4	5	PSHH220652S	PSHH220652	FUEL TO REFORMER	FUEL TO	REFORMER	DI	NIS								
		0104	ADV151-P	1-4-6	1	4	6	PSLL220651S	PSLL220651	FUEL TO REFORMER	FUEL TO	REFORMER	DI	NIS								
		0104	ADV151-P	1-4-7	1	4	7	PSL220722S	PSL220722	CO ANALYZER PURGE	CO ANALYZER	PURGE	DI	NIS								
		0104	ADV151-P	1-4-8	1	4	8	PSLL220720S	PSLL220720	O2 ANALYZER PURGE	O2 ANALYZER	PURGE	DI	NIS								
		0104	ADV151-P	1-4-9	1	4	9	ZSC220702S	ZSC220702				DI	NIS								
		0104	ADV151-P	1-4-10	1	4	10	ZSO220702S	ZSO220702				DI	NIS								
		0104	ADV151-P	1-4-11	1	4	11	BS220700	BS220700	DI FLAME DETECTION	DI FLAME DET	ECTION	DI	NIS								
		0104	ADV151-P	1-4-12	1	4	12	TSH220306B	TSH220306B	DI FLAME BPS PERMITTED	DI FLAME BPS	PERMITTED	DI	NIS								
		0104	ADV151-P	1-4-13	1	4	13	PSL220676	PSL220676	DI PURGE	DI PURGE		DI	NIS								
		0104	ADV151-P	1-4-14	1	4	14	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-15	1	4	15	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-16	1	4	16	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-17	1	4	17	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-18	1	4	18	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-19	1	4	19	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-20	1	4	20	SPARE	SPARE				DI	NIS								
		0104	ADV151-P	1-4-21	1	4	21	FLS220101AS	FLS220101A				DI	NIS							NG	
		0104	ADV151-P	1-4-22	1	4	22	PHS220101AS	PHS220101A				DI	NIS							NG	
		0104	ADV151-P	1-4-23	1	4	23	PHS220102AS	PHS220102A				DI	NIS							NG	
		0104	ADV151-P	1-4-24	1	4	24	PHS220103AS	PHS220103A				DI	NIS							NG	
		0104	ADV151-P	1-4-25	1	4	25	PHS220104AS	PHS220104A				DI	NIS							NG	
		0104	ADV151-P	1-4-26	1	4	26	PLS220105AS	PLS220105A				DI	NIS							NG	
		0104	ADV151-P	1-4-27	1	4	27	FLS220201AS	FLS220201A				DI	NIS							NG	
		0104	ADV151-P	1-4-28	1	4	28	PHS220201AS	PHS220201A				DI	NIS							NG	
		0104	ADV151-P	1-4-29	1	4	29	PHS220202AS	PHS220202A				DI	NIS							NG	
		0104	ADV151-P	1-4-30	1	4	30	PHS220203AS	PHS220203A				DI	NIS							NG	
		0104	ADV151-P	1-4-31	1	4	31	PHS220204AS	PHS220204A				DI	NIS							NG	
		0104	ADV151-P	1-4-32	1	4	32	PLS220205AS	PLS220205A				DI	NIS							NG	

Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description		IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
												Lower	Upper	LL	L		H	HH				
		0104	ADV551-P	1-5-1	1	5	1	SV2202000	SV220200	NAT GAS TO SP-779	NAT GAS TO S	P-779	DO	NIS								
		0104	ADV551-P	1-5-2	1	5	2	SV2202010	SV220201	STM TO REFORMER	STM TO	REFORMER	DO	NIS								
		0104	ADV551-P	1-5-3	1	5	3	SV2202030	SV220203	NAT GAS TO BURNER	NAT GAS TO	BURNER	DO	NIS								
		0104	ADV551-P	1-5-4	1	5	4	SV2202050	SV220205	VENT GAS TO BURNER	VENT GAS TO	BURNER	DO	NIS								
		0104	ADV551-P	1-5-5	1	5	5	SV220501AO	SV220501A	PROCESS CAS TO PSA	PROCESS CAS	TO PSA	DO	NIS								
		0104	ADV551-P	1-5-6	1	5	6	SV220501BO	SV220501B	PROCESS CAS TO PSA	PROCESS CAS	TO PSA	DO	NIS								
		0104	ADV551-P	1-5-7	1	5	7	SV220501CO	SV220501C	PROCESS CAS TO PSA	PROCESS CAS	TO PSA	DO	NIS								
		0104	ADV551-P	1-5-8	1	5	8	SV220501DO	SV220501D	PROCESS CAS TO PSA	PROCESS CAS	TO PSA	DO	NIS								
		0104	ADV551-P	1-5-9	1	5	9	SV220502AO	SV220502A	H2 PROD. & REPRESSURE	H2 PROD. &	REPRESSURE	DO	NIS								
		0104	ADV551-P	1-5-10	1	5	10	SV220502BO	SV220502B	H2 PROD. & REPRESSURE	H2 PROD. &	REPRESSURE	DO	NIS								
		0104	ADV551-P	1-5-11	1	5	11	SV220502CO	SV220502C	H2 PROD. & REPRESSURE	H2 PROD. &	REPRESSURE	DO	NIS								
		0104	ADV551-P	1-5-12	1	5	12	SV220502DO	SV220502D	H2 PROD. & REPRESSURE	H2 PROD. &	REPRESSURE	DO	NIS								
		0104	ADV551-P	1-5-13	1	5	13	SV220504AO	SV220504A	PSA BLOWDOWN	PSA BLOWDOWN		DO	NIS								
		0104	ADV551-P	1-5-14	1	5	14	SV220504BO	SV220504B	PSA BLOWDOWN	PSA BLOWDOWN		DO	NIS								
		0104	ADV551-P	1-5-15	1	5	15	SV220504CO	SV220504C	PSA BLOWDOWN	PSA BLOWDOWN		DO	NIS								
		0104	ADV551-P	1-5-16	1	5	16	SV220504DO	SV220504D	PSA BLOWDOWN	PSA BLOWDOWN		DO	NIS								
		0104	ADV551-P	1-5-17	1	5	17	SV220505AO	SV220505A	PSA LP EQUALIZATION	PSA LP	EQUALIZATION	DO	NIS								
		0104	ADV551-P	1-5-18	1	5	18	SV220505BO	SV220505B	PSA LP EQUALIZATION	PSA LP	EQUALIZATION	DO	NIS								
		0104	ADV551-P	1-5-19	1	5	19	SV220505CO	SV220505C	PSA LP EQUALIZATION	PSA LP	EQUALIZATION	DO	NIS								
		0104	ADV551-P	1-5-20	1	5	20	SV220505DO	SV220505D	PSA LP EQUALIZATION	PSA LP	EQUALIZATION	DO	NIS								
		0104	ADV551-P	1-5-21	1	5	21	SV220603AO	SV220603A	H2 PRODUCT	H2 PRODUCT		DO	NIS								
		0104	ADV551-P	1-5-22	1	5	22	SV220603BO	SV220603B	H2 PRODUCT	H2 PRODUCT		DO	NIS								
		0104	ADV551-P	1-5-23	1	5	23	SPARE	SPARE				DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-24	1	5	24	SPARE	SPARE				DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-25	1	5	25	SPARE	SPARE				DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-26	1	5	26	SPARE	SPARE				DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-27	1	5	27	SPARE	SPARE				DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-28	1	5	28	SPARE	SPARE				DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-29	1	5	29	AL220700	AL220700	FOSD TO BMS			DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-30	1	5	30	FSH220217	FSH220217	PURGE PERMISSIVE	PURGE	PERMISSIVE	DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-31	1	5	31	TSH220306A	TSH220306A	FLAME BPS REQUEST	FLAME BPS	REQUEST	DO	NIS							SV CHANGE TO BV	
		0104	ADV551-P	1-5-32	1	5	32	SV220811O	SV220811	BOILER FD WTR TO V-108	BOILER FD	WTR TO V-108	DO	NIS								
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description		IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
		0104	ADV551-P	1-6-1	1	6	1	FN220101O	FN220101	ID FAN START CMD	ID FAN	START CMD	DO	NIS								
		0104	ADV551-P	1-6-2	1	6	2	HSFN220101O	HS220102	ID FAN HAND SW	ID FAN	HAND SW	DO	NIS								
		0104	ADV551-P	1-6-3	1	6	3	FN220102O	FN220102	FD FAN START CMD	FD FAN	START CMD	DO	NIS								
		0104	ADV551-P	1-6-4	1	6	4	HSFN220102O	HS220102	FD FAN HAND SW	FD FAN	HAND SW	DO	NIS								
		0104	ADV551-P	1-6-5	1	6	5	PU220101AO	PU220101A	BFW PUMP A START CMD	BFW PUMP A	START CMD	DO	NIS								
		0104	ADV551-P	1-6-6	1	6	6	HSPU220101AO	HSPU220101A	BFW PUMP B HAND SW	BFW PUMP B	HAND SW	DO	NIS								
		0104	ADV551-P	1-6-7	1	6	7	PU220101BO	PU220101B	BFW PUMP B START CMD	BFW PUMP B	START CMD	DO	NIS								
		0104	ADV551-P	1-6-8	1	6	8	HSPU220101BO	HSPU220101B	BFW PUMP B HAND SW	BFW PUMP B	HAND SW	DO	NIS								
		0104	ADV551-P	1-6-9	1	6	9	PU220DZ1O	PU220DZ1	CHEMICAL DOSING PMP	CHEMICAL	DOSING PMP	DO	NIS								
		0104	ADV551-P	1-6-10	1	6	10	PU220DZ2O	PU220DZ2	CHEMICAL DOSING PMP	CHEMICAL	DOSING PMP	DO	NIS								
		0104	ADV551-P	1-6-11	1	6	11	2201EV11BO	2201EV11B	VENTING VALVE	VENTING VALV	E	DO	NIS							NG	
		0104	ADV551-P	1-6-12	1	6	12	2201EV12BO	2201EV12B	VENTING VALVE			DO	NIS							NG	
		0104	ADV551-P	1-6-13	1	6	13	CP2201O	CP2201	MAIN MOTOR NG COMPR			DO	NIS							NG	
		0104	ADV551-P	1-6-14	1	6	14	PU2201O	PU2201	MAIN MOTOR NG COMPR			DO	NIS							NG	
		0104	ADV551-P	1-6-15	1	6	15	2202EV11BO	2202EV11B	VENTING VLV			DO	NIS							NG	
		0104	ADV551-P	1-6-16	1	6	16	2202EV12BO	2202EV12B	VENTING VLV			DO	NIS							NG	
		0104	ADV551-P	1-6-17	1	6	17	CP2202O	CP2202	MAIN MOTOR NG COMPR	MAIN MOTOR N	G COMPR	DO	NIS							NG	
		0104	ADV551-P	1-6-18	1	6	18	PU2202O	PU2202	MAIN MOTOR NG COMPR	MAIN MOTOR N	G COMPR	DO	NIS							NG	
		0104	ADV551-P	1-6-19	1	6	19	PU150CCW11O	PU150CCW11	COOLING TWR PUMP	COOLING TWR	PUMP	DO	NIS								
		0104	ADV551-P	1-6-20	1	6	20	FN150CT05O	FN150CT05	COOLING TWR FAN	COOLING TWR	FAN	DO	NIS								
		0104	ADV551-P	1-6-21	1	6	21	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-22	1	6	22	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-23	1	6	23	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-24	1	6	24	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-25	1	6	25	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-26	1	6	26	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-27	1	6	27	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-28	1	6	28	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-29	1	6	29	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-30	1	6	30	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-31	1	6	31	SPARE	SPARE				DO	NIS								
		0104	ADV551-P	1-6-32	1	6	32	SPARE	SPARE				DO	NIS								

FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	
													Lower	Upper		LL	L	H	HH			
0104	AAI143-S	1-1-1	1	1	1	FN220101AI	VFD220101	%%FN220101AI	ID FAN VFD	ID FAN VFD		AI	NIS	0.00	50.0	Hz					HYD	MLD PVI
0104	AAI143-S	1-1-2	1	1	2	FN220102AI	VFD220102	%%FN220102AI	FD FAN VFD	FD FAN VFD		AI	NIS	0.00	50.0	Hz					HYD	MLD PVI
0104	AAI143-S	1-1-3	1	1	3	PU220101AAI	VFD220101A	%%PU220101AAI	BFW PUMP A VFD	BFW PUMP A	VFD	AI	NIS	0.0	100.0	%					HYD	
0104	AAI143-S	1-1-4	1	1	4	PU220101BAI	VFD220101B	%%PU220101BAI	BFW PUMP B VFD	BFW PUMP B	VFD	AI	NIS	0.0	100.0	%					HYD	
0104	AAI143-S	1-1-5	1	1	5	FN150CT05AI	VFD150CT05PVI	%%FN150CT05AI	1182G03A FREQ DRV FB	1182G03A FRE	Q DRV FB	AI	NIS	0.0	100.0	%					HYD	
0104	AAI143-S	1-1-6	1	1	6	FN220101AMP	FN220101AMP	%%FN220101AMP				AI	NIS	0.0	100.0	%					HYD	
0104	AAI143-S	1-1-7	1	1	7	FN220102AMP	FN220102AMP	%%FN220102A				AI	NIS									
0104	AAI143-S	1-1-8	1	1	8	CP2201AMP	CP2201AMP	%%CP2201AMP				AI	NIS									
0104	AAI143-S	1-1-9	1	1	9	CP2202AMP	CP2202AMP	%%CP2202AMP				AI	NIS									
0104	AAI143-S	1-1-10	1	1	10	SPARE	SPARE					AI	NIS									
0104	AAI143-S	1-1-11	1	1	11	SPARE	SPARE					AI	NIS									
0104	AAI143-S	1-1-12	1	1	12	SPARE	SPARE					AI	NIS									
0104	AAI143-S	1-1-13	1	1	13	SPARE	SPARE					AI	NIS									
0104	AAI143-S	1-1-14	1	1	14	CP2202AAI	VFD2202APVI	%%CP2202AAI				AI	NIS									
0104	AAI143-S	1-1-15	1	1	15	CP2201AAI	VFD2202APVI	%%CP2201AAI				AI	NIS									
0104	AAI143-S	1-1-16	1	1	16	SPARE	SPARE					AI	NIS									
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	
													Lower	Upper		LL	L	H	HH			
0104	ASI133-S	2-1-1	2	1	1	AT220720	AI220720	%%AT220720	FLUE GAS O2 ANALYZER	FLUE GAS O2	ANALYZER	AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	2-1-2	2	1	2	AT220722	AI220722	%%AT220722	H2 PRODUCT CO ANALYZER	H2 PRODUCT	CO ANALYZER	AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	2-1-3	2	1	3	LT220400	LIC220400	%%LT220400	FLUE GAS STMGGENERATOR	FLUE GAS STM	GENERATOR											
0104	ASI133-S	2-1-4	2	1	4	LT220402	LIC220402	%%LT220402	DEAERATOR LVL	DEAERATOR	LVL											
0104	ASI133-S	2-1-5	2	1	5	LT220403	LIC220403	%%LT220403	COLD COND SEPAR. LVL	COLD COND	SEPAR. LVL											
0104	ASI133-S	2-1-6	2	1	6	SPARE	SPARE															
0104	ASI133-S	2-1-7	2	1	7	PI150CT05R	PI150CT05R	%%PI150CT05														
0104	ASI133-S	2-1-8	2	1	8	PT150CT05	PI150CT05	%%PT150CT05														
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	
													Lower	Upper		LL	L	H	HH			
0104	ASI133-S	2-2-1	2	2	1	FT220200	FIC220200	%%FT220200	NAT. GAS TO REFORMER	NAT. GAS TO	REFORMER	AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	2-2-2	2	2	2	FT220201	FIC220201	%%FT220201	STM TO REFORMER	STM TO	REFORMER	AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	2-2-3	2	2	3	FT220203	FIC220203	%%FT220203	NAT. GAS TO BURNER	NAT. GAS TO	BURNER											
0104	ASI133-S	2-2-4	2	2	4	FT220204	FIC220204	%%FT220204	REPRESSURE H2	REPRESSURE	H2											
0104	ASI133-S	2-2-5	2	2	5	FT220205	FIC220205	%%FT220205	VENT GAS TO BURNER	VENT GAS TO	BURNER											
0104	ASI133-S	2-2-6	2	2	6	FT220206	FI220206	%%FT220206	H2 PRODUCT	H2 PRODUCT												
0104	ASI133-S	2-2-7	2	2	7	FT220217	FI220217	%%FT220217	CAP COMB. AIR DSCHRG	CAP COMB.	AIR DSCHRG											
0104	ASI133-S	2-2-8	2	2	8	RUSAK	PDI220601	%%RUSAK	220-R-101	220-R-101		AI	IS	0	1000	Nm³/h						
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	
													Lower	Upper		LL	L	H	HH			
0104	ASI133-S	3-1-1	3	1	1	PIC220601	PDT220601		220-R-101												HYD	External Power
0104	ASI133-S	3-1-2	3	1	2	PT220600	PIC220600	%%PT220600	EXPORT STM	EXPORT STM		AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	3-1-3	3	1	3	PT220602	PIC220602	%%PT220602	PROCESS GAS TO VENT HDR	PROCESS GAS	TO VENT HDR											
0104	ASI133-S	3-1-4	3	1	4	PT220603	PIC220603	%%PT220603	H2 PRODUCT	H2 PRODUCT												
0104	ASI133-S	3-1-5	3	1	5	PT220605A	PI220605A	%%PT220605A	PSA PRODECT	PSA PRODECT												
0104	ASI133-S	3-1-6	3	1	6	PT220605B	PI220605B	%%PT220605B	PSA PRODECT	PSA PRODECT												
0104	ASI133-S	3-1-7	3	1	7	PT220605C	PI220605C	%%PT220605C	PSA PRODECT	PSA PRODECT												
0104	ASI133-S	3-1-8	3	1	8	PT220605D	PI220605D	%%PT220605D	PSA PRODECT	PSA PRODECT												
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	
													Lower	Upper		LL	L	H	HH			
0104	ASI133-S	3-2-1	3	2	1	PT220606	PIC220606	%%PT220606	220V105 VENTGAS TO HDR	220V105 VENT	GAS TO HDR	AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	3-2-2	3	2	2	SPARE	SPARE					AI	IS	0	1000	Nm³/h					HYD	External Power
0104	ASI133-S	3-2-3	3	2	3	PT220613	PI220613	%%PT220613	NAT. GAS TO BURNER	NAT. GAS TO	BURNER											
0104	ASI133-S	3-2-4	3	2	4	PT220617	PI220617	%%PT220617	INST AIR SUPPLY	INST AIR	SUPPLY											
0104	ASI133-S	3-2-5	3	2	5	PT220635	PI220635	%%PT220635	NAT. GAS TO REFORMER	NAT. GAS TO	REFORMER											
0104	ASI133-S	3-2-6	3	2	6	PT220641A	PI220641A	%%PT220641A	BFW PUMP DSCHRG	BFW PUMP	DSCHRG											
0104	ASI133-S	3-2-7	3	2	7	PT220641B	PI220641B	%%PT220641B	BFW PUMP DSCHRG	BFW PUMP	DSCHRG											
0104	ASI133-S	3-2-8	3	2	8	SPARE																

[illegible]

FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
													Lower	Upper	LL		L	H	HH			
0104	AAI543-S	1-2-1	1	2	1	FN220101AO	VFD220101	%%FN220101AO				AO	NIS							H2		
0104	AAI543-S	1-2-2	1	2	2	FN220102AO	VFD220102	%%FN220102AO				AO	NIS							H2		
0104	AAI543-S	1-2-3	1	2	3	SPARE	SPARE					AO	NIS							H2		
0104	AAI543-S	1-2-4	1	2	4	SPARE	SPARE					AO	NIS							H2		
0104	AAI543-S	1-2-5	1	2	5	FN150CT05AO	VFD150CT05	%%FN150CT05AO				AO	NIS									
0104	AAI543-S	1-2-6	1	2	6	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-7	1	2	7	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-8	1	2	8	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-9	1	2	9	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-10	1	2	10	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-11	1	2	11	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-12	1	2	12	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-13	1	2	13	SPARE	SPARE					AO	NIS									
0104	AAI543-S	1-2-14	1	2	14	CP2202AO	VFD2202A	%%CP2202AO				AO	NIS									
0104	AAI543-S	1-2-15	1	2	15	CP2201AO	VFD2201A	%%CP2201AO				AO	NIS									
0104	AAI543-S	1-2-16	1	2	16	SPARE	SPARE					AO	NIS									
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
													Lower	Upper	LL		L	H	HH			
0104	ASI533-S	2-3-1	2	3	1	FV220200	FIC220200	%%FV220200	NAT GAS TO SP-779	NAT GAS TO	SP-779	AO	IS							H2		
0104	ASI533-S	2-3-2	2	3	2	FV220201	FIC220201	%%FV220201	STM TO REFORMER	STM TO	REFORMER	AO	IS							H2		
0104	ASI533-S	2-3-3	2	3	3	FV220203	FIC220203	%%FV220203	NAT GAS TO BURNER	NAT GAS TO	BURNER	AO	IS							H2		
0104	ASI533-S	2-3-4	2	3	4	FV220204	FIC220204	%%FV220204	REPRESSURE H2	REPRESSURE	H2	AO	IS							H2		
0104	ASI533-S	2-3-5	2	3	5	FV220205	FIC220205	%%FV220205	VENT GAS TO BURNER	VENT GAS TO	BURNER	AO	IS							H2		
0104	ASI533-S	2-3-6	2	3	6	SPARE	SPARE					AO	IS									
0104	ASI533-S	2-3-7	2	3	7	SPARE	SPARE					AO	IS									
0104	ASI533-S	2-3-8	2	3	8	SPARE	SPARE					AO	IS									
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
													Lower	Upper	LL		L	H	HH			
0104	ASI533-S	2-4-1	2	4	1	LV220400	LIC220400	%%LV220400	220-WH-102	220-WH-102		AO	IS							H2		
0104	ASI533-S	2-4-2	2	4	2	LV220402	LIC220402	%%LV220402	MAKE-UP WTR TO V106	MAKE-UP WTR	TO V106	AO	IS							H2		
0104	ASI533-S	2-4-3	2	4	3	LV220403	LIC220403	%%LV220403	COLD COND LVL	COLD COND	LVL	AO	IS							H2		
0104	ASI533-S	2-4-4	2	4	4	PV220600	PIC220600	%%PV220600	TOTAL STM MAKE	TOTAL STM	MAKE	AO	IS							H2		
0104	ASI533-S	2-4-5	2	4	5	PV220602	PIC220602	%%PV220602	PROCESS GAS TO VENT HDR	PROCESS GAS	TO VENT HDR	AO	IS							H2		
0104	ASI533-S	2-4-6	2	4	6	PV220603A	PIC220603	%%PV220603A	H2 PRODUCT	H2 PRODUCT		AO	IS							H2		
0104	ASI533-S	2-4-7	2	4	7	PV220603B	PIC220603	%%PV220603B	H2 PRODUCT	H2 PRODUCT		AO	IS							H2		
0104	ASI533-S	2-4-8	2	4	8	PV220606	PIC220606	%%PV220606	PROCESS GAS TO V-105	PROCESS GAS	TO V-105	AO	IS							H2		
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
													Lower	Upper	LL		L	H	HH			
0104	ASI533-S	3-3-1	3	3	1	TV220303A	TIC220303A	%%TV220303A	WH-106 FLUE GAS DSCHRG	WH-106 FLUE	GAS DSCHRG	AO	IS							H2		
0104	ASI533-S	3-3-2	3	3	2	TV220303B	TIC220303B	%%TV220303B	WH-106 FLUE GAS DSCHRG	WH-106 FLUE	GAS DSCHRG	AO	IS							H2		
0104	ASI533-S	3-3-3	3	3	3	TV220307A	TIC220307A	%%TV220307A	PROCESS GAS TO 220-V-102	PROCESS GAS	TO 220-V-102	AO	IS							H2		
0104	ASI533-S	3-3-4	3	3	4	TV220307B	TIC220307B	%%TV220307B	PROCESS GAS TO 220-V-102	PROCESS GAS	TO 220-V-102	AO	IS							H2		
0104	ASI533-S	3-3-5	3	3	5	SPARE	SPARE					AO	IS									
0104	ASI533-S	3-3-6	3	3	6	SPARE	SPARE					AO	IS									
0104	ASI533-S	3-3-7	3	3	7	SPARE	SPARE					AO	IS									
0104	ASI533-S	3-3-8	3	3	8	SPARE	SPARE					AO	IS									
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type		Range		Eng Units	Alarm & Trip Setting				Plant	Remarks
													Lower	Upper	LL		L	H	HH			
0104	ASI533-S	3-4-1	3	4	1	KCV220503A	KCV220503A	%%KCV220503A				AO	IS							H2	ADD 08 SEP 09	
0104	ASI533-S	3-4-2	3	4	2	KCV220503B	KCV220503B	%%KCV220503B				AO	IS							H2	ADD 08 SEP 09	
0104	ASI533-S	3-4-3	3	4	3	KCV220503C	KCV220503C	%%KCV220503C				AO	IS							H2	ADD 08 SEP 09	
0104	ASI533-S	3-4-4	3	4	4	KCV220503D	KCV220503D	%%KCV220503D				AO	IS							H2	ADD 08 SEP 09	
0104	ASI533-S	3-4-5	3	4	5	KCV220508	KCV220508	%%KCV220508				AO	IS							H2	ADD 08 SEP 09	
0104	ASI533-S	3-4-6	3	4	6	PCV22001	PIC22001	%%PCV22001				AO	IS							NG		
0104	ASI533-S	3-4-7	3	4	7	PCV22002	PIC22002	%%PCV22002				AO	IS							NG		
0104	ASI533-S	3-4-8	3	4	8	SPARE						AO	IS									

	io point given by wilmar	card order for FCS0102	comment
Electrolysis (IS-AI)/(NIS-AI)	60	enough	
Electrolysis (NIS-AO)	21	1	at least need 2 non is AO card
Electrolysis (NIS-DI)	81	enough	
Electrolysis (NIS-DO)	108	3	at least need 4 non is DO card

Signal Type :			Cabinet No. : H2 PANEL H2-DCS PANEL 1										FCS0101														
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>													HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART					
HSC	RTD																										
AI	AO																										
DI	DO																										
IS	NIS																										
HART	NON HART																										
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	MCB3-3 OVDC-3 24VDC-3 24VDC-5 OVDC-5																							
				TB				IP-R			Tag No.			Term.	Channel	NODE	SLOT	MODEL									
				TB1-001				14	R1-1	A2	SV220200O			A1	1	1	5	ADV551									
				TB1-002				11		A1																	
				TB1-003				14	R1-2	A2	SV220201O			A2	2	1	5	ADV551									
				TB1-004				11		A1																	
				TB1-005				14	R1-3	A2	SV220203O			A3	3	1	5	ADV551									
				TB1-006				11		A1																	
				TB1-007				14	R1-4	A2	SV220205O			A4	4	1	5	ADV551									
				TB1-008				11		A1																	
				TB1-009				14	R1-5	A2	SV220501AO			A5	5	1	5	ADV551									
				TB1-010				11		A1																	
				TB1-011				14	R1-6	A2	SV220501BO			A6	6	1	5	ADV551									
				TB1-012				11		A1																	
				TB1-013				14	R1-7	A2	SV220501CO			A7	7	1	5	ADV551									
				TB1-014				11		A1																	
				TB1-015				14	R1-8	A2	SV220501DO			A8	8	1	5	ADV551									
				TB1-016				11		A1																	
				TB1-017				14	R1-9	A2	SV220502AO			A9	9	1	5	ADV551									
				TB1-018				11		A1																	
				TB1-019				14	R1-10	A2	SV220502BO			A10	10	1	5	ADV551									
				TB1-020				11		A1																	
				TB1-021				14	R1-11	A2	SV220502CO			A11	11	1	5	ADV551									
				TB1-022				11		A1																	
				TB1-023				14	R1-12	A2	SV220502DO			A12	12	1	5	ADV551									
				TB1-024				11		A1																	
				TB1-025				14	R1-13	A2	SV220504AO			A13	13	1	5	ADV551									
				TB1-026				11		A1																	
				TB1-027				14	R1-14	A2	SV220504BO			A14	14	1	5	ADV551									
				TB1-028				11		A1																	
				TB1-029				14	R1-15	A2	SV220504CO			A15	15	1	5	ADV551									
				TB1-030				11		A1																	
				TB1-031				14	R1-16	A2	SV220504DO			A16	16	1	5	ADV551									
				TB1-032				11		A1																	
														A17	-	1	5	ADV551									
														A18	+												
GENERAL DESCRIPTION		DR.	DATE							PROJECT NAME							DWG. NO.										
Panel Wiring Drawing		DILA	01/07/09							WSH2 & SN PROJECT							19-DO										
		CH.	DATE							TITLE							SHT NO										
		HARINAH	01/07/09							H2 PANEL							19										
FILENAME		APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.							CONT NO										
H2		JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002							20										

Signal Type :			Cabinet No : H2 PANEL H2-DCS PANEL 1										FCS0101															
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC											RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART							
HSC	RTD																											
AI	AO																											
DI	DO																											
IS	NIS																											
HART	NON HART																											
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	MCB3-3 OVDC-3 24VDC-3										MCB3-5 24VDC-5 OVDC-5										Term.	Channel	NODE	SLOT	MODEL
				TB				IP-R			Tag No.																	
				TB1-033				14	R1-17	A2	SV220505AO			B1	17	1	5	ADV551										
				TB1-034				11		A1																		
				TB1-035				14	R1-18	A2	SV220505BO			B2	18	1	5	ADV551										
				TB1-036				11		A1																		
				TB1-037				14	R1-19	A2	SV220505CO			B3	19	1	5	ADV551										
				TB1-038				11		A1																		
				TB1-039				14	R1-20	A2	SV220505DO			B4	20	1	5	ADV551										
				TB1-040				11		A1																		
				TB1-041				14	R1-21	A2	SV220603AO			B5	21	1	5	ADV551										
				TB1-042				11		A1																		
				TB1-043				14	R1-22	A2	SV220603BO			B6	22	1	5	ADV551										
				TB1-044				11		A1																		
				TB1-045				14	R1-23	A2	SPARE			B7	23	1	5	ADV551										
				TB1-046				11		A1																		
				TB1-047				14	R1-24	A2	SPARE			B8	24	1	5	ADV551										
				TB1-048				11		A1																		
				TB1-049				14	R1-25	A2	SPARE			B9	25	1	5	ADV551										
				TB1-050				11		A1																		
				TB1-051				14	R1-26	A2	SPARE			B10	26	1	5	ADV551										
				TB1-052				11		A1																		
				TB1-053				14	R1-27	A2	SPARE			B11	27	1	5	ADV551										
				TB1-054				11		A1																		
				TB1-055				14	R1-28	A2	SPARE			B12	28	1	5	ADV551										
				TB1-056				11		A1																		
				TB1-057				14	R1-29	A2	AL220700			B13	29	1	5	ADV551										
				TB1-058				11		A1																		
				TB1-059				14	R1-30	A2	FSH220217			B14	30	1	5	ADV551										
				TB1-060				11		A1																		
				TB1-061				14	R1-31	A2	TSH220306A			B15	31	1	5	ADV551										
				TB1-062				11		A1																		
				TB1-063				14	R1-32	A2	SV220811O			B16	32	1	5	ADV551										
				TB1-064				11		A1																		
														B17	-	1	5	ADV551										
														B18	+													

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	20-DO
	CH.	DATE						TITLE		SHT NO
		HARINAH	01/07/09						H2 PANEL	20
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT NO
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	2

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME		DWG. NO.
	DILA	01/07/09							WSH2 & SN PROJECT		20-DO
	CH.	DATE							TITLE		SHT NO
	HARINAH	01/07/09							H2 PANEL		20
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT NO	
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	21	

Signal Type :			Cabinet No. : H2 PANEL H2-DCS PANEL 1										FCS0101														
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>													HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART					
HSC	RTD																										
AI	AO																										
DI	DO																										
IS	NIS																										
HART	NON HART																										
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	MCB3-4		OVDC-4		24VDC-4		MCB3-6		OVDC-6		Term.	Channel	NODE	SLOT	MODEL									
				TB					14		IP-R		Tag No.														
				TB1-065					14		R2-1	A2	FN220101O	A1	1	1	6	ADV551									
				TB1-066					11			A1															
				TB1-067					14		R2-2	A2	HSFN220101O	A2	2	1	6	ADV551									
				TB1-068					11			A1															
				TB1-069					14		R2-3	A2	FN220102O	A3	3	1	6	ADV551									
				TB1-070					11			A1															
				TB1-071					14		R2-4	A2	HSFN220102O	A4	4	1	6	ADV551									
				TB1-072					11			A1															
				TB1-073					14		R2-5	A2	PU220101AO	A5	5	1	6	ADV551									
				TB1-074					11			A1															
				TB1-075					14		R2-6	A2	HSPU220101AO	A6	6	1	6	ADV551									
				TB1-076					11			A1															
				TB1-077					14		R2-7	A2	PU220101BO	A7	7	1	6	ADV551									
				TB1-078					11			A1															
				TB1-079					14		R2-8	A2	HSPU220101BO	A8	8	1	6	ADV551									
				TB1-080					11			A1															
				TB1-081					14		R2-9	A2	PU220DZ1O	A9	9	1	6	ADV551									
				TB1-082					11			A1															
				TB1-083					14		R2-10	A2	PU220DZ2O	A10	10	1	6	ADV551									
				TB1-084					11			A1															
				TB1-085					14		R2-11	A2	2201EV11BO	A11	11	1	6	ADV551									
				TB1-086					11			A1															
				TB1-087					14		R2-12	A2	2201EV12BO	A12	12	1	6	ADV551									
				TB1-088					11			A1															
				TB1-089					14		R2-13	A2	CP2201O	A13	13	1	6	ADV551									
				TB1-090					11			A1															
				TB1-091					14		R2-14	A2	PU2201O	A14	14	1	6	ADV551									
				TB1-092					11			A1															
				TB1-093					14		R2-15	A2	2202EV11BO	A15	15	1	6	ADV551									
				TB1-094					11			A1															
				TB1-095					14		R2-16	A2	2202EV12BO	A16	16	1	6	ADV551									
				TB1-096					11			A1															
														A17	-	1	6	ADV551									
														A18	+												

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	21-DO
	CH.	DATE						TITLE		SHT NO
		HARINAH	01/07/09						H2 PANEL	21
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT NO
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	2

GENERAL DESCRIPTION Panel Wiring Drawing	DR.	DATE							PROJECT NAME	DWG. NO.
	DILA	01/07/09							WSH2 & SN PROJECT	21-DO
	CH. HARINAH	DATE 01/07/09							TITLE H2 PANEL	SHT NO 21
FILENAME H2	APP. JENNY	DATE 01/07/09	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO. WSH2SN-D32-002	CONT NO 22
			REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY		

Signal Type :			Cabinet No. :										FCS0101														
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	H2 PANEL H2-DCS PANEL 1										SYSTEM I/O				
HSC	RTD																										
AI	AO																										
DI	DO																										
IS	NIS																										
HART	NON HART																										
FIELD CABLE	CROSS WIRING TB	CROSS WIRE NO.	MCB3-4					MCB3-6					Term.	Channel	NODE	SLOT	MODEL										
			OVDC-4	24VDC-4	IP-R			24VDC-6	OVDC-6																		
			TB						Tag No.																		
			TB1-097		14	R2-17	A2	CP22020	B1	17	1	6	ADV551														
			TB1-098		11		A1																				
			TB1-099		14	R2-18	A2	PU22020	B2	18	1	6	ADV551														
			TB1-100		11		A1																				
			TB1-101		14	R2-19	A2	PU150CCW110	B3	19	1	6	ADV551														
			TB1-102		11		A1																				
			TB1-103		14	R2-20	A2	FN150CT050	B4	20	1	6	ADV551														
			TB1-104		11		A1																				
			TB1-105		14	R2-21	A2	SPARE	B5	21	1	6	ADV551														
			TB1-106		11		A1																				
			TB1-107		14	R2-22	A2	SPARE	B6	22	1	6	ADV551														
			TB1-108		11		A1																				
			TB1-109		14	R2-23	A2	SPARE	B7	23	1	6	ADV551														
			TB1-110		11		A1																				
			TB1-111		14	R2-24	A2	SPARE	B8	24	1	6	ADV551														
			TB1-112		11		A1																				
			TB1-113		14	R2-25	A2	SPARE	B9	25	1	6	ADV551														
			TB1-114		11		A1																				
			TB1-115		14	R2-26	A2	SPARE	B10	26	1	6	ADV551														
			TB1-116		11		A1																				
			TB1-117		14	R2-27	A2	SPARE	B11	27	1	6	ADV551														
			TB1-118		11		A1																				
			TB1-119		14	R2-28	A2	SPARE	B12	28	1	6	ADV551														
			TB1-120		11		A1																				
			TB1-121		14	R2-29	A2	SPARE	B13	29	1	6	ADV551														
			TB1-122		11		A1																				
			TB1-123		14	R2-30	A2	SPARE	B14	30	1	6	ADV551														
			TB1-124		11		A1																				
			TB1-125		14	R2-31	A2	SPARE	B15	31	1	6	ADV551														
			TB1-126		11		A1																				
			TB1-127		14	R2-32	A2	SPARE	B16	32	1	6	ADV551														
			TB1-128		11		A1																				
									B17	-	1	6	ADV551														
									B18	+																	

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	22-DO
	CH.	DATE							TITLE	SHT NO
	HARINAH	01/07/09							H2 PANEL	22
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT NO
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	23

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 1					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>											HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART
HSC	RTD																			
AI	AO																			
DI	DO																			
IS	NIS																			
HART	NON HART																			
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-1		24VDC-1		Term.	Channel	Node	Slot	Model								
				TB	Tag No.															
				TB2-001	FN220101STI		A1	1	1	3	ADV151									
				TB2-002			A17													
				TB2-003	FN220101TRI		A2	2	1	3	ADV151									
				TB2-004			A17													
				TB2-005	FN220101FFI		A3	3	1	3	ADV151									
				TB2-006			A17													
				TB2-007	FN220101RLI		A4	4	1	3	ADV151									
				TB2-008			A17													
				TB2-009	FN220102STI		A5	5	1	3	ADV151									
				TB2-010			A17													
				TB2-011	FN220102TRI		A6	6	1	3	ADV151									
				TB2-012			A17													
				TB2-013	FN220102FFI		A7	7	1	3	ADV151									
				TB2-014			A17													
				TB2-015	FN220102RLI		A8	8	1	3	ADV151									
				TB2-016			A17													
				TB2-017	PU220101ASTI		A9	9	1	3	ADV151									
				TB2-018			A17													
				TB2-019	PU220101ATRI		A10	10	1	3	ADV151									
				TB2-020			A17													
				TB2-021	PU220101AFFI		A11	11	1	3	ADV151									
				TB2-022			A17													
				TB2-023	PU220101ARLI		A12	12	1	3	ADV151									
				TB2-024			A17													
				TB2-025	PU220101BSTI		A13	13	1	3	ADV151									
				TB2-026			A17													
				TB2-027	PU220101BTRI		A14	14	1	3	ADV151									
				TB2-028			A17													
				TB2-029	PU220101BFFI		A15	15	1	3	ADV151									
				TB2-030			A17													
				TB2-031	PU220101BRLI		A16	16	1	3	ADV151									
				TB2-032			A17													

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		23-DI
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL		23
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		24

Signal Type : <table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	Cabinet No : H2 PANEL H2-DCS PANEL 1 MCB3-1 0VDC-1 24VDC-1			FCS0101					
			HSC	RTD																	
AI	AO																				
DI	DO																				
IS	NIS																				
HART	NON HART																				
SYSTEM I/O																					
FIELD CABLE	CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model												
			TB2-033	PU220DZ1STI	B1	17	1	3	ADV151												
			TB2-034		B17																
			TB2-035	PU220DZ1TRI	B2	18	1	3	ADV151												
			TB2-036		B17																
			TB2-037	PU220DZ2STI	B3	19	1	3	ADV151												
			TB2-038		B17																
			TB2-039	PU220DZ2TRI	B4	20	1	3	ADV151												
			TB2-040		B17																
			TB2-041	FN150CT05STI	B5	21	1	3	ADV151												
			TB2-042		B17																
			TB2-043	FN150CT05TRI	B6	22	1	3	ADV151												
			TB2-044		B17																
			TB2-045	PU150CCW11STI	B7	23	1	3	ADV151												
			TB2-046		B17																
			TB2-047	PU150CCW11TRI	B8	24	1	3	ADV151												
			TB2-048		B17																
			TB2-049	CP2201STI	B9	25	1	3	ADV151												
			TB2-050		B17																
			TB2-051	CP2201TRI	B10	26	1	3	ADV151												
			TB2-052		B17																
			TB2-053	PU2201STI	B11	27	1	3	ADV151												
			TB2-054		B17																
			TB2-055	PU2201TRI	B12	28	1	3	ADV151												
			TB2-056		B17																
			TB2-057	CP2202STI	B13	29	1	3	ADV151												
			TB2-058		B17																
			TB2-059	CP2202TRI	B14	30	1	3	ADV151												
			TB2-060		B17																
			TB2-061	PU2202STI	B15	31	1	3	ADV151												
			TB2-062		B17																
			TB2-063	PU2202TRI	B16	32	1	3	ADV151												
			TB2-064		B17																

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	24-DI
	CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL	24
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT'D
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	25

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 1					FCS0101				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			MCB3-2					SYSTEM I/O							
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-2		24VDC-2		Term.	Channel	Node	Slot	Model			
				TB	Tag No.										
				TB2-065	FLS220202S		A1	1	1	4	ADV151				
				TB2-066			A17								
				TB2-067	FLS220231S		A2	2	1	4	ADV151				
				TB2-068			A17								
				TB2-069	LSHH220405S		A3	3	1	4	ADV151				
				TB2-070			A17								
				TB2-071	LSLL220401S		A4	4	1	4	ADV151				
				TB2-072			A17								
				TB2-073	PSHH220652S		A5	5	1	4	ADV151				
				TB2-074			A17								
				TB2-075	PSLL220651S		A6	6	1	4	ADV151				
				TB2-076			A17								
				TB2-077	PSL220722S		A7	7	1	4	ADV151				
				TB2-078			A17								
				TB2-079	PSLL220720S		A8	8	1	4	ADV151				
				TB2-080			A17								
				TB2-081	ZSC220702S		A9	9	1	4	ADV151				
				TB2-082			A17								
				TB2-083	ZSO220702S		A10	10	1	4	ADV151				
				TB2-084			A17								
				TB2-085	BS220700		A11	11	1	4	ADV151				
				TB2-086			A17								
				TB2-087	TSH220306B		A12	12	1	4	ADV151				
				TB2-088			A17								
				TB2-089	PSL220676		A13	13	1	4	ADV151				
				TB2-090			A17								
				TB2-091	SPARE		A14	14	1	4	ADV151				
				TB2-092			A17								
				TB2-093	SPARE		A15	15	1	4	ADV151				
				TB2-094			A17								
				TB2-095	SPARE		A16	16	1	4	ADV151				
				TB2-096			A17								

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	25-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	01/07/09							H2 PANEL	25
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT'D
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	26

Signal Type : <table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	Cabinet No : H2 PANEL H2-DCS PANEL 1 MCB3-2			FCS0101					
			HSC	RTD																	
AI	AO																				
DI	DO																				
IS	NIS																				
HART	NON HART																				
SYSTEM I/O																					
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-2	24VDC-2	Term.	Channel	Node	Slot	Model											
				TB	Tag No.																
				TB2-097	SPARE	B1	17	1	4	ADV151											
				TB2-098		B17															
				TB2-099	SPARE	B2	18	1	4	ADV151											
				TB2-100		B17															
				TB2-101	SPARE	B3	19	1	4	ADV151											
				TB2-102		B17															
				TB2-103	SPARE	B4	20	1	4	ADV151											
				TB2-104		B17															
				TB2-105	FLS220101AS	B5	21	1	4	ADV151											
				TB2-106		B17															
				TB2-107	PHS220101AS	B6	22	1	4	ADV151											
				TB2-108		B17															
				TB2-109	PHS220102AS	B7	23	1	4	ADV151											
				TB2-110		B17															
				TB2-111	PHS220103AS	B8	24	1	4	ADV151											
				TB2-112		B17															
				TB2-113	PHS220104AS	B9	25	1	4	ADV151											
				TB2-114		B17															
				TB2-115	PLS220105AS	B10	26	1	4	ADV151											
				TB2-116		B17															
				TB2-117	FLS220201AS	B11	27	1	4	ADV151											
				TB2-118		B17															
				TB2-119	PHS220201AS	B12	28	1	4	ADV151											
				TB2-120		B17															
				TB2-121	PHS220202AS	B13	29	1	4	ADV151											
				TB2-122		B17															
				TB2-123	PHS220203AS	B14	30	1	4	ADV151											
				TB2-124		B17															
				TB2-125	PHS220204AS	B15	31	1	4	ADV151											
				TB2-126		B17															
				TB2-127	PLS220205AS	B16	32	1	4	ADV151											
				TB2-128		B17															

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	26-DI
	CH.	DATE								SHT. NO.
		HARINAH	01/07/09						H2 PANEL	26
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONT'D
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	27

Signal Type :				Cabinet No :				H2 PANEL H2-DCS PANEL 1					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC	RTD										AI	AO	DI	DO	IS	NIS	HART	NON HART		
HSC	RTD																					
AI	AO																					
DI	DO																					
IS	NIS																					
HART	NON HART																					
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.			Term.	Channel	Node	Slot	Model										
				TB3-001	FN220101AI			A1	1	1	1	AAI143										
				TB3-002				B1														
				TB3-003	FN220102AI			A2	2	1	1	AAI143										
				TB3-004				B2														
				TB3-005	PU220101AAI			A3	3	1	1	AAI143										
				TB3-006				B3														
				TB3-007	PU220101BAI			A4	4	1	1	AAI143										
				TB3-008				B4														
				TB3-009	FN150CT05AI			A5	5	1	1	AAI143										
				TB3-010				B5														
				TB3-011	FN220101AMP			A6	6	1	1	AAI143										
				TB3-012				B6														
				TB3-013	FN220102AMP			A7	7	1	1	AAI143										
				TB3-014				B7														
				TB3-015	CP2201AMP			A8	8	1	1	AAI143										
				TB3-016				B8														
				TB3-017	CP2202AMP			A9	9	1	1	AAI143										
				TB3-018				B9														
				TB3-019	SPARE			A10	10	1	1	AAI143										
				TB3-020				B10														
				TB3-021	SPARE			A11	11	1	1	AAI143										
				TB3-022				B11														
				TB3-023	SPARE			A12	12	1	1	AAI143										
				TB3-024				B12														
				TB3-025	SPARE			A13	13	1	1	AAI143										
				TB3-026				B13														
				TB3-027	CP2202AAI			A14	14	1	1	AAI143										
				TB3-028				B14														
				TB3-029	CP2201AAI			A15	15	1	1	AAI143										
				TB3-030				B15														
				TB3-031	SPARE			A16	16	1	1	AAI143										
				TB3-032				B16														
GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME				DWG. NO.									
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT				27-AI									
		CH.	DATE						TITLE				SHT. NO.									
		HARINAH	01/07/09						H2 PANEL				27									
FILENAME	APP.	DATE	1	AS PER FAT		20/10/09	DILA	HARINAH	JENNY	DOC. NO.				CONTD								
H2	JENNY	01/07/09	REV.	DESCRIPTION		DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002				28								

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 1					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC									RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	
HSC	RTD																			
AI	AO																			
DI	DO																			
IS	NIS																			
HART	NON HART																			
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model										
				TB4-001	FN220101AO	A1	1	1	2	AAI543										
				TB4-002		B1														
				TB4-003	FN220102AO	A2	2	1	2	AAI543										
				TB4-004		B2														
				TB4-005	SPARE	A3	3	1	2	AAI543										
				TB4-006		B3														
				TB4-007	SPARE	A4	4	1	2	AAI543										
				TB4-008		B4														
				TB4-009	FN150CT05AO	A5	5	1	2	AAI543										
				TB4-010		B5														
				TB4-011	SPARE	A6	6	1	2	AAI543										
				TB4-012		B6														
				TB4-013	SPARE	A7	7	1	2	AAI543										
				TB4-014		B7														
				TB4-015	SPARE	A8	8	1	2	AAI543										
				TB4-016		B8														
				TB4-017	SPARE	A9	9	1	2	AAI543										
				TB4-018		B9														
				TB4-019	SPARE	A10	10	1	2	AAI543										
				TB4-020		B10														
				TB4-021	SPARE	A11	11	1	2	AAI543										
				TB4-022		B11														
				TB4-023	SPARE	A12	12	1	2	AAI543										
				TB4-024		B12														
				TB4-025	SPARE	A13	13	1	2	AAI543										
				TB4-026		B13														
				TB4-027	CP2202AO	A14	14	1	2	AAI543										
				TB4-028		B14														
				TB4-029	CP2201AO	A15	15	1	2	AAI543										
				TB4-030		B15														
				TB4-031	SPARE	A16	16	1	2	AAI543										
				TB4-032		B16														

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		28-AO
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL		28
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		29

Signal Type :			Cabinet No :																				
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	H2 PANEL H2-DCS PANEL 2						FCS0101				
HSC	RTD																						
AI	AO																						
DI	DO																						
IS	NIS																						
HART	NON HART																						
									SYSTEM I/O														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model													
				TB5-001	AT220720	A1	1	2	1	ASI133													
				TB5-002		B1																	
				TB5-003	AT220722	A3	2	2	1	ASI133													
				TB5-004		B3																	
				TB5-005	LT220400	A5	3	2	1	ASI133													
				TB5-006		B5																	
				TB5-007	LT220402	A7	4	2	1	ASI133													
				TB5-008		B7																	
				TB5-009	LT220403	A10	5	2	1	ASI133													
				TB5-010		B10																	
				TB5-011	SPARE	A12	6	2	1	ASI133													
				TB5-012		B12																	
				TB5-013	PI150CT05R	A14	7	2	1	ASI133													
				TB5-014		B14																	
				TB5-015	PT150CT05	A16	8	2	1	ASI133													
				TB5-016		B16																	

GENERAL DESCRIPTION		DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing		DILA	01/07/09							WSH2 & SN PROJECT	29-AI
		CH.	DATE							TITLE	SHT. NO.
		HARINAH	01/07/09							H2 PANEL	29
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		30

Signal Type :

HSC	RTD
AI	AO
DI	DO
IS	NIS
HART	NON HART

Cabinet No :

H2 PANEL
H2-DCS PANEL 2

FCS0101

SYSTEM I/O

FIELD CABLE	CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model
			TB5-017	FT220200	A1	1	2	2	ASI133
			TB5-018		B1				
			TB5-019	FT220201	A3	2	2	2	ASI133
			TB5-020		B3				
			TB5-021	FT220203	A5	3	2	2	ASI133
			TB5-022		B5				
			TB5-023	FT220204	A7	4	2	2	ASI133
			TB5-024		B7				
			TB5-025	FT220205	A10	5	2	2	ASI133
			TB5-026		B10				
			TB5-027	FT220206	A12	6	2	2	ASI133
			TB5-028		B12				
			TB5-029	FT220217	A14	7	2	2	ASI133
			TB5-030		B14				
			TB5-031	RUSAK	A16	8	2	2	ASI133
			TB5-032		B16				

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	30-AI
	CH.	DATE								SHT. NO.
	HARINAH	01/07/09							H2 PANEL	30
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	31



Signal Type :			Cabinet No : H2 PANEL H2-DCS PANEL 2					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC											RTD	AI	AO	DI	DO
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	SYSTEM I/O													
				TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB5-033	PIC220601	A1	1	3	1	ASI133							
				TB5-034		B1											
				TB5-035	PT220600	A3	2	3	1	ASI133							
				TB5-036		B3											
				TB5-037	PT220602	A5	3	3	1	ASI133							
				TB5-038		B5											
				TB5-039	PT220603	A7	4	3	1	ASI133							
				TB5-040		B7											
				TB5-041	PT220605A	A10	5	3	1	ASI133							
				TB5-042		B10											
				TB5-043	PT220605B	A12	6	3	1	ASI133							
				TB5-044		B12											
				TB5-045	PT220605C	A14	7	3	1	ASI133							
				TB5-046		B14											
				TB5-047	PT220605D	A16	8	3	1	ASI133							
				TB5-048		B16											

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		31-AI
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL		31
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		32

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 2					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC									RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	
HSC	RTD																			
AI	AO																			
DI	DO																			
IS	NIS																			
HART	NON HART																			
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model										
				TB5-049	PT220606	A1	1	3	2	ASI133										
				TB5-050		B1														
				TB5-051	SPARE	A3	2	3	2	ASI133										
				TB5-052		B3														
				TB5-053	PT220613	A5	3	3	2	ASI133										
				TB5-054		B5														
				TB5-055	PT220617	A7	4	3	2	ASI133										
				TB5-056		B7														
				TB5-057	PT220635	A10	5	3	2	ASI133										
				TB5-058		B10														
				TB5-059	PT220641A	A12	6	3	2	ASI133										
				TB5-060		B12														
				TB5-061	PT220641B	A14	7	3	2	ASI133										
				TB5-062		B14														
				TB5-063	SPARE	A16	8	3	2	ASI133										
				TB5-064		B16														

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		32-AI
CH.	DATE						TITLE		SHT. NO.		
		HARINAH	01/07/09						H2 PANEL		32
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		33

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 2					FCS0101				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC													
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	SYSTEM I/O											
				TB	Tag No.	Term.	Channel	Node	Slot	Model					
				TB5-065	TT220300	A1	1	4	1	ASI133					
				TB5-066		B1									
				TB5-067	TT220303	A3	2	4	1	ASI133					
				TB5-068		B3									
				TB5-069	TT220304	A5	3	4	1	ASI133					
				TB5-070		B5									
				TB5-071	TT220305	A7	4	4	1	ASI133					
				TB5-072		B7									
				TB5-073	TT220306	A10	5	4	1	ASI133					
				TB5-074		B10									
				TB5-075	TT220307	A12	6	4	1	ASI133					
				TB5-076		B12									
				TB5-077	TT220310	A14	7	4	1	ASI133					
				TB5-078		B14									
				TB5-079	TT220311	A16	8	4	1	ASI133					
				TB5-080		B16									

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		33-AI
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL		33
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		34



Signal Type :			Cabinet No :				H2 PANEL H2-DCS PANEL 2					FCS0101				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC														
HSC	RTD															
AI	AO															
DI	DO															
IS	NIS															
HART	NON HART															
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	SYSTEM I/O												
		TB	Tag No.	Term.	Channel	Node	Slot	Model								
			TB5-081	TT220313	A1	1	4	2	ASI133							
			TB5-082		B1											
			TB5-083	TT220320	A3	2	4	2	ASI133							
			TB5-084		B3											
			TB5-085	TT220322	A5	3	4	2	ASI133							
			TB5-086		B5											
			TB5-087	TT220327	A7	4	4	2	ASI133							
			TB5-088		B7											
			TB5-089	PT220101A	A10	5	4	2	ASI133							
			TB5-090		B10											
			TB5-091	PT220102A	A12	6	4	2	ASI133							
			TB5-092		B12											
			TB5-093	PT220201A	A14	7	4	2	ASI133							
			TB5-094		B14											
			TB5-095	PT220202A	A16	8	4	2	ASI133							
			TB5-096		B16											

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		34-AI
		CH.	DATE								
		HARINAH	01/07/09								
FILENAME		APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONTD
H2		JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	35



Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 2			FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>									HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART
HSC	RTD																	
AI	AO																	
DI	DO																	
IS	NIS																	
HART	NON HART																	
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model								
				TB5-097	TI220HX101	A1	1	4	3	ASI133								
				TB5-098		B1												
				TB5-099	SPARE	A3	2	4	3	ASI133								
				TB5-100		B3												
				TB5-101	SPARE	A5	3	4	3	ASI133								
				TB5-102		B5												
				TB5-103	PT22001	A7	4	4	3	ASI133								
				TB5-104		B7												
				TB5-105	PT22002	A10	5	4	3	ASI133								
				TB5-106		B10												
				TB5-107	TT150CT05S	A12	6	4	3	ASI133								
				TB5-108		B12												
				TB5-109	TT150CT05R	A14	7	4	3	ASI133								
				TB5-110		B14												
				TB5-111	SPARE	A16	8	4	3	ASI133								
				TB5-112		B16												

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		35-AI
CH.	DATE						TITLE		SHT. NO.		
		HARINAH	01/07/09						H2 PANEL		35
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		36

Signal Type :				Cabinet No :																	
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>				HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	H2 PANEL H2-DCS PANEL 2				FCS0101			
HSC	RTD																				
AI	AO																				
DI	DO																				
IS	NIS																				
HART	NON HART																				
								SYSTEM I/O													
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model											
				TB5-113	TT220101A	A1	1	4	4	ASI133											
				TB5-114		B1															
				TB5-115	TT220102A	A3	2	4	4	ASI133											
				TB5-116		B3															
				TB5-117	TT220103A	A5	3	4	4	ASI133											
				TB5-118		B5															
				TB5-119	TT220104A	A7	4	4	4	ASI133											
				TB5-120		B7															
				TB5-121	TT220201A	A10	5	4	4	ASI133											
				TB5-122		B10															
				TB5-123	TT220202A	A12	6	4	4	ASI133											
				TB5-124		B12															
				TB5-125	TT220203A	A14	7	4	4	ASI133											
				TB5-126		B14															
				TB5-127	TT220204A	A16	8	4	4	ASI133											
				TB5-128		B16															

GENERAL DESCRIPTION		DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing		DILA	01/07/09							WSH2 & SN PROJECT	36-AI
		CH.	DATE							TITLE	SHT. NO.
		HARINAH	01/07/09							H2 PANEL	36
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		37

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 2					FCS0101				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
FIELD CABLE			CROSS WIRING TB	CROSS WIRE NO.	SYSTEM I/O										
			TB	Tag No.	Term.	Channel	Node	Slot	Model						
			TB6-001	FV220200	A1	1	2	3	ASI533						
			TB6-002		B1										
			TB6-003	FV220201	A3	2	2	3	ASI533						
			TB6-004		B3										
			TB6-005	FV220203	A5	3	2	3	ASI533						
			TB6-006		B5										
			TB6-007	FV220204	A7	4	2	3	ASI533						
			TB6-008		B7										
			TB6-009	FV220205	A10	5	2	3	ASI533						
			TB6-010		B10										
			TB6-011	SPARE	A12	6	2	3	ASI533						
			TB6-012		B12										
			TB6-013	SPARE	A14	7	2	3	ASI533						
			TB6-014		B14										
			TB6-015	SPARE	A16	8	2	3	ASI533						
			TB6-016		B16										

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	01/07/09							WSH2 & SN PROJECT	37-AO
	CH.	DATE								SHT. NO.
	HARINAH	01/07/09								37
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.	CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002	38

Signal Type :			Cabinet No :					H2 PANEL H2-DCS PANEL 2					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC											RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	
HSC	RTD																					
AI	AO																					
DI	DO																					
IS	NIS																					
HART	NON HART																					
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.		Term.	Channel	Node	Slot	Model											
				TB6-017	LV220400		A1	1	2	4	ASI533											
				TB6-018			B1															
				TB6-019	LV220402		A3	2	2	4	ASI533											
				TB6-020			B3															
				TB6-021	LV220403		A5	3	2	4	ASI533											
				TB6-022			B5															
				TB6-023	PV220600		A7	4	2	4	ASI533											
				TB6-024			B7															
				TB6-025	PV220602		A10	5	2	4	ASI533											
				TB6-026			B10															
				TB6-027	PV220603A		A12	6	2	4	ASI533											
				TB6-028			B12															
				TB6-029	PV220603B		A14	7	2	4	ASI533											
				TB6-030			B14															
				TB6-031	PV220606		A16	8	2	4	ASI533											
				TB6-032			B16															

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME			DWG. NO.	
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT			38-AO	
CH.	DATE						TITLE			SHT. NO.			
		HARINAH	01/07/09						H2 PANEL			38	
FILENAME	APP.	DATE	1	AS PER FAT		20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD	
H2	JENNY	01/07/09	REV.	DESCRIPTION		DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		39	


Signal Type :			Cabinet No :					H2 PANEL H2-DCS PANEL 2					FCS0101									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC											RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	
HSC	RTD																					
AI	AO																					
DI	DO																					
IS	NIS																					
HART	NON HART																					
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model												
				TB6-033	TV220303A	A1	1	3	3	ASI533												
				TB6-034		B1																
				TB6-035	TV220303B	A3	2	3	3	ASI533												
				TB6-036		B3																
				TB6-037	TV220307A	A5	3	3	3	ASI533												
				TB6-038		B5																
				TB6-039	TV220307B	A7	4	3	3	ASI533												
				TB6-040		B7																
				TB6-041	SPARE	A10	5	3	3	ASI533												
				TB6-042		B10																
				TB6-043	SPARE	A12	6	3	3	ASI533												
				TB6-044		B12																
				TB6-045	SPARE	A14	7	3	3	ASI533												
				TB6-046		B14																
				TB6-047	SPARE	A16	8	3	3	ASI533												
				TB6-048		B16																

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		39-AO
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL		39
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		40

Signal Type :			Cabinet No :			H2 PANEL H2-DCS PANEL 2					FCS0101				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
FIELD CABLE			CROSS WIRING TB	CROSS WIRE NO.	SYSTEM I/O										
			TB	Tag No.	Term.	Channel	Node	Slot	Model						
				TB6-049	A1	1	3	4	ASI533						
				TB6-050	B1										
				TB6-051	A3	2	3	4	ASI533						
				TB6-052	B3										
				TB6-053	A5	3	3	4	ASI533						
				TB6-054	B5										
				TB6-055	A7	4	3	4	ASI533						
				TB6-056	B7										
				TB6-057	A10	5	3	4	ASI533						
				TB6-058	B10										
				TB6-059	A12	6	3	4	ASI533						
				TB6-060	B12										
				TB6-061	A14	7	3	4	ASI533						
				TB6-062	B14										
				TB6-063	A16	8	3	4	ASI533						
				TB6-064	B16										

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	01/07/09						WSH2 & SN PROJECT		40-AO
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	01/07/09						H2 PANEL		40
FILENAME	APP.	DATE	1	AS PER FAT	20/10/09	DILA	HARINAH	JENNY	DOC. NO.		CONTD
H2	JENNY	01/07/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSH2SN-D32-002		-

