

Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description				IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
															Lower	Upper		LL	L	H	HH			
		0202	ASD143-P	1-5-1	1	5	1	SV131AOI	SV131A				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-2	1	5	2	SV131ACI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-3	1	5	3	SV131BOI	SV131B				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-4	1	5	4	SV131BCI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-5	1	5	5	SV131COI	SV131C				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-6	1	5	6	SV131CCI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-7	1	5	7	SV131DOI	SV131D				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-8	1	5	8	SV131DCI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-9	1	5	9	SV131EOI	SV131E				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-10	1	5	10	SV131ECI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-11	1	5	11	SV131FOI	SV131F				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-12	1	5	12	SV131FCI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-13	1	5	13	SV131GOI	SV131G				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-14	1	5	14	SV131GCI					DI	IS							Sod Mix			
		0202	ASD143-P	1-5-15	1	5	15	SV131HOI	SV131H				DI	IS							Sod Mix			
		0202	ASD143-P	1-5-16	1	5	16	SV131HCI					DI	IS							Sod Mix			
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description				IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
		0202	ASD143-P	2-4-1	2	4	1	SV131IOI	SV131I				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-2	2	4	2	SV131ICI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-3	2	4	3	SV132AOI	SV132A				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-4	2	4	4	SV132ACI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-5	2	4	5	SV132BOI	SV132B				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-6	2	4	6	SV132BCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-7	2	4	7	SV132COI	SV132C				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-8	2	4	8	SV132CCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-9	2	4	9	SV132DOI	SV132D				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-10	2	4	10	SV132DCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-11	2	4	11	SV132EOI	SV132E				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-12	2	4	12	SV132ECI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-13	2	4	13	SV132FOI	SV132F				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-14	2	4	14	SV132FCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-4-15	2	4	15	SV132GOI	SV132G				DI	IS							Sod Mix			
		0202	ASD143-P	2-4-16	2	4	16	SV132GCI					DI	IS							Sod Mix			
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description				IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
		0202	ASD143-P	2-5-1	2	5	1	SV132HOI	SV132H				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-2	2	5	2	SV132HCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-3	2	5	3	SV132IOI	SV132I				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-4	2	5	4	SV132ICI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-5	2	5	5	SV133AOI	SV133A				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-6	2	5	6	SV133ACI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-7	2	5	7	SV133BOI	SV133B				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-8	2	5	8	SV133BCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-9	2	5	9	SV133COI	SV133C				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-10	2	5	10	SV133CCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-11	2	5	11	SV133DOI	SV133D				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-12	2	5	12	SV133DCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-13	2	5	13	SV133EOI	SV133E				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-14	2	5	14	SV133ECI					DI	IS							Sod Mix			
		0202	ASD143-P	2-5-15	2	5	15	SV133FOI	SV133F				DI	IS							Sod Mix			
		0202	ASD143-P	2-5-16	2	5	16	SV133FCI					DI	IS							Sod Mix			
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description				IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
		0202	ASD143-P	2-6-1	2	6	1	SV133GOI	SV133G				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-2	2	6	2	SV133GCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-6-3	2	6	3	SV133HOI	SV133H				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-4	2	6	4	SV133HCI					DI	IS							Sod Mix			
		0202	ASD143-P	2-6-5	2	6	5	SV133IOI	SV133I				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-6	2	6	6	SV133ICI					DI	IS							Sod Mix			
		0202	ASD143-P	2-6-7	2	6	7	LSH131S	LSH131				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-8	2	6	8	LSH132S	LSH132				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-9	2	6	9	LSH133S	LSH133				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-10	2	6	10	LSL131S	LSL131				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-11	2	6	11	LSL132S	LSL132				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-12	2	6	12	LSL133S	LSL133				DI	IS							Sod Mix			
		0202	ASD143-P	2-6-13	2	6	13	LSH4510S	LSH4510				DI	IS										
		0202	ASD143-P	2-6-14	2	6	14	LSH4511S	LSH4511				DI	IS										
		0202	ASD143-P	2-6-15	2	6	15	LSL151AS	LSL151A				DI	IS										
		0202	ASD143-P	2-6-16	2	6	16	LSL151S	LSL151				DI	IS										

Cabinet Location	JB Location	FCU	Module					Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
														Lower	Upper	LL		L	H	HH				
		0202	ASD143-P	2-7-1	2	7	1	SPARE					DI	IS										
		0202	ASD143-P	2-7-2	2	7	2	SPARE					DI	IS										
		0202	ASD143-P	2-7-3	2	7	3	SPARE					DI	IS										
		0202	ASD143-P	2-7-4	2	7	4	SPARE					DI	IS										
		0202	ASD143-P	2-7-5	2	7	5	SPARE					DI	IS										
		0202	ASD143-P	2-7-6	2	7	6	SPARE					DI	IS										
		0202	ASD143-P	2-7-7	2	7	7	SPARE					DI	IS										
		0202	ASD143-P	2-7-8	2	7	8	SPARE					DI	IS										
		0202	ASD143-P	2-7-9	2	7	9	SPARE					DI	IS										
		0202	ASD143-P	2-7-10	2	7	10	SPARE					DI	IS										
		0202	ASD143-P	2-7-11	2	7	11	SPARE					DI	IS										
		0202	ASD143-P	2-7-12	2	7	12	SPARE					DI	IS										
		0202	ASD143-P	2-7-13	2	7	13	SPARE					DI	IS										
		0202	ASD143-P	2-7-14	2	7	14	SPARE					DI	IS										
		0202	ASD143-P	2-7-15	2	7	15	SPARE					DI	IS										
		0202	ASD143-P	2-7-16	2	7	16	SPARE					DI	IS										
Cabinet Location	JB Location	FCU	Module					Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
														Lower	Upper	LL		L	H	HH				
		0202	ADV151-P	4-1-1	4	1	1	SV121A1OI	SV121A1				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-2	4	1	2	SV121A1CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-3	4	1	3	SV121A2OI	SV121A2				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-4	4	1	4	SV121A2CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-5	4	1	5	SV121A3OI	SV121A3				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-6	4	1	6	SV121A3CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-7	4	1	7	SV121A4OI	SV121A4				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-8	4	1	8	SV121A4CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-9	4	1	9	SV122A1OI	SV122A1				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-10	4	1	10	SV122A1CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-11	4	1	11	SV122A2OI	SV122A2				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-12	4	1	12	SV122A2CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-13	4	1	13	SV122A3OI	SV122A3				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-14	4	1	14	SV122A3CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-15	4	1	15	SV122A4OI	SV122A4				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-16	4	1	16	SV122A4CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-17	4	1	17	SV123A1OI	SV123A1				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-18	4	1	18	SV123A1CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-19	4	1	19	SV123A2OI	SV123A2				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-20	4	1	20	SV123A2CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-21	4	1	21	SV121B1OI	SV121B1				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-22	4	1	22	SV121B1CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-23	4	1	23	SV121B2OI	SV121B2				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-24	4	1	24	SV121B2CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-25	4	1	25	SV121B3OI	SV121B3				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-26	4	1	26	SV121B3CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-27	4	1	27	SV121B4OI	SV121B4				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-28	4	1	28	SV121B4CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-29	4	1	29	SV122B1OI	SV122B1				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-30	4	1	30	SV122B1CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-31	4	1	31	SV122B2OI	SV122B2				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-1-32	4	1	32	SV122B2CI					DI	NIS								PME-Cooling		
Cabinet Location	JB Location	FCU	Module					Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
														Lower	Upper	LL		L	H	HH				
		0202	ADV151-P	4-2-1	4	2	1	SV122B3OI	SV122B3				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-2	4	2	2	SV122B3CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-3	4	2	3	SV122B4OI	SV122B4				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-4	4	2	4	SV122B4CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-5	4	2	5	SV123B1OI	SV123B1				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-6	4	2	6	SV123B1CI					DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-7	4	2	7	SV123B2OI	SV123B2				DI	NIS								PME-Cooling		
		0202	ADV151-P	4-2-8	4	2	8	SV123B2CI																

Cabinet Location	JB Location	FCU	Module			Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
													Lower	Upper		LL	L	H	HH			
		0202	ADV151-P	4-3-1	4	3	1	CT141ST1	CT141			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-2	4	3	2	CT141TRI				DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-3	4	3	3	LSH121AS	LSH121A			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-4	4	3	4	LSH122AS	LSH122A			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-5	4	3	5	LSH123AS	LSH123A			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-6	4	3	6	LSH121BS	LSH121B			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-7	4	3	7	LSH122BS	LSH122B			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-8	4	3	8	LSH123BS	LSH123B			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-9	4	3	9	LSH141S	LSH141			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-10	4	3	10	LSH141AS	LSH141A			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-11	4	3	11	LSL141AS	LSL141A			DI	NIS							PME-Cooling		
		0202	ADV151-P	4-3-12	4	3	12	AG131ST1	AG131			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-13	4	3	13	AG131TRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-14	4	3	14	AG132ST1	AG132			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-15	4	3	15	AG132TRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-16	4	3	16	AG133ST1	AG133			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-17	4	3	17	AG133TRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-18	4	3	18	PU131ST1	PU131			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-19	4	3	19	PU131TRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-20	4	3	20	PU132ST1	PU132			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-21	4	3	21	PU132TRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-22	4	3	22	PU133ST1	PU133			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-23	4	3	23	PU133TRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-24	4	3	24	PU4520BST1	PU4520B			DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-25	4	3	25	PU4520BTRI				DI	NIS							Sod Mix		
		0202	ADV151-P	4-3-26	4	3	26	SPARE	SPARE			DI	NIS							Utility 2 & Chiller		
		0202	ADV151-P	4-3-27	4	3	27	SV141OI	SV141			DI	NIS							Utility 2 & Chiller		
		0202	ADV151-P	4-3-28	4	3	28	SV141CI				DI	NIS							Utility 2 & Chiller		
		0202	ADV151-P	4-3-29	4	3	29	LSH4512S	LSH4512			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-3-30	4	3	30	LSH4513S	LSH4513			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-3-31	4	3	31	LSH4514S	LSH4514			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-3-32	4	3	32	LSL4512S	LSL4512			DI	NIS							PME-Filtration		
Cabinet Location	JB Location	FCU	Module			Source Tag	DCS Tag	Service Description			IO Type		Range		Eng Units	ALRM & TRP Setting				Plant	Remarks	Comment
		0202	ADV151-P	4-4-1	4	4	1	LSL4513S	LSL4513			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-4-2	4	4	2	LSL4514S	LSL4514			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-4-3	4	4	3	SPARE	SPARE			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-4-4	4	4	4	SPARE	SPARE			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-4-5	4	4	5	AG4510ST1	AG4510			DI	NIS							PME-Filtration		
		0202	ADV151-P	4-4-6	4	4	6	AG4510TRI				DI	NIS							PME-Filtration		
		0202	ADV151-P	4-4-7	4	4	7	SPARE				DI	NIS									
		0202	ADV151-P	4-4-8	4	4	8	PU4510AST1	PU4510A			DI	NIS									
		0202	ADV151-P	4-4-9	4	4	9	PU4510ATRI				DI	NIS									
		0202	ADV151-P	4-4-10	4	4	10	PU4510BST1	PU4510B			DI	NIS									
		0202	ADV151-P	4-4-11	4	4	11	PU4510BTRI				DI	NIS									
		0202	ADV151-P	4-4-12	4	4	12	PU4511ST1	PU4511			DI	NIS									
		0202	ADV151-P	4-4-13	4	4	13	PU4511TRI				DI	NIS									
		0202	ADV151-P	4-4-14	4	4	14	PU151AST1	PU151A			DI	NIS									
		0202	ADV151-P	4-4-15	4	4	15	PU151ATRI				DI	NIS									
		0202	ADV151-P	4-4-16	4	4	16	PU151BST1	PU151B			DI	NIS									
		0202	ADV151-P	4-4-17	4	4	17	PU151BTRI				DI	NIS									
		0202	ADV151-P	4-4-18	4	4	18	AG131TRV	AG131			DI	NIS									
		0202	ADV151-P	4-4-19	4	4	19	AG132TRV	AG132			DI	NIS									
		0202	ADV151-P	4-4-20	4	4	20	AG133TRV	AG133			DI	NIS									
		0202	ADV151-P	4-4-21	4	4	21	PU131TRV	PU131			DI	NIS									
		0202	ADV151-P	4-4-22	4	4	22	PU132TRV	PU132			DI	NIS									
		0202	ADV151-P	4-4-23	4	4	23	PU133TRV	PU133			DI	NIS									
		0202	ADV151-P	4-4-24	4	4	24	SPARE				DI	NIS									
		0202	ADV151-P	4-4-25	4	4	25	SPARE				DI	NIS									
		0202	ADV151-P	4-4-26	4	4	26	SPARE				DI	NIS									
		0202	ADV151-P	4-4-27	4	4	27	SPARE				DI	NIS									
		0202	ADV151-P	4-4-28	4	4	28	SPARE				DI	NIS									
		0202	ADV151-P	4-4-29	4	4	29	SPARE				DI	NIS									
		0202	ADV151-P	4-4-30	4	4	30	SPARE				DI	NIS									
		0202	ADV151-P	4-4-31	4	4	31	SPARE				DI	NIS									
		0202	ADV151-P	4-4-32	4	4	32	SPARE				DI	NIS									

Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	comment
														Lower	Upper		LL	L	H	HH			
		0202	ASD533-S	1-3-1	1	3	1	SPARE					DO	IS							Sod Mix		
		0202	ASD533-S	1-3-2	1	3	2	SPARE					DO	IS							Sod Mix		
		0202	ASD533-S	1-3-3	1	3	3	SPARE					DO	IS							Sod Mix		
		0202	ASD533-S	1-3-4	1	3	4	SV131DO	SV131D				DO	IS							Sod Mix		
		0202	ASD533-S	1-3-5	1	3	5	SV131EO	SV131E				DO	IS							Sod Mix		
		0202	ASD533-S	1-3-6	1	3	6	SV131FO	SV131F				DO	IS							Sod Mix		
		0202	ASD533-S	1-3-7	1	3	7	SV131GO	SV131G				DO	IS							Sod Mix		
		0202	ASD533-S	1-3-8	1	3	8	SV131HO	SV131H				DO	IS							Sod Mix		
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	comment
														Lower	Upper		LL	L	H	HH			
		0202	ASD533-S	1-4-1	1	4	1	SV131IO	SV131I				DO	IS							Sod Mix		
		0202	ASD533-S	1-4-2	1	4	2	SPARE					DO	IS							Sod Mix		
		0202	ASD533-S	1-4-3	1	4	3	SPARE					DO	IS							Sod Mix		
		0202	ASD533-S	1-4-4	1	4	4	SPARE					DO	IS							Sod Mix		
		0202	ASD533-S	1-4-5	1	4	5	SV132DO	SV132D				DO	IS							Sod Mix		
		0202	ASD533-S	1-4-6	1	4	6	SV132EO	SV132E				DO	IS							Sod Mix		
		0202	ASD533-S	1-4-7	1	4	7	SV132FO	SV132F				DO	IS							Sod Mix		
		0202	ASD533-S	1-4-8	1	4	8	SV132GO	SV132G				DO	IS							Sod Mix		
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	comment
														Lower	Upper		LL	L	H	HH			
		0202	ASD533-S	2-2-1	2	2	1	SV132HO	SV132H				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-2	2	2	2	SV132IO	SV132I				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-3	2	2	3	SV133AO	SV133A				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-4	2	2	4	SV133BO	SV133B				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-5	2	2	5	SV133CO	SV133C				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-6	2	2	6	SV133DO	SV133D				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-7	2	2	7	SV133EO	SV133E				DO	IS							Sod Mix		
		0202	ASD533-S	2-2-8	2	2	8	SV133FO	SV133F				DO	IS							Sod Mix		
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	comment
														Lower	Upper		LL	L	H	HH			
		0202	ASD533-S	2-3-1	2	3	1	SV133GO	SV133G				DO	IS							Sod Mix		
		0202	ASD533-S	2-3-2	2	3	2	SV133HO	SV133H				DO	IS							Sod Mix		
		0202	ASD533-S	2-3-3	2	3	3	SV133IO	SV133I				DO	IS							Sod Mix		
		0202	ASD533-S	2-3-4	2	3	4	SPARE					DO	IS									
		0202	ASD533-S	2-3-5	2	3	5	SPARE					DO	IS									
		0202	ASD533-S	2-3-6	2	3	6	SPARE					DO	IS									
		0202	ASD533-S	2-3-7	2	3	7	SPARE					DO	IS									
		0202	ASD533-S	2-3-8	2	3	8	SPARE					DO	IS									
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	comment
														Lower	Upper		LL	L	H	HH			
		0202	ADV551-P	4-5-1	4	5	1	SV121A1O	SV121A1				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-2	4	5	2	SV121A2O	SV121A2				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-3	4	5	3	SV121A3O	SV121A3				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-4	4	5	4	SV121A4O	SV121A4				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-5	4	5	5	SV122A1O	SV122A1				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-6	4	5	6	SV122A2O	SV122A2				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-7	4	5	7	SV122A3O	SV122A3				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-8	4	5	8	SV122A4O	SV122A4				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-9	4	5	9	SV123A1O	SV123A1				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-10	4	5	10	SV123A2O	SV123A2				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-11	4	5	11	SV121B1O	SV121B1				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-12	4	5	12	SV121B2O	SV121B2				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-13	4	5	13	SV121B3O	SV121B3				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-14	4	5	14	SV121B4O	SV121B4				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-15	4	5	15	SV122B1O	SV122B1				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-16	4	5	16	SV122B2O	SV122B2				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-17	4	5	17	SV122B3O	SV122B3				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-18	4	5	18	SV122B4O	SV122B4				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-19	4	5	19	SV123B1O	SV123B1				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-20	4	5	20	SV123B2O	SV123B2				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-21	4	5	21	SV141AO	SV141A				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-22	4	5	22	SV141BO	SV141B				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-23	4	5	23	AG121AO	AG121A				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-24	4	5	24	AG122AO	AG122A				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-25	4	5	25	AG123AO	AG123A				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-26	4	5	26	AG121BO	AG121B				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-27	4	5	27	AG122BO	AG122B				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-28	4	5	28	AG123BO	AG123B				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-29	4	5	29	PU4501AO	PU4501A				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-30	4	5	30	PU4501BO	PU4501B				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-31	4	5	31	PU4520AO	PU4520A				DO	NIS							PME-Cooling		
		0202	ADV551-P	4-5-32	4	5	32	CT141O	CT141				DO	NIS							PME-Cooling		
Cabinet Location	JB Location	FCU	Module				Source Tag	DCS Tag	Service Description	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	comment
														Lower	Upper		LL	L	H	HH			
		0202	ADV551-P	4-6-1	4	6	1	AG131O	AG131				DO	NIS							Sod Mix		

FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	Comment
													Lower	Upper		LL	L	H	HH			
0202	ASI133-H	1-1-1	1	1	1	LT131	LIC131	%%LT131				AI	IS							Sod Mix		
0202	ASI133-H	1-1-2	1	1	2	LT132	LIC132	%%LT132				AI	IS							Sod Mix		
0202	ASI133-H	1-1-3	1	1	3	LT133	LIC133	%%LT133				AI	IS							Sod Mix		
0202	ASI133-H	1-1-4	1	1	4	PT131	PI131	%%PT131				AI	IS							Sod Mix		
0202	ASI133-H	1-1-5	1	1	5	PT132	PI132	%%PT132				AI	IS							Sod Mix		
0202	ASI133-H	1-1-6	1	1	6	PT133	PI133	%%PT133				AI	IS							Sod Mix		
0202	ASI133-H	1-1-7	1	1	7	TT131A	TI131A	%%TT131A				AI	IS							Sod Mix		
0202	ASI133-H	1-1-8	1	1	8	TT131B	TI131B	%%TT131B				AI	IS							Sod Mix		
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	Comment
													Lower	Upper		LL	L	H	HH			
0202	ASI133-H	1-2-1	1	2	1	TT132A	TI132A	%%TT132A				AI	IS							Sod Mix		
0202	ASI133-H	1-2-2	1	2	2	TT132B	TI132B	%%TT132B				AI	IS							Sod Mix		
0202	ASI133-H	1-2-3	1	2	3	TT133A	TI133A	%%TT133A				AI	IS							Sod Mix		
0202	ASI133-H	1-2-4	1	2	4	TT133B	TI133B	%%TT133B				AI	IS							Sod Mix		
0202	ASI133-H	1-2-5	1	2	5	TT141A3	TI141A3	%%TT141A3				AI	IS							Sod Mix		
0202	ASI133-H	1-2-6	1	2	6	TT141A4	TI141A4	%%TT141A4				AI	IS							Sod Mix		
0202	ASI133-H	1-2-7	1	2	7	SPARE						AI	IS									
0202	ASI133-H	1-2-8	1	2	8	SPARE						AI	IS									
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	Comment
													Lower	Upper		LL	L	H	HH			
0202	ASI133-H	2-1-1	2	1	1	SPARE						AI	IS									
0202	ASI133-H	2-1-2	2	1	2	SPARE						AI	IS									
0202	ASI133-H	2-1-3	2	1	3	SPARE						AI	IS									
0202	ASI133-H	2-1-4	2	1	4	SPARE						AI	IS									
0202	ASI133-H	2-1-5	2	1	5	SPARE						AI	IS									
0202	ASI133-H	2-1-6	2	1	6	SPARE						AI	IS									
0202	ASI133-H	2-1-7	2	1	7	SPARE						AI	IS									
0202	ASI133-H	2-1-8	2	1	8	SPARE						AI	IS									
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	Comment
													Lower	Upper		LL	L	H	HH			
0202	AAI143-H	3-1-1	3	1	1	TT121A	TIC121A	%%TT121A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-2	3	1	2	TT121A1	TI121A1	%%TT121A1				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-3	3	1	3	TT121A2	TI121A2	%%TT121A2				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-4	3	1	4	TT122A	TIC122A	%%TT122A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-5	3	1	5	TT122A1	TI122A1	%%TT122A1				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-6	3	1	6	TT122A2	TI122A2	%%TT122A2				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-7	3	1	7	TIC123A	TIC123A	%%TIC123A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-8	3	1	8	TI123A	TI123A	%%TI123A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-9	3	1	9	TT121B	TIC121B	%%TT121B				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-10	3	1	10	TT121B1	TI121B1	%%TT121B1				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-11	3	1	11	TT121B2	TI121B2	%%TT121B2				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-12	3	1	12	TT122B	TIC122B	%%TT122B				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-13	3	1	13	TT122B1	TI122B1	%%TT122B1				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-14	3	1	14	TT122B2	TI122B2	%%TT122B2				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-15	3	1	15	TT123B1	TIC123B1	%%TT123B1				AI	NIS							PME-Cooling		
0202	AAI143-H	3-1-16	3	1	16	TT123B	TI123B	%%TT123B				AI	NIS							PME-Cooling		
FCU	Module					Source Tag	DCS Tag	IO Assigned Tag	Service Description			IO Type	Range		Eng Units	Alarm & Trip Setting				Plant	Remarks	Comment
													Lower	Upper		LL	L	H	HH			
0202	AAI143-H	3-2-1	3	2	1	TT141A1	TI141A1	%%TT141A1				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-2	3	2	2	TT141A2	TI141A2	%%TT141A2				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-3	3	2	3	LT121A	LIC121A	%%LT121A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-4	3	2	4	LT122A	LIC122A	%%LT122A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-5	3	2	5	LT123A	LI123A	%%LT123A				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-6	3	2	6	LT121B	LIC121B	%%LT121B				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-7	3	2	7	LT122B	LIC122B	%%LT122B				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-8	3	2	8	LT123B	LI123B	%%LT123B				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-9	3	2	9	LT141	LI141	%%LT141				AI	NIS							PME-Cooling		
0202	AAI143-H	3-2-10	3	2	10	TT151A	TI151A	%%TT151A				AI	NIS							Utility 2 & Chiller		
0202	AAI143-H	3-2-11	3	2	11	TT151B	TI151B	%%TT151B				AI	NIS							Utility 2 & Chiller		
0202	AAI143-H	3-2-12	3	2	12	LT4510	LIC4510	%%LT4510				AI	NIS							PME-Filtration		
0202	AAI143-H	3-2-13	3	2	13	LT4511	LI4511	%%LT4511				AI	NIS							PME-Filtration		
0202	AAI143-H	3-2-14	3	2	14	PT4512	PI4512	%%PT4512				AI	NIS							PME-Filtration		
0202	AAI143-H	3-2-15	3	2	15	PT4513	PI4513	%%PT4513				AI	NIS							PME-Filtration		
0202	AAI143-H	3-2-16	3	2	16	PT4514	PI4514	%%PT4514														

[illegible]

Signal Type :				Cabinet No :																	
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>				HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	PME & SOD MIXING (MC1)				FCS0202			
HSC	RTD																				
AI	AO																				
DI	DO																				
IS	NIS																				
HART	NON HART																				
								SYSTEM I/O													
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model											
				TB1-001	LT131	A1	1	1	1	ASI133											
				TB1-002		B1															
				TB1-003	LT132	A3	2	1	1	ASI133											
				TB1-004		B3															
				TB1-005	LT133	A5	3	1	1	ASI133											
				TB1-006		B5															
				TB1-007	PT131	A7	4	1	1	ASI133											
				TB1-008		B7															
				TB1-009	PT132	A10	5	1	1	ASI133											
				TB1-010		B10															
				TB1-011	PT133	A12	6	1	1	ASI133											
				TB1-012		B12															
				TB1-013	TT131A	A14	7	1	1	ASI133											
				TB1-014		B14															
				TB1-015	TT131B	A16	8	1	1	ASI133											
				TB1-016		B16															

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	17-AI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	17
FILENAME	APP.	DATE							DOC. NO.	CONTD
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	18

Signal Type :			Cabinet No : 				
---------------	--	--	--	--	--	--	--



Signal Type :			Cabinet No :			PME & SOD MIXING (MC1)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC													
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model					
				TB1-033	SPARE	A1	1	2	1	ASI133					
				TB1-034		B1									
				TB1-035	SPARE	A3	2	2	1	ASI133					
				TB1-036		B3									
				TB1-037	SPARE	A5	3	2	1	ASI133					
				TB1-038		B5									
				TB1-039	SPARE	A7	4	2	1	ASI133					
				TB1-040		B7									
				TB1-041	SPARE	A10	5	2	1	ASI133					
				TB1-042		B10									
				TB1-043	SPARE	A12	6	2	1	ASI133					
				TB1-044		B12									
				TB1-045	SPARE	A14	7	2	1	ASI133					
				TB1-046		B14									
				TB1-047	SPARE	A16	8	2	1	ASI133					
				TB1-048		B16									

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	15/01/09						WILMAR SURABAYA BD & ME PROJECT		19-AI
		CH.	DATE						TITLE		SHT. NO.
		HARINAH	15/01/09						PME & SOD MIXING		19
FILENAME		APP.	DATE						DOC. NO.		CONTD
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	20

Signal Type :			Cabinet No :			PME & SOD MIXING (MC1)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC													
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model					
				TB2-001	SV131AOI	A1	1	1	5	ASD143					
				TB2-002		B1									
				TB2-003	SV131ACI	A2	2	1	5	ASD143					
				TB2-004		B2									
				TB2-005	SV131BOI	A3	3	1	5	ASD143					
				TB2-006		B3									
				TB2-007	SV131BCI	A4	4	1	5	ASD143					
				TB2-008		B4									
				TB2-009	SV131COI	A6	5	1	5	ASD143					
				TB2-010		B6									
				TB2-011	SV131CCI	A7	6	1	5	ASD143					
				TB2-012		B7									
				TB2-013	SV131DOI	A8	7	1	5	ASD143					
				TB2-014		B8									
				TB2-015	SV131DCI	A9	8	1	5	ASD143					
				TB2-016		B9									
				TB2-017	SV131EOI	A10	9	1	5	ASD143					
				TB2-018		B10									
				TB2-019	SV131ECI	A11	10	1	5	ASD143					
				TB2-020		B11									
				TB2-021	SV131FOI	A12	11	1	5	ASD143					
				TB2-022		B12									
				TB2-023	SV131FCI	A13	12	1	5	ASD143					
				TB2-024		B13									
				TB2-025	SV131GOI	A15	13	1	5	ASD143					
				TB2-026		B15									
				TB2-027	SV131GCI	A16	14	1	5	ASD143					
				TB2-028		B16									
				TB2-029	SV131HOI	A17	15	1	5	ASD143					
				TB2-030		B17									
				TB2-031	SV131HCI	A18	16	1	5	ASD143					
				TB2-032		B18									
GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.				
Panel Wiring Drawing		DILA	15/01/09						WILMAR SURABAYA BD & ME PROJECT		20-DI				
		CH.	DATE						TITLE		SHT. NO.				
		HARINAH	15/01/09						PME & SOD MIXNG		20				
FILENAME		APP.	DATE						DOC. NO.		CONTD				
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	21				

Signal Type :			Cabinet No :					FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC											RTD	AI	AO	DI	DO
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	SYSTEM I/O													
				TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB2-033	SV131IOI	A1	1	2	4	ASD143							
				TB2-034		B1											
				TB2-035	SV131ICI	A2	2	2	4	ASD143							
				TB2-036		B2											
				TB2-037	SV132AOI	A3	3	2	4	ASD143							
				TB2-038		B3											
				TB2-039	SV132ACI	A4	4	2	4	ASD143							
				TB2-040		B4											
				TB2-041	SV132BOI	A6	5	2	4	ASD143							
				TB2-042		B6											
				TB2-043	SV132BCI	A7	6	2	4	ASD143							
				TB2-044		B7											
				TB2-045	SV132COI	A8	7	2	4	ASD143							
				TB2-046		B8											
				TB2-047	SV132CCI	A9	8	2	4	ASD143							
				TB2-048		B9											
				TB2-049	SV132DOI	A10	9	2	4	ASD143							
				TB2-050		B10											
				TB2-051	SV132DCI	A11	10	2	4	ASD143							
				TB2-052		B11											
				TB2-053	SV132EOI	A12	11	2	4	ASD143							
				TB2-054		B12											
				TB2-055	SV132ECI	A13	12	2	4	ASD143							
				TB2-056		B13											
				TB2-057	SV132FOI	A15	13	2	4	ASD143							
				TB2-058		B15											
				TB2-059	SV132FCI	A16	14	2	4	ASD143							
				TB2-060		B16											
				TB2-061	SV132GOI	A17	15	2	4	ASD143							
				TB2-062		B17											
				TB2-063	SV132GCI	A18	16	2	4	ASD143							
				TB2-064		B18											

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	21-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXNG	21
FILENAME	APP.	DATE							DOC. NO.	CONTD
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	22

Signal Type :			Cabinet No :					FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC											RTD	AI	AO	DI	DO
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
			PME & SOD MIXING (MC1)														
								SYSTEM I/O									
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB2-065	SV132HOI	A1	1	2	5	ASD143							
				TB2-066		B1											
				TB2-067	SV132HCI	A2	2	2	5	ASD143							
				TB2-068		B2											
				TB2-069	SV132IOI	A3	3	2	5	ASD143							
				TB2-070		B3											
				TB2-071	SV132ICI	A4	4	2	5	ASD143							
				TB2-072		B4											
				TB2-073	SV133AOI	A6	5	2	5	ASD143							
				TB2-074		B6											
				TB2-075	SV133ACI	A7	6	2	5	ASD143							
				TB2-076		B7											
				TB2-077	SV133BOI	A8	7	2	5	ASD143							
				TB2-078		B8											
				TB2-079	SV133BCI	A9	8	2	5	ASD143							
				TB2-080		B9											
				TB2-081	SV133COI	A10	9	2	5	ASD143							
				TB2-082		B10											
				TB2-083	SV133CCI	A11	10	2	5	ASD143							
				TB2-084		B11											
				TB2-085	SV133DOI	A12	11	2	5	ASD143							
				TB2-086		B12											
				TB2-087	SV133DCI	A13	12	2	5	ASD143							
				TB2-088		B13											
				TB2-089	SV133EOI	A15	13	2	5	ASD143							
				TB2-090		B15											
				TB2-091	SV133ECI	A16	14	2	5	ASD143							
				TB2-092		B16											
				TB2-093	SV133FOI	A17	15	2	5	ASD143							
				TB2-094		B17											
				TB2-095	SV133FCI	A18	16	2	5	ASD143							
				TB2-096		B18											
GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.						
Panel Wiring Drawing		DILA	15/01/09						WILMAR SURABAYA BD & ME PROJECT		22-DI						
		CH.	DATE						TITLE		SHT. NO.						
		HARINAH	15/01/09						PME & SOD MIXNG		22						
FILENAME		APP.	DATE						DOC. NO.		CONTD						
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002							
										23							

Signal Type :			Cabinet No :				FCS0202										
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC										RTD	AI	AO	DI	DO	IS
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
PME & SOD MIXING (MC1)				SYSTEM I/O													
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB2-097	SV133GOI	A1	1	2	6	ASD143							
				TB2-098		B1											
				TB2-099	SV133GCI	A2	2	2	6	ASD143							
				TB2-100		B2											
				TB2-101	SV133HOI	A3	3	2	6	ASD143							
				TB2-102		B3											
				TB2-103	SV133HCI	A4	4	2	6	ASD143							
				TB2-104		B4											
				TB2-105	SV133IOI	A6	5	2	6	ASD143							
				TB2-106		B6											
				TB2-107	SV133ICI	A7	6	2	6	ASD143							
				TB2-108		B7											
				TB2-109	LSH131S	A8	7	2	6	ASD143							
				TB2-110		B8											
				TB2-111	LSH132S	A9	8	2	6	ASD143							
				TB2-112		B9											
				TB2-113	LSH133S	A10	9	2	6	ASD143							
				TB2-114		B10											
				TB2-115	LSL131S	A11	10	2	6	ASD143							
				TB2-116		B11											
				TB2-117	LSL132S	A12	11	2	6	ASD143							
				TB2-118		B12											
				TB2-119	LSL133S	A13	12	2	6	ASD143							
				TB2-120		B13											
				TB2-121	LSH4510S	A15	13	2	6	ASD143							
				TB2-122		B15											
				TB2-123	LSH4511S	A16	14	2	6	ASD143							
				TB2-124		B16											
				TB2-125	LSL151AS	A17	15	2	6	ASD143							
				TB2-126		B17											
				TB2-127	LSL151S	A18	16	2	6	ASD143							
				TB2-128		B18											
GENERAL DESCRIPTION		DR.	DATE					PROJECT NAME			DWG. NO.						
Panel Wiring Drawing		DILA	15/01/09					WILMAR SURABAYA BD & ME PROJECT			23-DI						
		CH.	DATE					TITLE			SHT. NO.						
		HARINAH	15/01/09					PME & SOD MIXNG			23						
FILENAME		APP.	DATE					DOC. NO.			CONTD						
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002		24					

Signal Type :				Cabinet No :																	
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>				HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	PME & SOD MIXING (MC1)				FCS0202			
HSC	RTD																				
AI	AO																				
DI	DO																				
IS	NIS																				
HART	NON HART																				
								SYSTEM I/O													
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model											
				TB2-129	SPARE	A1	1	2	7	ASD143											
				TB2-130		B1															
				TB2-131	SPARE	A2	2	2	7	ASD143											
				TB2-132		B2															
				TB2-133	SPARE	A3	3	2	7	ASD143											
				TB2-134		B3															
				TB2-135	SPARE	A4	4	2	7	ASD143											
				TB2-136		B4															
				TB2-137	SPARE	A6	5	2	7	ASD143											
				TB2-138		B6															
				TB2-139	SPARE	A7	6	2	7	ASD143											
				TB2-140		B7															
				TB2-141	SPARE	A8	7	2	7	ASD143											
				TB2-142		B8															
				TB2-143	SPARE	A9	8	2	7	ASD143											
				TB2-144		B9															
				TB2-145	SPARE	A10	9	2	7	ASD143											
				TB2-146		B10															
				TB2-147	SPARE	A11	10	2	7	ASD143											
				TB2-148		B11															
				TB2-149	SPARE	A12	11	2	7	ASD143											
				TB2-150		B12															
				TB2-151	SPARE	A13	12	2	7	ASD143											
				TB2-152		B13															
				TB2-153	SPARE	A15	13	2	7	ASD143											
				TB2-154		B15															
				TB2-155	SPARE	A16	14	2	7	ASD143											
				TB2-156		B16															
				TB2-157	SPARE	A17	15	2	7	ASD143											
				TB2-158		B17															
				TB2-159	SPARE	A18	16	2	7	ASD143											
				TB2-160		B18															
GENERAL DESCRIPTION		DR.	DATE							PROJECT NAME	DWG. NO.										
Panel Wiring Drawing		DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	24-DI										
		CH.	DATE							TITLE	SHT. NO.										
		HARINAH	15/01/09							PME & SOD MIXING	24										
FILENAME		APP.	DATE							DOC. NO.	CONTD										
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	25										

Signal Type :			Cabinet No :					FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>													HSC	RTD	AI	AO	DI
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
PME & SOD MIXING (MC1)			SYSTEM I/O														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB3-001	SPARE	A1	1	1	3	ASD533							
				TB3-002		B1											
				TB3-003	SPARE	A3	2	1	3	ASD533							
				TB3-004		B3											
				TB3-005	SPARE	A5	3	1	3	ASD533							
				TB3-006		B5											
				TB3-007	SV131DO	A7	4	1	3	ASD533							
				TB3-008		B7											
				TB3-009	SV131EO	A10	5	1	3	ASD533							
				TB3-010		B10											
				TB3-011	SV131FO	A12	6	1	3	ASD533							
				TB3-012		B12											
				TB3-013	SV131GO	A14	7	1	3	ASD533							
				TB3-014		B14											
				TB3-015	SV131HO	A16	8	1	3	ASD533							
				TB3-016		B16											

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	15/01/09						WILMAR SURABAYA BD & ME PROJECT		25-DO
CH.	DATE						TITLE		SHT. NO.		
		HARINAH	15/01/09						PME & SOD MIXING		25
FILENAME		APP.	DATE						DOC. NO.		CONTD
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	26


Signal Type :			Cabinet No :					FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>													HSC	RTD	AI	AO	DI
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
			SYSTEM I/O														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB3-017	SV131IO	A1	1	1	4	ASD533							
				TB3-018		B1											
				TB3-019	SPARE	A3	2	1	4	ASD533							
				TB3-020		B3											
				TB3-021	SPARE	A5	3	1	4	ASD533							
				TB3-022		B5											
				TB3-023	SPARE	A7	4	1	4	ASD533							
				TB3-024		B7											
				TB3-025	SV132DO	A10	5	1	4	ASD533							
				TB3-026		B10											
				TB3-027	SV132EO	A12	6	1	4	ASD533							
				TB3-028		B12											
				TB3-029	SV132FO	A14	7	1	4	ASD533							
				TB3-030		B14											
				TB3-031	SV132GO	A16	8	1	4	ASD533							
				TB3-032		B16											

GENERAL DESCRIPTION		**DR.**	**DATE**						**PROJECT NAME**		**DWG. NO.**
Panel Wiring Drawing		**DILA**	**15/01/09**						**WILMAR SURABAYA BD & ME PROJECT**		**26-DO**
CH.	**DATE**						**TITLE**		**SHT. NO.**		
		HARINAH	**15/01/09**						**PME & SOD MIXING**		**26**
FILENAME		**APP.**	**DATE**						**DOC. NO.**		**CONTD**
PME & SOD MIXING		**JENNY**	**15/01/09**	**REV.**	**DESCRIPTION**	**DATE**	**DRAWN BY**	**CHECK BY**	**APPR. BY**	**WPMEGLY-D32-002**	**27**

Signal Type :			Cabinet No :					FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>													HSC	RTD	AI	AO	DI
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
PME & SOD MIXING (MC1)			SYSTEM I/O														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB3-033	SV132HO	A1	1	2	2	ASD533							
				TB3-034		B1											
				TB3-035	SV132IO	A3	2	2	2	ASD533							
				TB3-036		B3											
				TB3-037	SV133AO	A5	3	2	2	ASD533							
				TB3-038		B5											
				TB3-039	SV133BO	A7	4	2	2	ASD533							
				TB3-040		B7											
				TB3-041	SV133CO	A10	5	2	2	ASD533							
				TB3-042		B10											
				TB3-043	SV133DO	A12	6	2	2	ASD533							
				TB3-044		B12											
				TB3-045	SV133EO	A14	7	2	2	ASD533							
				TB3-046		B14											
				TB3-047	SV133FO	A16	8	2	2	ASD533							
				TB3-048		B16											

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	15/01/09						WILMAR SURABAYA BD & ME PROJECT		27-DO
CH.	DATE						TITLE		SHT. NO.		
		HARINAH	15/01/09						PME & SOD MIXING		27
FILENAME		APP.	DATE						DOC. NO.		CONTD
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	28

Signal Type :			Cabinet No :					FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>													HSC	RTD	AI	AO	DI
HSC	RTD																
AI	AO																
DI	DO																
IS	NIS																
HART	NON HART																
PME & SOD MIXING (MC1)			SYSTEM I/O														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model							
				TB3-049	SV133GO	A1	1	2	3	ASD533							
				TB3-050		B1											
				TB3-051	SV133HO	A3	2	2	3	ASD533							
				TB3-052		B3											
				TB3-053	SV133IO	A5	3	2	3	ASD533							
				TB3-054		B5											
				TB3-055	SPARE	A7	4	2	3	ASD533							
				TB3-056		B7											
				TB3-057	SPARE	A10	5	2	3	ASD533							
				TB3-058		B10											
				TB3-059	SPARE	A12	6	2	3	ASD533							
				TB3-060		B12											
				TB3-061	SPARE	A14	7	2	3	ASD533							
				TB3-062		B14											
				TB3-063	SPARE	A16	8	2	3	ASD533							
				TB3-064		B16											

GENERAL DESCRIPTION		DR.	DATE						PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	15/01/09						WILMAR SURABAYA BD & ME PROJECT		28-DO
CH.	DATE						TITLE		SHT. NO.		
		HARINAH	15/01/09						PME & SOD MIXING		28
FILENAME		APP.	DATE						DOC. NO.		CONTD
PME & SOD MIXING		JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	29


Signal Type :			Cabinet No :																			
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	PME & SOD MIXING (MC2)					FCS0203				
HSC	RTD																					
AI	AO																					
DI	DO																					
IS	NIS																					
HART	NON HART																					
								SYSTEM I/O														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model												
				TB4-001	TT121A	A1	1	3	1	AAI143												
				TB4-002		B1																
				TB4-003	TT121A1	A2	2	3	1	AAI143												
				TB4-004		B2																
				TB4-005	TT121A2	A3	3	3	1	AAI143												
				TB4-006		B3																
				TB4-007	TT122A	A4	4	3	1	AAI143												
				TB4-008		B4																
				TB4-009	TT122A1	A5	5	3	1	AAI143												
				TB4-010		B5																
				TB4-011	TT122A2	A6	6	3	1	AAI143												
				TB4-012		B6																
				TB4-013	TIC123A	A7	7	3	1	AAI143												
				TB4-014		B7																
				TB4-015	TI123A	A8	8	3	1	AAI143												
				TB4-016		B8																
				TB4-017	TT121B	A9	9	3	1	AAI143												
				TB4-018		B9																
				TB4-019	TT121B1	A10	10	3	1	AAI143												
				TB4-020		B10																
				TB4-021	TT121B2	A11	11	3	1	AAI143												
				TB4-022		B11																
				TB4-023	TT122B	A12	12	3	1	AAI143												
				TB4-024		B12																
				TB4-025	TT122B1	A13	13	3	1	AAI143												
				TB4-026		B13																
				TB4-027	TT122B2	A14	14	3	1	AAI143												
				TB4-028		B14																
				TB4-029	TT123B1	A15	15	3	1	AAI143												
				TB4-030		B15																
				TB4-031	TT123B	A16	16	3	1	AAI143												
				TB4-032		B16																

GENERAL DESCRIPTION		DR.	DATE							PROJECT NAME		DWG. NO.
Panel Wiring Drawing		DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT		29-AI
		CH.	DATE							TITLE		SHT. NO.
		HARINAH	15/01/09							PME & SOD MIXING		29
FILENAME	APP.	DATE								DOC. NO.		CONTD
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY		WPMEGLY-D32-002		30

Signal Type :				Cabinet No :																	
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>				HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	PME & SOD MIXING (MC2)				FCS0203			
HSC	RTD																				
AI	AO																				
DI	DO																				
IS	NIS																				
HART	NON HART																				
								SYSTEM I/O													
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model											
				TB4-033	TT141A1	A1	1	3	2	AAI143											
				TB4-034		B1															
				TB4-035	TT141A2	A2	2	3	2	AAI143											
				TB4-036		B2															
				TB4-037	LT121A	A3	3	3	2	AAI143											
				TB4-038		B3															
				TB4-039	LT122A	A4	4	3	2	AAI143											
				TB4-040		B4															
				TB4-041	LT123A	A5	5	3	2	AAI143											
				TB4-042		B5															
				TB4-043	LT121B	A6	6	3	2	AAI143											
				TB4-044		B6															
				TB4-045	LT122B	A7	7	3	2	AAI143											
				TB4-046		B7															
				TB4-047	LT123B	A8	8	3	2	AAI143											
				TB4-048		B8															
				TB4-049	LT141	A9	9	3	2	AAI143											
				TB4-050		B9															
				TB4-051	TT151A	A10	10	3	2	AAI143											
				TB4-052		B10															
				TB4-053	TT151B	A11	11	3	2	AAI143											
				TB4-054		B11															
				TB4-055	LT4510	A12	12	3	2	AAI143											
				TB4-056		B12															
				TB4-057	LT4511	A13	13	3	2	AAI143											
				TB4-058		B13															
				TB4-059	PT4512	A14	14	3	2	AAI143											
				TB4-060		B14															
				TB4-061	PT4513	A15	15	3	2	AAI143											
				TB4-062		B15															
				TB4-063	PT4514	A16	16	3	2	AAI143											
				TB4-064		B16															

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	30-AI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	30
FILENAME	APP.	DATE							DOC. NO.	CONTD
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	31

Signal Type :			Cabinet No :																			
<table border="1"> <tr><td>HSC</td><td>RTD</td></tr> <tr><td>AI</td><td>AO</td></tr> <tr><td>DI</td><td>DO</td></tr> <tr><td>IS</td><td>NIS</td></tr> <tr><td>HART</td><td>NON HART</td></tr> </table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	PME & SOD MIXING (MC2)					FCS0203				
HSC	RTD																					
AI	AO																					
DI	DO																					
IS	NIS																					
HART	NON HART																					
								SYSTEM I/O														
FIELD CABLE	CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model													
			TB4-065	VFDI-PU4501A	A1	1	3	3	AAI143													
			TB4-066		B1																	
			TB4-067	VFDI-PU4501B	A2	2	3	3	AAI143													
			TB4-068		B2																	
			TB4-069	VFDI-AG4510	A3	3	3	3	AAI143													
			TB4-070		B3																	
			TB4-071	VFDI-AG131	A4	4	3	3	AAI143													
			TB4-072		B4																	
			TB4-073	VFDI-AG132	A5	5	3	3	AAI143													
			TB4-074		B5																	
			TB4-075	VFDI-AG133	A6	6	3	3	AAI143													
			TB4-076		B6																	
			TB4-077	VFDI-PU131	A7	7	3	3	AAI143													
			TB4-078		B7																	
			TB4-079	VFDI-PU132	A8	8	3	3	AAI143													
			TB4-080		B8																	
			TB4-081	VFDI-PU133	A9	9	3	3	AAI143													
			TB4-082		B9																	
			TB4-083	SPARE	A10	10	3	3	AAI143													
			TB4-084		B10																	
			TB4-085	SPARE	A11	11	3	3	AAI143													
			TB4-086		B11																	
			TB4-087	SPARE	A12	12	3	3	AAI143													
			TB4-088		B12																	
			TB4-089	SPARE	A13	13	3	3	AAI143													
			TB4-090		B13																	
			TB4-091	SPARE	A14	14	3	3	AAI143													
			TB4-092		B14																	
			TB4-093	SPARE	A15	15	3	3	AAI143													
			TB4-094		B15																	
			TB4-095	SPARE	A16	16	3	3	AAI143													
			TB4-096		B16																	

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	31-AI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	31
FILENAME	APP.	DATE							DOC. NO.	CONTD
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WPMEGLY-D32-002	32

Signal Type :			Cabinet No : 				
---------------	--	--	--	--	--	--	--

Signal Type :			Cabinet No :			FCS0202									
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>											HSC	RTD	AI	AO	DI
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			PME & SOD MIXING (MC2)												
			MCB3-24			SYSTEM I/O									
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-24	24VDC-24	Term.	Channel	Node	Slot	Model					
				TB	Tag No.										
				TB6-001	SV121A1OI	A1	1	4	1	ADV151					
				TB6-002		A17									
				TB6-003	SV121A1CI	A2	2	4	1	ADV151					
				TB6-004		A17									
				TB6-005	SV121A2OI	A3	3	4	1	ADV151					
				TB6-006		A17									
				TB6-007	SV121A2CI	A4	4	4	1	ADV151					
				TB6-008		A17									
				TB6-009	SV121A3OI	A5	5	4	1	ADV151					
				TB6-010		A17									
				TB6-011	SV121A3CI	A6	6	4	1	ADV151					
				TB6-012		A17									
				TB6-013	SV121A4OI	A7	7	4	1	ADV151					
				TB6-014		A17									
				TB6-015	SV121A4CI	A8	8	4	1	ADV151					
				TB6-016		A17									
				TB6-017	SV122A1OI	A9	9	4	1	ADV151					
				TB6-018		A17									
				TB6-019	SV122A1CI	A10	10	4	1	ADV151					
				TB6-020		A17									
				TB6-021	SV122A2OI	A11	11	4	1	ADV151					
				TB6-022		A17									
				TB6-023	SV122A2CI	A12	12	4	1	ADV151					
				TB6-024		A17									
				TB6-025	SV122A3OI	A13	13	4	1	ADV151					
				TB6-026		A17									
				TB6-027	SV122A3CI	A14	14	4	1	ADV151					
				TB6-028		A17									
				TB6-029	SV122A4OI	A15	15	4	1	ADV151					
				TB6-030		A17									
				TB6-031	SV122A4CI	A16	16	4	1	ADV151					
				TB6-032		A17									

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	33-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	33
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	34

Signal Type : <table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>			HSC	RTD	AI	AO	DI	DO	IS	NIS	HART	NON HART	Cabinet No : PME & SOD MIXING (MC2) MCB3-24 0VDC-24 24VDC-24		FCS0202					
			HSC	RTD																
AI	AO																			
DI	DO																			
IS	NIS																			
HART	NON HART																			
SYSTEM I/O																				
FIELD CABLE	CROSS WIRING TB	CROSS WIRE NO.	TB	Tag No.	Term.	Channel	Node	Slot	Model											
			TB6-033	SV123A1OI	B1	17	4	1	ADV151											
			TB6-034		B17															
			TB6-035	SV123A1CI	B2	18	4	1	ADV151											
			TB6-036		B17															
			TB6-037	SV123A2OI	B3	19	4	1	ADV151											
			TB6-038		B17															
			TB6-039	SV123A2CI	B4	20	4	1	ADV151											
			TB6-040		B17															
			TB6-041	SV121B1OI	B5	21	4	1	ADV151											
			TB6-042		B17															
			TB6-043	SV121B1CI	B6	22	4	1	ADV151											
			TB6-044		B17															
			TB6-045	SV121B2OI	B7	23	4	1	ADV151											
			TB6-046		B17															
			TB6-047	SV121B2CI	B8	24	4	1	ADV151											
			TB6-048		B17															
			TB6-049	SV121B3OI	B9	25	4	1	ADV151											
			TB6-050		B17															
			TB6-051	SV121B3CI	B10	26	4	1	ADV151											
			TB6-052		B17															
			TB6-053	SV121B4OI	B11	27	4	1	ADV151											
			TB6-054		B17															
			TB6-055	SV121B4CI	B12	28	4	1	ADV151											
			TB6-056		B17															
			TB6-057	SV122B1OI	B13	29	4	1	ADV151											
			TB6-058		B17															
			TB6-059	SV122B1CI	B14	30	4	1	ADV151											
			TB6-060		B17															
			TB6-061	SV122B2OI	B15	31	4	1	ADV151											
			TB6-062		B17															
			TB6-063	SV122B2CI	B16	32	4	1	ADV151											
			TB6-064		B17															

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	34-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	34
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	35

Signal Type :			Cabinet No :			PME & SOD MIXING (MC2)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			MCB3-25					SYSTEM I/O							
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-25	24VDC-25	Term.	Channel	Node	Slot	Model					
				TB6-065	SV122B3OI	A1	1	4	2	ADV151					
				TB6-066		A17									
				TB6-067	SV122B3CI	A2	2	4	2	ADV151					
				TB6-068		A17									
				TB6-069	SV122B4OI	A3	3	4	2	ADV151					
				TB6-070		A17									
				TB6-071	SV122B4CI	A4	4	4	2	ADV151					
				TB6-072		A17									
				TB6-073	SV123B1OI	A5	5	4	2	ADV151					
				TB6-074		A17									
				TB6-075	SV123B1CI	A6	6	4	2	ADV151					
				TB6-076		A17									
				TB6-077	SV123B2OI	A7	7	4	2	ADV151					
				TB6-078		A17									
				TB6-079	SV123B2CI	A8	8	4	2	ADV151					
				TB6-080		A17									
				TB6-081	SV141AOI	A9	9	4	2	ADV151					
				TB6-082		A17									
				TB6-083	SV141ACI	A10	10	4	2	ADV151					
				TB6-084		A17									
				TB6-085	SV141BOI	A11	11	4	2	ADV151					
				TB6-086		A17									
				TB6-087	SV141BCI	A12	12	4	2	ADV151					
				TB6-088		A17									
				TB6-089	AG121ASTI	A13	13	4	2	ADV151					
				TB6-090		A17									
				TB6-091	SV132HCI	A14	14	4	2	ADV151					
				TB6-092		A17									
				TB6-093	AG122ASTI	A15	15	4	2	ADV151					
				TB6-094		A17									
				TB6-095	AG122ATRI	A16	16	4	2	ADV151					
				TB6-096		A17									

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	35-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	35
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	36

Signal Type :			Cabinet No :		PME & SOD MIXING (MC2)		FCS0202								
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>		HSC										RTD	AI	AO	DI
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-25	24VDC-25	SYSTEM I/O									
				TB	Tag No.	Term.	Channel	Node	Slot	Model					
				TB6-097	AG123ASTI	B1	17	4	2	ADV151					
				TB6-098		B17									
				TB6-099	AG123ATRI	B2	18	4	2	ADV151					
				TB6-100		B17									
				TB6-101	AG121BSTI	B3	19	4	2	ADV151					
				TB6-102		B17									
				TB6-103	AG121BTRI	B4	20	4	2	ADV151					
				TB6-104		B17									
				TB6-105	AG122BSTI	B5	21	4	2	ADV151					
				TB6-106		B17									
				TB6-107	AG122BTRI	B6	22	4	2	ADV151					
				TB6-108		B17									
				TB6-109	AG123BSTI	B7	23	4	2	ADV151					
				TB6-110		B17									
				TB6-111	AG123BTRI	B8	24	4	2	ADV151					
				TB6-112		B17									
				TB6-113	PU4501ASTI	B9	25	4	2	ADV151					
				TB6-114		B17									
				TB6-115	PU4501ATRI	B10	26	4	2	ADV151					
				TB6-116		B17									
				TB6-117	PU4501ATRV	B11	27	4	2	ADV151					
				TB6-118		B17									
				TB6-119	PU4501BSTI	B12	28	4	2	ADV151					
				TB6-120		B17									
				TB6-121	PU4501BTRI	B13	29	4	2	ADV151					
				TB6-122		B17									
				TB6-123	PU4501BTRV	B14	30	4	2	ADV151					
				TB6-124		B17									
				TB6-125	PU4520ASTI	B15	31	4	2	ADV151					
				TB6-126		B17									
				TB6-127	PU4520ATRI	B16	32	4	2	ADV151					
				TB6-128		B17									

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	36-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	36
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	37

GENERAL DESCRIPTION Panel Wiring Drawing	DR.	DATE							PROJECT NAME	DWG. NO.
	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	36-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	36
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	37

Signal Type :			Cabinet No :			PME & SOD MIXING (MC2)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			MCB3-26					SYSTEM I/O							
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-26		24VDC-26		Term.	Channel	Node	Slot	Model			
				TB	Tag No.										
				TB6-129	CT141STI		A1	1	4	3	ADV151				
				TB6-130			A17								
				TB6-131	CT141TRI		A2	2	4	3	ADV151				
				TB6-132			A17								
				TB6-133	LSH121AS		A3	3	4	3	ADV151				
				TB6-134			A17								
				TB6-135	LSH122AS		A4	4	4	3	ADV151				
				TB6-136			A17								
				TB6-137	LSH123AS		A5	5	4	3	ADV151				
				TB6-138			A17								
				TB6-139	LSH121BS		A6	6	4	3	ADV151				
				TB6-140			A17								
				TB6-141	LSH122BS		A7	7	4	3	ADV151				
				TB6-142			A17								
				TB6-143	LSH123BS		A8	8	4	3	ADV151				
				TB6-144			A17								
				TB6-145	LSH141S		A9	9	4	3	ADV151				
				TB6-146			A17								
				TB6-147	LSH141AS		A10	10	4	3	ADV151				
				TB6-148			A17								
				TB6-149	LSL141AS		A11	11	4	3	ADV151				
				TB6-150			A17								
				TB6-151	AG131STI		A12	12	4	3	ADV151				
				TB6-152			A17								
				TB6-153	AG131TRI		A13	13	4	3	ADV151				
				TB6-154			A17								
				TB6-155	AG132STI		A14	14	4	3	ADV151				
				TB6-156			A17								
				TB6-157	AG132TRI		A15	15	4	3	ADV151				
				TB6-158			A17								
				TB6-159	AG133STI		A16	16	4	3	ADV151				
				TB6-160			A17								

GENERAL DESCRIPTION	DR.	DATE								PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09								WILMAR SURABAYA BD & ME PROJECT	37-DI
	CH.	DATE								TITLE	SHT. NO.
	HARINAH	15/01/09								PME & SOD MIXING	37
FILENAME	APP.	DATE								DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY		WSBDME-D32-002	38

GENERAL DESCRIPTION Panel Wiring Drawing	DR.	DATE							PROJECT NAME	DWG. NO.
	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	37-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	37
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	38

Signal Type :			Cabinet No :			PME & SOD MIXING (MC2)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			MCB3-26					SYSTEM I/O							
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-26	24VDC-26		Term.	Channel	Node	Slot	Model				
				TB6-161			B1	17	4	3	ADV151				
				TB6-162	B17										
				TB6-163			B2	18	4	3	ADV151				
				TB6-164	B17										
				TB6-165			B3	19	4	3	ADV151				
				TB6-166	B17										
				TB6-167			B4	20	4	3	ADV151				
				TB6-168	B17										
				TB6-169			B5	21	4	3	ADV151				
				TB6-170	B17										
				TB6-171			B6	22	4	3	ADV151				
				TB6-172	B17										
				TB6-173			B7	23	4	3	ADV151				
				TB6-174	B17										
				TB6-175			B8	24	4	3	ADV151				
				TB6-176	B17										
				TB6-177			B9	25	4	3	ADV151				
				TB6-178	B17										
				TB6-179			B10	26	4	3	ADV151				
				TB6-180	B17										
				TB6-181			B11	27	4	3	ADV151				
				TB6-182	B17										
				TB6-183			B12	28	4	3	ADV151				
				TB6-184	B17										
				TB6-185			B13	29	4	3	ADV151				
				TB6-186	B17										
				TB6-187			B14	30	4	3	ADV151				
				TB6-188	B17										
				TB6-189			B15	31	4	3	ADV151				
				TB6-190	B17										
				TB6-191			B16	32	4	3	ADV151				
				TB6-192	B17										

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	38-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	38
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	39

GENERAL DESCRIPTION Panel Wiring Drawing	DR.	DATE							PROJECT NAME	DWG. NO.
	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	38-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	38
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	39

Signal Type :			Cabinet No :			PME & SOD MIXING (MC2)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			MCB3-28												
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-28	24VDC-28	SYSTEM I/O									
				TB	Tag No.	Term.	Channel	Node	Slot	Model					
				TB6-193	LSL4513S	A1	1	4	4	ADV151					
				TB6-194		A17									
				TB6-195	LSL4514S	A2	2	4	4	ADV151					
				TB6-196		A17									
				TB6-197	SPARE	A3	3	4	4	ADV151					
				TB6-198		A17									
				TB6-199	SPARE	A4	4	4	4	ADV151					
				TB6-200		A17									
				TB6-201	AG4510STI	A5	5	4	4	ADV151					
				TB6-202		A17									
				TB6-203	AG4510TRI	A6	6	4	4	ADV151					
				TB6-204		A17									
				TB6-205	SPARE	A7	7	4	4	ADV151					
				TB6-206		A17									
				TB6-207	PU4510ASTI	A8	8	4	4	ADV151					
				TB6-208		A17									
				TB6-209	PU4510ATRI	A9	9	4	4	ADV151					
				TB6-210		A17									
				TB6-211	PU4510BSTI	A10	10	4	4	ADV151					
				TB6-212		A17									
				TB6-213	PU4510BTRI	A11	11	4	4	ADV151					
				TB6-214		A17									
				TB6-215	PU4511STI	A12	12	4	4	ADV151					
				TB6-216		A17									
				TB6-217	PU4511TRI	A13	13	4	4	ADV151					
				TB6-218		A17									
				TB6-219	PU151ASTI	A14	14	4	4	ADV151					
				TB6-220		A17									
				TB6-221	PU151ATRI	A15	15	4	4	ADV151					
				TB6-222		A17									
				TB6-223	PU151BSTI	A16	16	4	4	ADV151					
				TB6-224		A17									

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	39-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	39
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	40

Signal Type :			Cabinet No :			PME & SOD MIXING (MC2)					FCS0202				
<table><tr><td>HSC</td><td>RTD</td></tr><tr><td>AI</td><td>AO</td></tr><tr><td>DI</td><td>DO</td></tr><tr><td>IS</td><td>NIS</td></tr><tr><td>HART</td><td>NON HART</td></tr></table>															
HSC	RTD														
AI	AO														
DI	DO														
IS	NIS														
HART	NON HART														
			MCB3-28					SYSTEM I/O							
FIELD CABLE		CROSS WIRING TB	CROSS WIRE NO.	0VDC-28	24VDC-28										
				TB	Tag No.		Term.	Channel	Node	Slot	Model				
				TB6-225	PU151BTRI		B1	17	4	4	ADV151				
				TB6-226			B17								
				TB6-227	AG131TRV		B2	18	4	4	ADV151				
				TB6-228			B17								
				TB6-229	AG132TRV		B3	19	4	4	ADV151				
				TB6-230			B17								
				TB6-231	AG133TRV		B4	20	4	4	ADV151				
				TB6-232			B17								
				TB6-233	PU131TRV		B5	21	4	4	ADV151				
				TB6-234			B17								
				TB6-235	PU132TRV		B6	22	4	4	ADV151				
				TB6-236			B17								
				TB6-237	PU133TRV		B7	23	4	4	ADV151				
				TB6-238			B17								
				TB6-239	SPARE		B8	24	4	4	ADV151				
				TB6-240			B17								
				TB6-241	SPARE		B9	25	4	4	ADV151				
				TB6-242			B17								
				TB6-243	SPARE		B10	26	4	4	ADV151				
				TB6-244			B17								
				TB6-245	SPARE		B11	27	4	4	ADV151				
				TB6-246			B17								
				TB6-247	SPARE		B12	28	4	4	ADV151				
				TB6-248			B17								
				TB6-249	SPARE		B13	29	4	4	ADV151				
				TB6-250			B17								
				TB6-251	SPARE		B14	30	4	4	ADV151				
				TB6-252			B17								
				TB6-253	SPARE		B15	31	4	4	ADV151				
				TB6-254			B17								
				TB6-255	SPARE		B16	32	4	4	ADV151				
				TB6-256			B17								

GENERAL DESCRIPTION	DR.	DATE							PROJECT NAME	DWG. NO.
Panel Wiring Drawing	DILA	15/01/09							WILMAR SURABAYA BD & ME PROJECT	40-DI
	CH.	DATE							TITLE	SHT. NO.
	HARINAH	15/01/09							PME & SOD MIXING	40
FILENAME	APP.	DATE							DOC. NO.	CONT'D
PME & SOD MIXING	JENNY	15/01/09	REV.	DESCRIPTION	DATE	DRAWN BY	CHECK BY	APPR. BY	WSBDME-D32-002	41