

PT. MULTIMAS KAB. BANTEN

PLANT: REFINERY 1

| Instrument type       | Brand          | Model                                  | IO type | Remarks |
|-----------------------|----------------|----------------------------------------|---------|---------|
| Mass flowmeter        | Endress+Hauser | Promass 80E-AD2SAAAAADAA+DAZ1          | AI      |         |
| Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B                | AI      |         |
| Vortex flowmeter      | Endress+Hauser | Prowirl F200, 7F2B-AABCCA1D25K         | AI      |         |
| Guided Radar level    | Endress+Hauser | Levelflex FMP51-AAACCALAAACG+OCZ1      | AI      |         |
| Differential Pressure | Yokogawa       | EJA210E-JMS2J-919EN-ED23A2WE03-B/D4/HE | AI      |         |
|                       |                | EJA110E-JMSWJ-919EB/D4/HE              | AI      |         |
| Pressure transmitter  | Yokogawa       | EJA530E-JBS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA510E-JAS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA310A-JLS2J-919EB/D3/HE              | AI      |         |
| Temperature           | Endress+Hauser | TR10-ABA3CASXH3000                     | AI      |         |
| PH meter              | Yokogawa       | FLXA21-DPDABP1NNANLANN/UM              | AI      |         |
| Pressure Switch       | IFM            | PN7097                                 | DI      |         |
| Fork level switch     | Endress+Hauser | FTL51-AGR2DB2G5A+Z1                    | DI      |         |
|                       |                | FTL50-AGR2AA2G5A+Z1                    | DI      |         |
| Paddle level switch   | Endress+Hauser | FTE20-AA16AE11+Z1                      | DI      |         |
| Float level switch    | Mobrey         | S36DA/F84                              | DI      |         |
| Load cell             |                |                                        | AI      |         |

| Item | Wilmar's Tags | Description                            | Type                  | Supplier/Brand | Model                           | IO Type | Range Proposed (kg/H) | Signal Type  |
|------|---------------|----------------------------------------|-----------------------|----------------|---------------------------------|---------|-----------------------|--------------|
| 1    | FT1001        | Flow Meter                             | Coriolis Mass         | Endress+Hauser | Promass 80E80-AD2SAAAAADAA+DAZ1 | AI      | 0-83424 kg/hr         | 4-20 mA HART |
| 2    | FT1011        | Flow Meter                             | Coriolis Mass         | Endress+Hauser | Promass 80E80-AD2SAAAAADAA+DAZ1 | AI      | 0-83334 kg/hr         | 4-20 mA HART |
| 3    | FT1702        | Flow Meter                             | Coriolis Mass         | Endress+Hauser | Promass 80E80-AD2SAAAAADAA+DAZ1 | AI      | 0-83334 kg/hr         | 4-20 mA HART |
| 4    | FT1714AG      | Flow Meter                             | Coriolis Mass         | Endress+Hauser | Promass 80E40 DN40 1-1/2"       | AI      | 0-9445 kg/hr          | 4-20 mA HART |
| 5    | FT1716B       | Flow Meter                             | Coriolis Mass         | Endress+Hauser | Promass 80F1H DN100 4"          | AI      | 0-96215 kg/hr         | 4-20 mA HART |
| 6    | FT1034CA      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B         | AI      | 15-147 l/hr           | 4-20 mA HART |
| 7    | FT1034NA      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B         | AI      | 35-348 l/hr           | 4-20 mA HART |
| 8    | FT1044CA      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B         | AI      | 6.6-135 l/hr          | 4-20 mA HART |
| 9    | FT1034PA      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B         | AI      | 10.8-77.5 l/hr        | 4-20 mA HART |
| 10   | FT1734CA      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B/SC      | AI      | 0-10 l/hr             | 4-20 mA HART |
| 11   | FT1734NA      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B         | AI      | 5.1-50.7 l/hr         | 4-20 mA HART |
| 12   | FT1978HW      | Flow Meter                             | Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B         | AI      | 933-9333 l/hr         | 4-20 mA HART |
| 13   | FT1842        | Flow Meter                             | Coriolis Mass         |                |                                 | AI      |                       | 4-20 mA HART |
| 14   | PT1990HP      | Actual pressure Boiler                 | Spare                 |                |                                 | AI      | Spare                 | Spare        |
| 15   | LT1001        | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-4700mmH2O           | 4-20 mA HART |
| 16   | LT1006        | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-1200mmH2O           | 4-20 mA HART |
| 17   | LT1034CA      | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-680mmH2O            | 4-20 mA HART |
| 18   | LT1034NA      | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-680mmH2O            | 4-20 mA HART |
| 19   | LT1044CA      | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-680mmH2O            | 4-20 mA HART |
| 20   | LT1034PA      | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-680mmH2O            | 4-20 mA HART |
| 21   | LT1734CA      | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-680mmH2O            | 4-20 mA HART |
| 22   | LT1734NA      | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-680mmH2O            | 4-20 mA HART |
| 23   | LT1082W       | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-1500mmH2O           | 4-20 mA HART |
| 24   | LT1635        | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-3650mmH2O           | 4-20 mA HART |
| 25   | PT1616B1      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 26   | PT1616B2      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 27   | PT1616C1      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 28   | PT1616C2      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 29   | PT1716A1      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 30   | PT1716A2      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 31   | PT1716B1      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 32   | PT1716B2      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 33   | TT1001        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 34   | TT1006        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 35   | TT1082W       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 36   | TT1635        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 37   | TT1732A       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 38   | TT1778        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 39   | TT1021A       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 40   | TT1021B       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 41   | TT1721IC      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 42   | TT1721X       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 43   | TT1781A       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 44   | TT1781AA      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 45   | TT1781AB      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 46   | TT1781B       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 47   | TT1781BS      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 48   | PH-1732A      | PH Meter                               |                       | Yokogawa       |                                 | AI      | 0-14 pH               |              |
| 49   | FT1949        | Flow Meter                             | Vortex                | Endress+Hauser |                                 | AI      | 0-667 kg/hr           | 4-20 mA HART |
| 50   | FT19SAC       | Flow Meter                             | Vortex                | Endress+Hauser |                                 | AI      | 0-14114 kg/hr         | 4-20 mA HART |
| 51   | LT1622        | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-2700mmH2O           | 4-20 mA HART |
| 52   | LT1702        | Level Transmitter                      | Differential Pressure | Yokogawa       |                                 | AI      | 0-4650mmH2O           | 4-20 mA HART |
| 53   | LT1722C       | Level Transmitter                      | Guided Radar          | Endress+Hauser |                                 | AI      |                       | 4-20 mA HART |
| 54   | LT1780B       | Level Transmitter                      | Guided Radar          | Endress+Hauser |                                 | AI      |                       | 4-20 mA HART |
| 55   | PT1949S       | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 56   | PT19SACR      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-20 barg             | 4-20 mA HART |
| 57   | PT1006        | Pressure Transmitter & Indicator       | Vacuum                | Yokogawa       |                                 | AI      | 0-1000 mbara          | 4-20 mA HART |
| 58   | TT1622B       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 59   | TT1702        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 60   | TT1604C       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 61   | TT1722C       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 62   | TT1780AD      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 63   | TT1780B       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 64   | TT1849        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 65   | FT1767        | Flow Meter                             | Coriolis Mass         |                |                                 | AI      |                       |              |
| 66   | FT1748        | Flow Meter                             | Magnetic Flow         |                |                                 | AI      |                       |              |
| 67   | FT1559        | Flow Meter                             | Vortex                |                |                                 | AI      |                       |              |
| 68   | FT1560        | Flow Meter                             | Vortex                |                |                                 | AI      |                       |              |
| 69   | FT1508        | Flow Meter                             | Vortex                |                |                                 | AI      |                       |              |
| 70   | FT1509        | Flow Meter                             | Vortex                |                |                                 | AI      |                       |              |
| 71   | FT1652        | Flow Meter                             | Vortex                |                |                                 | AI      |                       |              |
| 72   | FT1653        | Flow Meter                             | Vortex                |                |                                 | AI      |                       |              |
| 73   | FT1768        | Flow Meter                             | Coriolis Mass         |                |                                 | AI      |                       |              |
| 74   | FT1773        | Flow Meter                             | Coriolis Mass         |                |                                 | AI      |                       |              |
| 75   | FT1767        | Flow Meter                             | Coriolis Mass         |                |                                 | AI      |                       |              |
| 76   | TT1082        | Temperature Transmitter & Indicator    | RTD                   |                |                                 | AI      |                       |              |
| 77   | PT1842        |                                        | Vacuum                | Yokogawa       |                                 | AI      | 0-1000 mbara          | 4-20 mA HART |
| 78   | TT1842        |                                        |                       |                |                                 | AI      |                       | 4-20 mA HART |
| 79   | FT17001       |                                        | Vortex                |                |                                 | AI      | 72-800 m3/hr          | 4-20 mA HART |
| 80   | FT16001       |                                        | Vortex                |                |                                 | AI      | 448.3-5000 m3/hr      | 4-20 mA HART |
| 81   | FT16002       |                                        | Vortex                |                |                                 | AI      | 35.8-400 m3/hr        | 4-20 mA HART |
| 82   | FT16003       |                                        | Vortex                |                |                                 | AI      | 1667-2000 m3/hr       | 4-20 mA HART |
| 83   | TTC01         | Temperature Transmitter for Panel Room | RTD                   |                |                                 | AI      | 0 - 100 DegC          | 4-20 mA HART |
| 84   | FCV1001       | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 85   | LCV1006       | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 86   | TCV1021B      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 87   | LCV1082W      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 88   | LCV1635       | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 89   | LCV1622A      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 90   | FCV1702       | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 91   | LCV1714A      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 92   | TCV1721IC     | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 93   | LCV1722C      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 94   | LCV1780B      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 95   | TCV1781A      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 96   | TCV1781B      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 97   | PCV1006       | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 98   | TCV1722C      | Control Valve                          | Electro-pneumatic     | Samson         |                                 | AO      | 0-100%                | 4-20 mA HART |
| 99   | LT1714        | Level Transmitter                      | Guided Radar          | Endress+Hauser |                                 | AI      |                       | 4-20 mA HART |
| 100  | PT1635        | Pressure Transmitter & Indicator       | Vacuum                | Yokogawa       |                                 | AI      | 0-1000 mbara          | 4-20 mA HART |
| 101  | TT1714        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 102  | TT1722A6      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 103  | TT1780AA      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 104  | TT1780AB      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 105  | TT1780AC      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 106  | TT1021D       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 107  | PT1616A1      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 108  | PT1616A2      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 109  | PT1616A3      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 110  | PT1616A4      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 111  | PT1616A5      | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 112  | PT1616S       | Pressure Transmitter & Indicator       | Gauge                 | Yokogawa       |                                 | AI      | 0-6 barg              | 4-20 mA HART |
| 113  | PT1622        | Pressure Transmitter & Indicator       | Vacuum                | Yokogawa       |                                 | AI      | 0-1000 mbara          | 4-20 mA HART |
| 114  | TT1622A       | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 115  | TT1623        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 116  | TT1003        | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 117  | TT1641IC      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 118  | FT1723A       | Flow Meter                             | Vortex                | Endress+Hauser |                                 | AI      | 0-102675 kg/hr        | 4-20 mA HART |
| 119  | FT1714        | Flow Meter                             | Vortex                | Endress+Hauser |                                 | AI      | 0-113993 kg/hr        | 4-20 mA HART |
| 120  | TT1719IA      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | -50 to 100 DegC       | 4-20 mA HART |
| 121  | TT1719IB      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | -50 to 100 DegC       | 4-20 mA HART |
| 122  | TT1741IC      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |
| 123  | TT1721A2      | Temperature Transmitter & Indicator    | RTD                   | Endress+Hauser |                                 | AI      | 0-300 DegC            | 4-20 mA HART |

PT. MULTIMAS KAB. BATANG KAYU

PLANT: REFINERY 1

| Instrument type       | Brand          | Model                                  | IO type | Remarks |
|-----------------------|----------------|----------------------------------------|---------|---------|
| Mass flowmeter        | Endress+Hauser | Promass 80E-AD2SAAAAADAA+DAZ1          | AI      |         |
| Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B                | AI      |         |
| Vortex flowmeter      | Endress+Hauser | Prowirl F200, 7F2B-AABCCA1D2SK         | AI      |         |
| Guided Radar level    | Endress+Hauser | Levelflex FMP51-AAACCALAA4CG+OCZ1      | AI      |         |
| Differential Pressure | Yokogawa       | EJA210E-JMS2J-919EN-ED23A2WE03-B/D4/HE | AI      |         |
| Pressure transmitter  | Yokogawa       | EJA110E-JMSWJ-919EB/D4/HE              | AI      |         |
|                       |                | EJA530E-JBS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA510E-JAS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA310A-JLS2J-919EB/D3/HE              | AI      |         |
| Temperature           | Endress+Hauser | TR10-ABA3CASXH3000                     | AI      |         |
| PH meter              | Yokogawa       | FLXA21-DPDA8P1NNANLANN/UM              | AI      |         |
| Pressure Switch       | IFM            | PN7097                                 | DI      |         |
| Fork level switch     | Endress+Hauser | FTL51-AGR2DB2G5A+Z1                    | DI      |         |
|                       |                | FTL50-AGR2AA2G5A+Z1                    | DI      |         |
| Paddle level switch   | Endress+Hauser | FTE20-AA16AE11+Z1                      | DI      |         |
| Float level switch    | Mobrey         | S36DA/F84                              | DI      |         |
| Load cell             |                |                                        | AI      |         |

| Item | Wilmar's Tags | Description                         | Type                   | Supplier/Brand | Model          | IO Type | Range Proposed (kg/H) | Signal Type              |
|------|---------------|-------------------------------------|------------------------|----------------|----------------|---------|-----------------------|--------------------------|
| 124  | PT1719IA      | Pressure Transmitter & Indicator    | Gauge                  | Yokogawa       |                | AI      | -1 to 1 barg          | 4-20 mA HART             |
| 125  | PT1719IB      | Presssure Transmitter & Indicator   | Gauge                  | Yokogawa       |                | AI      | -1 to 1 barg          | 4-20 mA HART             |
| 126  | PT1722AA      | Pressure Transmitter & Indicator    | Vacuum                 | Yokogawa       |                | AI      | 0-1000 mbara          | 4-20 mA HART             |
| 127  | PT1722AB      | Pressure Transmitter & Indicator    | Vacuum                 | Yokogawa       |                | AI      | 0-50 mbara            | 4-20 mA HART             |
| 128  | TT1722A1      | Temperature Transmitter & Indicator | RTD                    | Endress+Hauser |                | AI      | 0-300 DegC            | 4-20 mA HART             |
| 129  | FT303         | Flow Meter                          | Vortex Flow            |                |                | AI      |                       |                          |
| 130  | TT1223        | Temperature Transmitter & Indicator | RTD                    |                |                | AI      |                       |                          |
| 131  | TT1083        | Temperature Transmitter & Indicator | RTD                    |                |                | AI      |                       |                          |
| 132  | TT1214        | Temperature Transmitter & Indicator | RTD                    |                |                | AI      |                       |                          |
| 133  | TCV1021D      | Control Valve                       | Electro-pneumatic      | Samson         |                | AO      | 0-100%                | 4-20 mA HART             |
| 134  | FCV1078HW     | Control Valve                       | Electro-pneumatic      | Samson         |                | AO      | 0-100%                | 4-20 mA HART             |
| 135  | PCV1635       | Control Valve                       | Electro-pneumatic      | Samson         |                | AO      | 0-100%                | 4-20 mA HART             |
| 136  | TCV1622A      | Control Valve                       | Electro-pneumatic      | Samson         |                | AO      | 0-100%                | 4-20 mA HART             |
| 137  | PCV1018       | Control Valve                       | Electro-pneumatic      | Samson         |                | AO      | 0-100%                | 4-20 mA HART             |
| 138  | SPP1990HP     | External SP Pressure Boiler         | Spare                  |                |                | AO      | Spare                 | Spare                    |
| 139  | SPT1990HP     | External SP Temperature Boiler      | Spare                  |                |                | AO      | Spare                 | Spare                    |
| 140  | V1001B-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 141  | V1001B-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 142  | V1001D-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 143  | V1001D-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 144  | V1006D-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 145  | V1024F-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 146  | V1024F-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 147  | V1024B-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 148  | V1024B-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 149  | V1034CAF-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 150  | V1034CAF-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 151  | V1034NAF-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 152  | V1034NAF-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 153  | V1044CAF-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 154  | V1044CAF-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 155  | V1635-ZO      | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 156  | V1034NA-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 157  | V1034NA-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 158  | V1635-ZO      | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 159  | V1635B-ZC     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 160  | V1682AB-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 161  | V1682AD1-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 162  | V1682AD1-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 163  | V1682AD2-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 164  | V1682AD2-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 165  | V1702BY-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 166  | V1702BY-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 167  | V1702D-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 168  | V1702D-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 169  | V1702F-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 170  | V1702F-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 171  | V1721XS-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 172  | V1682BBY-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 173  | V1682BBY-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 174  | V1692BD-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 175  | V1692BD-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 176  | V1721XS-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 177  | V1780BB-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 178  | V1780BB-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 179  | V1778-ZO      | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 180  | V1635S-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 181  | V1635S-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 182  | V1622A-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 183  | V1622A-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 184  | V1622C-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 185  | V1622C-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 186  | V1780BD-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 187  | V1780BD-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 188  | V1781AB-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 189  | V1781AB-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 190  | V1682AD-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 191  | V1682AD-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 192  | V1702B-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 193  | V1702B-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 194  | LSH1032C      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 195  | LSM1732A      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 196  | LSM1032C      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 197  | LSM1778A      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 198  | LSM1778B      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 199  | LSL1001       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 200  | LSL1006       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 201  | LSL1032C      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 202  | LSL1082W      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 203  | LSL1635       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 204  | LSL1604C      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 205  | LSL1732A      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 206  | LSL1778       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 207  | LSH1082W      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 208  | V1722CB-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 209  | V1722CB-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 210  | V1722CD1-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 211  | V1722CD1-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 212  | V1722CD2-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 213  | V1722CD2-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 214  | V1001D-SY     | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 215  | V1006D-SY     | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 216  | V1604CS-ZO    | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 217  | V1604CS-ZC    | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 218  | V1024F-SY     | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 219  | V1024B-SY     | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 220  | V1034NAF-SY   | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 221  | V1034PAF-SY   | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 222  | V1635-SY      | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 223  | V1635B-SY     | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 224  | V1682AB-SY    | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 225  | V1682AD1-SY   | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 226  | V1682AD2-SY   | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 227  | V1702BY-SY    | Actuator Valve                      | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 228  | V1722QED-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 229  | V1722QED-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 230  | V1949D-ZO     | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 231  | V1949D-ZC     | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 232  | V1780A2A-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 233  | V1780A2A-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 234  | V1780A2B-ZO   | Actuator Valve                      | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 235  | V1780A2B-ZC   | Actuator Valve                      | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 236  | LSH1001       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 237  | LSH1006       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 238  | LSH1622       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 239  | LSH1682A      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 240  | LSH1604C      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 241  | LSM1604C      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 242  | LSL1702       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 243  | LSL1622       | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 244  | LSL1682A      | Level Switch                        | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 245  | LSH1722C      | Level Switch                        | Float                  | Mobrey-Emerson |                | DI      |                       | PNP                      |
| 246  | LSL1722C      | Level Switch                        | Float                  | Mobrey-Emerson |                | DI      |                       | PNP                      |



PT. MULTIMAS KAB. BATANG KAYU  
PT. MULTIMAS KAB. BATANG KAYU

PLANT: REFINERY 1

| Instrument type       | Brand          | Model                                  | IO type | Remarks |
|-----------------------|----------------|----------------------------------------|---------|---------|
| Mass flowmeter        | Endress+Hauser | Promass 80E-AD2SAAAAADAA+DAZ1          | AI      |         |
| Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B                | AI      |         |
| Vortex flowmeter      | Endress+Hauser | Prowirl F200, 7F2B-AABCCA1D25K         | AI      |         |
| Guided Radar level    | Endress+Hauser | Levelflex FMP51-AAACCALAA4CG+OCZ1      | AI      |         |
| Differential Pressure | Yokogawa       | EJA210E-JMS2J-919EN-ED23A2WE03-B/D4/HE | AI      |         |
| Pressure transmitter  | Yokogawa       | EJA110E-JMSWJ-919EB/D4/HE              | AI      |         |
|                       |                | EJA530E-JBS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA510E-JAS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA310A-JLS2J-919EB/D3/HE              | AI      |         |
| Temperature           | Endress+Hauser | TR10-ABA3CASXH3000                     | AI      |         |
| PH meter              | Yokogawa       | FLXA21-DPDABP1NNANLANN/UM              | AI      |         |
| Pressure Switch       | IFM            | PN7097                                 | DI      |         |
| Fork level switch     | Endress+Hauser | FTL51-AGR2DB2G5A+Z1                    | DI      |         |
|                       |                | FTL50-AGR2AA2G5A+Z1                    | DI      |         |
| Paddle level switch   | Endress+Hauser | FTE20-AA16AE11+Z1                      | DI      |         |
| Float level switch    | Mobrey         | S36DA/F84                              | DI      |         |
| Load cell             |                |                                        | AI      |         |

| Item | Wilmar's Tags    | Description                    | Type                   | Supplier/Brand | Model          | IO Type | Range Proposed (kg/H) | Signal Type              |
|------|------------------|--------------------------------|------------------------|----------------|----------------|---------|-----------------------|--------------------------|
| 247  | LSH1780B         | Level Switch                   | Float                  | Mobrey-Emerson |                | DI      |                       | PNP                      |
| 248  | LSL1780B         | Level Switch                   | Float                  | Mobrey-Emerson |                | DI      |                       | PNP                      |
| 249  | LSH1610A         | Level Switch                   | Paddle                 |                |                | DI      |                       | DI Dry Contact           |
| 250  | LSL1610A         | Level Switch                   | Paddle                 |                |                | DI      |                       | DI Dry Contact           |
| 251  | LSH1610B         | Level Switch                   | Paddle                 |                |                | DI      |                       | DI Dry Contact           |
| 252  | LSL1610B         | Level Switch                   | Paddle                 |                |                | DI      |                       | DI Dry Contact           |
| 253  | LSH1610C         | Level Switch                   | Paddle                 |                |                | DI      |                       | DI Dry Contact           |
| 254  | LSL1610C         | Level Switch                   | Paddle                 |                |                | DI      |                       | DI Dry Contact           |
| 255  | LSLL1801         | Level Switch                   |                        |                |                | DI      |                       |                          |
| 256  | LS901            | Level Switch                   |                        |                |                | DI      |                       |                          |
| 257  | LS601            | Level Switch                   |                        |                |                | DI      |                       |                          |
| 258  | LSLL1901         | Level Switch                   |                        |                |                | DI      |                       |                          |
| 259  | LSLL1902         | Level Switch                   |                        |                |                | DI      |                       |                          |
| 260  | LSLL1903         | Level Switch                   |                        |                |                | DI      |                       |                          |
| 261  | FSL1082          | Flow Switch                    |                        |                |                | DI      |                       |                          |
| 262  | V1901-ZO         | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 263  | V1901-ZC         | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 264  | V1901A-ZO        | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 265  | V1901A-ZC        | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 266  | V1901B-ZO        | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 267  | V1901B-ZC        | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 268  | V1902-ZO         | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 269  | V1902-ZC         | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 270  | V1902A-ZO        | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 271  | V1902A-ZC        | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 272  | V1902B-ZO        | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 273  | V1902B-ZC        | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 274  | V1903-ZO         | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 275  | V1903-ZC         | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 276  | V1903A-ZO        | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 277  | V1903A-ZC        | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 278  | V1903B-ZO        | Actuator Valve                 | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 279  | V1903B-ZC        | Actuator Valve                 | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 280  | PSL8012          | Pressure Switch                |                        |                |                | DI      |                       |                          |
| 281  | PSL804           | Pressure Switch                |                        |                |                | DI      |                       |                          |
| 282  | PSL1101          | Pressure Switch                |                        |                |                | DI      |                       |                          |
| 283  | PSL8020          | Pressure Switch                |                        |                |                | DI      |                       |                          |
| 284  | V1622B-ZO        | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 285  | V1622B-ZC        | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 286  | V1722A6D-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 287  | V1722A6D-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 288  | LSLL2023         | Level Switch                   |                        |                |                | DI      |                       |                          |
| 289  | LS601            | Level Switch                   |                        |                |                | DI      |                       |                          |
| 290  | V1604CD-ZO       |                                | Valve open indication  |                |                | DI      |                       | NPN/PNP                  |
| 291  | V1604CD-ZC       |                                | Valve close indication |                |                | DI      |                       | NPN/PNP                  |
| 292  | PSL1719IC1       | Pressure Switch                |                        |                |                | DI      | 0-1000mbar            | DI dry contact           |
| 293  | PSL1719IC2       | Pressure Switch                |                        |                |                | DI      | 0-1000mbar            | DI dry contact           |
| 294  | V1734CA-ZO       | Actuator Valve                 | Valve open indication  | Spare          |                | DI      | Spare                 | Spare                    |
| 295  | V1734CA-ZC       | Actuator Valve                 | Valve close indication | Spare          |                | DI      | Spare                 | Spare                    |
| 296  | CCR-SERV-001-Tem | CCR-SERV-001-Temperature alarm |                        |                |                |         |                       |                          |
| 297  | CCR-SERV-001-Hum | CCR-SERV-001-Humidity alarm    |                        |                |                |         |                       |                          |
| 298  | V1702D-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 299  | V1702F-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 300  | V1721XS-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 301  | V1780BB-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 302  | V1778-SY         | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 303  | V1635S-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 304  | V1622A-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 305  | V1622C-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 306  | V1034NA-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 307  | V1682AD-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 308  | V1702B-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 309  | V1712D-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 310  | V1722CD1-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 311  | V1722CD2-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 312  | V1722CB-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 313  | V1614S1-ZO       | Actuator Valve                 | Valve open Indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 314  | V1682BBY-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 315  | V1692BD-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 316  | V1714AGB-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 317  | V1614S1-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 318  | V1714AGB-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 319  | V1006B-ZO        | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 320  | V1006B-ZC        | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 321  | V1780BD-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 322  | V1781AB-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 323  | V1006D-ZC        | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 324  | V1034PAF-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 325  | V1034PAF-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 326  | V1635B-ZC        | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 327  | V1682AB-ZC       | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 328  | V1778-ZC         | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 329  | V1604CS-SY       | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 330  | V1734NA-ZO       | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 331  | V1734NA-ZC       | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 332  | V1722QED-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 333  | V1949D-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 334  | V1780A2A-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 335  | V1780A2B-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 336  | V1712D-ZO        | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 337  | V1712D-ZC        | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 338  | SV1610A          | Solenoid Valve                 | W Timer Control        |                |                | DO      |                       | 24 VDC Wet supply        |
| 339  | SV1610B          | Solenoid Valve                 | W Timer Control        |                |                | DO      |                       | 24 VDC Wet supply        |
| 340  | SV1610C          | Solenoid Valve                 | W Timer Control        |                |                | DO      |                       | 24 VDC Wet supply        |
| 341  | V1901-SY         | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 342  | V1901A-SY        | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 343  | V1901B-SY        | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 344  | V1902-SY         | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 345  | V1902A-SY        | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 346  | V1902B-SY        | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 347  | V1903-SY         | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 348  | V1903A-SY        | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 349  | V1903B-SY        | Actuator Valve                 | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 350  | V1622B-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 351  | V1001B-SY        | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 352  | V1722A6D-SY      | Actuator Valve                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 353  | V1604CD-SY       |                                | Valve open command     |                |                | DO      |                       | 24VDC Wet Supply         |
| 354  | V1734CA-SY       | Actuator Valve                 | Valve open command     |                |                | DO      | Spare                 | Spare                    |
| 355  | V1616A1A-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 356  | V1616A1A-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 357  | V1616A1B-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 358  | V1616A1B-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 359  | V1616A1C-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 360  | V1616A1C-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 361  | V1616A1D-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 362  | V1616A1D-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 363  | V1616A1E-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 364  | V1616A1E-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 365  | V1616A1F-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 366  | V1616A1F-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 367  | V1616A1G-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 368  | V1616A1G-ZC      | Actuator Valve                 | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 369  | V1616A1H-ZO      | Actuator Valve                 | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |

**PLANT: REFINERY 1**

[illegible]



PT. MULTIMAS KAB. BATI INDONESIA - SERANG

PLANT: REFINERY 1

| Instrument type       | Brand          | Model                                  | IO type | Remarks |
|-----------------------|----------------|----------------------------------------|---------|---------|
| Mass flowmeter        | Endress+Hauser | Promass 80E-AD2SAAAAADAA+DAZ1          | AI      |         |
| Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B                | AI      |         |
| Vortex flowmeter      | Endress+Hauser | Prowirl F200, 7F2B-AABCCA1D25K         | AI      |         |
| Guided Radar level    | Endress+Hauser | Levelflex FMP51-AAACCALAA4CG+OCZ1      | AI      |         |
| Differential Pressure | Yokogawa       | EJA210E-JMS2J-919EN-ED23A2WE03-B/D4/HE | AI      |         |
|                       |                | EJA110E-JMSWJ-919EB/D4/HE              | AI      |         |
| Pressure transmitter  | Yokogawa       | EJA530E-JBS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA510E-JAS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA310A-JLS2J-919EB/D3/HE              | AI      |         |
| Temperature           | Endress+Hauser | TR10-ABA3CASXH3000                     | AI      |         |
| PH meter              | Yokogawa       | FLXA21-DPDABP1NNANLANN/UM              | AI      |         |
| Pressure Switch       | IFM            | PN7097                                 | DI      |         |
| Fork level switch     | Endress+Hauser | FTL51-AGR2DB2G5A+Z1                    | DI      |         |
|                       |                | FTL50-AGR2AA2G5A+Z1                    | DI      |         |
| Paddle level switch   | Endress+Hauser | FTE20-AA16AE11+Z1                      | DI      |         |
| Float level switch    | Mobrey         | S36DA/F84                              | DI      |         |
| Load cell             |                |                                        | AI      |         |

| Item | Wilmar's Tags | Description     | Type                   | Supplier/Brand | Model          | IO Type | Range Proposed (kg/H) | Signal Type              |
|------|---------------|-----------------|------------------------|----------------|----------------|---------|-----------------------|--------------------------|
| 493  | LSL1616B      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 494  | LSL1616C      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 495  | LSL1616D      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 496  | LSL1616E      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 497  | LSL1682B      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 498  | LSL1616S      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 499  | LSL1682F      | Level Switch    | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 500  | LSL1714       | Level Switch    | Float                  | Mobrey-Emerson |                | DI      |                       | PNP                      |
| 501  | V1604CV-ZO    | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 502  | V1604CV-ZC    | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 503  | V1615S1-ZO    |                 | Valve open indication  | Omaval/IFM     |                | DI      |                       | NPN/PNP                  |
| 504  | V1615S1-ZC    |                 | Valve close indication | Omaval/IFM     |                | DI      |                       | NPN/PNP                  |
| 505  | PSL17571      | Pressure Switch |                        |                |                | DI      |                       | DI dry contact           |
| 506  | V1616A1A-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 507  | V1616A1B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 508  | V1616A1C-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 509  | V1616A1D-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 510  | V1616A1E-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 511  | V1616A1F-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 512  | V1616A1G-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 513  | V1616A1H-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 514  | V1616A1I-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 515  | V1616A1J-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 516  | V1616A1M-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 517  | V1616A1N-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 518  | V1616A2A-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 519  | V1616A2B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 520  | V1616A2C-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 521  | V1616A2D-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 522  | V1616A2E-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 523  | V1616A2F-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 524  | V1616A2G-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 525  | V1616A2H-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 526  | V1616A2I-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 527  | V1616A2J-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 528  | V1616A2K-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 529  | V1616A3A-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 530  | V1616A3B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 531  | V1616A3C-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 532  | V1616A3D-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 533  | V1616A3E-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 534  | V1616A3F-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 535  | V1616A3G-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 536  | V1616A3H-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 537  | V1616A3I-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 538  | V1616A3J-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 539  | V1616A3K-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 540  | V1616A3N-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 541  | V1616A4A-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 542  | V1616A4B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 543  | V1616A4C-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 544  | V1616A4D-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 545  | V1616A4E-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 546  | V1616A4F-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 547  | V1616A4G-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 548  | V1616A4H-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 549  | V1616A4I-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 550  | V1616A4J-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 551  | V1616A4M-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 552  | V1616A5A-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 553  | V1616A5B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 554  | V1616A5C-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 555  | V1616A5D-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 556  | V1616A5E-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 557  | V1616A5F-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 558  | V1616A5G-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 559  | V1616A5H-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 560  | V1616A5I-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 561  | V1616A5J-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 562  | V1616A5K-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 563  | V1616A5N-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 564  | V1682A2B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 565  | V1682A2D-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 566  | V1682BBS-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 567  | V1682BD-SY    | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 568  | V1611S1-SY    | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 569  | V1619S1-SY    | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 570  | V1722QEC-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 571  | V1780A1A-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 572  | V1780A1B-SY   | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 573  | V1604CV-SY    | Actuator Valve  | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 574  | V1615S1-SY    |                 | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 575  | V1034CA-ZO    | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 576  | V1034CA-ZC    | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 577  | V1606A1D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 578  | V1606A1D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 579  | V1606A2D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 580  | V1606A2D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 581  | V1606A3D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 582  | V1606A3D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 583  | V1606A4D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 584  | V1606A4D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 585  | V1606A5D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 586  | V1606A5D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 587  | V1606A6D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 588  | V1606A6D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 589  | V1606B1D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 590  | V1606B1D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 591  | V1606B2D-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 592  | V1606B2D-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 593  | V1606A1F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 594  | V1606A1F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 595  | V1606A2F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 596  | V1606A2F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 597  | V1606A3F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 598  | V1606A3F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 599  | V1606A4F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 600  | V1606A4F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 601  | V1606A5F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 602  | V1606A5F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 603  | V1606A6F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 604  | V1606A6F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 605  | V1606B1F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 606  | V1606B1F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 607  | V1606B2F-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 608  | V1606B2F-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 609  | V1616A1K-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 610  | V1616A1K-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 611  | V1616A1L-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 612  | V1616A1L-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 613  | V1616A2L-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 614  | V1616A2L-ZC   | Actuator Valve  | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 615  | V1616A2M-ZO   | Actuator Valve  | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |

PT. MULTIMAS KAB. BATANG KAYU  
PT. MULTIMAS KAB. BATANG KAYU

PLANT: REFINERY 1

| Instrument type       | Brand          | Model                                  | IO type | Remarks |
|-----------------------|----------------|----------------------------------------|---------|---------|
| Mass flowmeter        | Endress+Hauser | Promass 80E-AD2SAAAAADAA+DAZ1          | AI      |         |
| Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B                | AI      |         |
| Vortex flowmeter      | Endress+Hauser | Prowirl F200, 7F2B-AABCCA1D25K         | AI      |         |
| Guided Radar level    | Endress+Hauser | Levelflex FMP51-AAACCALAA4CG+OCZ1      | AI      |         |
| Differential Pressure | Yokogawa       | EJA210E-JMS2J-919EN-ED23A2WE03-B/D4/HE | AI      |         |
| Pressure transmitter  | Yokogawa       | EJA110E-JMSWJ-919EB/D4/HE              | AI      |         |
|                       |                | EJA530E-JBS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA510E-JAS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA310A-JLS2J-919EB/D3/HE              | AI      |         |
| Temperature           | Endress+Hauser | TR10-ABA3CASXH3000                     | AI      |         |
| PH meter              | Yokogawa       | FLXA21-DPDABP1NNANLANN/UM              | AI      |         |
| Pressure Switch       | IFM            | PN7097                                 | DI      |         |
| Fork level switch     | Endress+Hauser | FTL51-AGR2DB2G5A+Z1                    | DI      |         |
|                       |                | FTL50-AGR2AA2G5A+Z1                    | DI      |         |
| Paddle level switch   | Endress+Hauser | FTE20-AA16AE11+Z1                      | DI      |         |
| Float level switch    | Mobrey         | S36DA/F84                              | DI      |         |
| Load cell             |                |                                        | AI      |         |

| Item | Wilmar's Tags | Description    | Type                   | Supplier/Brand | Model          | IO Type | Range Proposed (kg/H) | Signal Type              |
|------|---------------|----------------|------------------------|----------------|----------------|---------|-----------------------|--------------------------|
| 616  | V1616A2M-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 617  | V1616A3L-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 618  | V1616A3L-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 619  | V1616A3M-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 620  | V1616A3M-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 621  | V1616A4K-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 622  | V1616A4K-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 623  | V1616A4L-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 624  | V1616A4L-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 625  | V1616A5L-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 626  | V1616A5L-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 627  | V1616A5M-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 628  | V1616A5M-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 629  | V1623-ZC      | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 630  | V1623-ZC      | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 631  | V1612S1-ZC    | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 632  | V1612S1-ZC    | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 633  | V1616S1-ZC    | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 634  | V1616S1-ZC    | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 635  | V1610S1-ZC    | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 636  | V1610S1-ZC    | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 637  | V1606C1D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 638  | V1606C1D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 639  | V1606C2D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 640  | V1606C2D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 641  | V1606C1F-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 642  | V1606C1F-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 643  | V1606C2F-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 644  | V1606C2F-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 645  | V1722A5D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 646  | V1722A5D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 647  | LSH1616A      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 648  | LSH1616B      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 649  | LSH1616C      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 650  | LSH1616D      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 651  | LSH1616E      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 652  | LSH1616S      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 653  | V1003F-ZC     | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 654  | V1003F-ZC     | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 655  | V1003BY-ZC    | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 656  | V1003BY-ZC    | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 657  | V1630A12-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 658  | V1630A12-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 659  | V1630A34-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 660  | V1630A34-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 661  | V1630B-ZC     | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 662  | V1630B-ZC     | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 663  | V1630C-ZC     | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 664  | V1630C-ZC     | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 665  | V1722A4D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 666  | V1722A4D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 667  | LSL1003       | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 668  | LSL1630A      | Level Switch   | Paddle                 | Endress+Hauser |                | DI      |                       | DI Dry Contact           |
| 669  | LSL1630B      | Level Switch   | Paddle                 | Endress+Hauser |                | DI      |                       | DI Dry Contact           |
| 670  | LSH1630C      | Level Switch   | Paddle                 | Endress+Hauser |                | DI      |                       | DI Dry Contact           |
| 671  | LSL1630C      | Level Switch   | Paddle                 | Endress+Hauser |                | DI      |                       | DI Dry Contact           |
| 672  | V1721A2D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 673  | V1721A2D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 674  | V1722A3D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 675  | V1722A3D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 676  | V1719ICE-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 677  | V1719ICE-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 678  | V1719ICK-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 679  | V1719ICK-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 680  | V1714ICB-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 681  | V1714ICB-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 682  | LSL1719A      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 683  | LSL1719B      | Level Switch   | Tuning Fork            | Endress+Hauser |                | DI      |                       | PNP                      |
| 684  | LSH1630A      | Level Switch   | Paddle                 | Endress+Hauser |                | DI      |                       | DI Dry Contact           |
| 685  | LSH1630B      | Level Switch   | Paddle                 | Endress+Hauser |                | DI      |                       | DI Dry Contact           |
| 686  | V1722A2D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 687  | V1722A2D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 688  | V1719ICA-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 689  | V1719ICA-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 690  | V1719ICB-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 691  | V1719ICB-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 692  | V1719ICC-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 693  | V1719ICC-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 694  | V1719ICD-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 695  | V1719ICD-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 696  | V1719ICL-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 697  | V1719ICL-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 698  | V1719ICJ-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 699  | V1719ICJ-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 700  | LSM1721A      | Level Switch   | Float                  | Mobrey-Emerson |                | DI      |                       | PNP                      |
| 701  | V1721A1D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 702  | V1721A1D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 703  | V1722QEA-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 704  | V1722QEA-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 705  | V1722QEB-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 706  | V1722QEB-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 707  | V1722A1D-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 708  | V1722A1D-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 709  | V1719ICF-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 710  | V1719ICF-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 711  | V1719ICG-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 712  | V1719ICG-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 713  | V1719ICH-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 714  | V1719ICH-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 715  | V1719ICL-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 716  | V1719ICL-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 717  | V1719ICM-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 718  | V1719ICM-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 719  | V1719ICN-ZC   | Actuator Valve | Valve open indication  | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 720  | V1719ICN-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI      |                       | DI Dry Contact - NPN/PNP |
| 721  | RD-1719A      | Rupture Disc   |                        | KSPC           |                | DI      |                       | DI dry contact           |
| 722  | RD1719B       | Rupture Disc   |                        | KSPC           |                | DI      |                       | DI dry contact           |
| 723  | RD1757I       | Rupture Disc   |                        | KSPC           |                | DI      |                       | DI dry contact           |
| 724  | V1616A15-ZC   | Actuator Valve | Valve open indication  |                |                | DI      |                       | DI Dry Contact - NPN/PNP |
| 725  | V1616A15-ZC   | Actuator Valve | Valve close indication |                |                | DI      |                       | DI Dry Contact - NPN/PNP |
| 726  | V1006B-SY     | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 727  | V1034CAF-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 728  | V1044CAF-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 729  | V1734NA-SY    | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 730  | FSL1083       | Flow Switch    |                        |                |                | DI      |                       |                          |
| 731  | LSLL303       | Level Switch   |                        |                |                | DI      |                       |                          |
| 732  | LSLL301       | Level Switch   |                        |                |                | DI      |                       |                          |
| 733  | V1034CA-SY    | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 734  | V1606A1D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 735  | V1606A2D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 736  | V1606A3D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 737  | V1606A4D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |
| 738  | V1606A5D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO      |                       | 24VDC Wet Supply         |



PT. MULTIMAS NABATI INDONESIA - SERANG

PLANT: REFINERY 1

| Instrument type       | Brand          | Model                                  | IO type | Remarks |
|-----------------------|----------------|----------------------------------------|---------|---------|
| Mass flowmeter        | Endress+Hauser | Promass 80E-AD2SAAAAADAA+DAZ1          | AI      |         |
| Electromagnetic       | Yokogawa       | AXF002G-E2AL1S-BD41-41B                | AI      |         |
| Vortex flowmeter      | Endress+Hauser | Prowirl F200, 7F2B-AABCCA1D25K         | AI      |         |
| Guided Radar level    | Endress+Hauser | Levelflex FMP51-AAACCALAA4CGJ+OCZ1     | AI      |         |
| Differential Pressure | Yokogawa       | EJA210E-JMS2J-919EN-ED23A2WE03-B/D4/HE | AI      |         |
|                       |                | EJA110E-JMSWJ-919EB/D4/HE              | AI      |         |
| Pressure transmitter  | Yokogawa       | EJA530E-JBS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA510E-JAS8N-019EN/D3/HE              | AI      |         |
|                       |                | EJA310A-JLS2J-919EB/D3/HE              | AI      |         |
| Temperature           | Endress+Hauser | TR10-ABA3CASXH3000                     | AI      |         |
| PH meter              | Yokogawa       | FLXA21-DPDABP1NNANLANNN/UM             | AI      |         |
| Pressure Switch       | IFM            | PN7097                                 | DI      |         |
| Fork level switch     | Endress+Hauser | FTL51-AGR2DB2G5A+Z1                    | DI      |         |
|                       |                | FTL50-AGR2AA2G5A+Z1                    | DI      |         |
| Paddle level switch   | Endress+Hauser | FTE20-AA16AE11+Z1                      | DI      |         |
| Float level switch    | Mobrey         | S36DA/F84                              | DI      |         |
| Load cell             |                |                                        | AI      |         |

| Item | Wilmar's Tags | Description    | Type                   | Supplier/Brand | Model          | IO Type  | Range Proposed (kg/H) | Signal Type              |
|------|---------------|----------------|------------------------|----------------|----------------|----------|-----------------------|--------------------------|
| 739  | V1606A6D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 740  | V1606B1D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 741  | V1606B2D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 742  | V1606A1F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 743  | V1606A2F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 744  | V1606A3F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 745  | V1606A4F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 746  | V1606A5F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 747  | V1606A6F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 748  | V1606B1F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 749  | V1606B2F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 750  | V1616A1K-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 751  | V1616A1L-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 752  | V1616A2L-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 753  | V1616A2M-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 754  | V1616A3L-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 755  | V1616A3M-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 756  | V1616A4K-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 757  | V1616A4L-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 758  | V1616A5L-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 759  | V1616A5M-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 760  | V1623-SY      | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 761  | V1612S1-SY    | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 762  | V1616S1-SY    | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 763  | V1610S1-SY    | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 764  | V1606C1D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 765  | V1606C2D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 766  | V1606C1F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 767  | V1606C2F-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 768  | V1722A5D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 769  | V1003F-SY     | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 770  | V1003BY-SY    | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 771  | V1630A12-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 772  | V1630A34-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 773  | V1630B-SY     | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 774  | V1630C-SY     | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 775  | V1722A4D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 776  | V1721A2D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 777  | V1722A3D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 778  | V1719ICE-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 779  | V1719ICK-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 780  | V1714ICB-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 781  | SV1609C       | Solenoid Valve | W Timer Control        | MagAir         |                | DO       |                       | 24 VDC Wet supply        |
| 782  | V1722A2D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 783  | V1719ICA-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 784  | V1719ICB-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 785  | V1719ICC-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 786  | V1719ICD-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 787  | V1719ICL-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 788  | V1719ICJ-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 789  | SV1609A       | Solenoid Valve | W Timer Control        | MagAir         |                | DO       |                       | 24 VDC Wet supply        |
| 790  | SV1609B       | Solenoid Valve | W Timer Control        | MagAir         |                | DO       |                       | 24 VDC Wet supply        |
| 791  | V1721A1D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 792  | V1722QEA-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 793  | V1722QEB-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 794  | V1722A1D-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 795  | V1719ICF-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 796  | V1719ICG-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 797  | V1719ICH-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 798  | V1719ICL-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 799  | V1719ICM-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 800  | V1719ICN-SY   | Actuator Valve | Valve open command     | Omaval/IFM     | W Limit Switch | DO       |                       | 24VDC Wet Supply         |
| 801  | V1616A1S-ZC   | Actuator Valve | Valve open command     |                |                | DO       |                       | 24VDC Wet Supply         |
| 802  | V1614S1-ZC    | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI       |                       | DI Dry Contact - NPN/PNP |
| 803  | V1714AGB-ZC   | Actuator Valve | Valve close indication | Omaval/IFM     | W Limit Switch | DI       |                       | DI Dry Contact - NPN/PNP |
| 804  | WE1610A       | Load Cell      |                        |                |                | Profinet |                       |                          |
| 805  | WE1610B       | Load Cell      |                        |                |                | Profinet |                       |                          |
| 806  | WE1610C       | Load Cell      |                        |                |                | Profinet |                       |                          |
| 807  | WE1630A       | Load Cell      |                        | Utilcell       |                | Profinet |                       |                          |
| 808  | WE1630B       | Load Cell      |                        | Utilcell       |                | Profinet |                       |                          |
| 809  | WE1630C       | Load Cell      |                        | Utilcell       |                | Profinet |                       |                          |