

 MNA Serang			Project :		COMPRESSOR & N2 GEN													Page :		2 of 2		E&I PROJECT									
			Project Code :															Date :		31/07/2018											
			Document Name :		Motor List Compressor & N-2 Gen																										
			Document No :		BED-DCC-CMP-EI-01															REV.0											
Electromotor Data																									Cable Connection					Panel	Remarks
No.	Original Tag	Wilmar Tag	Designation	Requirement	Starting	Rated Power (KW)	Nom. Current (A)	PF	Poles/Rated Speed rpm	Rated Voltage (V)	Motor Brand	Motor Type/Model	EEX Proof Req.	Index Protection	Type	Size (sqmm)	Pulling Quantity (Set)	Length / Pulling (m)	Total Length(m)	Gland Size (mm)	Connecting										
1	C-701		Compressor #1 for N2	Continuous	O/G	275	512.6			380 V 50 Hz 3Ph			N/A		YYY-FR	See LVD cal.					LVD-23A	VFD									
2	C-702		Compressor #2 for Process	Standby	O/G	275	512.6			380 V 50 Hz 3Ph			N/A		YYY-FR	See LVD cal.					LVD-23A	Fixed Speed (S/D or S/S)									
				2	0	75 % Max Load																									
Total Connected Load				B+C=	A	550.00	1025.28	kW	A																						
Max Load					B	550.00	1025.28		412.5	759.0																					
Stand by Load					C	0.00	0.00																								