

			Project :		Texturing										Page : 4 of 11		Date : 01/08/2018		EAI PROJECT					
MNA Serang			Project Code :		ELECTRICAL LOAD LIST														REV.0					
			Document Name :		BED-DOC-TXT-EI-01																			
			Document No :																					
No.		Original Tag	Wilmar Tag	Designation	Requirement continue standby	Starting	Rated Power (KW)	Nom. Current (A)	PF	Poles/Rated Speed rpm	Rated Voltage (V)	Motor Brand	Motor Model/Type	EEX Proof Req.	Index Protection	Type	Size (sqmm)	Pulling Quantity (Set)	Length / Pulling (m)	Total Length(m)	Gland Size (mm)	Connecting	Remarks	
Line 2 (Shortening) - UNICORP																								
	1	2-CPM 03-01		Centrifugal Pump	1	DOL	15	28.0			380 V 50 Hz 3Ph						NYF-FR	dx10mm	1	150	150	M25	MCC-31A2	Pre-blended tank to 300/500
	2	2-CPM 02-02		Centrifugal Pump	1	DOL	15	28.0			380 V 50 Hz 3Ph						NYF-FR	dx10mm	1	150	150	M25	Pre-Blended tank to 300/500	
	3	2-AGM 03-01		Agitator motor	1	DOL	1.6	2.8			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Emulsifier tank 3-T-0301.
	4	2-CPM 03-01		Centrifugal Pump	1	DOL	4	7.5			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Emulsifier tank to Mxino tanks
	7	2-AGM 05-01		Agitator motor	1	VFD	4	7.5			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Mxino Tank 3-T-0501
	8	2-AGM 05-02		Agitator motor	1	VFD	4	7.5			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Mxino Tank 3-T-0511
	9	2-FM 05-01		Fan motor	1	DOL	0.03				220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Mxino Tank 3-T-0501
	10	2-FM 05-02		Fan motor	1	DOL	0.03				220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Mxino Tank 3-T-0511
	11	2-CPM 05-01		Centrifugal Pump	1	DOL	3	5.6			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Mxino Tanks circulation
	12	2-CPM 05-02		Centrifugal Pump	1	DOL	18.5	34.5			380 V 50 Hz 3Ph						NYF-FR	dx16mm	1	150	150	M32	MCC-31A2	Mxino Tank to PHE
	15	2-CPM 06-01		Water Circulation Pump	1	DOL	4	0.25	3.4		380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Pre Heat PHE
	16	2-CPM 06-02		Water Circulation Pump	1	DOL	4	18.2			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Pre Cool PHE
	17	2-HPH 07-01		High Pressure Pump	1	VFD	37	69.0			380 V 50 Hz 3Ph						NYF-FR	dx35mm	1	150	150	M32	MCC-31A2	P-3-68/100
	18	2-FM 07-01		Fan motor	1	DOL	0.20	0.4			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	P-3-68/100
	19	2-FPM 07-31		Perfector C1	1	S/S	11	20.5			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	Perfector (1+1+1+1)1150
	20	2-FPM 07-32		Perfector C2	1	S/S	11	20.5			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	Perfector (1+1+1+1)1150
	21	2-FPM 07-33		Perfector C3	1	S/S	15	28.0			380 V 50 Hz 3Ph						NYF-FR	dx10mm	1	150	150	M25	MCC-31A2	Perfector (1+1+1+1)1150
	22	2-FPM 07-34		Perfector C4	1	S/S	15	28.0			380 V 50 Hz 3Ph						NYF-FR	dx10mm	1	150	150	M25	MCC-31A2	Perfector (1+1+1+1)1150
	23	2-FM 07-31		Fan motor C1	1	DOL	0.20	0.4			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Perfector (1+1+1+1)1150
	24	2-FM 07-32		Fan motor C2	1	DOL	0.20	0.9			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Perfector (1+1+1+1)1150
	25	2-FM 07-33		Fan motor C3	1	DOL	0.20	0.9			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Perfector (1+1+1+1)1150
	26	2-FM 07-34		Fan motor C4	1	DOL	0.20	0.9			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Perfector (1+1+1+1)1150
	27	2-HT 07-91		Heater	1	DOL	18	33.6			380 V 50 Hz 3Ph						NYF-FR	dx16mm	1	150	150	M32	MCC-31A2	Built-in at Perfector
	28	2-HT 07-92		Heater	1	DOL	18	33.6			380 V 50 Hz 3Ph						NYF-FR	dx16mm	1	150	150	M32	MCC-31A2	Built-in at Perfector
	29	2-HT 07-93		Heater	1	DOL	18	33.6			380 V 50 Hz 3Ph						NYF-FR	dx16mm	1	150	150	M32	MCC-31A2	Built-in at Perfector
	30	2-CPM 07-91		Circulation pump (hot water)	1	DOL	0.25	0.5			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Built-in at Perfector
	31	2-PRM 07-42		Pin Rotor	1	VFD	18.5	84.1			380 V 50 Hz 3Ph						NYF-FR	dx16mm	1	150	150	M32	MCC-31A2	Pin Rotor, 2 x 100 lb
	32	2-PRM 07-41		Pin Rotor	1	VFD	18.5	34.5			380 V 50 Hz 3Ph						NYF-FR	dx16mm	1	150	150	M32	MCC-31A2	Pin Rotor, 2 x 100 lb
	33	2-FM 07-41		Fan motor	1	DOL	0.20	0.4			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Fan motor
	34	2-FM 07-42		Fan motor	1	DOL	0.20	0.4			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Fan motor
	35	1-HT 07-95		Heater	1	DOL	9	16.8			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	Built-in at Pin Rotor
	36	1-HT 07-96		Heater	1	DOL	9	16.8			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	Built-in at Pin Rotor
	37	1-CPM 07-92		Circulation pump (hot water)	1	DOL	0.37	0.7			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Built-in at Pin Rotor
	38	1-PRM 07-41		Plasticator	1	DOL	7.5	14.0			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	Plasticator 25L
	39	1-FM 07-51		Fan motor	1	DOL	0.1	0.2			220 V 50 Hz						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Plasticator 25L
	40	1-CPM 07-93		Circulation pump (hot water)	1	DOL	0.37	0.7			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Built-in at Plasticator
	41	1-HT 07-41		Heater	1	DOL	9	16.8			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	Built-in at Plasticator
	42	1-CPM 09-01		Water Circulation Pump (Hot Water)	1	DOL	4	7.5			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Remitt PHE (3-PHE-0901)
	43	1-AGM 09-11		Agitator motor	1	DOL	3	5.6			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	40000x Remitt Tank
	44	1-CPM 09-11		Remitt Tank to Mxino Tank	1	DOL	5.5	10.3			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M20	MCC-31A2	40000x Remitt Tank
	45	1-PM 10-03		BAC Evaporative Condensor	1	S/S	2	28.0			380 V 50 Hz 3Ph						NYF-FR	dx10mm	1	150	150	M25	MCC-31A2	Fan Motor
	46	1-CPM 10-01		BAC Evaporative Condensor	1	S/S	2.2	4.1			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Pump Motor
	47	1-AGM 11-01		Agitator motor	1	DOL	1.6	2.8			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	Flat Block tank
	50	1-CPM 11-01		Centrifugal Pump	1	DOL	4	7.5			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	Flat Block tank to Flusing tank (CS)
	51	1-CPM 12-01		Water Circulation Pump (Hot Water)	1	DOL	2.2	4.1			380 V 50 Hz 3Ph						NYF-FR	dx1.5mm	1	150	150	M20	MCC-31A2	95 den C PHE
	52	1-CPM 12-11		Water Circulation Pump (Hot Water)	1	DOL	7.5	14.0			380 V 50 Hz 3Ph						NYF-FR	dx6mm	1	150	150	M25	MCC-31A2	65 den C PHE
	53	1-CPM 12-21		Water Circulation Pump (Hot Water)	1	DOL	4	7.5			380 V 50 Hz 3Ph						NYF-FR	dx2.5mm	1	150	150	M20	MCC-31A2	45 den C Hot Water tank
Total Connected Load					B+C=		A	335.70	689.63			75 % Max Load												
Max Load							A	320.70	661.67			KW												
Stand by Load							C	15.00	27.86			A												