

Transformer List
PT. MNA Serang

NO	Tagname	In- operation since (year)	Feeding to which plant	Brand	Order no	Serial no	Power (KVA)	Phase	F (Hz)	HV (V)	LV (V)	HV (I)	LV (I)	Impedansi %	Insulation Class	Year Manuf	Standard	Type of Cooling	Type of oil	Vector Group	Temp rise oil/Windi ng (C)	Oil (liter)	weight (kg)	HV tap volt/pos						REMARKS	
1	TF-20A	2019	Boiler 1	B & D		19R248197	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1619	5352	21000	20500	20000	19500	19000	18500	18000	
2	TF-21A	2019	Boiler 1	B & D		19R247577	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1619	5352	21000	20500	20000	19500	19000	18500	18000	
3	TF-22A	2019	WTP	B & D		19R248198	1000 KVA	3 phase	50	20000	400	28,87	1443,38	5	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	740	2745	21000	20500	20000	19500	19000	18500	18000	
4	TF-22B	2019	ETP+Hydrant	B & D		19R247575	1000 KVA	3 phase	50	20000	400	28,87	1443,38	5	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	740	2745	21000	20500	20000	19500	19000	18500	18000	
5	TF-23A	2019	Compressor 1&2	B & D		19R248130	1600 KVA	3 phase	50	20000	400	46,19	2309,4	6	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1033	3724	21000	20500	20000	19500	19000	18500	18000	
6	TF-24A	2019	Compressor 3&4	B & D		19R249558	1600 KVA	3 phase	50	20000	400	46,19	2309,4	6	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1033	3724	21000	20500	20000	19500	19000	18500	18000	
7	TF-25A	2019	Chiller Fract	B & D		19R249546	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
8	TF-25B	2019	Refinery 1	B & D		19R248501	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1619	5352	21000	20500	20000	19500	19000	18500	18000	
9	TF-25C	2019	Fractionation 1	B & D		19R248121	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1619	5352	21000	20500	20000	19500	19000	18500	18000	
10	TF-26A	2019	Fractionation 2	B & D		19R247747	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
11	TF-26B	2019	Refinery 2	B & D		19R247839	1600 KVA	3 phase	50	20000	400	46,19	2309,4	6	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1033	3724	21000	20500	20000	19500	19000	18500	18000	
12	TF-26C	2019	CCR & Warehouse	B & D		19R247894	630 KVA	3 phase	50	20000	400	18,19	909,33	4	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	550	2190	21000	20500	20000	19500	19000	18500	18000	
13	TF-27A	2019	Tank Farm Ref + LU	B & D		19R247838	1250 KVA	3 phase	50	20000	400	36,01	1804,22	5,5	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	840	3105	21000	20500	20000	19500	19000	18500	18000	
14	TF-29A	2020	Hydrogenation	B & D		19R247895	1250 KVA	3 phase	50	20000	400	36,01	1804,22	5,5	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	840	3105	21000	20500	20000	19500	19000	18500	18000	
15	TF-29B	2020	QCD & SCD	B & D		19R248123	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1619	5352	21000	20500	20000	19500	19000	18500	18000	
16	TF-29C	2020	CPKO & EIE	B & D		19R247538	1250 KVA	3 phase	50	20000	400	36,01	1804,22	5,5	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	840	3105	21000	20500	20000	19500	19000	18500	18000	
17	TF-31A	2020	Texturizing A	B & D		19R243316	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K			21000	20500	20000	19500	19000	18500	18000	
18	TF-31B	2020	Texturizing B	B & D		19R248131	2500 KVA	3 phase	50	20000	400	72,17	3.608,44	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K			21000	20500	20000	19500	19000	18500	18000	
19	TF-32A	2020	Tank Farm SF	B & D		19R248114	1250 KVA	3 phase	50	20000	400	36,01	1.804,22	5,5	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	840	3105	21000	20500	20000	19500	19000	18500	18000	
20	TF-201A	2020	Genset 1	B & D		19R247896	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
21	TF-201B	2020	Genset 2	B & D		19R247539	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
22	TF-201C	2020	Genset 3	B & D		19R248907	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
23	TF-201D	2020	Genset 4	B & D		19R247840	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2019	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
24	TF-Genset	2014	Power House CPC	Trafindo		141306738	400 KVA	3 phase	50	20000	400	11,54	577,35	4	A	2014	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	420	1600	21000	20500	20000	19500	19000	18500	18000	
25	TF-Genset	2014	Power House CPC	Trafindo		141304110	2500 KVA	3 phase	50	20000	400	72,17	3608,44	7	A	2014	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1520	5700	21000	20500	20000	19500	19000			
26	TF-50 P	2014	MVD 50 P CPC	Trafindo		141304108	1000 KVA	3 phase	50	20000	400	28,87	1443,38	5	A	2014	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	630	2850	21000	20500	20000	19500	19000	18500	18000	
27	TF-50 Q	2014	MVD 50 Q CPC	Trafindo		141304109	1600 KVA	3 phase	50	20000	400	46,19	2309,4	6	A	2014	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	975	3870	21000	20500	20000	19500	19000			
28	TF-50 R	2015	MVD 50 R CPC	Trafindo		1405711	1000 KVA	3 phase	50	20000	400	28,87	1443,38	5	A	2014	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	750	3700	21000	20500	20000	19500	19000	18500	18000	
29	TF- 35 A	2020	Biodiesel 1	B & D		20R258858	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2020	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
30	TF- 35 B	2020	Biodiesel 2	B & D		20R258856	2000 KVA	3 phase	50	20000	400	57,74	2886,75	7	A	2020	IEC 60076	ONAN	Mineral Oil	Dyn5	60K/ 65K	1240	4423	21000	20500	20000	19500	19000	18500	18000	
31	PB1061	2018	ESP 1 Boiler 1	TENGY		20170923	n/a	2 phase	50	72000	380	0,3	81	n/a	n/a	2018	n/a	n/a	n/a	n/a	n/a	n/a	240	550	n/a	n/a	n/a	n/a	n/a	n/a	
32	PB1062	2018	ESP 2 Boiler 1	TENGY		20170916	n/a	2 phase	50	72000	380	0,3	81	n/a	n/a	2018	n/a	n/a	n/a	n/a	n/a	n/a	240	550	n/a	n/a	n/a	n/a	n/a	n/a	
33	PB1063	2018	ESP 3 Boiler 1	TENGY		20170918	n/a	2 phase	50	72000	380	0,3	81	n/a	n/a	2018	n/a	n/a	n/a	n/a	n/a	n/a	240	550	n/a	n/a	n/a	n/a	n/a	n/a	
34	PB2061	2018	ESP 1 Boiler 2	TENGY		20170924	n/a	2 phase	50	72000	380	0,3	81	n/a	n/a	2018	n/a	n/a	n/a	n/a	n/a	n/a	240	550	n/a	n/a	n/a	n/a	n/a	n/a	
35	PB2062	2018	ESP 2 Boiler 2	TENGY		20170915	n/a	2 phase	50	72000	380	0,3	81	n/a	n/a	2018	n/a	n/a	n/a	n/a	n/a	n/a	240	550	n/a	n/a	n/a	n/a	n/a	n/a	
36	PB2063	2018	ESP 3 Boiler 2	TENGY		20170914	n/a	2 phase	50	72000	380	0,3	81	n/a	n/a	2018	n/a	n/a	n/a	n/a	n/a	n/a	240	550	n/a	n/a	n/a	n/a	n/a	n/a	