

IO List - Continuously Refinery

Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00040

Document Status: For Final

Authorisations

	Name	Function	Signature
Developed By:	Zul Hasyidi Hassan	Project Engineer	ZHH 
Reviewed By:	Liow Kok Loong	Lead Engineer	LKL 
Released By:	Mohd. Nazim Ismail	Project Manager	MNI 

Distribution

Name	Company	Name	Company

Revision History

Rev	Status	Description	Date	Developed By	Reviewed By
A	For Review	Issued for Review	14-Sep-18	WMS	LKL
B	For Review	Issued for Review	17-Oct-18	ZHH	LKL
0	For Final	Issued for Final	1-Oct-19	ZHH	LKL

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

Emerson Automation Solution
Process System and Solutions
No. 1, Block A, Jalan SS13/5, SS13
Subang Jaya, 47500, Selangor
Malaysia
T +60 (3) 5624-2888
F +60 (3) 5638-1010
www.EmersonProcess.com

															RIO CABINET										DELTA V										SYSTEM CABINET																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
Vendor's tags		Wilmar's Tags		Emerson's Tag		Module Name		Description		Type	I/O Type	Range Proposed (kg/h)		Signal Type		Electrical Connection		Cabinet Name		TB Name		Term. (+)		Term. (-)		24V(+) Term.		24V(-) Term.		Term. (+)		Term. (-)		Name		Term. (+)		Term. (-)		Slot		Channel		Term. (+)		Term. (-)		Cabinet Name		Controller																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
2PT1741	PT1741	QD1-PT1741	QD1-PT1741	QD1-PT1741	Gauge	AI	-1.... 9 barg	4-20 mA HART	2 wire									QD1-RIO-001	TB-AI		37																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										

										RIO CABINET										DELTA V				SYSTEM CABINET			
Vendor's tags	Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	I/O Type	Range Proposed (kg/h)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Relay Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller	
2V3221	V10221-ZO	QD1-V10221-ZO	QD1_V10221	2TK322 Citric Acid Inlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	5	6								S1	3	3		#NA	SFO-DCS-003	SFO-CTRL3_1
2V3221	V10221-ZC	QD1-V10221-ZC	QD1_V10221	2TK322 Citric Acid Inlet	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	7	8								S1	4	4		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7512	V17512-ZO	QD1-V17512-ZO	QD1_V17512	Actuator Valve	Valve open indication	DI			2 wire	QD1-RIO-003	TB-DI	9	10								S1	5	5		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7512	V17512-ZC	QD1-V17512-ZC	QD1_V17512	Actuator Valve	Valve close indication	DI			2 wire	QD1-RIO-003	TB-DI	11	12								S1	6	6		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6611D	V16611D-ZO	QD1-V16611D-ZO	QD1_V16611D	2PU661 Drain to 2VE641	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	13	14								S1	7	7		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6611D	V16611D-ZC	QD1-V16611D-ZC	QD1_V16611D	2PU661 Drain to 2VE641	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	15	16								S1	8	8		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7215D	V17215D-ZO	QD1-V17215D-ZO	QD1_V17215D	Drain of 2PU721A&B	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	17	18								S1	9	9		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7215D	V17215D-ZC	QD1-V17215D-ZC	QD1_V17215D	Drain of 2PU721A&B	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	19	20								S1	10	10		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7611	V17611-ZO	QD1-V17611-ZO	QD1_V17611	2TK761 Citric Acid / Anti-oxidant top up	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	21	22								S1	11	11		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7611	V17611-ZC	QD1-V17611-ZC	QD1_V17611	2TK761 Citric Acid / Anti-oxidant top up	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	23	24								S1	12	12		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7218P	V17218P-ZO	QD1-V17218P-ZO	QD1_V17218P	Actuator Valve	Valve open indication	DI			2 wire	QD1-RIO-003	TB-DI	25	26								S1	13	13		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7218P	V17218P-ZC	QD1-V17218P-ZC	QD1_V17218P	Actuator Valve	Valve close indication	DI			2 wire	QD1-RIO-003	TB-DI	27	28								S1	14	14		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7711	V17711-ZO	QD1-V17711-ZO	QD1_V17711	2VE771 Oil Inlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	29	30								S1	15	15		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7711	V17711-ZC	QD1-V17711-ZC	QD1_V17711	2VE771 Oil Inlet	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	31	32								S1	16	16		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7712	V17712-ZO	QD1-V17712-ZO	QD1_V17712	2VE771 Oil Outlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	33	34								S1	17	17		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7712	V17712-ZC	QD1-V17712-ZC	QD1_V17712	2VE771 Oil Outlet	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	35	36								S1	18	18		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7715	V17715-ZO	QD1-V17715-ZO	QD1_V17715	2VE771 Steam Purging	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	37	38								S1	19	19		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7715	V17715-ZC	QD1-V17715-ZC	QD1_V17715	2VE771 Steam Purging	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	39	40								S1	20	20		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7511	V17511-ZO	QD1-V17511-ZO	QD1_V17511	2VE751 Fatty Acid Discharge	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	41	42								S1	21	21		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7511	V17511-ZC	QD1-V17511-ZC	QD1_V17511	2VE751 Fatty Acid Discharge	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	43	44								S1	22	22		#NA	SFO-DCS-003	SFO-CTRL3_1
2V751P	V17511P-ZO	QD1-V17511P-ZO	QD1_V17511P	2VE751 Compressed air & steam purging	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	45	46								S1	23	23		#NA	SFO-DCS-003	SFO-CTRL3_1
2V751P	V17511P-ZC	QD1-V17511P-ZC	QD1_V17511P	2VE751 Compressed air & steam purging	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	47	48								S1	24	24		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7422D	V17422D-ZO	QD1-V17422D-ZO	QD1_V17422D	2HE742 Drain	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	49	50								S1	25	25		#NA	SFO-DCS-003	SFO-CTRL3_1
2V7422D	V17422D-ZC	QD1-V17422D-ZC	QD1_V17422D	2HE742 Drain	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	51	52								S1	26	26		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6410	V16410-ZO	QD1-V16410-ZO	QD1_V16410	2VE641 Discharge to 2PU641	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	53	54								S1	27	27		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6410	V16410-ZC	QD1-V16410-ZC	QD1_V16410	2VE641 Discharge to 2PU641	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	55	56								S1	28	28		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6410P	V16410P-ZO	QD1-V16410P-ZO	QD1_V16410P	2VE641 to 2VE612	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	57	58								S1	29	29		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6410P	V16410P-ZC	QD1-V16410P-ZC	QD1_V16410P	2VE641 to 2VE612	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	59	60								S1	30	30		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6120P	V16120P-ZO	QD1-V16120P-ZO	QD1_V16120P	2PU641 Nitrogen Purging	Valve open indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	61	62								S1	31	31		#NA	SFO-DCS-003	SFO-CTRL3_1
2V6120P	V16120P-ZC	QD1-V16120P-ZC	QD1_V16120P	2PU641 Nitrogen Purging	Valve close indication	DI		PNP	2 wire	QD1-RIO-003	TB-DI	63	64								S1	32	32		#NA	SFO-DCS-003	SFO-CTRL3_1
2LSH821	LSH821	QD1-LSH821	QD1_LSH821	2TK321 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-003	TB-DI	65	66			+1	-1				S2	1	1		#NA	SFO-DCS-003	SFO-CTRL3_1
2LSH822	LSH822	QD1-LSH822	QD1_LSH822	2TK322 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-003	TB-DI	67	68			+2	-2				S2	2	2		#NA	SFO-DCS-003	SFO-CTRL3_1
2LSL701	LSL701	QD1-LSL701	QD1_LSL701	2VE701A&B Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-003	TB-DI	69	70			+3	-3				S2	3	3		#NA	SFO-DCS-003	SFO-CTRL3_1
2LSH771	LSH771	QD1-LSH771	QD1_LSH771	2VE771 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-003	TB-DI	71	72			+4	-4				S2	4	4		#NA	SFO-DCS-003	SFO-CTRL3_1
2LSL771	LSL771	QD1-LSL771	QD1_LSL771	2VE771 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-003	TB-DI</																

										RIO CABINET										DELTA V										SYSTEM CABINET													
Vendor's tags		Wilmar's Tags		Emerson's Tag		Module Name		Description		Type	I/O Type	Range Proposed (kg/h)		Signal Type		Electrical Connection		Cabinet Name		TB Name		Marshalling		Term. (+)		Term. (-)		Relay		Term. (+)		Term. (-)		Channel		Term. (+)		Term. (-)		Cabinet Name		Controller	
2V771S	V1771S-SY	QD1-V1771S-SY	QD1_V1771S	2VE771 Steam Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	19	20					QD1-RIO-003	TB-DO	14	11	RD01-10	A1	A2	S6	10														#NA	SFO-DCS-003	SFO-CTRL3_1	
2V7511	V17511-SY	QD1-V17511-SY	QD1_V17511	2VE751 Fatty Acid Discharge	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	21	22					QD1-RIO-003	TB-DO	14	11	RD01-11	A1	A2	S6	11														#NA	SFO-DCS-003	SFO-CTRL3_1	
2V751P	V1751P-SY	QD1-V1751P-SY	QD1_V1751P	2VE751 Compressed air & steam purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	23	24					QD1-RIO-003	TB-DO	14	11	RD01-12	A1	A2	S6	12														#NA	SFO-DCS-003	SFO-CTRL3_1	
2V7422D	V17422D-SY	QD1-V17422D-SY	QD1_V17422D	2HE742 Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	25	26					QD1-RIO-003	TB-DO	14	11	RD01-13	A1	A2	S6	13														#NA	SFO-DCS-003	SFO-CTRL3_1	
2V6410	V16410-SY	QD1-V16410-SY	QD1_V16410	2VE641 Discharge to 2PU641	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	27	28					QD1-RIO-003	TB-DO	14	11	RD01-14	A1	A2	S6	14														#NA	SFO-DCS-003	SFO-CTRL3_1	
2V6410P	V16410P-SY	QD1-V16410P-SY	QD1_V16410P	2VE641 to 2VE612	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	29	30					QD1-RIO-003	TB-DO	14	11	RD01-15	A1	A2	S6	15													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V6120P	V16120P-SY	QD1-V16120P-SY	QD1_V16120P	2PU641 Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	31	32					QD1-RIO-003	TB-DO	14	11	RD01-16	A1	A2	S6	16													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7112D	V17112D-SY	QD1-V17112D-SY	QD1_V17112D	2FL711A&B Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	33	34					QD1-RIO-003	TB-DO	14	11	RD01-17	A1	A2	S6	17													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7411	V17411-SY	QD1-V17411-SY	QD1_V17411	Oil Header Reject Line to CPO Tank	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	35	36					QD1-RIO-003	TB-DO	14	11	RD01-18	A1	A2	S6	18													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7413	V17413-SY	QD1-V17413-SY	QD1_V17413	Oil Header Oil Return to 2VE701A&B	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	37	38					QD1-RIO-003	TB-DO	14	11	RD01-19	A1	A2	S6	19													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7414	V17414-SY	QD1-V17414-SY	QD1_V17414	Oil Header Oil To RBD Storage	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	39	40					QD1-RIO-003	TB-DO	14	11	RD01-20	A1	A2	S6	20													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7411P	V17411P-SY	QD1-V17411P-SY	QD1_V17411P	2FL741A&B Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	41	42					QD1-RIO-003	TB-DO	14	11	RD01-21	A1	A2	S6	21													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V6410D	V16410D-SY	QD1-V16410D-SY	QD1_V16410D	2PU641 Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	43	44					QD1-RIO-003	TB-DO	14	11	RD01-22	A1	A2	S6	22													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7217D	V17217D-SY	QD1-V17217D-SY	QD1_V17217D	2HE711 Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	45	46					QD1-RIO-003	TB-DO	14	11	RD01-23	A1	A2	S6	23													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7215P	V17215P-SY	QD1-V17215P-SY	QD1_V17215P	Nitrogen Purging to 2PU721A&B	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	47	48					QD1-RIO-003	TB-DO	14	11	RD01-24	A1	A2	S6	24													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V6241P	V16241P-SY	QD1-V16241P-SY	QD1_V16241P	2FL623 BPO Discharge Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	49	50					QD1-RIO-003	TB-DO	14	11	RD01-25	A1	A2	S6	25													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7410N	V17410N-SY	QD1-V17410N-SY	QD1_V17410N	Oil Header Nitrogen Purging to 2VE701A&B	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	51	52					QD1-RIO-003	TB-DO	14	11	RD01-26	A1	A2	S6	26													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V3010	V10101-SY	QD1-V10101-SY	QD1_V10101	Actuator Valve for 2FL301A&B Feed Oil Inlet	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	53	54					QD1-RIO-003	TB-DO	14	11	RD01-27	A1	A2	S6	27													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V3112P	V10112P-SY	QD1-V10112P-SY	QD1_V10112P	Actuator Valve for 2FL301A&B Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	55	56					QD1-RIO-003	TB-DO	14	11	RD01-28	A1	A2	S6	28													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V7216	V17216-SY	QD1-V17216-SY	QD1_V17216	Actuator Valve for 2HE311 Hot Oil Inlet	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	57	58					QD1-RIO-003	TB-DO	14	11	RD01-29	A1	A2	S6	29													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V6121	V16121-SY	QD1-V16121-SY	QD1_V16121	Actuator Valve for 2VE612 Oil Discharge	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	59	60					QD1-RIO-003	TB-DO	14	11	RD01-30	A1	A2	S6	30													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V6121P	V16121P-SY	QD1-V16121P-SY	QD1_V16121P	Actuator Valve for 2VE612 Oil Discharge Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	61	62					QD1-RIO-003	TB-DO	14	11	RD01-31	A1	A2	S6	31													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V6210	V16210-SY	QD1-V16210-SY	QD1_V16210	Actuator Valve for 2PU621 Oil Inlet	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	63	64					QD1-RIO-003	TB-DO	14	11	RD01-32	A1	A2	S6	32													#NA	SFO-DCS-003	SFO-CTRL3_1		
2V621D	V1621D-SY	QD1-V1621D-SY	QD1_V1621D	Actuator Valve for 2PU621 drain to 2VE641	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-003	TB-DO	65	66					QD1-RIO-003	TB-DO	14	11	RD01-33	A1	A2	S7	1													#NA	SFO-DCS-003	SFO-CTRL3_1		

										RIO CABINET										SYSTEM CABINET									
										Marshalling				Relay				DELTA V				DELTA V							
Vendor's tags	Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	IO Type	Range Proposed (kg/h)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
2LSL611	LSL1611	QD1-LSL1611	QD1-LSL1611	2VE611 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-004	TB-DI	159	160	+10	-10						S3	16	16	#NA	SFO-DCS-003	SFO-CTRL3 2			
2LSL641	LSL1641	QD1-LSL1641	QD1-LSL1641	2VE641 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-004	TB-DI	161	162	+11	-11						S3	17	17	#NA	SFO-DCS-003	SFO-CTRL3 2			
2LSLL17313	LSLL17313	QD1-LSLL17313	QD1-LSLL17313	2VE771 Level Switch	Turning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-004	TB-DI	163	164	+12	-12						S3	18	18	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V61110	V161110-ZO	QD1-V161110-ZO	QD1-V161110	Actuator Valve for 2VE611 to 2VE612	Valve open indication	DI		PNP	2 wire	QD1-RIO-004	TB-DI	165	166								S3	19	19	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V61110	V161110-ZC	QD1-V161110-ZC	QD1-V161110	Actuator Valve for 2VE611 to 2VE612	Valve close indication	DI		PNP	2 wire	QD1-RIO-004	TB-DI	167	168								S3	20	20	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V61120	V161120-ZO	QD1-V161120-ZO	QD1-V161120	Actuator Valve for 2VE611 to 2VE612	Valve open indication	DI		PNP	2 wire	QD1-RIO-004	TB-DI	169	170								S3	21	21	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V61120	V161120-ZC	QD1-V161120-ZC	QD1-V161120	Actuator Valve for 2VE611 to 2VE612	Valve close indication	DI		PNP	2 wire	QD1-RIO-004	TB-DI	171	172								S3	22	22	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V6203B	V16203B-ZO	QD1-V16203B-ZO	QD1-V16203B	Actuator Valve for 2FL623A&B Circulation to 2VE612	Valve open indication	DI		PNP	2 wire	QD1-RIO-004	TB-DI	173	174								S3	23	23	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V6203B	V16203B-ZC	QD1-V16203B-ZC	QD1-V16203B	Actuator Valve for 2FL623A&B Circulation to 2VE612	Valve close indication	DI		PNP	2 wire	QD1-RIO-004	TB-DI	175	176								S3	24	24	#NA	SFO-DCS-003	SFO-CTRL3 2			
UPS26B2	UPS26B2	FR1-UPS26B2	FR1-UPS26B2	UPS for Emergency Lighting		DI		DI Dry contact	2 wire	QD1-RIO-004	TB-DI	177	178								S3	25	25	#NA	SFO-DCS-003	SFO-CTRL3 2			
UPS25B1R	UPS25B1R	FR1-UPS25B1R	FR1-UPS25B1R	UPS for Control System		DI		DI Dry contact	2 wire	QD1-RIO-004	TB-DI	179	180								S3	26	26	#NA	SFO-DCS-003	SFO-CTRL3 2			
UPS26B1R	UPS26B1R	FR1-UPS26B1R	FR1-UPS26B1R	UPS for Control System		DI		DI Dry contact	2 wire	QD1-RIO-004	TB-DI	181	182								S3	27	27	#NA	SFO-DCS-003	SFO-CTRL3 2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	QD1-RIO-004	TB-DI	183	184								S3	28	28	#NA	SFO-DCS-003	SFO-CTRL3 2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	QD1-RIO-004	TB-DI	185	186								S3	29	29	#NA	SFO-DCS-003	SFO-CTRL3 2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	QD1-RIO-004	TB-DI	187	188								S3	30	30	#NA	SFO-DCS-003	SFO-CTRL3 2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	QD1-RIO-004	TB-DI	189	190								S3	31	31	#NA	SFO-DCS-003	SFO-CTRL3 2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	QD1-RIO-004	TB-DI	191	192								S3	32	32	#NA	SFO-DCS-003	SFO-CTRL3 2			
2V7216D	V17216D-SY	QD1-V17216D-SY	QD1-V17216D	2HE711 Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	1	2			14	11	RD01-01	A1	A2	A2 (COMM)	S6	1	1	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7216A	V17216A-SY	QD1-V17216A-SY	QD1-V17216A	2HE721 Hot Oil Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	3	4			14	11	RD01-02	A1	A2		S6	2	2	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7216B	V17216B-SY	QD1-V17216B-SY	QD1-V17216B	2HE721 Hot Oil Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	5	6			14	11	RD01-03	A1	A2		S6	3	3	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7216C	V17216C-SY	QD1-V17216C-SY	QD1-V17216C	2HE721 Hot Oil Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	7	8			14	11	RD01-04	A1	A2		S6	4	4	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7216E	V17216E-SY	QD1-V17216E-SY	QD1-V17216E	2HE721 Hot Oil Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	9	10			14	11	RD01-05	A1	A2		S6	5	5	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7216F	V17216F-SY	QD1-V17216F-SY	QD1-V17216F	2HE721 Hot Oil Drain	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	11	12			14	11	RD01-06	A1	A2		S6	6	6	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7215	V17215-SY	QD1-V17215-SY	QD1-V17215	2HE721 to 2PU721A&B	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	13	14			14	11	RD01-07	A1	A2		S6	7	7	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7206D	V17206D-SY	QD1-V17206D-SY	QD1-V17206D	2HE721 Drain to Header	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	15	16			14	11	RD01-08	A1	A2		S6	8	8	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7205D	V17205D-SY	QD1-V17205D-SY	QD1-V17205D	2HE721 Drain to Header	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	17	18			14	11	RD01-09	A1	A2		S6	9	9	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7204D	V17204D-SY	QD1-V17204D-SY	QD1-V17204D	2HE721 Drain to Header	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	19	20			14	11	RD01-10	A1	A2		S6	10	10	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7203D	V17203D-SY	QD1-V17203D-SY	QD1-V17203D	2HE721 Drain to Header	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	21	22			14	11	RD01-11	A1	A2		S6	11	11	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7202D	V17202D-SY	QD1-V17202D-SY	QD1-V17202D	2HE721 Drain to Header	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	23	24			14	11	RD01-12	A1	A2		S6	12	12	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7201D	V17201D-SY	QD1-V17201D-SY	QD1-V17201D	2HE721 Drain to Header	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	25	26			14	11	RD01-13	A1	A2		S6	13	13	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7211P	V17211P-SY	QD1-V17211P-SY	QD1-V17211P	Nitrogen Purging from 2HE722	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	27	28			14	11	RD01-14	A1	A2		S6	14	14	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7610	V17610-SY	QD1-V17610-SY	QD1-V17610	2HE722 Citric Acid / Anti-oxidant Inlet	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	29	30			14	11	RD01-15	A1	A2		S6	15	15	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7001P	V17001P-SY	QD1-V17001P-SY	QD1-V17001P	2VE701A&B Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	QD1-RIO-004	TB-DO	31	32			14	11	RD01-16	A1	A2		S6	16	16	#NA	SFO-DCS-003	SFO-CTRL3 2		
2V7314	V17314-SY	QD1-V17314-SY	QD1-V17314	2DE731 Oil drain from bottom tray	Valve open command	DO		24V																					

										RIO CABINET										SYSTEM CABINET									
Vendor's tags		Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	I/O Type	Range Proposed (kg/h)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Marshalling	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Relay	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Delta V	Delta V
2V6230	V16230-ZC	QD1-V16230-ZC	QD1_V16230	Bypass 2FL623	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	107	108										S2	22	22	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6231	V16231-ZC	QD1-V16231-ZC	QD1_V16231	2FL623 Oil Inlet	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	109	110										S2	23	23	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6231P	V16231P-ZC	QD1-V16231P-ZC	QD1_V16231P	2FL623 Oil Inlet	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	111	112										S2	24	24	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6231P	V16231P-ZO	QD1-V16231P-ZO	QD1_V16231P	2FL623 Nitrogen Purging	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	113	114										S2	25	25	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6231P	V16231P-ZC	QD1-V16231P-ZC	QD1_V16231P	2FL623 Nitrogen Purging	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	115	116										S2	26	26	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6234	V16234-ZO	QD1-V16234-ZO	QD1_V16234	2FL623 Filtrate Oil Out	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	117	118										S2	27	27	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6234	V16234-ZC	QD1-V16234-ZC	QD1_V16234	2FL623 Filtrate Oil Out	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	119	120										S2	28	28	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6236	V16236-ZO	QD1-V16236-ZO	QD1_V16236	2FL623 Emptying	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	121	122										S2	29	29	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6236	V16236-ZC	QD1-V16236-ZC	QD1_V16236	2FL623 Emptying	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	123	124										S2	30	30	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6237	V16237-ZO	QD1-V16237-ZO	QD1_V16237	2FL623 Drying	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	125	126										S2	31	31	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6237	V16237-ZC	QD1-V16237-ZC	QD1_V16237	2FL623 Drying	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	127	128										S2	32	32	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6238	V16238-ZO	QD1-V16238-ZO	QD1_V16238	2FL623 Drying	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	129	130										S3	1	1	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6238	V16238-ZC	QD1-V16238-ZC	QD1_V16238	2FL623 Drying	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	131	132										S3	2	2	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6239	V16239-ZO	QD1-V16239-ZO	QD1_V16239	2FL623 Pre-draining	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	133	134										S3	3	3	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6239	V16239-ZC	QD1-V16239-ZC	QD1_V16239	2FL623 Pre-draining	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	135	136										S3	4	4	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6411	V16411-ZO	QD1-V16411-ZO	QD1_V16411	2FL623 Heel Oil Inlet	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	137	138										S3	5	5	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6411	V16411-ZC	QD1-V16411-ZC	QD1_V16411	2FL623 Heel Oil Inlet	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	139	140										S3	6	6	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6412	V16412-ZO	QD1-V16412-ZO	QD1_V16412	2FL623 Heel Oil to 2VE612	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	141	142										S3	7	7	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6412	V16412-ZC	QD1-V16412-ZC	QD1_V16412	2FL623 Heel Oil to 2VE612	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	143	144										S3	8	8	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6412P	V16412P-ZO	QD1-V16412P-ZO	QD1_V16412P	2FL623 Nitrogen Purging	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	145	146										S3	9	9	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6412P	V16412P-ZC	QD1-V16412P-ZC	QD1_V16412P	2FL623 Nitrogen Purging	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	147	148										S3	10	10	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6413	V16413-ZO	QD1-V16413-ZO	QD1_V16413	2FL623 Heel Oil Circulation to 2VE641	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	149	150										S3	11	11	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6413	V16413-ZC	QD1-V16413-ZC	QD1_V16413	2FL623 Heel Oil Circulation to 2VE641	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	151	152										S3	12	12	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6414	V16414-ZO	QD1-V16414-ZO	QD1_V16414	2FL623 Heel Oil to 2FL641A&B	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	153	154										S3	13	13	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6414	V16414-ZC	QD1-V16414-ZC	QD1_V16414	2FL623 Heel Oil to 2FL641A&B	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	155	156										S3	14	14	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6418A	V16418A-ZO	QD1-V16418A-ZO	QD1_V16418A	2VE701A Oil Inlet from 2FL641A&B	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	157	158										S3	15	15	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6418A	V16418A-ZC	QD1-V16418A-ZC	QD1_V16418A	2VE701A Oil Inlet from 2FL641A&B	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	159	160										S3	16	16	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6418B	V16418B-ZO	QD1-V16418B-ZO	QD1_V16418B	2VE701B Oil Inlet from 2FL641A&B	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	161	162										S3	17	17	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6418B	V16418B-ZC	QD1-V16418B-ZC	QD1_V16418B	2VE701B Oil Inlet from 2FL641A&B	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	163	164										S3	18	18	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6611	V16611-ZO	QD1-V16611-ZO	QD1_V16611	2PU661 Oil Inlet	Valve open indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	165	166										S3	19	19	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6611	V16611-ZC	QD1-V16611-ZC	QD1_V16611	2PU661 Oil Inlet	Valve close indication	DI			PNP	2 wire	QD1-RIO-005	TB-DI	167	168										S3	20	20	#NA	SFO-DCS-003	SFO-CTRL3_2
2V6611N	V16611N-ZO	QD1-V16611N-ZO	QD1_V16611N	2PU661 Nitrogen Purging	Valve open indication	DI																							

										RIO CABINET										SYSTEM CABINET									
										Marshalling				Relay		DELTA V				DELTA V									
Vendor's tags	Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	IO Type	Range Proposed (kg/h)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
2V622S	V1622S-ZO	QD1-V1622S-ZO	QD1_V1622S	2FL622 Steam Inlet for Blowing	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	55	56								S1	28	28	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V622S	V1622S-ZC	QD1-V1622S-ZC	QD1_V1622S	2FL622 Steam Inlet for Blowing	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	57	58								S1	29	29	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V623Z	V1623Z-ZO	QD1-V1623Z-ZO	QD1_V1623Z	2FL623 Venting	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	59	60								S1	30	30	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V623Z	V1623Z-ZC	QD1-V1623Z-ZC	QD1_V1623Z	2FL623 Venting	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	61	62								S1	31	31	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V6232PA	V16232PA-ZO	QD1-V16232PA-ZO	QD1_V16232PA	2FL623 Compressed air to buffer tank	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	63	64								S1	32	32	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V6232PA	V16232PA-ZC	QD1-V16232PA-ZC	QD1_V16232PA	2FL623 Compressed air to buffer tank	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	65	66								S2	1	1	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V6232PB	V16232PB-ZO	QD1-V16232PB-ZO	QD1_V16232PB	2FL623 Compressed air to filter	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	67	68								S2	2	2	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V6232PB	V16232PB-ZC	QD1-V16232PB-ZC	QD1_V16232PB	2FL623 Compressed air to filter	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	69	70								S2	3	3	#NA	SFO-DCS-003	SFO-CTRL3_2			
2L5H632A	LSH1632A	QD1-LSH1632A	QD1_LSH1632A	2TK632A Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	71	72	+6	-6						S2	4	4	#NA	SFO-DCS-003	SFO-CTRL3_2			
2L5H632B	LSH1632B	QD1-LSH1632B	QD1_LSH1632B	2TK632B Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	73	74	+7	-7						S2	5	5	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSH1730	LSH1730	QD1-LSH1730	QD1_LSH1730	2VE730 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	75	76	+8	-8						S2	6	6	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSH1751	LSH1751	QD1-LSH1751	QD1_LSH1751	2VE751 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	77	78	+9	-9						S2	7	7	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LS1512	LSL1012	QD1-LSL1012	QD1_LSL1012	2MX312 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	79	80	+10	-10						S2	8	8	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL632A	LSL1632A	QD1-LSL1632A	QD1_LSL1632A	2TK632A Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	81	82	+11	-11						S2	9	9	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL632B	LSL1632B	QD1-LSL1632B	QD1_LSL1632B	2TK632B Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	83	84	+12	-12						S2	10	10	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL633A	LSL1633A	QD1-LSL1633A	QD1_LSL1633A	2DU631A Level Switch	Tuning Fork	DI		PNP	3 wire PNP	QD1-RIO-006	TB-DI	85	86	+		A1	A2	RD1-01	11	14(comm)	S2	11	11	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL633B	LSL1633B	QD1-LSL1633B	QD1_LSL1633B	2DU631B Level Switch	Tuning Fork	DI		PNP	3 wire PNP	QD1-RIO-006	TB-DI	87	88	+		A1	A2	RD1-02	11	14	S2	12	12	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL722	LSH17311	QD1-LSH17311	QD1_LSH17311	2HE722 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	89	90	+13	-13						S2	13	13	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL730	LSL1730	QD1-LSL1730	QD1_LSL1730	2VE730 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	91	92	+14	-14						S2	14	14	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL751	LSL1751	QD1-LSL1751	QD1_LSL1751	2VE751 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	93	94	+15	-15						S2	15	15	#NA	SFO-DCS-003	SFO-CTRL3_2			
2LSL751	LSL1751	QD1-LSL1751	QD1_LSL1751	2VE751 Level Switch	Tuning Fork	DI		Dry contact	2 wire 24VDC supply+2 wire dry contact	QD1-RIO-006	TB-DI	95	96	+16	-16						S2	16	16	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V632B	V1632B-ZO	QD1-V1632B-ZO	QD1_V1632B	2DU631B Activated Carbon Dosing	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	97	98								S2	17	17	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V632B	V1632B-ZC	QD1-V1632B-ZC	QD1_V1632B	2DU631B Activated Carbon Dosing	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	99	100								S2	18	18	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7221	V17221-ZO	QD1-V17221-ZO	QD1_V17221	2HE722 Oil Inlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	101	102								S2	19	19	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7221	V17221-ZC	QD1-V17221-ZC	QD1_V17221	2HE722 Oil Inlet	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	103	104								S2	20	20	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7222D	V17222D-ZO	QD1-V17222D-ZO	QD1_V17222D	2HE722 Drain	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	105	106								S2	21	21	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7222D	V17222D-ZC	QD1-V17222D-ZC	QD1_V17222D	2HE722 Drain	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	107	108								S2	22	22	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7230P	V17230P-ZO	QD1-V17230P-ZO	QD1_V17230P	2HE723 Nitrogen Purging	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	109	110								S2	23	23	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7230P	V17230P-ZC	QD1-V17230P-ZC	QD1_V17230P	2HE723 Nitrogen Purging	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	111	112								S2	24	24	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7231	V17231-ZO	QD1-V17231-ZO	QD1_V17231	2HE723 Oil Inlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	113	114								S2	25	25	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7231	V17231-ZC	QD1-V17231-ZC	QD1_V17231	2HE723 Oil Inlet	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	115	116								S2	26	26	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7231S	V17231S-ZO	QD1-V17231S-ZO	QD1_V17231S	2HE723 Steam Inlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	117	118								S2	27	27	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7231S	V17231S-ZC	QD1-V17231S-ZC	QD1_V17231S	2HE723 Steam Inlet	Valve close indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	119	120								S2	28	28	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7234A	V17234A-ZO	QD1-V17234A-ZO	QD1_V17234A	2HE723 Oil Outlet	Valve open indication	DI		PNP	2 wire	QD1-RIO-006	TB-DI	121	122								S2	29	29	#NA	SFO-DCS-003	SFO-CTRL3_2			
2V7234A	V17234A-ZC																												

										RIO CABINET										SYSTEM CABINET						
										Marshalling				Relay				DELTA V				DELTA V				
Vendor's tags	Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
2LC632B	LC1632B	QD1-LC1632B	KIV	2TK632B weight of activated carbon		Profinet			Add 24VDC power supply	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU751	PU1751-HS	QD1-PU1751-HS	QD1 PU1751	Fatty Acid Distillate Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU751	PU1751-XL	QD1-PU1751-XL	QD1 PU1751	Fatty Acid Distillate Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU751	PU1751-XA	QD1-PU1751-XA	QD1 PU1751	Fatty Acid Distillate Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU751	PU1751-CU	QD1-PU1751-CU	QD1 PU1751	Fatty Acid Distillate Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU751	PU1751-SP	QD1-PU1751-SP	QD1 PU1751	Fatty Acid Distillate Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU321	PU1021-HS	QD1-PU1021-HS	QD1 PU1021	Phosphoric Acid Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU321	PU1021-XL	QD1-PU1021-XL	QD1 PU1021	Phosphoric Acid Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU321	PU1021-XA	QD1-PU1021-XA	QD1 PU1021	Phosphoric Acid Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU321	PU1021-CU	QD1-PU1021-CU	QD1 PU1021	Phosphoric Acid Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU321	PU1021-SP	QD1-PU1021-SP	QD1 PU1021	Phosphoric Acid Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU701	PU1701-HS	QD1-PU1701-HS	QD1 PU1701	Deodorizer Feed Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU701	PU1701-XL	QD1-PU1701-XL	QD1 PU1701	Deodorizer Feed Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU701	PU1701-XA	QD1-PU1701-XA	QD1 PU1701	Deodorizer Feed Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU701	PU1701-CU	QD1-PU1701-CU	QD1 PU1701	Deodorizer Feed Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU701	PU1701-SP	QD1-PU1701-SP	QD1 PU1701	Deodorizer Feed Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721A	PU1721A-HS	QD1-PU1721A-HS	QD1 PU1721A	Hot Oil Discharge Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721A	PU1721A-XL	QD1-PU1721A-XL	QD1 PU1721A	Hot Oil Discharge Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721A	PU1721A-XA	QD1-PU1721A-XA	QD1 PU1721A	Hot Oil Discharge Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721A	PU1721A-CU	QD1-PU1721A-CU	QD1 PU1721A	Hot Oil Discharge Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721A	PU1721A-SP	QD1-PU1721A-SP	QD1 PU1721A	Hot Oil Discharge Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721B	PU1721B-HS	QD1-PU1721B-HS	QD1 PU1721B	Hot Oil Discharge Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721B	PU1721B-XL	QD1-PU1721B-XL	QD1 PU1721B	Hot Oil Discharge Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721B	PU1721B-XA	QD1-PU1721B-XA	QD1 PU1721B	Hot Oil Discharge Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721B	PU1721B-CU	QD1-PU1721B-CU	QD1 PU1721B	Hot Oil Discharge Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721B	PU1721B-SP	QD1-PU1721B-SP	QD1 PU1721B	Hot Oil Discharge Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305A	PU305A-HS	QD1-PU305A-HS	QD1 PU305A	Cooling Water Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305A	PU305A-XL	QD1-PU305A-XL	QD1 PU305A	Cooling Water Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305A	PU305A-XA	QD1-PU305A-XA	QD1 PU305A	Cooling Water Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305A	PU305A-CU	QD1-PU305A-CU	QD1 PU305A	Cooling Water Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305B	PU305B-HS	QD1-PU305B-HS	QD1 PU305B	Cooling Water Pump	Motor start command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305B	PU305B-XL	QD1-PU305B-XL	QD1 PU305B	Cooling Water Pump	Motor run feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305B	PU305B-XA	QD1-PU305B-XA	QD1 PU305B	Cooling Water Pump	Motor trip feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305B	PU305B-CU	QD1-PU305B-CU	QD1 PU305B	Cooling Water Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU1701	PU1701-SC	QD1-PU1701-SC	QD1 PU1701	Deodorizer Feed Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721A	PU1721A-SC	QD1-PU1721A-SC	QD1 PU1721A	Hot Oil Discharge Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU721B	PU1721B-SC	QD1-PU1721B-SC	QD1 PU1721B	Hot Oil Discharge Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU751	PU1751-SC	QD1-PU1751-SC	QD1 PU1751	Fatty Acid Distillate Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU321	PU1021-SC	QD1-PU1021-SC	QD1 PU1021	Phosphoric Acid Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU322	PU1022-SC	QD1-PU1022-SC	QD1 PU1022	Citric Acid Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU322	PU1022-CU	QD1-PU1022-CU	QD1 PU1022	Citric Acid Pump	Motor current feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU322	PU1022-SP	QD1-PU1022-SP	QD1 PU1022	Citric Acid Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU322	PU1022-XL	QD1-PU1022-XL	QD1 PU1022	Citric Acid Pump	Motor run feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU322	PU1022-XA	QD1-PU1022-XA	QD1 PU1022	Citric Acid Pump	Motor trip feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
2PU322	PU1022-HS	QD1-PU1022-HS	QD1 PU1022	Citric Acid Pump	Motor start command	Profinet		24VDC Wet supply	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305A	PU305A-SC	QD1-PU305A-SC	QD1 PU305A	Fatty Acid Distillate Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305A	PU305A-SP	QD1-PU305A-SP	QD1 PU305A	Fatty Acid Distillate Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305B	PU305B-SC	QD1-PU305B-SC	QD1 PU305B	Fatty Acid Distillate Pump	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
PU-305B	PU305B-SP	QD1-PU305B-SP	QD1 PU305B	Fatty Acid Distillate Pump	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
CT-305	CT305-SC	QD1-CT305-SC	QD1 CT305	Cooling Tower	Motor speed command	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
CT-305	CT305-SP	QD1-CT305-SP	QD1 CT305	Cooling Tower	Motor speed feedback	Profinet				SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
CT-305	CT305-CU	QD1-CT305-CU	QD1 CT305	Cooling Tower	Motor trip feedback	Profinet		4-20 mA	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
CT-305	CT305-XL	QD1-CT305-XL	QD1 CT305	Cooling Tower	Motor run feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
CT-305	CT305-XA	QD1-CT305-XA	QD1 CT305	Cooling Tower	Motor trip feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2
CT-305	CT305-HS	QD1-CT305-HS	QD1 CT305	Cooling Tower	Motor start command	Profinet		24VDC Wet supply	2 wire	SFO-DCS-003															SFO-DCS-003	SFO-CTRL3_2