

# IO List - Enzymatic Interesterification

## Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA  
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00039

Document Status: For Final

### Authorisations

|               | Name               | Function         | Signature                                                                                 |
|---------------|--------------------|------------------|-------------------------------------------------------------------------------------------|
| Developed By: | Zul Hasyidi Hassan | Project Engineer | ZHH  |
| Reviewed By:  | Liow Kok Loong     | Lead Engineer    | LKL  |
| Released By:  | Mohd. Nazim Ismail | Project Manager  | MNI  |

### Distribution

| Name | Company | Name | Company |
|------|---------|------|---------|
|      |         |      |         |
|      |         |      |         |

## Revision History

| Rev | Status     | Description       | Date      | Developed By | Reviewed By |
|-----|------------|-------------------|-----------|--------------|-------------|
| A   | For Review | Issued for Review | 18-Sep-18 | ZHH          | LKL         |
| B   | For Review | Issued for Review | 11-Oct-18 | DRY          | LKL         |
| 0   | For Final  | Issued for Final  | 24-Oct-19 | ZHH          | LKL         |
|     |            |                   |           |              |             |
|     |            |                   |           |              |             |
|     |            |                   |           |              |             |

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

### Emerson Automation Solution

#### Process System and Solutions

No. 1, Block A, Jalan SS13/5, SS13

Subang Jaya, 47500, Selangor

Malaysia

T +60 (3) 5624-2888

F +60 (3) 5638-1010

[www.EmersonProcess.com](http://www.EmersonProcess.com)



|               |             |                 |                       |                |                          |      |         |                       |             |                       | RIO CABINET  |         |           |           |              |              |           |           |      |           | SYSTEM CABINET |      |         |           |           |              |            |  |  |  |
|---------------|-------------|-----------------|-----------------------|----------------|--------------------------|------|---------|-----------------------|-------------|-----------------------|--------------|---------|-----------|-----------|--------------|--------------|-----------|-----------|------|-----------|----------------|------|---------|-----------|-----------|--------------|------------|--|--|--|
| Vendor's tags |             | Wilmar's Tags   | Emerson Database Tags | Module Name    | Description              | Type | IO Type | Range Proposed (kg/H) | Signal Type | Electrical Connection | Marshalling  |         |           |           | Relay        |              | DELTA V   |           |      |           | DELTA V        |      |         |           |           |              |            |  |  |  |
|               |             |                 |                       |                |                          |      |         |                       |             |                       | Cabinet Name | TB Name | Term. (+) | Term. (-) | 24V(+) Term. | 24V(-) Term. | Term. (+) | Term. (-) | Name | Term. (+) | Term. (-)      | Slot | Channel | Term. (+) | Term. (-) | Cabinet Name | Controller |  |  |  |
| PSE-E2603B    | RD1103B     | EI1-RD1103B     | EI1 RD1103B           | Rupture Disk   | Rupture Disk             | DI   | DI      | DI Dry contact        | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 15        | 16        |              |              |           |           |      |           |                | S1   | 8       | 8         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-D1  | V1103AD1-ZO | EI1-V1103AD1-ZO | EI1 V1103AD1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 17        | 18        |              |              |           |           |      |           |                | S1   | 9       | 9         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-D1  | V1103AD1-ZC | EI1-V1103AD1-ZC | EI1 V1103AD1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 19        | 20        |              |              |           |           |      |           |                | S1   | 10      | 10        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| PSE-E2603C    | RD1103C     | EI1-RD1103C     | EI1 RD1103C           | Rupture Disk   | Rupture Disk             | DI   |         | DI Dry contact        | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 21        | 22        |              |              |           |           |      |           |                | S1   | 11      | 11        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-D2  | V1103AD2-ZO | EI1-V1103AD2-ZO | EI1 V1103AD2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 23        | 24        |              |              |           |           |      |           |                | S1   | 12      | 12        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-D2  | V1103AD2-ZC | EI1-V1103AD2-ZC | EI1 V1103AD2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 25        | 26        |              |              |           |           |      |           |                | S1   | 13      | 13        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| PSE-E2603D    | RD1103D     | EI1-RD1103D     | EI1 RD1103D           | Rupture Disk   | Rupture Disk             | DI   |         | DI Dry contact        | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 27        | 28        |              |              |           |           |      |           |                | S1   | 14      | 14        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-F1  | V1103AF1-ZO | EI1-V1103AF1-ZO | EI1 V1103AF1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 29        | 30        |              |              |           |           |      |           |                | S1   | 15      | 15        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-F1  | V1103AF1-ZC | EI1-V1103AF1-ZC | EI1 V1103AF1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 31        | 32        |              |              |           |           |      |           |                | S1   | 16      | 16        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-F2  | V1103AF2-ZO | EI1-V1103AF2-ZO | EI1 V1103AF2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 33        | 34        |              |              |           |           |      |           |                | S1   | 17      | 17        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-F2  | V1103AF2-ZC | EI1-V1103AF2-ZC | EI1 V1103AF2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 35        | 36        |              |              |           |           |      |           |                | S1   | 18      | 18        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-R   | V1103AR-ZO  | EI1-V1103AR-ZO  | EI1 V1103AR           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 37        | 38        |              |              |           |           |      |           |                | S1   | 19      | 19        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-R   | V1103AR-ZC  | EI1-V1103AR-ZC  | EI1 V1103AR           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 39        | 40        |              |              |           |           |      |           |                | S1   | 20      | 20        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-V   | V1103AV-ZO  | EI1-V1103AV-ZO  | EI1 V1103AV           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 41        | 42        |              |              |           |           |      |           |                | S1   | 21      | 21        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603A-V   | V1103AV-ZC  | EI1-V1103AV-ZC  | EI1 V1103AV           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 43        | 44        |              |              |           |           |      |           |                | S1   | 22      | 22        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-BN  | V1103BBN-ZO | EI1-V1103BBN-ZO | EI1 V1103BBN          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 45        | 46        |              |              |           |           |      |           |                | S1   | 23      | 23        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-BN  | V1103BBN-ZC | EI1-V1103BBN-ZC | EI1 V1103BBN          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 47        | 48        |              |              |           |           |      |           |                | S1   | 24      | 24        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-D1  | V1103BD1-ZO | EI1-V1103BD1-ZO | EI1 V1103BD1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 49        | 50        |              |              |           |           |      |           |                | S1   | 25      | 25        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-D1  | V1103BD1-ZC | EI1-V1103BD1-ZC | EI1 V1103BD1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 51        | 52        |              |              |           |           |      |           |                | S1   | 26      | 26        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-D2  | V1103BD2-ZO | EI1-V1103BD2-ZO | EI1 V1103BD2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 53        | 54        |              |              |           |           |      |           |                | S1   | 27      | 27        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-D2  | V1103BD2-ZC | EI1-V1103BD2-ZC | EI1 V1103BD2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 55        | 56        |              |              |           |           |      |           |                | S1   | 28      | 28        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-F1  | V1103BF1-ZO | EI1-V1103BF1-ZO | EI1 V1103BF1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 57        | 58        |              |              |           |           |      |           |                | S1   | 29      | 29        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-F1  | V1103BF1-ZC | EI1-V1103BF1-ZC | EI1 V1103BF1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 59        | 60        |              |              |           |           |      |           |                | S1   | 30      | 30        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-F2  | V1103BF2-ZO | EI1-V1103BF2-ZO | EI1 V1103BF2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 61        | 62        |              |              |           |           |      |           |                | S1   | 31      | 31        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-F2  | V1103BF2-ZC | EI1-V1103BF2-ZC | EI1 V1103BF2          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 63        | 64        |              |              |           |           |      |           |                | S1   | 32      | 32        | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-R   | V1103BR-ZO  | EI1-V1103BR-ZO  | EI1 V1103BR           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 65        | 66        |              |              |           |           |      |           |                | S2   | 1       | 1         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-R   | V1103BR-ZC  | EI1-V1103BR-ZC  | EI1 V1103BR           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 67        | 68        |              |              |           |           |      |           |                | S2   | 2       | 2         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-V   | V1103BV-ZO  | EI1-V1103BV-ZO  | EI1 V1103BV           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 69        | 70        |              |              |           |           |      |           |                | S2   | 3       | 3         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603B-V   | V1103BV-ZC  | EI1-V1103BV-ZC  | EI1 V1103BV           | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 71        | 72        |              |              |           |           |      |           |                | S2   | 4       | 4         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603C-BN  | V1103CBN-ZO | EI1-V1103CBN-ZO | EI1 V1103CBN          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 73        | 74        |              |              |           |           |      |           |                | S2   | 5       | 5         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603C-BN  | V1103CBN-ZC | EI1-V1103CBN-ZC | EI1 V1103CBN          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 75        | 76        |              |              |           |           |      |           |                | S2   | 6       | 6         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603C-D1  | V1103CD1-ZO | EI1-V1103CD1-ZO | EI1 V1103CD1          | Actuator Valve | Pneumatic Actuated Valve | DI   |         |                       | NP/NPN      | 2 wire                | EI1-RIO-002  | TB-DI   | 77        | 78        |              |              |           |           |      |           |                | S2   | 7       | 7         | NA        | SFO-DCS-002  | SFO-CTRL2  |  |  |  |
| XV-E2603C-D1  | V1103CD1-ZC | EI1-V1103CD1-ZC | EI1 V1103CD1          | Actuator Valve | P                        |      |         |                       |             |                       |              |         |           |           |              |              |           |           |      |           |                |      |         |           |           |              |            |  |  |  |



Emerson Automation Solution - Confidential and Proprietary

|               |               |                       |              |                       |                          |          |                       |                  |                       | RIO CABINET  |         |           |           |              |              |           |           |         |           | SYSTEM CABINET |      |         |           |           |              |            |
|---------------|---------------|-----------------------|--------------|-----------------------|--------------------------|----------|-----------------------|------------------|-----------------------|--------------|---------|-----------|-----------|--------------|--------------|-----------|-----------|---------|-----------|----------------|------|---------|-----------|-----------|--------------|------------|
|               |               |                       |              |                       |                          |          |                       |                  |                       | Marshalling  |         |           |           | Relay        |              |           |           | DELTA V |           |                |      | DELTA V |           |           |              |            |
| Vendor's tags | Wilmar's Tags | Emerson Database Tags | Module Name  | Description           | Type                     | IO Type  | Range Proposed (kg/H) | Signal Type      | Electrical Connection | Cabinet Name | TB Name | Term. (+) | Term. (-) | 24V(+) Term. | 24V(-) Term. | Term. (+) | Term. (-) | Name    | Term. (+) | Term. (-)      | Slot | Channel | Term. (+) | Term. (-) | Cabinet Name | Controller |
| XV-E3635E-W   | V1235EW-SY    | EI1-V1235EW-SY        | EI1 V1235EW  | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 15        | 16        |              |              | 14        | 11        | RDO1-08 | A1        | A2             | S6   | 8       | 8         | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-2646A-D    | V1246AD-SY    | EI1-V1246AD-SY        | EI1 V1246AD  | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 17        | 18        |              |              | 14        | 11        | RDO1-09 | A1        | A2             | S6   | 9       | 9         | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2682B2-V  | V1282B2V-SY   | EI1-V1282B2V-SY       | EI1 V1282B2V | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 19        | 20        |              |              | 14        | 11        | RDO1-10 | A1        | A2             | S6   | 10      | 10        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-PE2635E-BN | V1135EBN-SY   | EI1-V1135EBN-SY       | EI1 V1135EBN | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 21        | 22        |              |              | 14        | 11        | RDO1-11 | A1        | A2             | S6   | 11      | 11        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2603A-QE  | V1103AQE-SY   | EI1-V1103AQE-SY       | EI1 V1103AQE | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 23        | 24        |              |              | 14        | 11        | RDO1-12 | A1        | A2             | S6   | 12      | 12        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2603B-FY  | V1103BFY-SY   | EI1-V1103BFY-SY       | EI1 V1103BFY | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 25        | 26        |              |              | 14        | 11        | RDO1-13 | A1        | A2             | S6   | 13      | 13        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2603B-QE  | V1103BQE-SY   | EI1-V1103BQE-SY       | EI1 V1103BQE | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 27        | 28        |              |              | 14        | 11        | RDO1-14 | A1        | A2             | S6   | 14      | 14        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2603C-FY  | V1103CFY-SY   | EI1-V1103CFY-SY       | EI1 V1103CFY | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 29        | 30        |              |              | 14        | 11        | RDO1-15 | A1        | A2             | S6   | 15      | 15        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2603C-QE  | V1103CQE-SY   | EI1-V1103CQE-SY       | EI1 V1103CQE | Actuator Valve        | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 31        | 32        |              |              | 14        | 11        | RDO1-16 | A1        | A2             | S6   | 16      | 16        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| XV-E2682B1-V  | V1282B1V-SY   | EI1-V1282B1V-SY       | EI1 V1282B1V |                       | Pneumatic Actuated Valve | DO       |                       | 24VDC Wet Supply | 2 wire                | EI1-RIO-003  | TB-DO   | 33        | 34        |              |              | 14        | 11        | RDO1-17 | A1        | A2             | S6   | 17      | 16        | NA        | SFO-DCS-002  | SFO-CTRL3  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 35        | 36        |              |              | 14        | 11        | RDO1-18 | A1        | A2             | S6   | 18      | 18        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 37        | 38        |              |              | 14        | 11        | RDO1-19 | A1        | A2             | S6   | 19      | 19        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 39        | 40        |              |              | 14        | 11        | RDO1-20 | A1        | A2             | S6   | 20      | 20        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 41        | 42        |              |              | 14        | 11        | RDO1-21 | A1        | A2             | S6   | 21      | 21        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 43        | 44        |              |              | 14        | 11        | RDO1-22 | A1        | A2             | S6   | 22      | 22        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 45        | 46        |              |              | 14        | 11        | RDO1-23 | A1        | A2             | S6   | 23      | 23        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 47        | 48        |              |              | 14        | 11        | RDO1-24 | A1        | A2             | S6   | 24      | 24        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 49        | 50        |              |              | 14        | 11        | RDO1-25 | A1        | A2             | S6   | 25      | 25        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 51        | 52        |              |              | 14        | 11        | RDO1-26 | A1        | A2             | S6   | 26      | 26        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 53        | 54        |              |              | 14        | 11        | RDO1-27 | A1        | A2             | S6   | 27      | 27        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 55        | 56        |              |              | 14        | 11        | RDO1-28 | A1        | A2             | S6   | 28      | 28        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 57        | 58        |              |              | 14        | 11        | RDO1-29 | A1        | A2             | S6   | 29      | 29        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 59        | 60        |              |              | 14        | 11        | RDO1-30 | A1        | A2             | S6   | 30      | 30        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 61        | 62        |              |              | 14        | 11        | RDO1-31 | A1        | A2             | S6   | 31      | 31        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| SPARE         | SPARE         | SPARE                 | SPARE        | SPARE                 | SPARE                    | SPARE    | SPARE                 | SPARE            | SPARE                 | EI1-RIO-003  | TB-DO   | 63        | 64        |              |              | 14        | 11        | RDO1-32 | A1        | A2             | S6   | 32      | 32        | NA        | SFO-DCS-002  | SFO-CTRL2  |
| PE2682A       | PU1082A-HS    | EI1-PU1082A-HS        | EI1 PU1082A  | Reactor Oil Feed Pump | Motor start command      | Profinet |                       |                  |                       | SFO-DCS-002  |         |           |           |              |              |           |           |         |           |                |      |         |           |           | SFO-DCS-002  | SFO-CTRL2  |
| PE2682A       | PU1082A-XL    | EI1-PU1082A-XL        | EI1 PU1082A  | Reactor Oil Feed Pump | Motor run feedback       | Profinet |                       |                  |                       | SFO-DCS-002  |         |           |           |              |              |           |           |         |           |                |      |         |           |           | SFO-DCS-002  | SFO-CTRL2  |
| PE2682A       | PU1082A-XA    | EI1-PU1082A-XA        | EI1 PU1082A  | Reactor Oil Feed Pump | Motor trip feedback      | Profinet |                       |                  |                       | SFO-DCS-002  |         |           |           |              |              |           |           |         |           |                |      |         |           |           | SFO-DCS-002  | SFO-CTRL2  |
| PE2682A       | PU1082A-CU    | EI1-PU1082A-CU        | EI1 PU1082A  | Reactor Oil Feed Pump | Motor current feedback   | Profinet |                       |                  |                       | SFO-DCS-002  |         |           |           |              |              |           |           |         |           |                |      |         |           |           | SFO-DCS-002  | SFO-CTRL2  |
| PE2682A       | PU1082A-SC    | EI1-PU1082A-SC        | EI1 PU1082A  | Reactor Oil Feed Pump | Motor current feedback   | Profinet |                       |                  |                       | SFO-DCS-002  |         |           |           |              |              |           |           |         |           |                |      |         |           |           | SFO-DCS-002  | SFO-CTRL2  |
| PE2682A       | PU1082A-SP    | EI1-PU1082A-SP        | EI1 PU1082A  | Reactor Oil Feed Pump | Motor speed feedback     | Profinet |                       |                  |                       | SFO-DCS-002  |         |           |           |              |              |           |           |         |           |                |      |         |           |           | SFO-DCS-002  | SFO-CTRL2  |