

IO List – WWTP/ETP

Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00053

Document Status: For Final

Authorisations

	Name	Function	Signature
Developed By:	Zul Hasyidi Hassan	Project Engineer	ZHH 
Reviewed By:	Liow Kok Loong	Lead Engineer	LKL 
Released By:	Mohd. Nazim Ismail	Project Manager	MNI 

Distribution

Name	Company	Name	Company

Revision History

Rev	Status	Description	Date	Developed By	Reviewed By
A	For Review	Issued for Review	18-Oct-18	ZHH	LKL
0	For Final	Issued for Final	27-Sep-18	ZHH	LKL

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

Emerson Automation Solution
Process System and Solutions

No. 1, Block A, Jalan SS13/5, SS13
Subang Jaya, 47500, Selangor
Malaysia
T +60 (3) 5624-2888
F +60 (3) 5638-1010
www.EmersonProcess.com

										RIO CABINET										SYSTEM CABINET									
										Relay										DELTA V									
Vendor's tags	Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	I/O type	Range Proposed (kg/H)	Signal type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
PU-1802A	PU1802A-XL	EP1-PU1802A-XL	EP1 PU1802A	EQ Tank pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	1	2								S1	1		NA	UTI-DCS-002	UTI-CTRL2			
PU-1802A	PU1802A-XL	EP1-PU1802A-XL	EP1 PU1802A	EQ Tank pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	3	4								S1	2		NA	UTI-DCS-002	UTI-CTRL2			
PU-1802B	PU1802B-XL	EP1-PU1802B-XL	EP1 PU1802B	EQ Tank pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	5	6								S1	3		NA	UTI-DCS-002	UTI-CTRL2			
PU-1802B	PU1802B-XL	EP1-PU1802B-XL	EP1 PU1802B	EQ Tank pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	7	8								S1	4		NA	UTI-DCS-002	UTI-CTRL2			
PU-1801A	PU1801A-XL	EP1-PU1801A-XL	EP1 PU1801A	Accident Tank pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	9	10								S1	5		NA	UTI-DCS-002	UTI-CTRL2			
PU-1801A	PU1801A-XL	EP1-PU1801A-XL	EP1 PU1801A	Accident Tank pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	11	12								S1	6		NA	UTI-DCS-002	UTI-CTRL2			
PU-1801B	PU1801B-XL	EP1-PU1801B-XL	EP1 PU1801B	Accident Tank pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	13	14								S1	7		NA	UTI-DCS-002	UTI-CTRL2			
PU-1801B	PU1801B-XL	EP1-PU1801B-XL	EP1 PU1801B	Accident Tank pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	15	16								S1	8		NA	UTI-DCS-002	UTI-CTRL2			
PU-1812A	PU1812A-XL	EP1-PU1812A-XL	EP1 PU1812A	Lime dosing pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	17	18								S1	9		NA	UTI-DCS-002	UTI-CTRL2			
PU-1812A	PU1812A-XL	EP1-PU1812A-XL	EP1 PU1812A	Lime dosing pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	19	20								S1	10		NA	UTI-DCS-002	UTI-CTRL2			
PU-1812B	PU1812B-XL	EP1-PU1812B-XL	EP1 PU1812B	Lime dosing pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	21	22								S1	11		NA	UTI-DCS-002	UTI-CTRL2			
PU-1812B	PU1812B-XL	EP1-PU1812B-XL	EP1 PU1812B	Lime dosing pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	23	24								S1	12		NA	UTI-DCS-002	UTI-CTRL2			
ACH-1815	ACH1815-XL	EP1-ACH1815-XL	EP1 ACH1815	Feeder Motor	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	25	26								S1	13		NA	UTI-DCS-002	UTI-CTRL2			
ACH-1815	ACH1815-XL	EP1-ACH1815-XL	EP1 ACH1815	Feeder Motor	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	27	28								S1	14		NA	UTI-DCS-002	UTI-CTRL2			
AG1810A	AG1810A-XL	EP1-AG1810A-XL	EP1 AG1810A	Agitator for clarifier reactor	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	29	30								S1	15		NA	UTI-DCS-002	UTI-CTRL2			
AG1810A	AG1810A-XL	EP1-AG1810A-XL	EP1 AG1810A	Agitator for clarifier reactor	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	31	32								S1	16		NA	UTI-DCS-002	UTI-CTRL2			
AG1810B	AG1810B-XL	EP1-AG1810B-XL	EP1 AG1810B	Agitator for clarifier reactor	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	33	34								S1	17		NA	UTI-DCS-002	UTI-CTRL2			
AG1810B	AG1810B-XL	EP1-AG1810B-XL	EP1 AG1810B	Agitator for clarifier reactor	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	35	36								S1	18		NA	UTI-DCS-002	UTI-CTRL2			
SCP1831	SCP1831-XL	EP1-SCP1831-XL	EP1 SCP1831	Scrapper	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	37	38								S1	19		NA	UTI-DCS-002	UTI-CTRL2			
SCP1831	SCP1831-XL	EP1-SCP1831-XL	EP1 SCP1831	Scrapper	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	39	40								S1	20		NA	UTI-DCS-002	UTI-CTRL2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	EP1-RMCC 1	TB-DI	41	42								S1	21		NA	UTI-DCS-002	UTI-CTRL2			
SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE	EP1-RMCC 1	TB-DI	43	44								S1	22		NA	UTI-DCS-002	UTI-CTRL2			
PU-1852A	PU1852A-XL	EP1-PU1852A-XL	EP1 PU1852A	Sump pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	45	46								S1	23		NA	UTI-DCS-002	UTI-CTRL2			
PU-1852A	PU1852A-XL	EP1-PU1852A-XL	EP1 PU1852A	Sump pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	47	48								S1	24		NA	UTI-DCS-002	UTI-CTRL2			
PU-1852B	PU1852B-XL	EP1-PU1852B-XL	EP1 PU1852B	Sump pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	49	50								S1	25		NA	UTI-DCS-002	UTI-CTRL2			
PU-1852B	PU1852B-XL	EP1-PU1852B-XL	EP1 PU1852B	Sump pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	51	52								S1	26		NA	UTI-DCS-002	UTI-CTRL2			
PU-1831A	PU1831A-XL	EP1-PU1831A-XL	EP1 PU1831A	Aerobic clarifier recycle pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	53	54								S1	27		NA	UTI-DCS-002	UTI-CTRL2			
PU-1831A	PU1831A-XL	EP1-PU1831A-XL	EP1 PU1831A	Aerobic clarifier recycle pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	55	56								S1	28		NA	UTI-DCS-002	UTI-CTRL2			
PU-1831B	PU1831B-XL	EP1-PU1831B-XL	EP1 PU1831B	Aerobic clarifier recycle pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	57	58								S1	29		NA	UTI-DCS-002	UTI-CTRL2			
PU-1831B	PU1831B-XL	EP1-PU1831B-XL	EP1 PU1831B	Aerobic clarifier recycle pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	59	60								S1	30		NA	UTI-DCS-002	UTI-CTRL2			
PU-1841A	PU1841A-XL	EP1-PU1841A-XL	EP1 PU1841A	Chemical clarifier scum pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	61	62								S1	31		NA	UTI-DCS-002	UTI-CTRL2			
PU-1841A	PU1841A-XL	EP1-PU1841A-XL	EP1 PU1841A	Chemical clarifier scum pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	63	64								S1	32		NA	UTI-DCS-002	UTI-CTRL2			
PU-1841B	PU1841B-XL	EP1-PU1841B-XL	EP1 PU1841B	Chemical clarifier scum pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	65	66								S2	1		NA	UTI-DCS-002	UTI-CTRL2			
PU-1841B	PU1841B-XL	EP1-PU1841B-XL	EP1 PU1841B	Chemical clarifier scum pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	67	68								S2	2		NA	UTI-DCS-002	UTI-CTRL2			
PU-1850A	PU1850A-XL	EP1-PU1850A-XL	EP1 PU1850A	Diaphragm air pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	69	70								S2	3		NA	UTI-DCS-002	UTI-CTRL2			
PU-1850A	PU1850A-XL	EP1-PU1850A-XL	EP1 PU1850A	Diaphragm air pump	Motor trip feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	71	72								S2	4		NA	UTI-DCS-002	UTI-CTRL2			
PU-1850B	PU1850B-XL	EP1-PU1850B-XL	EP1 PU1850B	Diaphragm air pump	Motor run feedback	DI		DI Dry Contact	2 wire	EP1-RMCC 1	TB-DI	73	74								S2	5		NA	UTI-DCS-002	UTI-CTRL2			
PU-1850B	PU1850B-XL	EP1-PU1850B-XL																											

Emerson Automation Solution - Confidential and Proprietary

										RIO CABINET														SYSTEM CABINET		
Vendor's tag	Wilmar's Tags	Emerson's Tag	Module Name	Description	Type	I/O type	Range Proposed (kg/H)	Signal type	Electrical Connection	Marshalling						Relay				DELTA V				DELTA V		
										Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
PU1813	PU01813-CU	EP1-PU01813-CU	EP1_PU01813	Acid dosing pump	Motor Current Feedback	Profinet				UTI-DCS-002															UTI-DCS-002	UTI-CTRL2
PU1813	PU01813-SP	EP1-PU01813-SP	EP1_PU01813	Acid dosing pump	Motor Speed Feedback	Profinet				UTI-DCS-002															UTI-DCS-002	UTI-CTRL2