

IO List - Hydrogenation 1

Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00042

Document Status: For Final

Authorisations

	Name	Function	Signature
Developed By:	Zul Hasyidi Hassan	Project Engineer	ZHH 
Reviewed By:	Liow Kok Loong	Lead Engineer	LKL 
Released By:	Mohd. Nazim Ismail	Project Manager	MNI 

Distribution

Name	Company	Name	Company

Revision History

Rev	Status	Description	Date	Developed By	Reviewed By
A	For Review	Issued for Review	18-Sep-18	ZHH	LKL
B	For Review	Issued for Review	11-Oct-18	ZHH	LKL
0	For Final	Issued for Final	18-Oct-19	ZHH	LKL

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

Emerson Automation Solution

Process System and Solutions

No. 1, Block A, Jalan SS13/5, SS13

Subang Jaya, 47500, Selangor

Malaysia

T +60 (3) 5624-2888

F +60 (3) 5638-1010

www.EmersonProcess.com

										RIO CABINET										SYSTEM CABINET									
										IS BARRIER										DELTA V									
										Name										Name									
Vendor's tags	Wilmar's Tags	Emerson's Database Tag	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Classification	Cabinet Name	TB Name	Term. (+)	Term. (-)	Term. (+)	Term. (-)	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Term. (+)	Term. (-)	Cabinet Name	Term. (+)	Term. (-)	
FT-1542	FT1542	HY1-FT1542	HY1-FT1542	Instrument Air	Vortex Flowmeter	AI			2 wire	IS	HY1-RIO-001	TB-AI	57	58	1	3	BAI-015	7	8	13	25	26	SFO-DCS-005	SFO-CTRL5					
FT-1486	FT1486	HW1-FT1486	HW1-FT1486	Flow Meter		AI			2wire	IS	HY1-RIO-001	TB-AI	59	60	4	6		10	11	S2	14	27	SFO-DCS-005	SFO-CTRL5					
FT-1486	FT1486	HW1-FT1486	HW1-FT1486	Flow Meter		AI			2wire	IS	HY1-RIO-001	TB-AI	61	62	1	3	BAI-016	7	8	S2	15	29	SFO-DCS-005	SFO-CTRL5					
FT-1646	FT1646	HY1-FT1646	HY1-FT1646	Nitrogen	Vortex Flowmeter	AI			2 wire	IS	HY1-RIO-001	TB-AI	63	64	4	6		10	11	S2	16	31	SFO-DCS-005	SFO-CTRL5					
FT-1647	FT1647	HY1-FT1647	HY1-FT1647	Nitrogen	Vortex Flowmeter	AI			2 wire	IS	HY1-RIO-001	TB-AI	65	66	1	3	BAI-017	7	8	S3	1	2	SFO-DCS-005	SFO-CTRL5					
TT-1319	TT1319	HY1-TT1319	HY1-TT1319	Temperature Transmitter & Indicator	RTD	AI			2 wire	IS	HY1-RIO-001	TB-AI	67	68	4	6		10	11	S3	2	3	SFO-DCS-005	SFO-CTRL5					
TT-1312	TT1312	HY1-TT1312	HY1-TT1312	Temperature Transmitter & Indicator	RTD	AI			2 wire	IS	HY1-RIO-001	TB-AI	69	70	1	3	BAI-018	7	8	S3	3	5	SFO-DCS-005	SFO-CTRL5					
TT-1287	TT1287	HY1-TT1287	HY1-TT1287	Temperature Transmitter & Indicator	RTD	AI			2 wire	IS	HY1-RIO-001	TB-AI	71	72	4	6		10	11	S3	4	7	SFO-DCS-005	SFO-CTRL5					
TT-1280	TT1280	HY1-TT1280	HY1-TT1280	Temperature Transmitter & Indicator	RTD	AI			2 wire	IS	HY1-RIO-001	TB-AI	73	74	1	3	BAI-019	7	8	S3	5	9	SFO-DCS-005	SFO-CTRL5					
TT-1123	TT1123	HY1-TT1123	HY1-TT1123	Temperature Transmitter & Indicator	RTD	AI			2 wire	IS	HY1-RIO-001	TB-AI	75	76	4	6		10	11	S3	6	11	SFO-DCS-005	SFO-CTRL5					
FT-1165	FT1165	HY1-FT1167	HY1-FT1165	Hydrogent	Vortex Flowmeter	AI			2 wire	IS	HY1-RIO-001	TB-AI	77	78	1	3	BAI-020	7	8	S3	7	13	SFO-DCS-005	SFO-CTRL5					
FT-1167	FT1167	HY1-FT1167	HY1-FT1167	Hydrogent	Vortex Flowmeter	AI			2 wire	IS	HY1-RIO-001	TB-AI	79	80	4	6		10	11	S3	8	15	SFO-DCS-005	SFO-CTRL5					
PT-2-1316C1	PT1316C1	HY1-PT1316C1	HY1-PT1316C1	Olein	Gauge	AI	0-6 barg	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	81	82	1	3	BAI-021	7	8	S3	9	17	SFO-DCS-005	SFO-CTRL5					
PT-2-1316C2	PT1316C2	HY1-PT1316C2	HY1-PT1316C2	Olein	Gauge	AI	0-20 barg	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	83	84	4	6		10	11	S3	10	19	SFO-DCS-005	SFO-CTRL5					
PT-2-MP	PT131MP	HY1-PT131MP	HY1-PT131MP	Olein	Gauge	AI	0-20 barg	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	85	86	1	3	BAI-022	7	8	S3	11	21	SFO-DCS-005	SFO-CTRL5					
PT-1166	PT1166	HY1-PT1166	HY1-PT1166	Pressure transmitter for Hydrogent Gas Supply	Gauge	AI		4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	87	88	4	6		10	11	S3	12	23	SFO-DCS-005	SFO-CTRL5					
PT-1167	PT1167	HY1-PT1167	HY1-PT1167	Pressure transmitter for Hydrogent Gas Supply	Gauge	AI		4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	89	90	1	3	BAI-023	7	8	S3	13	25	SFO-DCS-005	SFO-CTRL5					
TT-1166	TT1166	HY1-PT1166	HY1-PT1166	Temperature transmitter for Hydrogent Gas Supply	RTD	AI		4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	91	92	4	6		10	11	S3	14	27	SFO-DCS-005	SFO-CTRL5					
TT-1167	TT1167	HY1-PT1167	HY1-PT1167	Temperature transmitter for Hydrogent Gas Supply	RTD	AI		4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AI	93	94	1	3	BAI-024	7	8	S3	15	29	SFO-DCS-005	SFO-CTRL5					
FCV-2-P1378TW	FCV1078TW	HY1-FCV1078TW	HY1-FCV1078TW	Air	AO	0 - 100 DegC			2 wire	IS	HY1-RIO-001	TB-AO	1	2	1	2	BAI-001	8	7	S4	1	2	SFO-DCS-005	SFO-CTRL5					
TCV-2-1381B	TCV1381B	HY1-TCV1381B	HY1-TCV1381B	Control Valve	Electro-pneumatic	AO	0-100%	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AO	3	4	1	2	BAI-002	8	7	S4	2	3	SFO-DCS-005	SFO-CTRL5					
FCV-2-P1382B	FCV1028B	HY1-FCV1028B	HY1-FCV1028B	Control Valve	Electro-pneumatic	AO	0-100%	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AO	5	6	1	2	BAI-003	8	7	S4	3	5	SFO-DCS-005	SFO-CTRL5					
PCV-2-1303-H	PCV1203H	HY1-PCV1203H	HY1-PCV1203H	Control Valve	Electro-pneumatic	AO	0-100%	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AO	7	8	1	2	BAI-004	8	7	S4	4	7	SFO-DCS-005	SFO-CTRL5					
TCV-2-1381A	TCV1281A	HY1-TCV1281A	HY1-TCV1281A	Control Valve	Electro-pneumatic	AO	0-100%	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AO	9	10	1	2	BAI-005	8	7	S4	5	9	SFO-DCS-005	SFO-CTRL5					
FCV-2-P1301	FCV1001	HY1-FCV1001	HY1-FCV1001	Control Valve	Electro-pneumatic	AO	0-100%	4-20 mA HART	2 wire	IS	HY1-RIO-001	TB-AO	11	12	1	2	BAI-006	8	7	S4	6	11	SFO-DCS-005	SFO-CTRL5					
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-001	TB-AO	13	14						S4	7	13	SFO-DCS-005	SFO-CTRL5					
XV-2-1316B-4	V1316B4-ZO	HY1-V1316B4-ZO	HY1-V1316B4	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	1	2	1	2	BDI-001	5	6	S1	1	1	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1316B-5	V1316B5-ZC	HY1-V1316B5-ZC	HY1-V1316B5	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	3	4				5	6	S1	2	3	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1316B-5	V1316B5-ZC	HY1-V1316B5-ZC	HY1-V1316B5	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	5	6	1	2	BDI-002	5	6	S1	2	3	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1316B-5	V1316B5-ZC	HY1-V1316B5-ZC	HY1-V1316B5	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	7	8	3	4		5	6	S1	4	4	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335A	V1135A-ZO	HY1-V1135A-ZO	HY1-V1135A	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	9	10	1	2	BDI-003	5	6	S1	5	5	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335A	V1135A-ZC	HY1-V1135A-ZC	HY1-V1135A	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	11	12	3	4		5	6	S1	6	6	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-P1335A-BN	V1135BN-ZO	HY1-V1135BN-ZO	HY1-V1235BN	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	13	14	1	2	BDI-004	5	6	S1	7	7	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-P1335A-BN	V1135BN-ZC	HY1-V1135BN-ZC	HY1-V1235BN	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	15	16	3	4		5	6	S1	8	8	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335A-D	V1135-ZO	HY1-V1135-ZO	HY1-V1135	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	17	18	1	2	BDI-005	5	6	S1	9	9	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335A-D	V1135-ZC	HY1-V1135-ZC	HY1-V1135	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	19	20	3	4		5	6	S1	10	10	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335A-S	V1135AS-ZO	HY1-V1135AS-ZO	HY1-V1135AS	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	21	22	1	2	BDI-006	5	6	S1	11	11	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335A-S	V1135AS-ZC	HY1-V1135AS-ZC	HY1-V1135AS	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	23	24	3	4		5	6	S1	12	12	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335B-D	V1135BD-ZO	HY1-V1135BD-ZO	HY1-V1135BD	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	25	26	1	2	BDI-007	5	6	S1	13	13	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335B-D	V1135BD-ZC	HY1-V1135BD-ZC	HY1-V1135BD	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	27	28	3	4		5	6	S1	14	14	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335B-F	V1135BF-ZO	HY1-V1135BF-ZO	HY1-V1135BF	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	29	30	1	2	BDI-008	5	6	S1	15	15	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335B-F	V1135BF-ZC	HY1-V1135BF-ZC	HY1-V1135BF	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	31	32	3	4		5	6	S1	16	16	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335B-S	V1135BS-ZO	HY1-V1135BS-ZO	HY1-V1135BS	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	33	34	1	2	BDI-009	5	6	S1	17	17	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1335B-S	V1135BS-ZC	HY1-V1135BS-ZC	HY1-V1135BS	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	35	36	3	4		5	6	S1	18	18	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1382B-D	V1282BD-ZO	HY1-V1282BD-ZO	HY1-V1282BD	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	37	38	1	2	BDI-010	5	6	S1	19	19	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1382B-D	V1282BD-ZC	HY1-V1282BD-ZC	HY1-V1282BD	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	39	40	3	4		5	6	S1	20	20	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1382C-D	V1282CD-ZO	HY1-V1282CD-ZO	HY1-V1282CD	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	41	42	1	2	BDI-011	5	6	S1	21	21	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-1382C-D	V1282CD-ZC	HY1-V1282CD-ZC	HY1-V1282CD	Actuator Valve	Valve close indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	43	44	3	4		5	6	S1	22	22	NA	SFO-DCS-005	SFO-CTRL5				
XV-2-P1335B-BN	V1135BBN-ZO	HY1-V1135BBN-ZO	HY1-V1135BBN	Actuator Valve	Valve open indication	DI			2 wire	IS	HY1-RIO-002	TB-DI	45	46	3	4	BDI-012	5	6	S1	23	23	NA	SFO-					

										RIO CABINET										DELTA V				SYSTEM CABINET	
Vendor's tags		Wilmar's Tags	Emerson's Database Tag	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Classification	Marshalling		Term. (+)	Term. (-)	IS BARRIER		Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
							DI					TB Name													
LSL-2-1316A	LSL1316A	HY1-LSL1316A	HY1-LSL1316A	Level Switch	Tuning Fork	DI			NAMUR	2 wire	IS	HY1-RIO-002	TB-DI	193	194	1	2								
LSS-2-1316B	LSL1316B	HY1-LSL1316B	HY1-LSL1316B	Level Switch	Tuning Fork	DI			NAMUR	2 wire	IS	HY1-RIO-002	TB-DI	195	196	3	4								
LSLL-2-1316A	LSLL1316A	HY1-LSL1316A	HY1-LSL1316A	Level Switch	Tuning Fork	DI			NAMUR	2 wire	IS	HY1-RIO-002	TB-DI	197	198	1	2								
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	199	200	3	4								
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	201	202										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	203	204										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	205	206										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	207	208										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	209	210										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	211	212										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	213	214										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	215	216										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	217	218										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	219	220										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	221	222										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	223	224										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	225	226										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	227	228										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	229	230										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	231	232										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	233	234										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	235	236										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	237	238										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	239	240										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	241	242										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	243	244										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	245	246										
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	HY1-RIO-002	TB-DI	247	248										
CR3-SERV-001-Tempel	CR3-SERV-001-Temp	CR3-SERV-001-Temperature alarm										HY1-RIO-002	TB-DI	249	250										
CR3-SERV-001-Humidit	CR3-SERV-001-Humidit	CR3-SERV-001-Humidity alarm										HY1-RIO-002	TB-DI	251	252										
CR3-NET-001-PSU11 a	CR3-NET-001-PSU11	CR3-NET-001-PSU11 alarm										HY1-RIO-002	TB-DI	253	254										
CR3-NET-001-PSU21 a	CR3-NET-001-PSU21	CR3-NET-001-PSU21 alarm										HY1-RIO-002	TB-DI	255	256										
XV-2-1316B-4	V1316B4-SY	HY1-V1316B4-SY	HY1_V1316B4	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	1	2	1	2							
XV-2-1316B-5	V1316B5-SY	HY1-V1316B5-SY	HY1_V1316B5	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	3	4	4	5							
XV-2-1335A	V1135A-SY	HY1-V1135A-SY	HY1_V1135A	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	5	6	1	2							
XV-2-1335A-BN	V1135BN-SY	HY1-V1135BN-SY	HY1_V1135BN	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	7	8	4	5							
XV-2-1335A-D	V1135-SY	HY1-V1135-SY	HY1_V1135	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	9	10	1	2							
XV-2-1335A-S	V1135AS-SY	HY1-V1135AS-SY	HY1_V1135AS	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	11	12	4	5							
XV-2-P135B-BN	V1135BBN-SY	HY1-V1135BBN-SY	HY1_V1135BBN	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	13	14	1	2							
XV-2-1335B-D	V1135BD-SY	HY1-V1135BD-SY	HY1_V1135BD	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	15	16	4	5							
XV-2-1335B-F	V1135BF-SY	HY1-V1135BF-SY	HY1_V1135BF	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	17	18	1	2							
XV-2-1335B-S	V1135BS-SY	HY1-V1135BS-SY	HY1_V1135BS	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	19	20	4	5							
XV-2-1382B-D	V1282BD-SY	HY1-V1282BD-SY	HY1_V1282BD	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	21	22	1	2							
XV-2-1382C-BN	V1282CBN-SY	HY1-V1282CBN-SY	HY1_V1282CBN	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	23	24	4	5							
XV-2-1382C-D	V1282CD-SY	HY1-V1282CD-SY	HY1_V1282CD	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	25	26	1	2							
XV-2-1382B-BN	V1282BBN-SY	HY1-V1282BBN-SY	HY1_V1282BBN	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	27	28	4	5							
XV-2-1382B-F1	V1282BF1-SY	HY1-V1282BF1-SY	HY1_V1282BF1	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	29	30	1	2							
XV-2-1378T-W	V131078TW-SY	HY1-V131078TW-SY	HY1_V131078TW	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	31	32	4	5							
XV-2-1303	V1203-SY	HY1-V1203-SY	HY1_V1203	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	33	34	1	2							
XV-2-1303-D	V1203D-SY	HY1-V1203D-SY	HY1_V1203D	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	35	36	4	5							
XV-2-1303-E	V1203E-SY	HY1-V1203E-SY	HY1_V1203E	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	37	38	1	2							
XV-2-1316A-1	V1316A1-SY	HY1-V1316A1-SY	HY1_V1316A1	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	39	40	4	5							
XV-2-1316A-2	V1316A2-SY	HY1-V1316A2-SY	HY1_V1316A2	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	41	42	1	2							
XV-2-1316A-3	V1316A3-SY	HY1-V1316A3-SY	HY1_V1316A3	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	43	44	4	5							
XV-2-1316A-4	V1316A4-SY	HY1-V1316A4-SY	HY1_V1316A4	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	45	46	1	2							
XV-2-1316A-6	V1316A6-SY	HY1-V1316A6-SY	HY1_V1316A6	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	47	48	4	5							
XV-2-1316A-9	V1316A9-SY	HY1-V1316A9-SY	HY1_V1316A9	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	49	50	1	2							
XV-2-1316A-10	V1316A10-SY	HY1-V1316A10-SY	HY1_V1316A10	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	51	52	4	5							
XV-2-P1316A-BN	VP1316ABN-SY	HY1-VP1316ABN-SY	HY1_VP1316ABN	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	53	54	1	2							
XV-2-1316A-V3A	V1316AV3A-SY	HY1-V1316AV3A-SY	HY1_V1316AV3A	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	55	56	4	5							
XV-2-1316A-V3B	V1316AV3B-SY	HY1-V1316AV3B-SY	HY1_V1316AV3B	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	57	58	1	2							
XV-2-1316A-V3C	V1316AV3C-SY	HY1-V1316AV3C-SY	HY1_V1316AV3C	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	59	60	4	5							
XV-2-1316A-Y	V1316AY-SY	HY1-V1316AY-SY	HY1_V1316AY	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	61	62	1	2							
XV-2-1316B-1	V1316B1-SY	HY1-V1316B1-SY	HY1_V1316B1	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	63	64	4	5							
XV-2-1316B-2	V1316B2-SY	HY1-V1316B2-SY	HY1_V1316B2	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-002	TB-DO	65	66	1	2							
XV-2-1316B-3	V1316B3-SY	HY1-V1316B3-SY	HY1_V1316B3	Actuator Valve	Valve open command	DO				2															

											RIO CABINET										SYSTEM CABINET							
Vendor's tags		Wilmar's Tags	Emerson's Database Tag	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Classification	Marshallng				IS BARRIER				DELTA V				DELTA V				
												Cabinet Name	TB Name	Term. (+)	Term. (-)	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller		
XV-2-1301-BN	V1001BN-ZC	HY1-V1001BN-ZC	HY1_V1001BN	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	57	58	1	2		BDI-015	5	6	S1	29	29	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1301-F	V1001F-ZO	HY1-V1001F-ZO	HY1_V1001F	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	59	60	3	4			7	8	S1	30	30	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1301-F	V1001F-ZC	HY1-V1001F-ZC	HY1_V1001F	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	61	62	1	2			5	6	S1	31	31	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316A-V3D	V136AV3D-ZO	HY1-V136AV3D-ZO	HY1_V136AV3D	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	63	64	3	4		BDI-016	5	6	S1	32	32	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316A-V3D	V136AV3D-ZC	HY1-V136AV3D-ZC	HY1_V136AV3D	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	65	66	1	2		BDI-017	5	6	S2	1	1	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316A-V3E	V1216AV3E-ZO	HY1-V1216AV3E-ZO	HY1_V1216AV3E	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	67	68	3	4			7	8	S2	2	2	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316A-V3E	V1216AV3E-ZC	HY1-V1216AV3E-ZC	HY1_V1216AV3E	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	69	70	1	2		BDI-018	5	6	S2	3	3	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316A-V3F	V1116AV3F-ZO	HY1-V1116AV3F-ZO	HY1_V1116AV3F	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	71	72	3	4			7	8	S2	4	4	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316A-V3F	V1116AV3F-ZC	HY1-V1116AV3F-ZC	HY1_V1116AV3F	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	73	74	1	2		BDI-019	5	6	S2	5	5	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316B-8	V1316B8-ZO	HY1-V1316B8-ZO	HY1_V1316B8	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	75	76	3	4			7	8	S2	6	6	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1316B-8	V1316B8-ZC	HY1-V1316B8-ZC	HY1_V1316B8	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	77	78	1	2		BDI-020	5	6	S2	7	7	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1382C-R	V1382CR-ZO	HY1-V1382CR-ZO	HY1_V1382CR	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	79	80	3	4			7	8	S2	8	8	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1382C-R	V1382CR-ZC	HY1-V1382CR-ZC	HY1_V1382CR	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	81	82	1	2		BDI-021	5	6	S2	9	9	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-P1382C-F3	V1282CF3-ZO	HY1-V1282CF3-ZO	HY1_V1282CF3	Actuator Valve	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	83	84	3	4			7	8	S2	10	10	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-P1382C-F3	V1282CF3-ZC	HY1-V1282CF3-ZC	HY1_V1282CF3	Actuator Valve	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	85	86	1	2		BDI-022	5	6	S2	11	11	NA	SFO-DCS-005	SFO-CTRL5	
LS-905	LSL905	HY1-LSL905	HY1_LSL905	Effluent		DI						HY1-RIO-003	TB-DI	87	88	3	4			7	8	S2	12	12	NA	SFO-DCS-005	SFO-CTRL5	
LS-607	LSL607	HY1-LSL607	HY1_LSL607	Effluent		DI						HY1-RIO-003	TB-DI	89	90	1	2		BDI-023	5	6	S2	13	13	NA	SFO-DCS-005	SFO-CTRL5	
LSL-2-1382C	HY1-LSL1282C	HY1-LSL1282C	HY1_LSL1282C	Level Switch	Tuning Fork				NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	91	92	3	4			7	8	S2	14	14	NA	SFO-DCS-005	SFO-CTRL5	
PS-2-1301-1	PSH1011	HY1-PSH1011	HY1_PSH1011	Pressure Switches	Switching	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	93	94	1	2		BDI-024	5	6	S2	15	15	NA	SFO-DCS-005	SFO-CTRL5	
FS-1319	FSL1319	HY1-FSL1319	HY1_FSL1319	Flow Switch		DI						HY1-RIO-003	TB-DI	95	96	3	4			5	6	S2	16	16	NA	SFO-DCS-005	SFO-CTRL5	
FS-1123	FSL1123	HY1-FSL1123	HY1_FSL1123	Flow Switch		DI						HY1-RIO-003	TB-DI	97	98	1	2		BDI-025	5	6	S2	17	17	NA	SFO-DCS-005	SFO-CTRL5	
LSLL-309	LSLL309	HY1-LSLL309	HY1_LSL309	Level Switch		DI						HY1-RIO-003	TB-DI	99	100	3	4			7	8	S2	18	18	NA	SFO-DCS-005	SFO-CTRL5	
LSLL-3013	LSLL3013	HY1-LSLL3013	HY1_LSL3013	Level Switch		DI						HY1-RIO-003	TB-DI	101	102	1	2		BDI-026	5	6	S2	19	19	NA	SFO-DCS-005	SFO-CTRL5	
LS-905	LSH905	HY1-LSH905	HY1_LSH905	Level Switch		DI						HY1-RIO-003	TB-DI	103	104	3	4			7	8	S2	20	20	NA	SFO-DCS-005	SFO-CTRL5	
LS-607	LSH607	HY1-LSH607	HY1_LSH607	Level Switch		DI						HY1-RIO-003	TB-DI	105	106	1	2		BDI-027	5	6	S2	21	21	NA	SFO-DCS-005	SFO-CTRL5	
PS-8018	PSL8018	HY1-PSL8018	HY1_PSL8018	Pressure Switches		DI						HY1-RIO-003	TB-DI	107	108	3	4			7	8	S2	22	22	NA	SFO-DCS-005	SFO-CTRL5	
PS-808	PSL808	HY1-PSL808	HY1_PSL808	Pressure Switches		DI						HY1-RIO-003	TB-DI	109	110	1	2		BDI-028	5	6	S2	23	23	NA	SFO-DCS-005	SFO-CTRL5	
PS-1105A	PSL1105A	HY1-PSL1105A	HY1_PSL1105A	Pressure Switches		DI						HY1-RIO-003	TB-DI	111	112	3	4			7	8	S2	24	24	NA	SFO-DCS-005	SFO-CTRL5	
PS-1105B	PSL1105B	HY1-PSL1105B	HY1_PSL1105B	Pressure Switches		DI						HY1-RIO-003	TB-DI	113	114	1	2		BDI-029	5	6	S2	25	25	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1303V2	V2203V2-ZO	HY1-V2203V2-ZO	HY1_V2203V2	OLEIN	Valve open indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	115	116	3	4			7	8	S2	26	26	NA	SFO-DCS-005	SFO-CTRL5	
XV-2-1303V2	V2203V2-ZC	HY1-V2203V2-ZC	HY1_V2203V2	OLEIN	Valve close indication	DI			NAMUR	2 wire	IS	HY1-RIO-003	TB-DI	117	118	1	2		BDI-030	5	6	S2	27	27	NA	SFO-DCS-005	SFO-CTRL5	
Spare	Spare	Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare	HY1-RIO-003	TB-DI	119	120	3	4			7	8	S2	28	28	NA	SFO-DCS-005	SFO-CTRL5	
Spare	Spare	Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare	HY1-RIO-003	TB-DI	121	122						S2	29	29	NA	SFO-DCS-005	SFO-CTRL5		
Spare	Spare	Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare	HY1-RIO-003	TB-DI	123	124						S2	30	30	NA	SFO-DCS-005	SFO-CTRL5		
Spare	Spare	Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare	HY1-RIO-003	TB-DI	125	126						S2	31	31	NA	SFO-DCS-005	SFO-CTRL5		
Spare	Spare	Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare	HY1-RIO-003	TB-DI	127	128						S2	32	32	NA	SFO-DCS-005	SFO-CTRL5		
XV-2-1303-F	V1203F-SY	HY1-V1203F-SY	HY1_V1203F	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-003	TB-DO	1	2	1	2		BDI-001	7	8	S5	1	1	NA	SFO-DCS-005	SFO-CTRL5
XV-2-1303-H	V1203H-SY	HY1-V1203H-SY	HY1_V1203H	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-003	TB-DO	3	4	4	5			9	8	S5	2	2	NA	SFO-DCS-005	SFO-CTRL5
XV-2-1303-S	V1203S-SY	HY1-V1203S-SY	HY1_V1203S	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-003	TB-DO	5	6	1	2		BDI-002	7	8	S5	3	3	NA	SFO-DCS-005	SFO-CTRL5
XV-2-1303-WR	V1203WR-SY	HY1-V1203WR-SY	HY1_V1203WR	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-003	TB-DO	7	8	4	5			9	8	S5	4	4	NA	SFO-DCS-005	SFO-CTRL5
XV-2-1303-WV	V1203WV-SY	HY1-V1203WV-SY	HY1_V1203WV	Actuator Valve	Valve open command	DO				24VDC Wet Supply	2 wire	IS	HY1-RIO-003	TB-DO	9	10	1	2		BDI-003	7	8	S5	5	5	NA	SFO-DCS-005	