

IO List – Refinery #2

Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00034

Document Status: For Final

Authorisations

	Name	Function	Signature
Developed By:	Zul Hasyidi Hassan	Project Engineer	ZHH 
Reviewed By:	Liow Kok Loong	Lead Engineer	LKL 
Released By:	Mohd. Nazim Ismail	Project Manager	MNI 

Distribution

Name	Company	Name	Company

Revision History

Rev	Status	Description	Date	Developed By	Reviewed By
A	For Review	Issued for Review	18-Sep-18	ZHH	LKL
B	For Review	Issued for Review	11-Oct-18	ZHH	LKL
0	For Final	Issued for Final	4-Nov-19	ZHH	LKL

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

Emerson Automation Solution Process System and Solutions

No. 1, Block A, Jalan SS13/5, SS13
Subang Jaya, 47500, Selangor
Malaysia
T +60 (3) 5624-2888
F +60 (3) 5638-1010
www.EmersonProcess.com

										RIO CABINET										SYSTEM CABINET						
										MARSHALLING										DELTA V						
Vendor's tags	Wilmar Tag	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
MT504AC1	MX2004AC-CU	RF2-MX2004AC-CU	RF2_MX2004AC	Acid Mixer	Motor current feedback	AI		4-20 mA	2 wire	RF2-RMCC	1 TB-AI	1	2								S1	1	1	2	REF-DCS-003	REF-CTRL3_1
P641X	PU2641X-CU	RF2-PU2641X-CU	RF2_PU2641X	Vacuum Pump	Motor current feedback	AI		4-20 mA	2 wire	RF2-RMCC	1 TB-AI	3	4								S1	2	3	4	REF-DCS-003	REF-CTRL3_1
P802	PU2702-CU	RF2-PU2702-CU	RF2_PU2702	Deaerator Transfer Pump	Motor current feedback	AI		4-20 mA	2 wire	RF2-RMCC	1 TB-AI	5	6								S1	3	5	6	REF-DCS-003	REF-CTRL3_1
P814AG	PU2714AG-CU	RF2-PU2714AG-CU	RF2_PU2714AG	Fatty Acids Circulating Pump	Motor current feedback	AI		4-20 mA	2 wire	RF2-RMCC	1 TB-AI	7	8								S1	4	7	8	REF-DCS-003	REF-CTRL3_1
P822-1	PU27221-CU	RF2-PU27221-CU	RF2_PU27221	Deodorizer Oil Pump	Motor current feedback	AI		4-20 mA	2 wire	RF2-RMCC	1 TB-AI	9	10								S1	5	9	10	REF-DCS-003	REF-CTRL3_1
P822-2	PU27222-CU	RF2-PU27222-CU	RF2_PU27222	Deodorizer Oil Pump	Motor current feedback	AI		4-20 mA	2 wire	RF2-RMCC	1 TB-AI	11	12								S1	6	11	12	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	13	14								S1	7	13	14	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	15	16								S1	8	15	16	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	17	18								S1	9	17	18	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	19	20								S1	10	19	20	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	21	22								S1	11	21	22	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	23	24								S1	12	23	24	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	25	26								S1	13	25	26	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	27	28								S1	14	27	28	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	29	30								S1	15	29	30	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RMCC	1 TB-AI	31	32								S1	16	31	32	REF-DCS-003	REF-CTRL3_1
890HP	PU2990HP-XL	RF2-PU2990HP-XL	RF2_PU2990HP	Boiler	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	1	2								S2	1	1	#NA	REF-DCS-003	REF-CTRL3_1
890HP	PU2990HP-XA	RF2-PU2990HP-XA	RF2_PU2990HP	Boiler	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	3	4								S2	2	2	#NA	REF-DCS-003	REF-CTRL3_1
M604C	AG2604C-XL	RF2-AG2604C-XL	RF2_AG2604C	Agitator for 604C	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	5	6								S2	3	3	#NA	REF-DCS-003	REF-CTRL3_1
M604C	AG2604C-XA	RF2-AG2604C-XA	RF2_AG2604C	Agitator for 604C	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	7	8								S2	4	4	#NA	REF-DCS-003	REF-CTRL3_1
M834CA	AG2734CA-XL	RF2-AG2734CA-XL	RF2_AG2734CA	Agitator for T834CA	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	9	10								S2	5	5	#NA	REF-DCS-003	REF-CTRL3_1
M834CA	AG2734CA-XA	RF2-AG2734CA-XA	RF2_AG2734CA	Agitator for T834CA	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	11	12								S2	6	6	#NA	REF-DCS-003	REF-CTRL3_1
MT503-A	AG2003A-XL	RF2-AG2003A-XL	RF2_AG2003A	Agitator for T503	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	13	14								S2	7	7	#NA	REF-DCS-003	REF-CTRL3_1
MT503-A	AG2003A-XA	RF2-AG2003A-XA	RF2_AG2003A	Agitator for T503	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	15	16								S2	8	8	#NA	REF-DCS-003	REF-CTRL3_1
MT504AC1	MX2004AC-XL	RF2-MX2004AC-XL	RF2_MX2004AC	Acid Mixer	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	17	18								S2	9	9	#NA	REF-DCS-003	REF-CTRL3_1
MT504AC1	MX2004AC-XA	RF2-MX2004AC-XA	RF2_MX2004AC	Acid Mixer	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	19	20								S2	10	10	#NA	REF-DCS-003	REF-CTRL3_1
MT534CA	AG2034CA-XL	RF2-AG2034CA-XL	RF2_AG2034CA	Agitator for T534CA	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	21	22								S2	11	11	#NA	REF-DCS-003	REF-CTRL3_1
MT534CA	AG2034CA-XA	RF2-AG2034CA-XA	RF2_AG2034CA	Agitator for T534CA	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	23	24								S2	12	12	#NA	REF-DCS-003	REF-CTRL3_1
MV610B	RL2610B-XL	RF2-RL2610B-XL	RF2_RL2610B	Rotary Valve(Blower)	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	25	26								S2	13	13	#NA	REF-DCS-003	REF-CTRL3_1
MV610B	RL2610B-XA	RF2-RL2610B-XA	RF2_RL2610B	Rotary Valve(Blower)	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	27	28								S2	14	14	#NA	REF-DCS-003	REF-CTRL3_1
MV610C	RL2610C-XL	RF2-RL2610C-XL	RF2_RL2610C	Rotary Valve(Blower)	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	29	30								S2	15	15	#NA	REF-DCS-003	REF-CTRL3_1
MV610C	RL2610C-XA	RF2-RL2610C-XA	RF2_RL2610C	Rotary Valve(Blower)	Motor trip feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	31	32								S2	16	16	#NA	REF-DCS-003	REF-CTRL3_1
P534NA	PU2034NA-XL	RF2-PU2034NA-XL	RF2_PU2034NA	Motor run feedback	DI			DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	33	34								S2	17	17	#NA	REF-DCS-003	REF-CTRL3_1
P534NA	PU2034NA-XA	RF2-PU2034NA-XA	RF2_PU2034NA	Motor trip feedback	DI			DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	35	36								S2	18	18	#NA	REF-DCS-003	REF-CTRL3_1
P578HW	PU2978HW-XL	RF2-PU2978HW-XL	RF2_PU2978HW	Recovered Oil Pump	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	37	38								S2	19	19	#NA	REF-DCS-003	REF-CTRL3_1
P578HW	PU2978HW-XA	RF2-PU2978HW-XA	RF2_PU2978HW	Motor trip feedback	DI			DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	39	40								S2	20	20	#NA	REF-DCS-003	REF-CTRL3_1
P604C	PU2604C-XL	RF2-PU2604C-XL	RF2_PU2604C	Filter Aid Pump	Motor run feedback	DI		DI Dry Contact	2 wire	RF2-RMCC	1 TB-DI	41	42								S2	21	21	#NA	REF-DCS-003	REF-CTRL3_1
P604C	PU2604C-XA	RF2-PU2604C-XA	RF2_PU2604C	Filter Aid Pump	Motor trip feedback	DI</																				

											RIO CABINET										SYSTEM CABINET						
											MARSHALLING										DELTA V						
Vendor's tags	Wilmar Tag	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection		Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
P822C2	PU2722C2-HS	RF2-PU2722C2-HS	RF2_PU2722C2	Deodorizer Oil Transfer Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	39	40								S6	20	20	#NA	REF-DCS-003	REF-CTRL3_1
P822-1	PU27221-HS	RF2-PU27221-HS	RF2_PU27221	Deodorizer Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	41	42								S6	21	21	#NA	REF-DCS-003	REF-CTRL3_1
P822-2	PU27222-HS	RF2-PU27222-HS	RF2_PU27222	Deodorizer Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	43	44								S6	22	22	#NA	REF-DCS-003	REF-CTRL3_1
M834CA	AG2734CA-HS	RF2-AG2734CA-HS	RF2_PU2734CA	Agitator for T834CA	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	45	46								S6	23	23	#NA	REF-DCS-003	REF-CTRL3_1
P841X	PU2741X-HS	RF2-PU2741X-HS	RF2_PU2741X	Vacuum Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	47	48								S6	24	24	#NA	REF-DCS-003	REF-CTRL3_1
890HP	PU2990HP-HS	RF2-PU2990HP-HS	RF2_PU2990HP	Boiler	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	49	50								S6	25	25	#NA	REF-DCS-003	REF-CTRL3_1
PU-901B	PU901B -HS	RF2-PU901B -HS	RF2_PU901B	Effluent Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	51	52								S6	26	26	#NA	REF-DCS-003	REF-CTRL3_1
PU-601B	PU601B-HS	RF2-PU601B-HS	RF2_PU601B	Condensate Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	53	54								S6	27	27	#NA	REF-DCS-003	REF-CTRL3_1
PU-2023B	PU2023B-HS	RF2-PU2023B-HS	RF2_PU2023B	Caustic Soda Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	55	56								S6	28	28	#NA	REF-DCS-003	REF-CTRL3_1
PU-2025B	PU2025B-HS	RF2-PU2025B-HS	RF2_PU2025B	Citric Acid Mna Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	57	58								S6	29	29	#NA	REF-DCS-003	REF-CTRL3_1
PU-1801B	PU1801B-HS	RF2-PU1801B-HS	RF2_PU1801B	Chemical Distribution Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	59	60								S6	30	30	#NA	REF-DCS-003	REF-CTRL3_1
MV610B	RL2610B-HS	RF2-RL2610B-HS	RF2_RL2610B	Rotary Valve(Blower)	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	61	62								S6	31	31	#NA	REF-DCS-003	REF-CTRL3_1
MV610C	RL2610C-HS	RF2-RL2610C-HS	RF2_RL2610C	Rotary Valve(Blower)	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	63	64								S6	32	32	#NA	REF-DCS-003	REF-CTRL3_1
PU-601B	PU601B-HS	RF2-PU601B-HS	RF2_PU601B	CONDENSATE PUMP	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	65	66								S7	1	1	#NA	REF-DCS-003	REF-CTRL3_1
P534NA	PU2034NA-HS	RF2-PU2034NA-HS	RF2_PU2034NA		Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	67	68								S7	2	2	#NA	REF-DCS-003	REF-CTRL3_1
P578HW	PU2978HW-HS	RF2-PU2978HW-HS	RF2_PU2978HW		Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	69	70								S7	3	3	#NA	REF-DCS-003	REF-CTRL3_1
P609A	BW2609A-HS	RF2-BW2609A-HS	RF2_BW2609A	Blower for 609A	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	71	72								S7	4	4	#NA	REF-DCS-003	REF-CTRL3_1
PE09B	BW2609B-HS	RF2-BW2609B-HS	RF2_BW2609B	Blower for 609B	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	73	74								S7	5	5	#NA	REF-DCS-003	REF-CTRL3_1
PU-1901C	PU1901C-HS	RF2-PU1901C-HS	RF2_PU1901C	Mna Fuel Distribution Pump	Motor start command	DO		24VDC Wet supply	2 wire		RF2-RMCC_1	TB-DO	75	76								S7	6	6	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	77	78								S7	7	7	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	79	80								S7	8	8	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	81	82								S7	9	9	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	83	84								S7	10	10	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	85	86								S7	11	11	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	87	88								S7	12	12	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	89	90								S7	13	13	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	91	92								S7	14	14	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	93	94								S7	15	15	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	95	96								S7	16	16	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	97	98								S7	17	17	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	99	100								S7	18	18	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	101	102								S7	19	19	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	103	104								S7	20	20	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	105	106								S7	21	21	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	107	108								S7	22	22	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	109	110								S7	23	23	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	111	112								S7	24	24	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare		Spare	Spare	Spare	Spare	Spare		RF2-RMCC_1	TB-DO	113	114								S7					

Emerson Automation Solution - Confidential and Proprietary

										RIO CABINET														SYSTEM CABINET			
										RIO CABINET														DELTA V			
Vendor's tags	Wilmar Tag	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller	
XV-2-822QE2-F	V2722QEC-ZC	RF2-V2722QEC-ZC	RF2_V2722QEC	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	211	212								S4	10	10	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-P822A6-D	V2722A6B-ZG	RF2-V2722A6B-ZG	RF2_V2722A6B	Valve-open-indication	DI			NP/NPN	2-wire	RF2-RIO-002	TB-DI	213	214								S4	11	11	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-P822A6B-D	V2722A6B-ZC	RF2-V2722A6B-ZC	RF2_V2722A6B	Valve-close-indication	DI			NP/NPN	2-wire	RF2-RIO-002	TB-DI	215	216								S4	12	12	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A1-D1	V2780A1A-ZO	RF2-V2780A1A-ZO	RF2_V2780A1A	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	217	218								S4	13	13	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A1-D1	V2780A1A-ZC	RF2-V2780A1A-ZC	RF2_V2780A1A	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	219	220								S4	14	14	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A1-D2	V2780A1B-ZO	RF2-V2780A1B-ZO	RF2_V2780A1B	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	221	222								S4	15	15	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A1-D2	V2780A1B-ZC	RF2-V2780A1B-ZC	RF2_V2780A1B	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	223	224								S4	16	16	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T534CA-F	V2034CAF-ZO	RF2-V2034CAF-ZO	RF2_V2034CAF	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	225	226								S4	17	17	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T534CA-F	V2034CAF-ZC	RF2-V2034CAF-ZC	RF2_V2034CAF	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	227	228								S4	18	18	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T534PA-F	V2034PAF-ZO	RF2-V2034PAF-ZO	RF2_V2034PAF	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	229	230								S4	19	19	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T534PA-F	V2034PAF-ZC	RF2-V2034PAF-ZC	RF2_V2034PAF	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	231	232								S4	20	20	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-822QE2-BY	V2722QED-ZO	RF2-V2722QED-ZO	RF2_V2722QED	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	233	234								S4	21	21	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-822QE2-BY	V2722QED-ZC	RF2-V2722QED-ZC	RF2_V2722QED	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	235	236								S4	22	22	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A2-D1	V2780A2A-ZO	RF2-V2780A2A-ZO	RF2_V2780A2A	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	237	238								S4	23	23	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A2-D1	V2780A2A-ZC	RF2-V2780A2A-ZC	RF2_V2780A2A	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	239	240								S4	24	24	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A2-D2	V2780A2B-ZO	RF2-V2780A2B-ZO	RF2_V2780A2B	Valve open indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	241	242								S4	25	25	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-880A2-D2	V2780A2B-ZC	RF2-V2780A2B-ZC	RF2_V2780A2B	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	243	244								S4	26	26	#NA	REF-DCS-003	REF-CTRL3_1	
LSH-2-610A	LSH2610A	RF2-LSH2610A	RF2_LSH2610A	Paddle	DI			OI Dry contact	2 wire supply+2 wire dry contact	RF2-RIO-002	TB-DI	245	246	+3	-3						S4	27	27	#NA	REF-DCS-003	REF-CTRL3_1	
LSL-2-610A	LSL2610A	RF2-LSL2610A	RF2_LSL2610A	Paddle	DI			OI Dry contact	2 wire supply+2 wire dry contact	RF2-RIO-002	TB-DI	247	248	+4	-4						S4	28	28	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-604C-D	V2604CD-ZO	RF2-V2604CD-ZO	RF2_V2604CD	Valve open indication	DI	0-4 mm		NP/NPN	2 wire	RF2-RIO-002	TB-DI	249	250								S4	29	29	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-604C-D	V2604CD-ZC	RF2-V2604CD-ZC	RF2_V2604CD	Valve close indication	DI			NP/NPN	2 wire	RF2-RIO-002	TB-DI	251	252								S4	30	30	#NA	REF-DCS-003	REF-CTRL3_1	
LSLL-2025	LSLL2025	RF1-LSLL2025	RF1_LSLL2025	Tuning Fork	DI					RF2-RIO-002	TB-DI	253	254								S4	31	31	#NA	REF-DCS-003	REF-CTRL3_1	
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-002	TB-DI	255	256								S4	32	32	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T506-B	V2006B-SY	RF2-V2006B-SY	RF2_V2006B	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	1	2			14	11	RDO1-01	A1	A2 (comm)	S6	1	1	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T506-D	V2006D-SY	RF2-V2006D-SY	RF2_V2006D	24VDC Wet supply	DO			2 wire		RF2-RIO-002	TB-DO	3	4			14	11	RDO1-02	A1	A2	S6	2	2	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T524-F	V2024F-SY	RF2-V2024F-SY	RF2_V2024F	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	5	6			14	11	RDO1-03	A1	A2	S6	3	3	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-T524-B	V2024B-SY	RF2-V2024B-SY	RF2_V2024B	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	7	8			14	11	RDO1-04	A1	A2	S6	4	4	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-622721-BS	V2622A-SY	RF2-V2622A-SY	RF2_V2622A	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	9	10			14	11	RDO1-05	A1	A2	S6	5	5	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-682A-B	V2682AB-SY	RF2-V2682AB-SY	RF2_V2682AB	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	11	12			14	11	RDO1-06	A1	A2	S6	6	6	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-682A-D	V2682AD-SY	RF2-V2682AD-SY	RF2_V2682AD	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	13	14			14	11	RDO1-07	A1	A2	S6	7	7	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-682A-D1	V2682AD1-SY	RF2-V2682AD1-SY	RF2_V2682AD1	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	15	16			14	11	RDO1-08	A1	A2	S6	8	8	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-682A-D2	V2682AD2-SY	RF2-V2682AD2-SY	RF2_V2682AD2	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	17	18			14	11	RDO1-09	A1	A2	S6	9	9	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-682B-BY	V2682BBY-SY	RF2-V2682BBY-SY	RF2_V2682BBY	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	19	20			14	11	RDO1-10	A1	A2	S6	10	10	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-P682B-D	V2692BD-SY	RF2-V2692BD-SY	RF2_V2692BD	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO	21	22			14	11	RDO1-11	A1	A2	S6	11	11	#NA	REF-DCS-003	REF-CTRL3_1	
XV-2-4S1	V264S1-SY	RF2-V264S1-SY	RF2_V264S1	Valve open command	DO			24VDC Wet supply	2 wire	RF2-RIO-002	TB-DO</																

											RIO CABINET											SYSTEM CABINET					
											MARSHALLING											DELTA V					
Vendor's tags	Wilmar Tag	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection		Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
XV-2-616A2-11	V2616A2K-ZC	RF2-V2616A2K-ZC	RF2_V2616A2K	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	89	90								S2	13	13	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A2-11	V2616A2K-ZC	RF2-V2616A2K-ZC	RF2_V2616A2K	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	91	92								S2	14	14	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-1A	V2616A3B-ZC	RF2-V2616A3B-ZC	RF2_V2616A3B	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	93	94								S2	15	15	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-1A	V2616A3B-ZC	RF2-V2616A3B-ZC	RF2_V2616A3B	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	95	96								S2	16	16	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-2	V2616A3C-ZC	RF2-V2616A3C-ZC	RF2_V2616A3C	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	97	98								S2	17	17	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-2	V2616A3C-ZC	RF2-V2616A3C-ZC	RF2_V2616A3C	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	99	100								S2	18	18	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-3	V2616A3D-ZC	RF2-V2616A3D-ZC	RF2_V2616A3D	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	101	102								S2	19	19	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-3	V2616A3D-ZC	RF2-V2616A3D-ZC	RF2_V2616A3D	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	103	104								S2	20	20	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-3A	V2616A3E-ZC	RF2-V2616A3E-ZC	RF2_V2616A3E	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	105	106								S2	21	21	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-3A	V2616A3E-ZC	RF2-V2616A3E-ZC	RF2_V2616A3E	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	107	108								S2	22	22	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-4	V2616A3F-ZC	RF2-V2616A3F-ZC	RF2_V2616A3F	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	109	110								S2	23	23	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-4	V2616A3F-ZC	RF2-V2616A3F-ZC	RF2_V2616A3F	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	111	112								S2	24	24	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-6	V2616A3G-ZC	RF2-V2616A3G-ZC	RF2_V2616A3G	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	113	114								S2	25	25	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-6	V2616A3G-ZC	RF2-V2616A3G-ZC	RF2_V2616A3G	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	115	116								S2	26	26	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-7	V2616A3H-ZC	RF2-V2616A3H-ZC	RF2_V2616A3H	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	117	118								S2	27	27	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-7	V2616A3H-ZC	RF2-V2616A3H-ZC	RF2_V2616A3H	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	119	120								S2	28	28	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-8	V2616A3I-ZC	RF2-V2616A3I-ZC	RF2_V2616A3I	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	121	122								S2	29	29	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-8	V2616A3I-ZC	RF2-V2616A3I-ZC	RF2_V2616A3I	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	123	124								S2	30	30	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-9	V2616A3J-ZC	RF2-V2616A3J-ZC	RF2_V2616A3J	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	125	126								S2	31	31	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-9	V2616A3J-ZC	RF2-V2616A3J-ZC	RF2_V2616A3J	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	127	128								S2	32	32	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-11	V2616A3K-ZC	RF2-V2616A3K-ZC	RF2_V2616A3K	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	129	130								S3	1	1	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3-11	V2616A3K-ZC	RF2-V2616A3K-ZC	RF2_V2616A3K	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	131	132								S3	2	2	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3/4-5	V2616A3N-ZC	RF2-V2616A3N-ZC	RF2_V2616A3N	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	133	134								S3	3	3	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A3/4-5	V2616A3N-ZC	RF2-V2616A3N-ZC	RF2_V2616A3N	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	135	136								S3	4	4	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-1A	V2616A4B-ZC	RF2-V2616A4B-ZC	RF2_V2616A4B	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	137	138								S3	5	5	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-1A	V2616A4B-ZC	RF2-V2616A4B-ZC	RF2_V2616A4B	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	139	140								S3	6	6	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-2	V2616A4C-ZC	RF2-V2616A4C-ZC	RF2_V2616A4C	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	141	142								S3	7	7	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-2	V2616A4C-ZC	RF2-V2616A4C-ZC	RF2_V2616A4C	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	143	144								S3	8	8	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-3	V2616A4D-ZC	RF2-V2616A4D-ZC	RF2_V2616A4D	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	145	146								S3	9	9	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-3	V2616A4D-ZC	RF2-V2616A4D-ZC	RF2_V2616A4D	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	147	148								S3	10	10	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-3A	V2616A4E-ZC	RF2-V2616A4E-ZC	RF2_V2616A4E	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	149	150								S3	11	11	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-3A	V2616A4E-ZC	RF2-V2616A4E-ZC	RF2_V2616A4E	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	151	152								S3	12	12	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-4	V2616A4F-ZC	RF2-V2616A4F-ZC	RF2_V2616A4F	Valve open indication	DI			NP/N/PNP	2 wire		RF2-RIO-003	TB-DI	153	154								S3	13	13	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-616A4-4	V2616A4F-ZC	RF2-V2616A4F-ZC	RF2_V2616A4F	Valve close indication	DI			NP/N/PNP	2 wire		RF2-RIO-003																

										RIO CABINET														SYSTEM CABINET		
										MARSHALLING														DELTA V		
Vendor's tags	Wilmar Tag	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
XV-2-604C-V	V2604CV-SY	RF2-V2604CV-SY	RF2_V2604CV	Valve open command	Valve	DO		24VDC Wet supply	2 wire	RF2-RIO-003	TB-DO	95	96			14	11	RDO1-48	A1	A2	S7	16	16	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-SS1	V265S1-SY	RF2-V265S1-SY	RF2_V265S1	Valve open command	Valve	DO		24VDC Wet Supply	2 wire	RF2-RIO-003	TB-DO	97	98			14	11	RDO1-49	A1	A2	S7	17	17	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-614C-B	V2714CB-SY	RF2-V2714CB-SY	RF2_V2714CB	Valve open command	Valve	DO		24VDC Wet Supply	2 wire	RF2-RIO-003	TB-DO	99	100			14	11	RDO1-50	A1	A2	S7	18	18	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	101	102			14	11	RDO1-51	A1	A2	S7	19	19	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	103	104			14	11	RDO1-52	A1	A2	S7	20	20	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	105	106			14	11	RDO1-53	A1	A2	S7	21	21	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	107	108			14	11	RDO1-54	A1	A2	S7	22	22	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	109	110			14	11	RDO1-55	A1	A2	S7	23	23	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	111	112			14	11	RDO1-56	A1	A2	S7	24	24	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	113	114			14	11	RDO1-57	A1	A2	S7	25	25	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	115	116			14	11	RDO1-58	A1	A2	S7	26	26	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	117	118			14	11	RDO1-59	A1	A2	S7	27	27	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	119	120			14	11	RDO1-60	A1	A2	S7	28	28	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	121	122			14	11	RDO1-61	A1	A2	S7	29	29	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	123	124			14	11	RDO1-62	A1	A2	S7	30	30	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	125	126			14	11	RDO1-63	A1	A2	S7	31	31	#NA	REF-DCS-003	REF-CTRL3_1
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-003	TB-DO	127	128			14	11	RDO1-64	A1	A2 (comm)	S7	32	32	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A1-D	V2606A1D-ZO	RF2-V2606A1D-ZO	RF2_V2606A1D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	1	2								S1	1	1	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A1-D	V2606A1D-ZC	RF2-V2606A1D-ZC	RF2_V2606A1D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	3	4								S1	2	2	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A2-D	V2606A2D-ZO	RF2-V2606A2D-ZO	RF2_V2606A2D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	5	6								S1	3	3	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A2-D	V2606A2D-ZC	RF2-V2606A2D-ZC	RF2_V2606A2D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	7	8								S1	4	4	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A3-D	V2606A3D-ZO	RF2-V2606A3D-ZO	RF2_V2606A3D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	9	10								S1	5	5	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A3-D	V2606A3D-ZC	RF2-V2606A3D-ZC	RF2_V2606A3D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	11	12								S1	6	6	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A4-D	V2606A4D-ZO	RF2-V2606A4D-ZO	RF2_V2606A4D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	13	14								S1	7	7	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A4-D	V2606A4D-ZC	RF2-V2606A4D-ZC	RF2_V2606A4D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	15	16								S1	8	8	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A5-D	V2606A5D-ZO	RF2-V2606A5D-ZO	RF2_V2606A5D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	17	18								S1	9	9	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A5-D	V2606A5D-ZC	RF2-V2606A5D-ZC	RF2_V2606A5D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	19	20								S1	10	10	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A6-D	V2606A6D-ZO	RF2-V2606A6D-ZO	RF2_V2606A6D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	21	22								S1	11	11	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A6-D	V2606A6D-ZC	RF2-V2606A6D-ZC	RF2_V2606A6D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	23	24								S1	12	12	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606B1-D	V2606B1D-ZO	RF2-V2606B1D-ZO	RF2_V2606B1D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	25	26								S1	13	13	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606B1-D	V2606B1D-ZC	RF2-V2606B1D-ZC	RF2_V2606B1D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	27	28								S1	14	14	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606B2-D	V2606B2D-ZO	RF2-V2606B2D-ZO	RF2_V2606B2D	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	29	30								S1	15	15	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606B2-D	V2606B2D-ZC	RF2-V2606B2D-ZC	RF2_V2606B2D	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	31	32								S1	16	16	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A1-F	V2606A1F-ZO	RF2-V2606A1F-ZO	RF2_V2606A1F	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	33	34								S1	17	17	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A1-F	V2606A1F-ZC	RF2-V2606A1F-ZC	RF2_V2606A1F	Valve close indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-004	TB-DI	35	36								S1	18	18	#NA	REF-DCS-003	REF-CTRL3_1
XV-2-606A2-F	V2606A2F-ZO	RF2-V2606A2F-ZO	RF2_V2606A2F	Valve open indication	Valve	DI		NP/N/PNP	2 wire	RF2-RIO-0																

										RIO CABINET										SYSTEM CABINET									
										MARSHALLING										DELTA V									
Vendor's tags	Wilmar Tag	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
XV-2-822A1-D	V2722A1D-ZC	RF2-V2722A1D-ZC	RF2_V2722A1D	Valve close indication	DI	DI		NP/NPN	2 wire	RF2-RIO-004	TB-DI	229	230													REF-DCS-003	REF-CTRL3_1		
LSH-2-616A3	LSH2616C	RF2-LSH2616C	RF2_LSH2616C	Tuning Fork	DI	DI		PNP	3 wire PNP	RF2-RIO-004	TB-DI	231	232	+		A1	A2	RD1-07	14	11	S4	19	20	#NA	REF-DCS-003	REF-CTRL3_1			
LSH-2-832A/B	LSH2732A	RF2-LSH2732A	RF2_LSH2732A	Tuning Fork	DI	DI		PNP	3 wire PNP	RF2-RIO-004	TB-DI	233	234	+		A1	A2(comm)	RD1-08	14	11(comm)	S4	21	21	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	235	236								S4	22	22	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	237	238								S4	23	23	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	239	240								S4	24	24	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	241	242								S4	25	25	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	243	244								S4	26	26	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	245	246								S4	27	27	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	247	248								S4	28	28	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	249	250								S4	29	29	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	251	252								S4	30	30	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	253	254								S4	31	31	#NA	REF-DCS-003	REF-CTRL3_1			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF2-RIO-004	TB-DI	255	256								S4	32	32	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A1-D	V2606A1D-SY	RF2-V2606A1D-SY	RF2_V2606A1D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	1	2			14	11	RDO1-01	A1	A2 (comm)	S6	1	1	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A2-D	V2606A2D-SY	RF2-V2606A2D-SY	RF2_V2606A2D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	3	4			14	11	RDO1-02	A1	A2	S6	2	2	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A3-D	V2606A3D-SY	RF2-V2606A3D-SY	RF2_V2606A3D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	5	6			14	11	RDO1-03	A1	A2	S6	3	3	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A4-D	V2606A4D-SY	RF2-V2606A4D-SY	RF2_V2606A4D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	7	8			14	11	RDO1-04	A1	A2	S6	4	4	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A5-D	V2606A5D-SY	RF2-V2606A5D-SY	RF2_V2606A5D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	9	10			14	11	RDO1-05	A1	A2	S6	5	5	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A6-D	V2606A6D-SY	RF2-V2606A6D-SY	RF2_V2606A6D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	11	12			14	11	RDO1-06	A1	A2	S6	6	6	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606B1-D	V2606B1D-SY	RF2-V2606B1D-SY	RF2_V2606B1D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	13	14			14	11	RDO1-07	A1	A2	S6	7	7	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606B2-D	V2606B2D-SY	RF2-V2606B2D-SY	RF2_V2606B2D	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	15	16			14	11	RDO1-08	A1	A2	S6	8	8	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A1-F	V2606A1F-SY	RF2-V2606A1F-SY	RF2_V2606A1F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	17	18			14	11	RDO1-09	A1	A2	S6	9	9	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A2-F	V2606A2F-SY	RF2-V2606A2F-SY	RF2_V2606A2F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	19	20			14	11	RDO1-10	A1	A2	S6	10	10	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A3-F	V2606A3F-SY	RF2-V2606A3F-SY	RF2_V2606A3F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	21	22			14	11	RDO1-11	A1	A2	S6	11	11	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A4-F	V2606A4F-SY	RF2-V2606A4F-SY	RF2_V2606A4F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	23	24			14	11	RDO1-12	A1	A2	S6	12	12	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A5-F	V2606A5F-SY	RF2-V2606A5F-SY	RF2_V2606A5F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	25	26			14	11	RDO1-13	A1	A2	S6	13	13	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606A6-F	V2606A6F-SY	RF2-V2606A6F-SY	RF2_V2606A6F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	27	28			14	11	RDO1-14	A1	A2	S6	14	14	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606B1-F	V2606B1F-SY	RF2-V2606B1F-SY	RF2_V2606B1F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	29	30			14	11	RDO1-15	A1	A2	S6	15	15	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-606B2-F	V2606B2F-SY	RF2-V2606B2F-SY	RF2_V2606B2F	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	31	32			14	11	RDO1-16	A1	A2	S6	16	16	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-616A1-10/1	V2616A1K-SY	RF2-V2616A1K-SY	RF2_V2616A1K	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	33	34			14	11	RDO1-17	A1	A2	S6	17	17	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-616A1-10/2	V2616A1L-SY	RF2-V2616A1L-SY	RF2_V2616A1L	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	35	36			14	11	RDO1-18	A1	A2	S6	18	18	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-616A2-10/1	V2616A2L-SY	RF2-V2616A2L-SY	RF2_V2616A2L	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	37	38			14	11	RDO1-19	A1	A2	S6	19	19	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-616A2-10/2	V2616A2M-SY	RF2-V2616A2M-SY	RF2_V2616A2M	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	39	40			14	11	RDO1-20	A1	A2	S6	20	20	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-616A3-10/1	V2616A3L-SY	RF2-V2616A3L-SY	RF2_V2616A3L	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	41	42			14	11	RDO1-21	A1	A2	S6	21	21	#NA	REF-DCS-003	REF-CTRL3_1			
XV-2-616A3-10/2	V2616A3M-SY	RF2-V2616A3M-SY	RF2_V2616A3M	Valve open command	DO	DO		24VDC Wet supply	2 wire	RF2-RIO-004	TB-DO	43	44			14	11	RDO1-22	A1	A2	S6	22							