

IO List – Refinery #1

Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00033

Document Status: For Final

Authorisations

	Name	Function	Signature
Developed By:	Zul Hasyidi Hassan	Project Engineer	ZHH 
Reviewed By:	Liow Kok Loong	Lead Engineer	LKL 
Released By:	Mohd. Nazim Ismail	Project Manager	MNI 

Distribution

Name	Company	Name	Company

Revision History

Rev	Status	Description	Date	Developed By	Reviewed By
A	For Review	Issued for Review	18-Sep-18	ZHH	LKL
B	For Review	Issued for Review	11-Oct-18	ZHH	LKL
0	For Final	Issued for Final	4-Nov-19	ZHH	LKL

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

Emerson Automation Solution
Process System and Solutions
No. 1, Block A, Jalan SS13/5, SS13
Subang Jaya, 47500, Selangor
Malaysia
T +60 (3) 5624-2888
F +60 (3) 5638-1010
www.EmersonProcess.com

										RIO CABINET														SYSTEM CABINET				
										Marshalling				Relay				DELTA V				DELTA V						
Vendor's tags	Wilmar's Tags	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller		
M504-A	MX1004A-XA	RF1-MX1004A-CU	RF1-MX1004A	Acid Mixer	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	1	2								S1	1	2			REF-DCS-002	REF-CTRL2	
MT504AC1	MX1004AC-CU	RF1-MX1004AC-CU	RF1-MX1004AC	Acid Mixer	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	3	4								S1	2	3	4		REF-DCS-002	REF-CTRL2	
P641X1	VP1641X1-CU	RF1-VP1641X1-CU	RF1-VP1641X1	Vacuum Pump	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	5	6								S1	3	5	6		REF-DCS-002	REF-CTRL2	
P641X2	VP1641X2-CU	RF1-VP1641X2-CU	RF1-VP1641X2	Vacuum Pump	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	7	8								S1	4	7	8		REF-DCS-002	REF-CTRL2	
P802	PU1702-CU	RF1-PU1702-CU	RF1-PU1702	Deaerator Circulating Pump	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	9	10								S1	5	9	10		REF-DCS-002	REF-CTRL2	
P814AG	PU1714AG-CU	RF1-PU1714AG-CU	RF1-PU1714AG	Fatty Acids Circulating Pump	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	11	12								S1	6	11	12		REF-DCS-002	REF-CTRL2	
P822-1	PU17221-CU	RF1-PU17221-CU	RF1-PU17221	Deodorizer Oil Pump	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	13	14								S1	7	13	14		REF-DCS-002	REF-CTRL2	
P822-2	PU17222-CU	RF1-PU17222-CU	RF1-PU17222	Deodorizer Oil Pump	Motor current feedback	AI		4-20 mA	2 wire	RF1-RMCC 1	TB-AI	15	16								S1	8	15	16		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	17	18								S1	9	17	18		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	19	20								S1	10	19	20		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	21	22								S1	11	21	22		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	23	24								S1	12	23	24		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	25	26								S1	13	25	26		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	27	28								S1	14	27	28		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	29	30								S1	15	29	30		REF-DCS-002	REF-CTRL2	
Spare	Spare	Spare	Spare	Spare	Spare	Spare			Spare	RF1-RMCC 1	TB-AI	31	32								S1	16	31	32		REF-DCS-002	REF-CTRL2	
M501	AG1001-XL	RF1-AG1001-XL	RF1-AG1001	Agitator for 501	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	1	2								S2	1	1			NA	REF-DCS-002	REF-CTRL2
M501	AG1001-XA	RF1-AG1001-XA	RF1-AG1001	Agitator for 501	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	3	4								S2	2	2			NA	REF-DCS-002	REF-CTRL2
P501-FAN	FN1001-XL	RF1-FN1001-XL	RF1-FN1001	Force cooling fan for P501	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	5	6								S2	3	3			NA	REF-DCS-002	REF-CTRL2
P501-FAN	FN1001-XA	RF1-FN1001-XA	RF1-FN1001	Force cooling fan for P501	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	7	8								S2	4	4			NA	REF-DCS-002	REF-CTRL2
M504-A	MX1004A-XL	RF1-MX1004A-XL	RF1-MX1004A	Acid Mixer	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	9	10								S2	5	5			NA	REF-DCS-002	REF-CTRL2
M504-A	MX1004A-XA	RF1-MX1004A-XA	RF1-MX1004A	Acid Mixer	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	11	12								S2	6	6			NA	REF-DCS-002	REF-CTRL2
P532C	PU1032C-XL	RF1-PU1032C-XL	RF1-PU1032C	Recovered Oil Pump	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	13	14								S2	7	7			NA	REF-DCS-002	REF-CTRL2
P532C	PU1032C-XA	RF1-PU1032C-XA	RF1-PU1032C	Recovered Oil Pump	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	15	16								S2	8	8			NA	REF-DCS-002	REF-CTRL2
M534CA	AG1034CA-XL	RF1-AG1034CA-XL	RF1-AG1034CA	Agitator for 534CA	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	17	18								S2	9	9			NA	REF-DCS-002	REF-CTRL2
M534CA	AG1034CA-XA	RF1-AG1034CA-XA	RF1-AG1034CA	Agitator for 534CA	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	19	20								S2	10	10			NA	REF-DCS-002	REF-CTRL2
P578HW	PU1078HW-XL	RF1-PU1078HW-XL	RF1-PU1078HW	Hot Water Dosing Pump	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	21	22								S2	11	11			NA	REF-DCS-002	REF-CTRL2
P578HW	PU1078HW-XA	RF1-PU1078HW-XA	RF1-PU1078HW	Hot Water Dosing Pump	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	23	24								S2	12	12			NA	REF-DCS-002	REF-CTRL2
P582W	PU1082W-XL	RF1-PU1082W-XL	RF1-PU1082W	Wash Water Pump	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	25	26								S2	13	13			NA	REF-DCS-002	REF-CTRL2
P582W	PU1082W-XA	RF1-PU1082W-XA	RF1-PU1082W	Wash Water Pump	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	27	28								S2	14	14			NA	REF-DCS-002	REF-CTRL2
S18	CF1018-XL	RF1-CF1018-XL	RF1-CF1018	Centrifugal separator	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	29	30								S2	15	15			NA	REF-DCS-002	REF-CTRL2
S18	CF1018-XA	RF1-CF1018-XA	RF1-CF1018	Centrifugal separator	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	31	32								S2	16	16			NA	REF-DCS-002	REF-CTRL2
PT506	PU1006-XL	RF1-PU1006-XL	RF1-PU1006	Vacuum Dryer Oil Pump	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	33	34								S2	17	17			NA	REF-DCS-002	REF-CTRL2
PT506	PU1006-XA	RF1-PU1006-XA	RF1-PU1006	Vacuum Dryer Oil Pump	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	35	36								S2	18	18			NA	REF-DCS-002	REF-CTRL2
MT504AC1	MX1004AC-XL	RF1-MX1004AC-XL	RF1-MX1004AC	Acid Mixer	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	37	38								S2	19	19			NA	REF-DCS-002	REF-CTRL2
MT504AC1	MX1004AC-XA	RF1-MX1004AC-XA	RF1-MX1004AC	Acid Mixer	Motor trip feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	39	40								S2	20	20			NA	REF-DCS-002	REF-CTRL2
MT503	AG1003-XL	RF1-AG1003-XL	RF1-AG1003	Agitator for T503	Motor run feedback	DI		DI Dry Contact	2 wire	RF1-RMCC 1	TB-DI	41	42															

										RIO CABINET										SYSTEM CABINET									
										Marshalling										Relay									
										DELTA V										DELTA V									
Vendor's tags	Wilmar's Tags	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	241	242								S5	25	25	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	243	244								S5	26	26	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	245	246								S5	27	27	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	247	248								S5	28	28	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	249	250								S5	29	29	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	251	252								S5	30	30	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	253	254								S5	31	31	NA	REF-DCS-002	REF-CTRL2			
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	RF1-RMCC 1	TB-DI	255	256								S5	32	32	NA	REF-DCS-002	REF-CTRL2			
M501	AG1001-HS	RF1-AG1001-HS	RF1-AG1001	Agitator for 501	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	1	2								S6	1	1	NA	REF-DCS-002	REF-CTRL2			
P501-FAN	FN1001-HS	RF1-FN1001-HS	RF1-FN1001	Force cooling fan for P501	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	3	4								S6	2	2	NA	REF-DCS-002	REF-CTRL2			
M504-A	MX1004A-HS	RF1-MX1004A-HS	RF1-MX1004A	Acid Mixer	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	5	6								S6	3	3	NA	REF-DCS-002	REF-CTRL2			
P532C	PU1032C-HS	RF1-PU1032C-HS	RF1-PU1032C	Recovered Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	7	8								S6	4	4	NA	REF-DCS-002	REF-CTRL2			
M534CA	AG1034CA-HS	RF1-AG1034CA-HS	RF1-AG1034CA	Agitator for 534CA	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	9	10								S6	5	5	NA	REF-DCS-002	REF-CTRL2			
P578HW	PU1078HW-HS	RF1-PU1078HW-HS	RF1-PU1078HW	Hot Water Dosing Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	11	12								S6	6	6	NA	REF-DCS-002	REF-CTRL2			
P582W	PU1082W-HS	RF1-PU1082W-HS	RF1-PU1082W	Wash Water Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	13	14								S6	7	7	NA	REF-DCS-002	REF-CTRL2			
S18	CF1018-HS	RF1-CF1018-HS	RF1-CF1018	Centrifugal separator	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	15	16								S6	8	8	NA	REF-DCS-002	REF-CTRL2			
PT506	PU1006-HS	RF1-PU1006-HS	RF1-PU1006	Vacuum Dryer Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	17	18								S6	9	9	NA	REF-DCS-002	REF-CTRL2			
MT504AC1	MX1004AC-HS	RF1-MX1004AC-HS	RF1-MX1004AC	Acid Mixer	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	19	20								S6	10	10	NA	REF-DCS-002	REF-CTRL2			
MT503	AG1003-HS	RF1-AG1003-HS	RF1-AG1003	Agitator for T503	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	21	22								S6	11	11	NA	REF-DCS-002	REF-CTRL2			
MT534CA	AG1044CA-HS	RF1-AG1044CA-HS	RF1-AG1044CA	Agitator for T534CA	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	23	24								S6	12	12	NA	REF-DCS-002	REF-CTRL2			
P622-1	PU16221-HS	RF1-PU16221-HS	RF1-PU16221	Filter Feed Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	25	26								S6	13	13	NA	REF-DCS-002	REF-CTRL2			
P622-2	PU16222-HS	RF1-PU16222-HS	RF1-PU16222	Filter Feed Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	27	28								S6	14	14	NA	REF-DCS-002	REF-CTRL2			
P622-3	PU16223-HS	RF1-PU16223-HS	RF1-PU16223	Filter Feed Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	29	30								S6	15	15	NA	REF-DCS-002	REF-CTRL2			
P622-4	PU16224-HS	RF1-PU16224-HS	RF1-PU16224	Filter Feed Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	31	32								S6	16	16	NA	REF-DCS-002	REF-CTRL2			
P622-5	PU16225-HS	RF1-PU16225-HS	RF1-PU16225	Filter Feed Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	33	34								S6	17	17	NA	REF-DCS-002	REF-CTRL2			
P635	PU1635-HS	RF1-PU1635-HS	RF1-PU1635	Continuous Wet Bleacher Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	35	36								S6	18	18	NA	REF-DCS-002	REF-CTRL2			
P682A	PU1682A-HS	RF1-PU1682A-HS	RF1-PU1682A	Recovered Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	37	38								S6	19	19	NA	REF-DCS-002	REF-CTRL2			
P682B	PU1682B-HS	RF1-PU1682B-HS	RF1-PU1682B	Filtered Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	39	40								S6	20	20	NA	REF-DCS-002	REF-CTRL2			
P641X1	VP1641X1-HS	RF1-VP1641X1-HS	RF1-VP1641X1	Vacuum Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	41	42								S6	21	21	NA	REF-DCS-002	REF-CTRL2			
P641X2	VP1641X2-HS	RF1-VP1641X2-HS	RF1-VP1641X2	Vacuum Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	43	44								S6	22	22	NA	REF-DCS-002	REF-CTRL2			
P641X1-CIP	VP1641XA-HS	RF1-VP1641XA-HS	RF1-VP1641XA	Circulation Pump for P641X1	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	45	46								S6	23	23	NA	REF-DCS-002	REF-CTRL2			
P641X2-CIP	VP1641XB-HS	RF1-VP1641XB-HS	RF1-VP1641XB	Circulation Pump for P641X2	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	47	48								S6	24	24	NA	REF-DCS-002	REF-CTRL2			
P802	PU1702-HS	RF1-PU1702-HS	RF1-PU1702	Deaerator Transfer Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	49	50								S6	25	25	NA	REF-DCS-002	REF-CTRL2			
P814AG	PU1714AG-HS	RF1-PU1714AG-HS	RF1-PU1714AG	Fatty Acids Circulating Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	51	52								S6	26	26	NA	REF-DCS-002	REF-CTRL2			
P822C1	PU1722C1-HS	RF1-PU1722C1-HS	RF1-PU1722C1	Deodorizer Oil Transfer Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	53	54								S6	27	27	NA	REF-DCS-002	REF-CTRL2			
P822C2	PU1722C2-HS	RF1-PU1722C2-HS	RF1-PU1722C2	Deodorizer Oil Transfer Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	55	56								S6	28	28	NA	REF-DCS-002	REF-CTRL2			
P822-1	PU17221-HS	RF1-PU17221-HS	RF1-PU17221	Deodorizer Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	57	58								S6	29	29	NA	REF-DCS-002	REF-CTRL2			
P822-2	PU17222-HS	RF1-PU17222-HS	RF1-PU17222	Deodorizer Oil Pump	Motor start command	DO		24VDC Wet supply	2 wire	RF1-RMCC 1	TB-DO	59	60								S6	30	30	NA	REF-DCS-002	REF-CTRL2			
MT834CA	AG1734CA-HS	RF1-AG1734CA-HS	RF1																										

Emerson Automation Solution - Confidential and Proprietary

																				RIO CABINET										SYSTEM CABINET									
																				Relay										DELTA V									
																				Name										DELTA V									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									
																				Term. (+)										Term. (-)									

										RIO CABINET														SYSTEM CABINET									
										Marshalling				Relay				DELTA V				DELTA V				Controller							
Vendor's tags	Wilmar's Tags	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller							
XV-1-P534NA	V1034NA-SY	RF1-V1034NA-SY	RF1_V1034NA	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	17	18			14	11	RD01-09	A1	A2	S6	9	9		NA	REF-DCS-002	REF-CTRL2						
XV-1-T534CA-F	V1044CAF-SY	RF1-V1044CAF-SY	RF1_V1044CAF	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	19	20			14	11	RD01-10	A1	A2	S6	10	10		NA	REF-DCS-002	REF-CTRL2						
XV-1-T534PA-F	V1034PAF-SY	RF1-V1034PAF-SY	RF1_V1034PAF	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	21	22			14	11	RD01-11	A1	A2	S6	11	11		NA	REF-DCS-002	REF-CTRL2						
XV-1-635	V1635-SY	RF1-V1635-SY	RF1_V1635	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	23	24			14	11	RD01-12	A1	A2	S6	12	12		NA	REF-DCS-002	REF-CTRL2						
XV-1-635-B	V1635B-SY	RF1-V1635B-SY	RF1_V1635B	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	25	26			14	11	RD01-13	A1	A2	S6	13	13		NA	REF-DCS-002	REF-CTRL2						
XV-1-682A-B	V1682AB-SY	RF1-V1682AB-SY	RF1_V1682AB	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	27	28			14	11	RD01-14	A1	A2	S6	14	14		NA	REF-DCS-002	REF-CTRL2						
XV-1-682A-D1	V1682AD1-SY	RF1-V1682AD1-SY	RF1_V1682AD1	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	29	30			14	11	RD01-15	A1	A2	S6	15	15		NA	REF-DCS-002	REF-CTRL2						
XV-1-682A-D2	V1682AD2-SY	RF1-V1682AD2-SY	RF1_V1682AD2	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	31	32			14	11	RD01-16	A1	A2	S6	16	16		NA	REF-DCS-002	REF-CTRL2						
XV-1-682B-BY	V1682BBY-SY	RF1-V1682BBY-SY	RF1_V1682BBY	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	33	34			14	11	RD01-17	A1	A2	S6	17	17		NA	REF-DCS-002	REF-CTRL2						
XV-1-P682B-D	V1692BD-SY	RF1-V1692BD-SY	RF1_V1692BD	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	35	36			14	11	RD01-18	A1	A2	S6	18	18		NA	REF-DCS-002	REF-CTRL2						
XV-1-802-BY	V1702BY-SY	RF1-V1702BY-SY	RF1_V1702BY	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	37	38			14	11	RD01-19	A1	A2	S6	19	19		NA	REF-DCS-002	REF-CTRL2						
XV-1-P802-D	V1702D-SY	RF1-V1702D-SY	RF1_V1702D	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	39	40			14	11	RD01-20	A1	A2	S6	20	20		NA	REF-DCS-002	REF-CTRL2						
XV-1-802-F	V1702F-SY	RF1-V1702F-SY	RF1_V1702F	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	41	42			14	11	RD01-21	A1	A2	S6	21	21		NA	REF-DCS-002	REF-CTRL2						
XV-1-821X-S	V1721XS-SY	RF1-V1721XS-SY	RF1_V1721XS	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	43	44			14	11	RD01-22	A1	A2	S6	22	22		NA	REF-DCS-002	REF-CTRL2						
XV-1-880B-B	V1780BB-SY	RF1-V1780BB-SY	RF1_V1780BB	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	45	46			14	11	RD01-23	A1	A2	S6	23	23		NA	REF-DCS-002	REF-CTRL2						
XV-1-880B-D	V1780BD-SY	RF1-V1780BD-SY	RF1_V1780BD	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	47	48			14	11	RD01-24	A1	A2	S6	24	24		NA	REF-DCS-002	REF-CTRL2						
XV-1-881A-B	V1781AB-SY	RF1-V1781AB-SY	RF1_V1781AB	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	49	50			14	11	RD01-25	A1	A2	S6	25	25		NA	REF-DCS-002	REF-CTRL2						
XV-1-878023C-R	V1778-SY	RF1-V1778-SY	RF1_V1778	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	51	52			14	11	RD01-26	A1	A2	S6	26	26		NA	REF-DCS-002	REF-CTRL2						
XV-1-834NA	V1734NA-SY	RF1-V1734NA-SY	RF1_V1734NA	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	53	54			14	11	RD01-27	A1	A2	S6	27	27		NA	REF-DCS-002	REF-CTRL2						
XV-1-635-S	V1635S-SY	RF1-V1635S-SY	RF1_V1635S	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	55	56			14	11	RD01-28	A1	A2	S6	28	28		NA	REF-DCS-002	REF-CTRL2						
XV-1-622/21-BS	V1622A-SY	RF1-V1622A-SY	RF1_V1622A	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	57	58			14	11	RD01-29	A1	A2	S6	29	29		NA	REF-DCS-002	REF-CTRL2						
XV-1-622/21-D2	V1622C-SY	RF1-V1622C-SY	RF1_V1622C	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	59	60			14	11	RD01-30	A1	A2	S6	30	30		NA	REF-DCS-002	REF-CTRL2						
XV-1-682A-D	V1682AD-SY	RF1-V1682AD-SY	RF1_V1682AD	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	61	62			14	11	RD01-31	A1	A2	S6	31	31		NA	REF-DCS-002	REF-CTRL2						
XV-1-604C-S	V1604CS-SY	RF1-V1604CS-SY	RF1_V1604CS	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	63	64			14	11	RD01-32	A1	A2	S6	32	32		NA	REF-DCS-002	REF-CTRL2						
XV-1-802-B	V1702B-SY	RF1-V1702B-SY	RF1_V1702B	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	65	66			14	11	RD01-33	A1	A2	S7	1	1		NA	REF-DCS-002	REF-CTRL2						
XV-1-802-D	V1712D-SY	RF1-V1712D-SY	RF1_V1712D	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	67	68			14	11	RD01-34	A1	A2	S7	2	2		NA	REF-DCS-002	REF-CTRL2						
XV-1-822Q2E-BY	V1722QED-SY	RF1-V1722QED-SY	RF1_V1722QED	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	69	70			14	11	RD01-35	A1	A2	S7	3	3		NA	REF-DCS-002	REF-CTRL2						
XV-1-849-D	V1949D-SY	RF1-V1949D-SY	RF1_V1949D	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	71	72			14	11	RD01-36	A1	A2	S7	4	4		NA	REF-DCS-002	REF-CTRL2						
XV-1-880A-D1	V1780A2A-SY	RF1-V1780A2A-SY	RF1_V1780A2A	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	73	74			14	11	RD01-37	A1	A2	S7	5	5		NA	REF-DCS-002	REF-CTRL2						
XV-1-880A-D2	V1780A2B-SY	RF1-V1780A2B-SY	RF1_V1780A2B	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	75	76			14	11	RD01-38	A1	A2	S7	6	6		NA	REF-DCS-002	REF-CTRL2						
XV-1-822C-D1	V1722CD1-SY	RF1-V1722CD1-SY	RF1_V1722CD1	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	77	78			14	11	RD01-39	A1	A2	S7	7	7		NA	REF-DCS-002	REF-CTRL2						
XV-1-822C-D2	V1722CD2-SY	RF1-V1722CD2-SY	RF1_V1722CD2	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire	RF1-RIO-003	TB-DO	79	80			14	11	RD01-40	A1	A2	S7	8	8		NA	REF-DCS-002	REF-CTRL2						
SOV-1-610A	SV1610A	RF1-SV1610A	RF1_SV1610A	Solenoid Valve																													

										RIO CABINET										SYSTEM CABINET									
										Marshalling										DELTA V									
										Relay										DELTA V									
Vendor's tags	Wilmar's Tags	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
XV-1-61644-4	V161644F-ZC	RF1-V161644F-ZC	RF1 V161644F	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	161	162							S3	17	17			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-4	V161644F-ZC	RF1-V161644F-ZC	RF1 V161644F	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	163	164							S3	18	18			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-6	V161644G-ZC	RF1-V161644G-ZC	RF1 V161644G	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	165	166							S3	19	19			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-6	V161644G-ZC	RF1-V161644G-ZC	RF1 V161644G	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	167	168							S3	20	20			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-7	V161644H-ZC	RF1-V161644H-ZC	RF1 V161644H	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	169	170							S3	21	21			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-7	V161644H-ZC	RF1-V161644H-ZC	RF1 V161644H	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	171	172							S3	22	22			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-8	V161644I-ZC	RF1-V161644I-ZC	RF1 V161644I	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	173	174							S3	23	23			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-8	V161644I-ZC	RF1-V161644I-ZC	RF1 V161644I	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	175	176							S3	24	24			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-9	V161644J-ZC	RF1-V161644J-ZC	RF1 V161644J	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	177	178							S3	25	25			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-9	V161644J-ZC	RF1-V161644J-ZC	RF1 V161644J	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	179	180							S3	26	26			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-11	V161644M-ZC	RF1-V161644M-ZC	RF1 V161644M	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	181	182							S3	27	27			NA	REF-DCS-002	REF-CTRL2		
XV-1-61644-11	V161644M-ZC	RF1-V161644M-ZC	RF1 V161644M	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	183	184							S3	28	28			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-1	V161645A-ZC	RF1-V161645A-ZC	RF1 V161645A	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	185	186							S3	29	29			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-1	V161645A-ZC	RF1-V161645A-ZC	RF1 V161645A	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	187	188							S3	30	30			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-1A	V161645B-ZC	RF1-V161645B-ZC	RF1 V161645B	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	189	190							S3	31	31			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-1A	V161645B-ZC	RF1-V161645B-ZC	RF1 V161645B	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	191	192							S3	32	32			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-2	V161645C-ZC	RF1-V161645C-ZC	RF1 V161645C	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	193	194							S4	1	1			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-2	V161645C-ZC	RF1-V161645C-ZC	RF1 V161645C	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	195	196							S4	2	2			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-3	V161645D-ZC	RF1-V161645D-ZC	RF1 V161645D	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	197	198							S4	3	3			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-3	V161645D-ZC	RF1-V161645D-ZC	RF1 V161645D	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	199	200							S4	4	4			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-3A	V161645E-ZC	RF1-V161645E-ZC	RF1 V161645E	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	201	202							S4	5	5			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-3A	V161645E-ZC	RF1-V161645E-ZC	RF1 V161645E	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	203	204							S4	6	6			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-4	V161645F-ZC	RF1-V161645F-ZC	RF1 V161645F	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	205	206							S4	7	7			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-4	V161645F-ZC	RF1-V161645F-ZC	RF1 V161645F	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	207	208							S4	8	8			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-5	V161645G-ZC	RF1-V161645G-ZC	RF1 V161645G	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	209	210							S4	9	9			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-5	V161645G-ZC	RF1-V161645G-ZC	RF1 V161645G	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	211	212							S4	10	10			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-6	V161645H-ZC	RF1-V161645H-ZC	RF1 V161645H	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	213	214							S4	11	11			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-6	V161645H-ZC	RF1-V161645H-ZC	RF1 V161645H	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	215	216							S4	12	12			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-7	V161645I-ZC	RF1-V161645I-ZC	RF1 V161645I	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	217	218							S4	13	13			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-7	V161645I-ZC	RF1-V161645I-ZC	RF1 V161645I	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	219	220							S4	14	14			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-8	V161645J-ZC	RF1-V161645J-ZC	RF1 V161645J	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	221	222							S4	15	15			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-8	V161645J-ZC	RF1-V161645J-ZC	RF1 V161645J	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	223	224							S4	16	16			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-9	V161645K-ZC	RF1-V161645K-ZC	RF1 V161645K	Actuator Valve	Valve open indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	225	226							S4	17	17			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-9	V161645K-ZC	RF1-V161645K-ZC	RF1 V161645K	Actuator Valve	Valve close indication	DI		DI Dry Contact - NPN/PNP	2 wire	RF1-RIO-004	TB-DI	227	228							S4	18	18			NA	REF-DCS-002	REF-CTRL2		
XV-1-61645-115																													

										RIO CABINET																SYSTEM CABINET																
										Marshalling				Relay				DELTA V				DELTA V				Cabinet Name	TB Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller							
Vendor's tags	Wilmar's Tags	Emerson's Database Tags	Module Name	Description	Type	IO Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	A2	S7	25	25	NA	REF-DCS-002	REF-CTRL2																	
XV-1-616A5-11	V1616A5K-SY	RF1-V1616A5K-SY	RF1_V1616A5K	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	113	114					RD01-57	A1	A2	S7	25	25	NA	REF-DCS-002	REF-CTRL2
XV-1-682A2-B	V1682A2B-SY	RF1-V1682A2B-SY	RF1_V1682A2B	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	115	116					RD01-58	A1	A2	S7	26	26	NA	REF-DCS-002	REF-CTRL2
XV-1-682A2-D	V1682A2D-SY	RF1-V1682A2D-SY	RF1_V1682A2D	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	117	118					RD01-59	A1	A2	S7	27	27	NA	REF-DCS-002	REF-CTRL2
XV-1-682B-BS	V1682BBS-SY	RF1-V1682BBS-SY	RF1_V1682BBS	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	119	120					RD01-60	A1	A2	S7	28	28	NA	REF-DCS-002	REF-CTRL2
XV-1-682B-D	V1682BDS-SY	RF1-V1682BDS-SY	RF1_V1682BDS	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	121	122					RD01-61	A1	A2	S7	29	29	NA	REF-DCS-002	REF-CTRL2
XV-1-151S1	V161151-SY	RF1-V161151-SY	RF1_V161151	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	123	124					RD01-62	A1	A2	S7	30	30	NA	REF-DCS-002	REF-CTRL2
XV-1-95S1	V161951-SY	RF1-V161951-SY	RF1_V161951	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	125	126					RD01-63	A1	A2	S7	31	31	NA	REF-DCS-002	REF-CTRL2
XV-1-822QE2-F	V1722QEC-SY	RF1-V1722QEC-SY	RF1_V1722QEC	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	127	128					RD01-64	A1	A2	S7	32	32	NA	REF-DCS-002	REF-CTRL2
XV-1-880A1-D1	V1780A1A-SY	RF1-V1780A1A-SY	RF1_V1780A1A	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	129	130					RD01-65	A1	A2	S8	1	1	NA	REF-DCS-002	REF-CTRL2
XV-1-880A1-D2	V1780A1B-SY	RF1-V1780A1B-SY	RF1_V1780A1B	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	131	132					RD01-66	A1	A2	S8	2	2	NA	REF-DCS-002	REF-CTRL2
XV-1-604C-V	V1604CV-SY	RF1-V1604CV-SY	RF1_V1604CV	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	133	134					RD01-67	A1	A2	S8	3	3	NA	REF-DCS-002	REF-CTRL2
XV-1-55S1	V1615S1-SY	RF1-V1615S1-SY	RF1_V1615S1	Actuator Valve	Valve open command	DO		24VDC Wet Supply	2 wire																	RF1-RIO-004	TB-DO	135	136					RD01-68	A1	A2	S8	4	4	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	137	138					RD01-69	A1	A2	S8	5	5	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	139	140					RD01-70	A1	A2	S8	6	6	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	141	142					RD01-71	A1	A2	S8	7	7	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	143	144					RD01-72	A1	A2	S8	8	8	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	145	146					RD01-73	A1	A2	S8	9	9	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	147	148					RD01-74	A1	A2	S8	10	10	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	149	150					RD01-75	A1	A2	S8	11	11	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	151	152					RD01-76	A1	A2	S8	12	12	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	153	154					RD01-77	A1	A2	S8	13	13	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	155	156					RD01-78	A1	A2	S8	14	14	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	157	158					RD01-79	A1	A2	S8	15	15	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	159	160					RD01-80	A1	A2	S8	16	16	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	161	162					RD01-81	A1	A2	S8	17	17	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	163	164					RD01-82	A1	A2	S8	18	18	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	165	166					RD01-83	A1	A2	S8	19	19	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare																	RF1-RIO-004	TB-DO	167	168					RD01-84	A1	A2	S8	20	20	NA	REF-DCS-002	REF-CTRL2
Spare	Spare	Spare	Spare	S																																						

EMERSON.

