

IO List - Semi Continuous Refinery

Wilmar Industrial Complex PT MNA Serang, Indonesia

End Customer: Wilmar Industrial Complex PT MNA
Serang, Indonesia

End Customer Reference Number:

Document File Name: 3258585-PSS-PASH-DWG-00041
Document Status: For Final

Authorisations

	Name	Function	Signature
Developed By:	Zul Hasyidi Hassan	Project Engineer	ZHH 
Reviewed By:	Liow Kok Loong	Lead Engineer	LKL 
Released By:	Mohd. Nazim Ismail	Project Manager	MNI 

Distribution

Name	Company	Name	Company

Revision History

Rev	Status	Description	Date	Developed By	Reviewed By
A	For Review	Issued for Review	14-Sep-18	WMS	LKL
B	For Review	Issued for Review	11-Oct-18	ZHH	LKL
0	For Final	Issued for Final	30-Sep-19	ZHH	LKL

© Emerson Automation Solution. All rights reserved. Unauthorized duplication, in whole or in part, is prohibited. Trademarks identified in this document are owned by one of the Emerson Process Management group of companies. Unless otherwise agreed to in writing by the parties, any information provided in this document is confidential or proprietary and may not be used or disclosed without the expressed written permission of Emerson Process Management.

Emerson Automation Solution Process System and Solutions

No. 1, Block A, Jalan SS13/5, SS13
Subang Jaya, 47500, Selangor
Malaysia
T +60 (3) 5624-2888
F +60 (3) 5638-1010
www.EmersonProcess.com

										RIO CABINET										SYSTEM CABINET						
										Marshalling				Relay				DELTA V								
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
PU-202B	PU-202B-CU	SD1-PU-202B-CU	SD1 PU_ 202B	RO Water Distribution Pump	Motor current feedback	AI	Spare	4-20 mA	2 wire	SD1-RMCC_1	TB-AI	1	2								S1	1	1	2	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	3	4								S1	2	3	4	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	5	6								S1	3	5	6	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	7	8								S1	4	7	8	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	9	10								S1	5	9	10	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	11	12								S1	6	11	12	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	13	14								S1	7	13	14	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	15	16								S1	8	15	16	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	17	18								S1	9	17	18	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	19	20								S1	10	19	20	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	21	22								S1	11	21	22	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	23	24								S1	12	23	24	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	25	26								S1	13	25	26	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	27	28								S1	14	27	28	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	29	30								S1	15	29	30	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-AI	31	32								S1	16	31	32	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	1	2								S2	1	1	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	3	4								S2	2	2	#N/A	SFO-DCS-004	SFO-CTRL4
CUT38A	CP2738A-XL	SD1-CP2738A-XL	SD1 CP2738A	Ammonia Compressor A	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	5	6								S2	3	3	#N/A	SFO-DCS-004	SFO-CTRL4
CUT38A	CP2738A-XA	SD1-CP2738A-XA	SD1 CP2738A	Ammonia Compressor A	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	7	8								S2	4	4	#N/A	SFO-DCS-004	SFO-CTRL4
CUT38B	CP2738B-XL	SD1-CP2738B-XL	SD1 CP2738B	Ammonia Compressor B	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	9	10								S2	5	5	#N/A	SFO-DCS-004	SFO-CTRL4
CUT38B	CP2738B-XA	SD1-CP2738B-XA	SD1 CP2738B	Ammonia Compressor B	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	11	12								S2	6	6	#N/A	SFO-DCS-004	SFO-CTRL4
EP631	CONV631-XL	SD1-CONV631-XL	SD1 CONV631	Blower For Pneumatic Conveying System	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	13	14								S2	7	7	#N/A	SFO-DCS-004	SFO-CTRL4
EP631	CONV631-XA	SD1-CONV631-XA	SD1 CONV631	Blower For Pneumatic Conveying System	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	15	16								S2	8	8	#N/A	SFO-DCS-004	SFO-CTRL4
HB721	HPS1921-XL	SD1-HPS1921-XL	SD1 HPS1921	High Pressure Steam Boiler	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	17	18								S2	9	9	#N/A	SFO-DCS-004	SFO-CTRL4
HB721	HPS1921-XA	SD1-HPS1921-XA	SD1 HPS1921	High Pressure Steam Boiler	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	19	20								S2	10	10	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736A-XL	SD1-XH2736A-XL	SD1 XH2736A	Ammonia Evaporative Condenser	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	21	22								S2	11	11	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736A-XA	SD1-XH2736A-XA	SD1 XH2736A	Ammonia Evaporative Condenser	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	23	24								S2	12	12	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736B-XL	SD1-XH2736B-XL	SD1 XH2736B	Ammonia Evaporative Condenser	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	25	26								S2	13	13	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736B-XA	SD1-XH2736B-XA	SD1 XH2736B	Ammonia Evaporative Condenser	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	27	28								S2	14	14	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736C-XL	SD1-XH2736C-XL	SD1 XH2736C	Ammonia Evaporative Condenser	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	29	30								S2	15	15	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736C-XA	SD1-XH2736C-XA	SD1 XH2736C	Ammonia Evaporative Condenser	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	31	32								S2	16	16	#N/A	SFO-DCS-004	SFO-CTRL4
MX311	MX2011-XL	SD1-MX2011-XL	SD1 MX2011	Acid Mixer	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	33	34								S2	17	17	#N/A	SFO-DCS-004	SFO-CTRL4
MX311	MX2011-XA	SD1-MX2011-XA	SD1 MX2011	Acid Mixer	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	35	36								S2	18	18	#N/A	SFO-DCS-004	SFO-CTRL4
MX312	MX2012-XL	SD1-MX2012-XL	SD1 MX2012	Degumming Reactor	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	37	38								S2	19	19	#N/A	SFO-DCS-004	SFO-CTRL4
MX312	MX2012-XA	SD1-MX2012-XA	SD1 MX2012	Degumming Reactor	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	39	40								S2	20	20	#N/A	SFO-DCS-004	SFO-CTRL4
MX322	MX2022-XL	SD1-MX2022-XL	SD1 MX2022	Citric Acid Day Tank Mixer	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	41	42								S2	21	21	#N/A	SFO-DCS-004	SFO-CTRL4
MX322	MX2022-XA	SD1-MX2022-XA	SD1 MX2022	Citric Acid Day Tank Mixer	Motor trip feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	43	44								S2	22	22	#N/A	SFO-DCS-004	SFO-CTRL4
MX761A	MX2761A-XL	SD1-MX2761A-XL	SD1 MX2761A	Citric Acid And Anti Oxidant Day Tank Mixer A	Motor run feedback	DI		DI Dry Contact	2 wire	SD1-RMCC_1	TB-DI	45	46	</												

										RIO CABINET										SYSTEM CABINET						
										Marshalling				Relay				DELTA V				DELTA V				
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	221	222								S5	15	15	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	223	224								S5	16	16	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	225	226								S5	17	17	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	227	228								S5	18	18	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	229	230								S5	19	19	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	231	232								S5	20	20	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	233	234								S5	21	21	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	235	236								S5	22	22	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	237	238								S5	23	23	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	239	240								S5	24	24	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	241	242								S5	25	25	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	243	244								S5	26	26	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	245	246								S5	27	27	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	247	248								S5	28	28	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	249	250								S5	29	29	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	251	252								S5	30	30	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	253	254								S5	31	31	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DI	255	256								S5	32	32	#N/A	SFO-DCS-004	SFO-CTRL4
VP734B	VP2734B-HS	SD1-VP2734B-HS	SD1 VP2734B	Deodorizer Vacuum Pump B	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	1	2								S6	1	1	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736A-HS	SD1-XH2736A-HS	SD1 XH2736A	Ammonia Evaporative Condenser	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	3	4								S6	2	2	#N/A	SFO-DCS-004	SFO-CTRL4
VP734A	VP2734A-HS	SD1-VP2734A-HS	SD1 VP2734A	Deodorizer Vacuum Pump A	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	5	6								S6	3	3	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736B-HS	SD1-XH2736B-HS	SD1 XH2736B	Ammonia Evaporative Condenser	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	7	8								S6	4	4	#N/A	SFO-DCS-004	SFO-CTRL4
VP611B	VP2611B-HS	SD1-VP2611B-HS	SD1 VP2611B	Bleaching Vacuum Pump B	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	9	10								S6	5	5	#N/A	SFO-DCS-004	SFO-CTRL4
HE736	XH2736C-HS	SD1-XH2736C-HS	SD1 XH2736C	Ammonia Evaporative Condenser	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	11	12								S6	6	6	#N/A	SFO-DCS-004	SFO-CTRL4
VP611A	VP2611A-HS	SD1-VP2611A-HS	SD1 VP2611A	Bleaching Vacuum Pump A	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	13	14								S6	7	7	#N/A	SFO-DCS-004	SFO-CTRL4
HB721	HPS1921-HS	SD1-HPS1921-HS	SD1 HPS1921	High Pressure Steam Boiler	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	15	16								S6	8	8	#N/A	SFO-DCS-004	SFO-CTRL4
VB632B	VB1632B-HS	SD1-VB1632B-HS	SD1 VB1632B	Vibrator For Activated Carbon	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	17	18								S6	9	9	#N/A	SFO-DCS-004	SFO-CTRL4
EP631	CONV631-HS	SD1-CONV631-HS	SD1 CONV631	Blower For Pneumatic Conveying System	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	19	20								S6	10	10	#N/A	SFO-DCS-004	SFO-CTRL4
VB632A	VB1632A-HS	SD1-VB1632A-HS	SD1 VB1632A	Vibrator For Bleaching Earth Hopper	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	21	22								S6	11	11	#N/A	SFO-DCS-004	SFO-CTRL4
CU738B	CP2738B-HS	SD1-CP2738B-HS	SD1 CP2738B	Ammonia Compressor B	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	23	24								S6	12	12	#N/A	SFO-DCS-004	SFO-CTRL4
PU903B	PU903B-HS	SD1-PU903B-HS	SD1 PU903B	Effluent Pump	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	25	26								S6	13	13	#N/A	SFO-DCS-004	SFO-CTRL4
CU738A	CP2738A-HS	SD1-CP2738A-HS	SD1 CP2738A	Ammonia Compressor A	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	27	28								S6	14	14	#N/A	SFO-DCS-004	SFO-CTRL4
PU752	PU2752-HS	SD1-PU2752-HS	SD1 PU2752	Tempered Water Pump	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	29	30								S6	15	15	#N/A	SFO-DCS-004	SFO-CTRL4
PU751	PU2751-HS	SD1-PU2751-HS	SD1 PU2751	Fatty Acid Distillate Pump	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	31	32								S6	16	16	#N/A	SFO-DCS-004	SFO-CTRL4
PU743	PU2743-HS	SD1-PU2743-HS	SD1 PU2743	Hot Water Pump	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	33	34								S6	17	17	#N/A	SFO-DCS-004	SFO-CTRL4
PU736	PU2736-HS	SD1-PU2736-HS	SD1 PU2736	Condenser Circulation Pump	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	35	36								S6	18	18	#N/A	SFO-DCS-004	SFO-CTRL4
PU735	PU2735-HS	SD1-PU2735-HS	SD1 PU2735	Wastewater Discharge Pump	Motor start command	DO		24VDC Wet Supply	2 wire	SD1-RMCC_1	TB-DO	37	38								S6	19	19	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DO	39	40								S6	20	20	#N/A	SFO-DCS-004	SFO-CTRL4
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RMCC_1	TB-DO	41	42													

Emerson Automation Solution - Confidential and Proprietary

										RIO CABINET										SYSTEM CABINET						
										Marshalling				Relay				DELTA V				DELTA V				
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
1LSH761B	LSH2761B	SD1-LSH2761B	SD1 LSH2761B	Level Switch for 1TK761B High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	101	102	+8	-8						S2	19	19	#N/A	SFO-DCS-004	SFO-CTRL4
1LSH761A	LSH2761A	SD1-LSH2761A	SD1 LSH2761A	Level Switch for 1TK761A High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	103	104	+9	-9						S2	20	20	#N/A	SFO-DCS-004	SFO-CTRL4
1LSH322	LSH2022	SD1-LSH2022	SD1 LSH2022	Level Switch for 1TK322 High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	105	106	+10	-10						S2	21	21	#N/A	SFO-DCS-004	SFO-CTRL4
1LSH321	LSH2021	SD1-LSH2021	SD1 LSH2021	Level Switch for 1TK321 High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	107	108	+11	-11						S2	22	22	#N/A	SFO-DCS-004	SFO-CTRL4
1V7412P	V27412P-ZO	SD1-V27412P-ZO	SD1 V27412P	Actuator Valve for Purging	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	109	110								S2	23	23	#N/A	SFO-DCS-004	SFO-CTRL4
1V7412P	V27412P-ZC	SD1-V27412P-ZC	SD1 V27412P	Actuator Valve for Purging	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	111	112								S2	24	24	#N/A	SFO-DCS-004	SFO-CTRL4
1V7412	V27412-ZO	SD1-V27412-ZO	SD1 V27412	Actuator Valve for RBD Oil to Tank Farm	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	113	114								S2	25	25	#N/A	SFO-DCS-004	SFO-CTRL4
1V7412	V27412-ZC	SD1-V27412-ZC	SD1 V27412	Actuator Valve for RBD Oil to Tank Farm	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	115	116								S2	26	26	#N/A	SFO-DCS-004	SFO-CTRL4
1V7411P	V27411P-ZO	SD1-V27411P-ZO	SD1 V27411P	Actuator Valve for Purging	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	117	118								S2	27	27	#N/A	SFO-DCS-004	SFO-CTRL4
1V7411P	V27411P-ZC	SD1-V27411P-ZC	SD1 V27411P	Actuator Valve for Purging	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	119	120								S2	28	28	#N/A	SFO-DCS-004	SFO-CTRL4
1V7411	V27411-ZO	SD1-V27411-ZO	SD1 V27411	Actuator Valve for Recirculation of Oil to 1VE701A/B	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	121	122								S2	29	29	#N/A	SFO-DCS-004	SFO-CTRL4
1V7411	V27411-ZC	SD1-V27411-ZC	SD1 V27411	Actuator Valve for Recirculation of Oil to 1VE701A/B	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	123	124								S2	30	30	#N/A	SFO-DCS-004	SFO-CTRL4
1V712	V2712-ZO	SD1-V2712-ZO	SD1 V2712	Actuator Valve for Stock Change	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	125	126								S2	31	31	#N/A	SFO-DCS-004	SFO-CTRL4
1V712	V2712-ZC	SD1-V2712-ZC	SD1 V2712	Actuator Valve for Stock Change	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	127	128								S2	32	32	#N/A	SFO-DCS-004	SFO-CTRL4
1V711D	V2711D-ZO	SD1-V2711D-ZO	SD1 V2711D	Actuator Valve for Drain	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	129	130								S3	1	1	#N/A	SFO-DCS-004	SFO-CTRL4
1V711D	V2711D-ZC	SD1-V2711D-ZC	SD1 V2711D	Actuator Valve for Drain	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	131	132								S3	2	2	#N/A	SFO-DCS-004	SFO-CTRL4
1V711	V2711-ZO	SD1-V2711-ZO	SD1 V2711	Actuator Valve for Stock Change	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	133	134								S3	3	3	#N/A	SFO-DCS-004	SFO-CTRL4
1V711	V2711-ZC	SD1-V2711-ZC	SD1 V2711	Actuator Valve for Stock Change	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	135	136								S3	4	4	#N/A	SFO-DCS-004	SFO-CTRL4
1V6416	V26416-ZO	SD1-V26416-ZO	SD1 V26416	Actuator Valve for 1FL641A/B Outlet to 1VE701A/B	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	137	138								S3	5	5	#N/A	SFO-DCS-004	SFO-CTRL4
1V6416	V26416-ZC	SD1-V26416-ZC	SD1 V26416	Actuator Valve for 1FL641A/B Outlet to 1VE701A/B	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	139	140								S3	6	6	#N/A	SFO-DCS-004	SFO-CTRL4
1V6415	V26415-ZO	SD1-V26415-ZO	SD1 V26415	Actuator Valve for 1FL641A/B Outlet to 1VE641	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	141	142								S3	7	7	#N/A	SFO-DCS-004	SFO-CTRL4
1V6415	V26415-ZC	SD1-V26415-ZC	SD1 V26415	Actuator Valve for 1FL641A/B Outlet to 1VE641	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	143	144								S3	8	8	#N/A	SFO-DCS-004	SFO-CTRL4
1V7392W	V27392W-ZO	SD1-V27392W-ZO	SD1 V27392W	Actuator Valve for Cooling Water Return to 1DE731	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	145	146								S3	9	9	#N/A	SFO-DCS-004	SFO-CTRL4
1V7392W	V27392W-ZC	SD1-V27392W-ZC	SD1 V27392W	Actuator Valve for Cooling Water Return to 1DE731	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	147	148								S3	10	10	#N/A	SFO-DCS-004	SFO-CTRL4
1V7313	V27313-ZO	SD1-V27313-ZO	SD1 V27313	Actuator Valve for 1PU731A/B Discharge Back to 1DE731 Drop Tray	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	149	150								S3	11	11	#N/A	SFO-DCS-004	SFO-CTRL4
1V7313	V27313-ZC	SD1-V27313-ZC	SD1 V27313	Actuator Valve for 1PU731A/B Discharge Back to 1DE731 Drop Tray	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	151	152								S3	12	12	#N/A	SFO-DCS-004	SFO-CTRL4
1V7311P	V27311P-ZO	SD1-V27311P-ZO	SD1 V27311P	Actuator Valve for Purging	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	153	154								S3	13	13	#N/A	SFO-DCS-004	SFO-CTRL4
1V7311P	V27311P-ZC	SD1-V27311P-ZC	SD1 V27311P	Actuator Valve for Purging	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	155	156								S3	14	14	#N/A	SFO-DCS-004	SFO-CTRL4
1V7311	V27311-ZO	SD1-V27311-ZO	SD1 V27311	Actuator Valve for 1DE731 Outlet to 1PU731A/B	Valve open indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	158						A1	A2	RD11-03	14	11			SFO-DCS-004	SFO-CTRL4
1V7311	V27311-ZC	SD1-V27311-ZC	SD1 V27311	Actuator Valve for 1DE731 Outlet to 1PU731A/B	Valve close indication	DI		PNP	2 wire	SD1-RIO-002	TB-DI	160						A1	A2	RD11-04	14	11			SFO-DCS-004	SFO-CTRL4
1LSL2612	LSL2612	SD1-LSL2612	SD1 LSL2612	Level Switch for 1VE612 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	161	162	+12	-12						S3	17	17	#N/A	SFO-DCS-004	SFO-CTRL4
1LSL2743	LSL2743	SD1-LSL2743	SD1 LSL2743	Level Switch for 1VE743 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	163	164	+13	-13						S3	18	18	#N/A	SFO-DCS-004	SFO-CTRL4
1LSL612	LSL2612	SD1-LSL2612	SD1 LSL2612	Level Switch for 1VE612 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-002	TB-DI	165	166	+14	-14						S3	19	19	#N/A	SFO-DCS-004	SFO-CTRL4
1V770	V2770-ZO	SD1-V2770-ZO	SD1 V2770	Actuator Valve for Splash Oil from 1DE731 to 1VE771	Val																					

										RIO CABINET										SYSTEM CABINET													
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Marshalling		Relay		DELTA V		DELTA V		Cabinet Name	Controller														
										Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)			Term. (-)	Channel	Term. (+)	Term. (-)										
1V621D	V2621D-SY	SD1-V2621D-SY	SD1 V2621D	Actuator Valve for Drain	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	33	34			14	11			RDO1-17	A1	A2	S6	17	17	#N/A						SFO-DCS-004	SFO-CTRL4
1V621B	V2621B-SY	SD1-V2621B-SY	SD1 V2621B	Actuator Valve for 1VE641 Outlet to 1PU621	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	35	36			14	11			RDO1-18	A1	A2	S6	18	18	#N/A						SFO-DCS-004	SFO-CTRL4
1V612P	V2612P-SY	SD1-V2612P-SY	SD1 V2612P	Actuator Valve for Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	37	38			14	11			RDO1-19	A1	A2	S6	19	19	#N/A						SFO-DCS-004	SFO-CTRL4
1V612	V2612-SY	SD1-V2612-SY	SD1 V2612	Actuator Valve for 1VE612 Outlet	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	39	40			14	11			RDO1-20	A1	A2	S6	20	20	#N/A						SFO-DCS-004	SFO-CTRL4
1V7316	V27316-SY	SD1-V27316-SY	SD1 V27316	Actuator Valve for 1HE311 Outlet to 1HE742	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	41	42			14	11			RDO1-21	A1	A2	S6	21	21	#N/A						SFO-DCS-004	SFO-CTRL4
1V322F	V2022F-SY	SD1-V2022F-SY	SD1 V2022F	Actuator Valve for Citric Acid Supply to 1TK322	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	43	44			14	11			RDO1-22	A1	A2	S6	22	22	#N/A						SFO-DCS-004	SFO-CTRL4
1V321F	V2021F-SY	SD1-V2021F-SY	SD1 V2021F	Actuator Valve for Phosphoric Acid Supply to 1TK321	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	45	46			14	11			RDO1-23	A1	A2	S6	23	23	#N/A						SFO-DCS-004	SFO-CTRL4
1V301D	V201D-SY	SD1-V201D-SY	SD1 V201D	Actuator Valve for Feed Line Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	47	48			14	11			RDO1-24	A1	A2	S6	24	24	#N/A						SFO-DCS-004	SFO-CTRL4
1V7393W	V27393W-SY	SD1-V27393W-SY	SD1 V27393W	Actuator Valve for Cooling Water Discharge to TK735	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	49	50			14	11			RDO1-25	A1	A2	S6	25	25	#N/A						SFO-DCS-004	SFO-CTRL4
1V301AP	V2001AP-SY	SD1-V2001AP-SY	SD1 V2001AP	Actuator Valve for Feed Line Nitrogen Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	51	52			14	11			RDO1-26	A1	A2	S6	26	26	#N/A						SFO-DCS-004	SFO-CTRL4
1V739V	V2739V-SY	SD1-V2739V-SY	SD1 V2739V	Actuator Valve for Vent	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	53	54			14	11			RDO1-27	A1	A2	S6	27	27	#N/A						SFO-DCS-004	SFO-CTRL4
1V3012	V20012-SY	SD1-V20012-SY	SD1 V20012	Actuator Valve for Stock Change	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	55	56			14	11			RDO1-28	A1	A2	S6	28	28	#N/A						SFO-DCS-004	SFO-CTRL4
1V3011	V20011-SY	SD1-V20011-SY	SD1 V20011	Actuator Valve for Stock Change	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	57	58			14	11			RDO1-29	A1	A2	S6	29	29	#N/A						SFO-DCS-004	SFO-CTRL4
1V771S	V2771S-SY	SD1-V2771S-SY	SD1 V2771S	Actuated Valve for 1VE771 Steam Supply	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	59	60			14	11			RDO1-30	A1	A2	S6	30	30	#N/A						SFO-DCS-004	SFO-CTRL4
1V771	V2771-SY	SD1-V2771-SY	SD1 V2771	Actuator Valve for 1VE771 Outlet to Fatty Acid Storage	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	61	62			14	11			RDO1-31	A1	A2	S6	31	31	#N/A						SFO-DCS-004	SFO-CTRL4
1V751A	V2751A-SY	SD1-V2751A-SY	SD1 V2751A	Actuator Valve for Lauric Acid from 1PU751 to Fatty Acid Storage	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	63	64			14	11			RDO1-32	A1	A2	S6	32	32	#N/A						SFO-DCS-004	SFO-CTRL4
1V761C	V2761C-SY	SD1-V2761C-SY	SD1 V2761C	Actuator Valve for Antioxidant Supply to 1MX742	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	65	66			14	11			RDO1-33	A1	A2	S7	1	1	#N/A						SFO-DCS-004	SFO-CTRL4
1V761B	V2761B-SY	SD1-V2761B-SY	SD1 V2761B	Actuator Valve for Antioxidant Supply to 1MX742	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	67	68			14	11			RDO1-34	A1	A2	S7	2	2	#N/A						SFO-DCS-004	SFO-CTRL4
1V751P	V2751P-SY	SD1-V2751P-SY	SD1 V2751P	Actuator Valve for Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	69	70			14	11			RDO1-35	A1	A2	S7	3	3	#N/A						SFO-DCS-004	SFO-CTRL4
1V751B	V2751B-SY	SD1-V2751B-SY	SD1 V2751B	Actuator Valve for Palmitic Acid from 1PU751 to Fatty Acid Storage	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	71	72			14	11			RDO1-36	A1	A2	S7	4	4	#N/A						SFO-DCS-004	SFO-CTRL4
1V7312	V27312-SY	SD1-V27312-SY	SD1 V27312	Actuator Valve for 1PU731A/B Discharge to 1HE311	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	73	74			14	11			RDO1-37	A1	A2	S7	5	5	#N/A						SFO-DCS-004	SFO-CTRL4
1V712	V2712-SY	SD1-V2712-SY	SD1 V2712	Actuator Valve for Stock Change	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	75	76			14	11			RDO1-38	A1	A2	S7	6	6	#N/A						SFO-DCS-004	SFO-CTRL4
1V711D	V2711D-SY	SD1-V2711D-SY	SD1 V2711D	Actuator Valve for Drain	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	77	78			14	11			RDO1-39	A1	A2	S7	7	7	#N/A						SFO-DCS-004	SFO-CTRL4
1V711	V2711-SY	SD1-V2711-SY	SD1 V2711	Actuator Valve for Stock Change	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	79	80			14	11			RDO1-40	A1	A2	S7	8	8	#N/A						SFO-DCS-004	SFO-CTRL4
1V6416	V26416-SY	SD1-V26416-SY	SD1 V26416	Actuator Valve for 1FL641A/B Outlet to 1VE701A/B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	81	82			14	11			RDO1-41	A1	A2	S7	9	9	#N/A						SFO-DCS-004	SFO-CTRL4
1V6415	V26415-SY	SD1-V26415-SY	SD1 V26415	Actuator Valve for 1FL641A/B Outlet to 1VE641	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	83	84			14	11			RDO1-42	A1	A2	S7	10	10	#N/A						SFO-DCS-004	SFO-CTRL4
1V7412P	V27412P-SY	SD1-V27412P-SY	SD1 V27412P	Actuator Valve for Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	85	86			14	11			RDO1-43	A1	A2	S7	11	11	#N/A						SFO-DCS-004	SFO-CTRL4
1V7412	V27412-SY	SD1-V27412-SY	SD1 V27412	Actuator Valve for RBD Oil to Tank Farm	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	87	88			14	11			RDO1-44	A1	A2	S7	12	12	#N/A						SFO-DCS-004	SFO-CTRL4
1V7411P	V27411P-SY	SD1-V27411P-SY	SD1 V27411P	Actuator Valve for Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	89	90			14	11			RDO1-45	A1	A2	S7	13	13	#N/A						SFO-DCS-004	SFO-CTRL4
1V7411	V27411-SY	SD1-V27411-SY	SD1 V27411	Actuator Valve for Recirculation of Oil to 1VE701A/B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-002	TB-DO	91	92			14	11			RDO1-46	A1	A2	S7	14	14	#N/A							

										RIO CABINET										SYSTEM CABINET									
										Relay										DELTA V									
										Name										Cabinet Name									
Vendor's tags	Wilmara's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller			
1V6233P	V26233P-ZC	SD1-V26233P-ZC	SD1 V26233P	Actuator Valve for Purging	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	157	158								S3	15	15	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6234	V26234-ZO	SD1-V26234-ZO	SD1 V26234	Actuator Valve for 1FL623 Filtrate to 1FL624A/B	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	159	160								S3	16	16	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6234	V26234-ZC	SD1-V26234-ZC	SD1 V26234	Actuator Valve for 1FL623 Filtrate to 1FL624A/B	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	161	162								S3	17	17	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6235	V26235-ZO	SD1-V26235-ZO	SD1 V26235	Actuated Valve for Discharge from 1FL623 to 1VE641	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	163	164								S3	18	18	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6235	V26235-ZC	SD1-V26235-ZC	SD1 V26235	Actuated Valve for Discharge from 1FL623 to 1VE641	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	165	166								S3	19	19	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6237	V26237-ZO	SD1-V26237-ZO	SD1 V26237	Actuated Valve for Discharge from 1FL623 to 1CL641	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	167	168								S3	20	20	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6237	V26237-ZC	SD1-V26237-ZC	SD1 V26237	Actuated Valve for Discharge from 1FL623 to 1CL641	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	169	170								S3	21	21	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V623P	V2623P-ZO	SD1-V2623P-ZO	SD1 V2623P	Actuator Valve for 1FL623 Cake Drying	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	171	172								S3	22	22	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V623P	V2623P-ZC	SD1-V2623P-ZC	SD1 V2623P	Actuator Valve for 1FL623 Cake Drying	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	173	174								S3	23	23	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V623PA	V2623PA-ZO	SD1-V2623PA-ZO	SD1 V2623PA	Actuator Valve for Purging	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	175	176								S3	24	24	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V623PA	V2623PA-ZC	SD1-V2623PA-ZC	SD1 V2623PA	Actuator Valve for Purging	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	177	178								S3	25	25	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V623PB	V2623PB-ZC	SD1-V2623PB-ZC	SD1 V2623PB	Actuator Valve for Purging	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	179	180								S3	26	26	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V623PB	V2623PB-ZO	SD1-V2623PB-ZO	SD1 V2623PB	Actuator Valve for Purging	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	181	182								S3	27	27	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6240	V26240-ZO	SD1-V26240-ZO	SD1 V26240	Actuated Valve for Discharge from 1FL621 to 1FL624A/B	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	183	184								S3	28	28	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6240	V26240-ZC	SD1-V26240-ZC	SD1 V26240	Actuated Valve for Discharge from 1FL621 to 1FL624A/B	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	185	186								S3	29	29	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6411	V26411-ZO	SD1-V26411-ZO	SD1 V26411	Actuator Valve for Recirculation of Oil to 1FL623	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	187	188								S3	30	30	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6411	V26411-ZC	SD1-V26411-ZC	SD1 V26411	Actuator Valve for Recirculation of Oil to 1FL623	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	189	190								S3	31	31	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6412	V26412P-ZO	SD1-V26412P-ZO	SD1 V26412P	Actuator Valve for 1PU641 Outlet to 1VE612	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	191	192								S3	32	32	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6412	V26412P-ZC	SD1-V26412P-ZC	SD1 V26412P	Actuator Valve for 1PU641 Outlet to 1VE612	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	193	194								S4	1	1	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6414	V26414-ZO	SD1-V26414-ZO	SD1 V26414	Actuator Valve for 1PU641 Outlet to 1FL641A/B	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	195	196								S4	2	2	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V6414	V26414-ZC	SD1-V26414-ZC	SD1 V26414	Actuator Valve for 1PU641 Outlet to 1FL641A/B	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	197	198								S4	3	3	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V641D	V2641D-ZO	SD1-V2641D-ZO	SD1 V2641D	Actuator Valve for Condensate from 1HE641 to 1TK735	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	200		199			A1	A2(comm)	RD11-01	14	11(comm)	S4	4	4	#N/A	SFO-DCS-004	SFO-CTRL4 2		
1V641D	V2641D-ZC	SD1-V2641D-ZC	SD1 V2641D	Actuator Valve for Condensate from 1HE641 to 1TK735	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	202		201			A1	A2	RD11-02	14	11	S4	5	5	#N/A	SFO-DCS-004	SFO-CTRL4 2		
1V641W	V2641W-ZO	SD1-V2641W-ZO	SD1 V2641W	Cooling Water Inlet for 1HE641	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	203	204								S4	6	6	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V641W	V2641W-ZC	SD1-V2641W-ZC	SD1 V2641W	Cooling Water Inlet for 1HE641	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	205	206								S4	7	7	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001A	V27001A-ZO	SD1-V27001A-ZO	SD1 V27001A	Actuator Valve for 1FL624A/B outlet to 1VE701A	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	207	208								S4	8	8	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001A	V27001A-ZC	SD1-V27001A-ZC	SD1 V27001A	Actuator Valve for 1FL624A/B outlet to 1VE701A	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	209	210								S4	9	9	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001B	V27001B-ZO	SD1-V27001B-ZO	SD1 V27001B	Actuator Valve for 1FL624A/B outlet to 1VE701B	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	211	212								S4	10	10	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001B	V27001B-ZC	SD1-V27001B-ZC	SD1 V27001B	Actuator Valve for 1FL624A/B outlet to 1VE701B	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	213	214								S4	11	11	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001C	V27001C-ZO	SD1-V27001C-ZO	SD1 V27001C	Actuator Valve for 1FL641A/B outlet to 1VE701A	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	215	216								S4	12	12	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001C	V27001C-ZC	SD1-V27001C-ZC	SD1 V27001C	Actuator Valve for 1FL641A/B outlet to 1VE701A	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	217	218								S4	13	13	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001D	V27001D-ZO	SD1-V27001D-ZO	SD1 V27001D	Actuator Valve for 1FL641A/B outlet to 1VE701B	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	219	220								S4	14	14	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V7001D	V27001D-ZC	SD1-V27001D-ZC	SD1 V27001D	Actuator Valve for 1FL641A/B outlet to 1VE701B	Valve close indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	221	222								S4	15	15	#N/A	SFO-DCS-004	SFO-CTRL4 2			
1V737	V2737-ZO	SD1-V2737-ZO	SD1 V2737	Actuator Valve for 1DE731 Oil drain from tray 6 to 7	Valve open indication	DI		PNP	2 wire	SD1-RI0-003	TB-DI	224		223															

										RIO CABINET										SYSTEM CABINET						
										Marshalling					Relay					DELTA V				DELTA V		
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
1V6213B	V26213B-SY	SD1-V26213B-SY	SD1 V26213B	Actuator Valve for 2FL621 Circulation to 2VE641	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	89	90			14	11	RDO1-45	A1	A2	S7	13	13	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6213A	V26213A-SY	SD1-V26213A-SY	SD1 V26213A	Actuator Valve for 2FL621 Circulation to 2VE612	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	91	92			14	11	RDO1-46	A1	A2	S7	14	14	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6212	V26212-SY	SD1-V26212-SY	SD1 V26212	Actuator Valve for 1FL621 Venting	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	93	94			14	11	RDO1-47	A1	A2	S7	15	15	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6211P	V26211P-SY	SD1-V26211P-SY	SD1 V26211P	Actuator Valve for 1FL621 Oil Inlet Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	95	96			14	11	RDO1-48	A1	A2	S7	16	16	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6211	V26211-SY	SD1-V26211-SY	SD1 V26211	Actuator Valve for 1FL621 Oil Inlet	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	97	98			14	11	RDO1-49	A1	A2	S7	17	17	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V621	V2621-SY	SD1-V2621-SY	SD1 V2621	Actuator Valve for 1FL621 Cake Discharge	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	99	100			14	11	RDO1-50	A1	A2	S7	18	18	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V737	V2737-SY	SD1-V2737-SY	SD1 V2737	Actuator Valve for 1DE731 Oil drain from tray 6 to 7	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	101	102			14	11	RDO1-51	A1	A2	S7	19	19	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V621PAB	V2621PAB-SY	SD1-V2621PAB-SY	SD1 V2621PAB	Actuator Valve for Compressed Air Supply to 1FL621 Vibrator	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	103	104			14	11	RDO1-52	A1	A2	S7	20	20	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V621PBB	V2621PBB-SY	SD1-V2621PBB-SY	SD1 V2621PBB	Actuator Valve for Compressed Air Supply to 1FL621 Vibrator	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	105	106			14	11	RDO1-53	A1	A2	S7	21	21	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6223B	V26223B-SY	SD1-V26223B-SY	SD1 V26223B	Actuator Valve for 2FL622 Circulation to 2VE641	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	107	108			14	11	RDO1-54	A1	A2	S7	22	22	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6223AP	V26223AP-SY	SD1-V26223AP-SY	SD1 V26223AP	Actuator Valve for Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	109	110			14	11	RDO1-55	A1	A2	S7	23	23	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V622PAB	V2622PAB-SY	SD1-V2622PAB-SY	SD1 V2622PAB	Actuator Valve for Compressed Air Supply to 1FL622 Vibrator	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	111	112			14	11	RDO1-56	A1	A2	S7	24	24	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V622PBB	V2622PBB-SY	SD1-V2622PBB-SY	SD1 V2622PBB	Actuator Valve for Compressed Air Supply to 1FL622 Vibrator	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	113	114			14	11	RDO1-57	A1	A2	S7	25	25	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6231B	V26231B-SY	SD1-V26231B-SY	SD1 V26231B	Actuator Valve for Inlet to 1FL623	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	115	116			14	11	RDO1-58	A1	A2	S7	26	26	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6234A	V26234A-SY	SD1-V26234A-SY	SD1 V26234A	Actuator Valve for 1FL623 Filtrate to 1FL624A	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	117	118			14	11	RDO1-59	A1	A2	S7	27	27	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6234B	V26234B-SY	SD1-V26234B-SY	SD1 V26234B	Actuator Valve for 1FL623 Filtrate to 1FL624B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	119	120			14	11	RDO1-60	A1	A2	S7	28	28	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6234C	V26234C-SY	SD1-V26234C-SY	SD1 V26234C	Actuated Valve for Discharge from 1FL623 to 1FL641A/B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	121	122			14	11	RDO1-61	A1	A2	S7	29	29	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6234CP	V26234CP-SY	SD1-V26234CP-SY	SD1 V26234CP	Actuator Valve for Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	123	124			14	11	RDO1-62	A1	A2	S7	30	30	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6234P	V26234P-SY	SD1-V26234P-SY	SD1 V26234P	Actuator Valve for Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	125	126			14	11	RDO1-63	A1	A2	S7	31	31	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6238	V26238-SY	SD1-V26238-SY	SD1 V26238	Actuated Valve for Discharge from 1FL623 to 1CL641	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	127	128			14	11	RDO1-64	A1	A2	S7	32	32	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6240A	V26240A-SY	SD1-V26240A-SY	SD1 V26240A	Actuated Valve for Discharged Oil from 1V6240 to 1FL624A	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	129	130			14	11	RDO1-65	A1	A2	S8	1	1	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6240B	V26240B-SY	SD1-V26240B-SY	SD1 V26240B	Actuated Valve for Discharged Oil from 1V6240 to 1FL624B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	131	132			14	11	RDO1-66	A1	A2	S8	2	2	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6241	V26241-SY	SD1-V26241-SY	SD1 V26241	Actuated Valve for Discharge from 1FL6212to 1FL624B/A	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	133	134			14	11	RDO1-67	A1	A2	S8	3	3	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6241A	V26241A-SY	SD1 V26241A	SD1 V26241A	Actuated Valve for Discharged Oil from 1V6241 to 1FL624A	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	135	136			14	11	RDO1-68	A1	A2	S8	4	4	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V6241B	V26241B-SY	SD1 V26241B	SD1 V26241B	Actuated Valve for Discharged Oil from 1V6241 to 1FL624B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	137	138			14	11	RDO1-69	A1	A2	S8	5	5	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V7001E	V27001E-SY	SE1-V27001E-SY	SD1 V27001E	Actuator Valve for 1FL624A/B outlet to 1VE701A	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	139	140			14	11	RDO1-70	A1	A2	S8	6	6	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V7001F	V27001F-SY	SE1-V27001F-SY	SD1 V27001F	Actuator Valve for 1FL624A/B outlet to 1VE701B	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	141	142			14	11	RDO1-71	A1	A2	S8	7	7	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V701S	V2701S-SY	SD1 V2701S	SD1 V2701S	Actuator Valve for Steam Purging	Valve open command	DO		24VDC Wet Supply	2 wire	SD1-RIO-003	TB-D00	143	144			14	11	RDO1-72	A1	A2	S8	8	8	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	145	146			14	11	RDO1-73	A1	A2	S8	9	9	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	147	148			14	11	RDO1-74	A1	A2	S8	10	10	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	149	150			14	11	RDO1-75	A1	A2	S8	11	11	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	151	152			14	11	RDO1-76	A1	A2	S8	12	12	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	153	154			14	11	RDO1-77	A1	A2	S8	13	13	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	155	156			14	11	RDO1-78	A1	A2	S8	14	14	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	157	158			14	11	RDO1-79	A1	A2	S8	15	15	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	159	160			14	11	RDO1-80	A1	A2	S8	16	16	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	161	162			14	11	RDO1-81	A1	A2	S8	17	17	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	163	164			14	11	RDO1-82	A1	A2	S8	18	18	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	165	166			14	11	RDO1-83	A1	A2	S8	19	19	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	167	168			14	11	RDO1-84	A1	A2	S8	20	20	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	169	170			14	11	RDO1-85	A1	A2	S8	21	21	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	171	172			14	11	RDO1-86	A1	A2	S8	22	22	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	173	174			14	11	RDO1-87	A1	A2	S8	23	23	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	175	176			14	11	RDO1-88	A1	A2	S8	24	24	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	177	178			14	11	RDO1-89	A1	A2	S8	25	25	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	179	180			14	11	RDO1-90	A1	A2	S8	26	26	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	181	182			14	11	RDO1-91	A1	A2	S8	27	27	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	183	184			14	11	RDO1-92	A1	A2	S8	28	28	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	185	186			14	11	RDO1-93	A1	A2	S8	29	29	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	187	188			14	11	RDO1-94	A1	A2	S8	30	30	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	189	190			14	11	RDO1-95	A1	A2	S8	31	31	#N/A	SFO-DCS-004	SFO-CTRL4_2
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-003	TB-D00	191	192			14	11	RDO1-96	A1	A2(comm)	S8	32	32	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V736	V2736-ZO	SD1-V2736-ZO	SD1 V2736	Actuator Valve for 1DE731 Oil drain from tray 5 to 6	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-D1	2		1		A1	A2(comm)	RDI1-01	14	11(comm)	S1	1	1	#N/A	SFO-DCS-004	SFO-CTRL4_2
1V736-ZC	V2736-ZC	SD1-V2736-ZC	SD1 V2736	Actuator Valve for 1DE731 Oil drain from tray 5 to 6	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-D1	4		3		A1	A2	RDI1-								

										RIO CABINET										SYSTEM CABINET				
										Relay										DELTA V				
										DELTA V										DELTA V				
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)
1V7311S	V27311S-ZO	SD1-V27311S-ZO	SD1 V27311S	Actuator Valve for 1DE731 Measuring Tray Steam Supply	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	149	150								S3	11	11	#N/A
1V7311S	V27311S-ZC	SD1-V27311S-ZC	SD1 V27311S	Actuator Valve for 1DE731 Measuring Tray Steam Supply	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	151	152								S3	12	12	#N/A
1V713	V2713-ZO	SD1-V2713-ZO	SD1 V2713	Actuator Valve for 1FL711A/B to 1DE731	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	153	154								S3	13	13	#N/A
1V713	V2713-ZC	SD1-V2713-ZC	SD1 V2713	Actuator Valve for 1FL711A/B to 1DE731	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	155	156								S3	14	14	#N/A
1LSL736	LSL2736	SD1-LSL2736	SD1 LSL2736	Level Switch for Tray 5 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	157	158	+1	-1						S3	15	15	#N/A
1LSL611A	LSL2611A	SD1-LSL2611A	SD1 LSL2611A	Level Switch for 1VE611A Low Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	159	160	+2	-2						S3	16	16	#N/A
1LSL611A	LSL2611A	SD1-LSL2611A	SD1 LSL2611A	Level Switch for 1VE611A Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	161	162	+3	-3						S3	17	17	#N/A
1V6413	V26413-ZO	SD1-V26413-ZO	SD1 V26413	Actuator Valve for 1VE641 Outlet to 1PU621/2	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	163	164								S3	18	18	#N/A
1V6413	V26413-ZC	SD1-V26413-ZC	SD1 V26413	Actuator Valve for 1VE641 Outlet to 1PU621/2	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	165	166								S3	19	19	#N/A
1LSL1312	LSL12012	SD1-LSL12012	SD1 LSL2012	Level Switch for 1MX312 Low Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	167	168	+4	-4						S3	20	20	#N/A
Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	Spare	SD1-RIO-004	TB-DI	169	170								S3	21	21	#N/A
1LSL734	LSL2734	SD1-LSL2734	SD1 LSL2734	Level Switch for Tray 3 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	171	172	+5	-5						S3	22	22	#N/A
1LSHH611A	LSHH2611A	SD1-LSHH2611A	SD1 LSHH2611A	Level Switch for 1VE611A High High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	173	174	+6	-6						S3	23	23	#N/A
1LSH611A	LSH2611A	SD1-LSH2611A	SD1 LSH2611A	Level Switch for 1VE611A High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	175	176	+7	-7						S3	24	24	#N/A
1LSL733	LSL2733	SD1-LSL2733	SD1 LSL2733	Level Switch for Tray 2 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	177	178	+8	-8						S3	25	25	#N/A
1LSL732	LSL2732	SD1-LSL2732	SD1 LSL2732	Level Switch for Tray 1 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	179	180	+9	-9						S3	26	26	#N/A
1LSL632B	LSL2632B	SD1-LSL2632B	SD1 LSL2632B	Level Switch for 1TK632B Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	181	182	+10	-10						S3	27	27	#N/A
1LSL632A	LSL2632A	SD1-LSL2632A	SD1 LSL2632A	Level Switch for 1TK632A Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	183	184	+11	-11						S3	28	28	#N/A
1LS631B	LS2631B	SD1-LS2631B	SD1 LS2631B	Level Switch for 1TK631B Low Level	Capacitive	DI		PNP	3 wire	SD1-RIO-004	TB-DI	185	186	+		A1	A2	RD1-21	14	11	S3	29	29	#N/A
1LS631A	LS2631A	SD1-LS2631A	SD1 LS2631A	Level Switch for 1TK631A Low Level	Capacitive	DI		PNP	3 wire	SD1-RIO-004	TB-DI	187	188	+		A1	A2(comm)	RD1-22	14	11(comm)	S3	30	30	#N/A
1LSHH731	LSHH2731	SD1-LSHH2731	SD1 LSHH2731	Level Switch for Measuring tray High High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	189	190	+12	-12						S3	31	31	#N/A
1LSH632B	LSH2632B	SD1-LSH2632B	SD1 LSH2632B	Level Switch for 1TK632B High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	191	192	+13	-13						S3	32	32	#N/A
1LSH632A	LSH2632A	SD1-LSH2632A	SD1 LSH2632A	Level Switch for 1TK632A High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	193	194	+14	-14						S4	1	1	#N/A
1LSHT733A	LSH2733A	SD1-LSH2733A	SD1 LSH2733A	Level Switch for 1VE733 High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	195	196	+15	-15						S4	2	2	#N/A
1LSHT735W	LSH2735W	SD1-LSH2735W	SD1 LSH2735W	Level Switch for 1TK735 High Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	197	198	+16	-16						S4	3	3	#N/A
1LSL312	LSL2012	SD1-LSL2012	SD1 LSL2012	Level Switch for 1MX312 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	199	200	+17	-17						S4	4	4	#N/A
1LSL731	LSL2731	SD1-LSL2731	SD1 LSL2731	Level Switch for Measuring Tray Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	201	202	+18	-18						S4	5	5	#N/A
1LSL733A	LSL2733A	SD1-LSL2733A	SD1 LSL2733A	Level Switch for 1VE733 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	203	204	+19	-19						S4	6	6	#N/A
1LSL735W	LSL2735W	SD1-LSL2735W	SD1 LSL2735W	Level Switch for 1TK735 Low Level	Tuning Fork	DI		DI Dry contact	2 wire supply 24VDC+2 wire dry cont.	SD1-RIO-004	TB-DI	205	206	+20	-20						S4	7	7	#N/A
1V611A	V2611A-ZO	SD1-V2611A-ZO	SD1 V2611A	Actuator Valve for 1VE611A Outlet to 1VE611B	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	207	208								S4	8	8	#N/A
1V611A	V2611A-ZC	SD1-V2611A-ZC	SD1 V2611A	Actuator Valve for 1VE611A Outlet to 1VE611B	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	209	210								S4	9	9	#N/A
1V621NA	V2621NA-ZO	SD1-V2621NA-ZO	SD1 V2621NA	Solenoid Valve	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	211	212								S4	10	10	#N/A
1V621NA	V2621NA-ZC	SD1-V2621NA-ZC	SD1 V2621NA	Solenoid Valve	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	213	214								S4	11	11	#N/A
1V621NB	V2621NB-ZO	SD1-V2621NB-ZO	SD1 V2621NB	Solenoid Valve	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	215	216								S4	12	12	#N/A
1V621NB	V2621NB-ZC	SD1-V2621NB-ZC	SD1 V2621NB	Solenoid Valve	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	217	218								S4	13	13	#N/A
1V622NA	V2622NA-ZO	SD1-V2622NA-ZO	SD1 V2622NA	Solenoid Valve	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	219	220								S4	14	14	#N/A
1V622NA	V2622NA-ZC	SD1-V2622NA-ZC	SD1 V2622NA	Solenoid Valve	Valve close indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	221	222								S4	15	15	#N/A
1V622NB	V2622NB-ZO	SD1-V2622NB-ZO	SD1 V2622NB	Solenoid Valve	Valve open indication	DI		PNP	2 wire	SD1-RIO-004	TB-DI	223												

										RIO CABINET										SYSTEM CABINET						
										Marshalling				Relay		DELTA V				DELTA V						
Vendor's tags	Wilmar's Tags	Emerson's Tags	Module Name	Description	Type	I/O Type	Range Proposed (kg/H)	Signal Type	Electrical Connection	Cabinet Name	TB Name	Term. (+)	Term. (-)	24V(+) Term.	24V(-) Term.	Term. (+)	Term. (-)	Name	Term. (+)	Term. (-)	Slot	Channel	Term. (+)	Term. (-)	Cabinet Name	Controller
PU321	PU2021-HS	SD1-PU2021-HS	SD1 PU2021	Phosphoric Acid Pump	Motor start command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU321	PU2021-XL	SD1-PU2021-XL	SD1 PU2021	Phosphoric Acid Pump	Motor run feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU321	PU2021-XA	SD1-PU2021-XA	SD1 PU2021	Phosphoric Acid Pump	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU321	PU2021-CU	SD1-PU2021-CU	SD1 PU2021	Phosphoric Acid Pump	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU321	PU2021-SP	SD1-PU2021-SP	SD1 PU2021	Phosphoric Acid Pump	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU321	PU2021-SC	SD1-PU2021-SC	SD1 PU2021	Phosphoric Acid Pump	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU322	PU2022-HS	SD1-PU2022-HS	SD1 PU2022	Citric Acid Pump	Motor start command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU322	PU2022-XL	SD1-PU2022-XL	SD1 PU2022	Citric Acid Pump	Motor run feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU322	PU2022-XA	SD1-PU2022-XA	SD1 PU2022	Citric Acid Pump	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU322	PU2022-CU	SD1-PU2022-CU	SD1 PU2022	Citric Acid Pump	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU322	PU2022-SP	SD1-PU2022-SP	SD1 PU2022	Citric Acid Pump	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU322	PU2022-SC	SD1-PU2022-SC	SD1 PU2022	Citric Acid Pump	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761A	PU2761A-HS	SD1-PU2761A-HS	SD1 PU2761A	Citric Acid And Anti Oxidant Pump A	Motor start command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761A	PU2761A-XL	SD1-PU2761A-XL	SD1 PU2761A	Citric Acid And Anti Oxidant Pump A	Motor run feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761A	PU2761A-XA	SD1-PU2761A-XA	SD1 PU2761A	Citric Acid And Anti Oxidant Pump A	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761A	PU2761A-CU	SD1-PU2761A-CU	SD1 PU2761A	Citric Acid And Anti Oxidant Pump A	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761A	PU2761A-SP	SD1-PU2761A-SP	SD1 PU2761A	Citric Acid And Anti Oxidant Pump A	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761A	PU2761A-SC	SD1-PU2761A-SC	SD1 PU2761A	Citric Acid And Anti Oxidant Pump A	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761B	PU2761B-HS	SD1-PU2761B-HS	SD1 PU2761B	Citric Acid And Anti Oxidant Pump B	Motor start command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761B	PU2761B-XL	SD1-PU2761B-XL	SD1 PU2761B	Citric Acid And Anti Oxidant Pump B	Motor run feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761B	PU2761B-XA	SD1-PU2761B-XA	SD1 PU2761B	Citric Acid And Anti Oxidant Pump B	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761B	PU2761B-CU	SD1-PU2761B-CU	SD1 PU2761B	Citric Acid And Anti Oxidant Pump B	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761B	PU2761B-SP	SD1-PU2761B-SP	SD1 PU2761B	Citric Acid And Anti Oxidant Pump B	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761B	PU2761B-SC	SD1-PU2761B-SC	SD1 PU2761B	Citric Acid And Anti Oxidant Pump B	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761C	PU2761C-HS	SD1-PU2761C-HS	SD1 PU2761C	Citric Acid And Anti Oxidant Pump C	Motor start command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761C	PU2761C-XL	SD1-PU2761C-XL	SD1 PU2761C	Citric Acid And Anti Oxidant Pump C	Motor run feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761C	PU2761C-XA	SD1-PU2761C-XA	SD1 PU2761C	Citric Acid And Anti Oxidant Pump C	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761C	PU2761C-CU	SD1-PU2761C-CU	SD1 PU2761C	Citric Acid And Anti Oxidant Pump C	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761C	PU2761C-SP	SD1-PU2761C-SP	SD1 PU2761C	Citric Acid And Anti Oxidant Pump C	Motor trip feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU761C	PU2761C-SC	SD1-PU2761C-SC	SD1 PU2761C	Citric Acid And Anti Oxidant Pump C	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
CT-306	CT306-XL	SD1-CT306-XL	SD1 CT306	Cooling Tower	Motor run feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
CT-306	CT306-XA	SD1-CT306-XA	SD1 CT306	Cooling Tower	Motor trip feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
CT-306	CT306-HS	SD1-CT306-HS	SD1 CT306	Cooling Tower	Motor start command	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU301	PU2001-SC	SD1-PU2001-SC	SD1 PU2001	Feed Oil Pump	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU301	PU2001-CU	SD1-PU2001-CU	SD1 PU2001	Feed Oil Pump	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU301	PU2001-SP	SD1-PU2001-SP	SD1 PU2001	Feed Oil Pump	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU301	PU2001-XL	SD1-PU2001-XL	SD1 PU2001	Feed Oil Pump	Motor run feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU301	PU2001-XA	SD1-PU2001-XA	SD1 PU2001	Feed Oil Pump	Motor trip feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU301	PU2001-HS	SD1-PU2001-HS	SD1 PU2001	Feed Oil Pump	Motor start command	Profinet		24VDC Wet Supply	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731A	PU2731A-SC	SD1-PU2731A-SC	SD1 PU2731A	Deodoriser Discharge Pump	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731A	PU2731A-CU	SD1-PU2731A-CU	SD1 PU2731A	Deodoriser Discharge Pump	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731A	PU2731A-SP	SD1-PU2731A-SP	SD1 PU2731A	Deodoriser Discharge Pump	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731A	PU2731A-XL	SD1-PU2731A-XL	SD1 PU2731A	Deodoriser Discharge Pump	Motor run feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731A	PU2731A-XA	SD1-PU2731A-XA	SD1 PU2731A	Deodoriser Discharge Pump	Motor trip feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731A	PU2731A-HS	SD1-PU2731A-HS	SD1 PU2731A	Deodoriser Discharge Pump	Motor start command	Profinet		24VDC Wet Supply	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731B	PU2731B-SC	SD1-PU2731B-SC	SD1 PU2731B	Deodoriser Discharge Pump	Motor speed command	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731B	PU2731B-CU	SD1-PU2731B-CU	SD1 PU2731B	Deodoriser Discharge Pump	Motor current feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731B	PU2731B-SP	SD1-PU2731B-SP	SD1 PU2731B	Deodoriser Discharge Pump	Motor speed feedback	Profinet				SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731B	PU2731B-XL	SD1-PU2731B-XL	SD1 PU2731B	Deodoriser Discharge Pump	Motor run feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731B	PU2731B-XA	SD1-PU2731B-XA	SD1 PU2731B	Deodoriser Discharge Pump	Motor trip feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
PU731B	PU2731B-HS	SD1-PU2731B-HS	SD1 PU2731B	Deodoriser Discharge Pump	Motor start command	Profinet		24VDC Wet Supply	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
CT-306	CT306-SC	SD1-CT306-SC	SD1 CT306	Cooling Tower	Motor speed command	Profinet		4-20 mA	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
CT-306	CT306-CU	SD1-CT306-CU	SD1 CT306	Cooling Tower	Motor current feedback	Profinet		DI Dry Contact	2 wire	SFO-DCS-004															SFO-DCS-004	SFO-CTRL4 2
CT-306	CT306-SP	SD1-CT306-SP	SD1 CT306	Cooling Tower	Motor speed feedback	Profinet		4-20 mA	2 wire	SFO-DCS-004																