

CERTIFICATE OF COMPLIANCE

Certificate Number 20150210-R25577
Report Reference R25577-20150129
Issue Date 2015-FEBRUARY-10

Issued to: PCJ INDUSTRIES CO LTD
199/24-25 VIBHAVADEERANGSIT RD
SAMSENNAI
PAYATHAI 10400 THAILAND

**This is to certify that
representative samples of**

SWINGING TYPE FIRE DOORS, POSITIVE PRESSURE
TESTED ; SWINGING TYPE FIRE DOORS
Model FRD, swinging-type fire door assembly of the hollow
metal type with Max 100 sq in. glazing material, 3 Hr rating.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/UL 10B - Fire Tests of Door Assemblies
ANSI/UL 10C - Positive Pressure Fire Tests Of Door
Assemblies
CAN/ULC-S104 - Standard Method for Fire Tests of Door
Assemblies

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

