

A Multilevel Voltage–Source Inverter with Separate DC Sources for Static Var Generation

Fang Zheng Peng, *Senior Member, IEEE*, Jih-Sheng Lai, *Senior Member, IEEE*,
John W. McKeever, and James VanCoevering, *Member, IEEE*

Abstract—A new multilevel voltage–source inverter with separate dc sources is proposed for high-voltage, high-power applications, such as flexible ac transmission systems (FACTS) including static var generation (SVG), power-line conditioning, series compensation, phase shifting, voltage balancing, fuel cell, and photovoltaic utility systems interfacing, etc. The new M -level inverter consists of $(M-1)/2$ single-phase full bridges in which each bridge has its own separate dc source. This inverter can generate almost sinusoidal waveform voltage with only one time switching per cycle as the number of levels increases. It can solve the size-and-weight problems of conventional transformer-based multipulse inverters and the component-counts problems of multilevel diode-clamp and flying-capacitor inverters. To demonstrate the superiority of the new inverter, an SVG system using the new inverter topology is discussed through analysis, simulation, and experiment.

I. INTRODUCTION

A. Background

WITH long-distance ac power transmission and load growth, active control of reactive power (var) is indispensable to stabilize the power systems and to maintain the supply voltage. Static var generators (SVG's) using voltage–source inverters have been widely accepted as the next-generation reactive power controllers of power systems to replace the conventional var compensators, such as thyristor switched capacitors (TSC's) and thyristor controlled reactors (TCR's) [1]–[9].

Fig. 1 shows a typical 48-pulse inverter for static var generation applications. The 48-pulse inverter consists of eight 6-pulse inverters connected together through eight zigzag-arrangement transformers using the harmonic cancellation technique [2], or connected through Wye/Delta and Delta/Delta connection transformers and using sophisticated control schemes, in order to reduce harmonic distortion and to reach high voltage. These transformers, or harmonic neutralizing magnetics:

- 1) are the most expensive equipment in the system;

Paper IPCSD 96-13, approved by the Industrial Power Converter Committee of the IEEE Industry Applications Society for presentation at the 1995 IEEE Industry Applications Society Annual Meeting, Lake Buena Vista, FL, October 8–12. This work was prepared by the Oak Ridge National Laboratory, Oak Ridge, TN 37831-8058, and managed by Lockheed Martin Energy Research Corp. for the U.S. Department of Energy under Contract DE-AC05-96OR22464. Manuscript released for publication February 5, 1996.

F. Z. Peng is with the University of Tennessee, Knoxville, and Oak Ridge National Laboratory, Oak Ridge, TN 37831-8058 USA.

J.-S. Lai, J. W. McKeever, and J. VanCoevering are with the Oak Ridge National Laboratory, Oak Ridge, TN 37831-8058 USA.

Publisher Item Identifier S 0093-9994(96)05092-X.

- 2) produce about 50% of the total losses of the system;
- 3) occupy up to 40% of the total system's real estate, which is an excessively large area;
- 4) cause difficulties in control due to dc magnetizing and surge overvoltage problems resulting from saturation of the transformers in transient states; and
- 5) are prone to failure.

To solve these problems, a diode-clamped multilevel inverter and a flying-capacitor multilevel inverter have been proposed for SVG applications [6], [7], [9], [12]. These multilevel inverters can eliminate the transformers required in an SVG using conventional 6-pulse inverters; however, they encounter new problems.

B. Multilevel Inverters and Their Problems

In recent years, a relatively new type of inverters, multilevel voltage source inverters, has attracted many researchers' attention [10]. Multilevel inverters can reach high voltage and reduce harmonics by their own structures without transformers, a benefit that many contributors have been trying to appropriate for high-voltage, high-power applications [11].

Fig. 2 shows the structure of a 5-level diode-clamp inverter. This inverter can reach high performance without transformers. It does, however, require additional clamping diodes. For this 5-level inverter, obviously, D1, D2, and D3 need to block $1V_{dc}$, $2V_{dc}$, and $3V_{dc}$, respectively, assuming each dc capacitor has the same dc voltage, V_{dc} . When diodes are selected to have the same voltage rating as the main switching devices, D2 and D3 comprise two diodes in series and three diodes in series, respectively, to withstand the voltage. Therefore, the number of the additional clamping diodes is equal to $(M-1) \times (M-2) \times 3$ for an M -level inverter. For example, if $M = 51$ (for direct connection to 69 kV power lines), then the number of the clamping diodes will be 7350. These clamping diodes not only raise costs but also cause packaging problems and exhibit parasitic inductances; thus, the number of levels for a multilevel diode-clamped inverter may be limited to seven or nine in practical use [7], [12].

A relatively new structure, the multilevel flying-capacitor inverter [9], is supposed to be able to solve the voltage unbalance problem [7], [13] and excessive diode count in multilevel diode clamped inverters. Fig. 3 shows the configuration of a 5-level flying-capacitor inverter. In this inverter, however, a large number of flying capacitors are needed. The required number of flying capacitors for an M -level inverter, provided that the voltage rating of each capacitor used is the same




Fig. 1. Structure of the conventional 48-pulse inverter.

as the main power switches, is determined by the formula, $(M - 1) \times (M - 2) \times 3/2 + (M - 1)$. With the assumption of the same capacitor voltage rating, an M -level diode clamped inverter only requires $(M - 1)$ capacitors. Therefore, the flying capacitor inverter requires large capacitance compared with the conventional inverter [9]. In addition, control is very complicated, and higher switching frequency is required to balance each capacitor voltage [13].

A new type of multilevel inverter is proposed here to solve all the above-mentioned problems of the conventional multipulse and multilevel inverters. This new multilevel inverter eliminates the excessively large number of 1) bulky transformers required by conventional multipulse inverters, 2) clamping diodes required by multilevel diode-clamped inverters, and 3) flying capacitors required by multilevel flying-capacitor inverters. Also, it has the following features.

- 1) It is much more suitable to high-voltage, high-power applications than the conventional inverters.




Fig. 2. Structure of the 5-level diode clamped inverter.




Fig. 3. Structure of the 5-level flying capacitor inverter.

- 2) It switches each device only once per line cycle and generates a multistep staircase voltage waveform approaching a pure sinusoidal output voltage by increasing the number of levels.
- 3) Since the inverter structure itself consists of a cascade connection of many single-phase, full-bridge inverter (FBI) units and each bridge is fed with a separate dc source, it does not require voltage balance (sharing) circuits or voltage matching of the switching devices.
- 4) Packaging/layout is much easier because of the simplicity of structure and lower component count.

II. A NEW MULTILEVEL INVERTER

A. Inverter Structure and Operating Principle

Fig. 4 shows the single-phase configuration of the proposed multilevel separate dc-source inverter. It consists of $(M - 1)/2$ single-phase FBI units connected in cascade to generate an M level output voltage over half fundamental cycle. Each full-bridge inverter has its own dc source. This new inverter, hereafter called a cascade inverter, does not require any transformers, clamping diodes, or flying capacitors, which are required in today's multilevel inverters.

Figs. 5 and 6 show three-phase structures of the proposed cascade inverter (level number $M = 9$). Fig. 5 is used as




Fig. 4. Single-phase structure of multilevel cascade inverter.




Fig. 5. Three-phase Wye-connection structure of 9-level cascade inverter.

an example to explain its operating principle. Fig. 7 shows waveforms generated by the 9-level cascade inverter shown in Fig. 5. The output phase voltage is the sum of four inverter units' outputs. That is, $v_{Can} = v_{Ca1} + v_{Ca2} + v_{Ca3} + v_{Ca4}$. Each FBI unit can generate three-level output, $+V_{dc}$, 0, and $-V_{dc}$. This is made possible by connecting the dc-source sequentially to the ac side via the four switching devices. Note that each device is switched only once per line cycle.

Since the phase current i_{Ca} is leading or lagging the phase voltage v_{Can} by 90° , the average charge to each dc capacitor is equal to zero over every half line cycle. From Fig. 7, the average charge to each dc capacitor over half cycle $[0, \pi]$, Q_i , can be expressed as

$$Q_i = \int_{\theta_i}^{\pi-\theta_i} \sqrt{2}I \cos \theta d\theta = 0 \quad (1)$$

where $i = 1, 2, 3, 4$; $[\theta_i, \pi - \theta_i]$ represents the time interval




Fig. 6. Three-phase Delta-connection structure of 9-level cascade inverter.




Fig. 7. Waveforms of the 9-level cascade inverter shown in Fig. 5.

during which the dc capacitor connects to the ac side, and I is the rms value of the line current. Because of this symmetric charge flow, voltages on all the dc capacitors remain theoretically balanced.

B. System Configuration and Control Scheme of SVGs

Fig. 8 shows the system configuration and control block diagram of an SVG using the new cascade inverter, where v_S represents the source voltage, L_S is the source impedance, and L_C is the inverter interface inductance. The switching pattern table shown in Fig. 8 contains switching timings for the inverter to generate the desired output voltage as shown in Fig. 7. The switching angles, θ_i [$i = 1, 2, \dots, (M-1)/2$], are calculated off-line to minimize harmonics for each modulation index (MI), which is defined as V_C^*/V_{Cmax} , where V_C^* is the amplitude command of the inverter output phase voltage, and V_{Cmax} is the maximum obtainable amplitude, i.e., the




Fig. 8. System configuration of an SVG using the cascade inverter.

amplitude of the phase voltage when all the switching angles, θ_i are equal to zero. As mentioned in Section II-A, the average charge on each dc capacitor will be zero if each FBI unit's output voltage v_{Ci} lags or leads the line current i_C by exactly 90° as shown in Fig. 7, which means that no real power flows into the dc capacitor; however, with no power delivered to the dc capacitors, the dc capacitor voltage cannot be maintained due to switching device loss and capacitor loss. Therefore, the inverter should be controlled so that some real power is delivered to the dc capacitors. In principle, each dc capacitor voltage can be controlled to be exactly the dc command voltage, V_{dc}^* . The control block diagram shown in Fig. 8 includes two control loops. The outer loop controls the total power flow to all the FBI units, whereas the inner loop offsets power flow into each individual unit. The control principle can be explained with the aid of Fig. 9. In Fig. 9, v_S is the source voltage, i_C is the current flowing into the inverter, and v_C is the inverter output voltage. If v_C is controlled so that it lags v_S by α_C , then the total real power P_i flowing into the inverter is

$$P_i = \frac{V_S V_C \sin \alpha_C}{X_{Lc}} \quad (2)$$

where X_{Lc} is the impedance of interface inductor. Since inverter devices are not ideal and have different tolerance errors, each dc capacitor voltage may not be exactly balanced with the outer loop only. If the i th FBI unit's output voltage v_{Ci} is as shown with the lighter wider line in Fig. 9, then the average charge into the dc capacitor over each half cycle, the area shown by the lighter shadow, will be almost zero. However, if v_{Ci} is shifted ahead by $\Delta\alpha_{Ci}$ as shown by the darker line waveform in the figure, then the charge shown by the darker area can be expressed as

$$\begin{aligned} Q_i &= \int_{\theta_i - \Delta\alpha_{Ci}}^{\pi - \theta_i - \Delta\alpha_{Ci}} \sqrt{2}I \cos \theta d\theta \\ &= 2\sqrt{2}I \cos \theta_i \sin \Delta\alpha_{Ci} \end{aligned} \quad (3)$$

which is proportional to $\Delta\alpha_{Ci}$ when $\Delta\alpha_{Ci}$ is small. Therefore, each FBI unit's dc voltage can be controlled by slightly shifting the switching pattern. The magnitude of this shift is




Fig. 9. Control principle of each dc capacitor voltage.

usually much smaller than α_C . For high-voltage high-power applications, the total power loss of the inverter is typically less than 1%, thus $\Delta\alpha_{Ci} \ll \alpha_C < 0.01$ rad.

III. REQUIRED CAPACITANCE OF DC CAPACITORS

The above description has shown that the proposed cascade inverter has the simplest structure and least components, compared with the conventional multipulse inverter, the diode-clamped multilevel inverter, and the flying-capacitor multilevel inverter. However, the new inverter's capacitor requirements are higher than the conventional multipulse inverter and the diode-clamped multilevel inverter. Here, the required capacitance of the cascade inverter will be formulated and compared with that of the conventional multipulse inverter.

A. For the Conventional Multipulse Inverters

It is generally required that an SVG has the capability to generate 100% negative-sequence var for unbalanced loads or in case of phase fault. The authors have investigated five existing SVG sets running in Japan [16] and discovered that most of them were designed this way, yet the used dc capacitors are far smaller, lighter, and much more efficient than the transformers used in those SVG's. Therefore, the required capacitance C_{dc} of dc capacitors used in the conventional inverter shown in Fig. 1 should accommodate this generation of 100% negative-sequence var and can be expressed as

$$\frac{1}{2} C_{dc} (V_{DC \max}^2 - V_{DC \min}^2) = \int_0^{T/4} Q_{\text{var}} \sin 2\omega t dt \quad (4)$$

or

$$\begin{aligned} C_{dc} &= \frac{2Q_{\text{var}}}{\omega(V_{DC \max}^2 - V_{DC \min}^2)} \\ &= \frac{Q_{\text{var}}}{2\omega\varepsilon V_{DC}^2} \end{aligned} \quad (5)$$

where $V_{DC \max}$ and $V_{DC \min}$ represent the maximum and minimum values of dc voltage, respectively, Q_{var} is the var rating, T is the line period, and ω is the line frequency. V_{DC} is the average dc voltage, $V_{DC} = (V_{DC \max} + V_{DC \min})/2$.

ε is the regulation factor of dc voltage, $\varepsilon = (V_{DC\max} - V_{DC\min})/(2V_{DC})$, whose value may range from 5–20% for practical use. Therefore, given an allowable regulation factor ε , average dc voltage V_{DC} , and var rating Q_{var} , one can obtain the required capacitance C_{dc} from (5).

B. For the Cascade Inverters

For the proposed cascade inverter, since each phase has its own separate dc capacitors, calculation of the required capacitance of each FBI unit's dc capacitor is straightforward and automatically covers both positive-sequence and negative-sequence reactive power. The required capacitance C_i can be formulated from Fig. 7 as

$$C_i = \frac{\Delta Q_i}{\Delta V_{dc}} = \frac{\int_{\theta_i(t)}^{T/4} \sqrt{2}I \cos \omega t dt}{2\varepsilon V_{dc}} = \frac{\sqrt{2}I(1 - \sin \theta_i)}{2\omega\varepsilon V_{dc}} \quad (6)$$

where I is the current rating of the inverter ($I = I_{SVG}$ for the Wye structure, and $I = I_{SVG}/\sqrt{3}$ for the Delta structure, I_{SVG} is the current rating of the SVG), and θ_i is the switching timing angle of FBI unit i as shown in Fig. 7. Therefore, the total required capacitance for a three phase M -level inverter C is

$$C = 3 \sum_{i=1}^{(M-1)/2} C_i. \quad (7)$$

As mentioned before, θ_i is calculated for each MI value. To generate $\pm Q_{var}$ reactive power, MI would change between MI_{\min} and MI_{\max} , where the SVG produces $+Q_{var}$ at $MI = MI_{\max}$ and produces $-Q_{var}$ for $MI = MI_{\min}$. For $MI = MI_{\max}$, θ_i becomes minimum, and for $MI = MI_{\min}$, θ_i becomes maximum. Therefore, we can use $\theta_i|_{MI=MI_{\max}}$ in (6) to calculate the required capacitance so that the dc voltage ripple will not be larger than the given regulation factor, ε , for all loads.

C. Comparison of the Required Capacitance

Now, a comparison will be made between two example systems. An experimental prototype of Fig. 8 has been built to demonstrate the validity of the new inverter. This SVG system uses 5 FBI units per phase to form an 11-level Wye-connected cascade inverter. The system parameters are shown in Table I. The switching timing angles θ_i ($i = 1, 2, \dots, 5$) are specially calculated to minimize harmonics (under 25th order) of voltage and stored in the switching pattern table of Fig. 8 as shown in Table II.

Using the parameters of Tables I and II and (6) and (7), we get $C_1 = 2.1$ mF, $C_2 = 1.89$ mF, $C_3 = 1.56$ mF, $C_4 = 1.18$ mF, $C_5 = 0.79$ mF, and the total capacitance $C = 22.56$ mF. For a comparable conventional multipulse inverter, the required capacitance is, $C_{dc} = 16.6$ mF, according to (5). Therefore, the required capacitance of the 11-level cascade

TABLE I
SYSTEM PARAMETERS OF EXPERIMENTAL PROTOTYPE

Source Voltage Rating V_S	240 V
Var Rating Q_{var}	± 1 kvar
Current Rating I	2.4 A
DC Voltage V_{dc}	40 V
DC Voltage Regulation factor ε	$\pm 5\%$
Interface Inductance L_C	20% (32 mH)
Source Impedance L_S	3% (0.03 pu)
Modulation Index $[MI_{\min}, MI_{\max}]$	[0.615, 0.915]

TABLE II
SWITCHING PATTERN TABLE OF 11-LEVEL CASCADE INVERTER

Modulation Index	Switching Timing Angles [rad.]				
MI^*	θ_1	θ_2	θ_3	θ_4	θ_5
0.615	0.4353	0.7274	0.8795	1.0665	1.2655
...
0.915	0.0687	0.1595	0.3124	0.4978	0.7077

* The resolution of MI equals to 0.01 in the experimental system.







inverter is 1.36 times of that of the conventional multipulse inverter.

Actually, when the number of levels is increased for high-voltage applications, the required capacitance of the cascade inverter will approach that of the conventional multipulse inverter, that is, the ratio C/C_{dc} will approach one as a limit. For example, consider an SVG system using the Delta structure of a 21-level (10 FBI units per phase) cascade inverter connected directly to a 13-kV power system. The SVG capacity is ± 50 Mvar. $I_{SVG} = 2.22$ kA (the current rating of inverter, $I = 1.282$ kA), $L_C = 3\%$, $MI = [0.6385, 0.8054]$, $V_{dc} = 2$ kV, and $\varepsilon = \pm 5\% = \pm 0.05$. At the rated load of $+50$ Mvar, $[\theta_1, \theta_2, \dots, \theta_{10}] = [0.0334, 0.1840, 0.2491, 0.3469, 0.4275, 0.5381, 0.6692, 0.8539, 0.9840, 1.1613]$ rad. For this SVG system, the total required capacitance of dc capacitors can be calculated as $C = 370$ mF. The required capacitance for a comparable conventional multipulse inverter will be $C_{dc} = 332$ mF. Therefore, the ratio C/C_{dc} is 1.11, which is approaching 1.0, as stated.

IV. SIMULATION AND EXPERIMENTAL RESULTS


To demonstrate the validity of the new inverter, an SVG prototype using an 11-level Wye-connected cascade inverter was built. Fig. 8 and Tables I and II show the system configuration and the corresponding parameters. For the dc voltage control loops, only C_1 and C_5 's voltages of phase "a" are detected and controlled directly. The control of C_2 , C_3 , and C_4 's voltage uses interpolating values of $\Delta\alpha_{c1}$ and $\Delta\alpha_{c5}$.

Figs. 10–12 show experimental results when the SVG generates $+1$ kvar. Fig. 13 shows experimental results at zero var output. Figs. 14 and 15 show the case of -1 kvar output.



 Fig. 10. Experimental results showing phase voltages of the inverter, V_{Can} , V_{Cbn} , and V_{Ccn} , and the line current I_{Ca} at +1 kvar output.

 Fig. 13. Experimental results showing phase voltages of the inverter V_{Can} , V_{Cbn} , and V_{Ccn} , and the line current I_{Ca} at zero var output.

 Fig. 11. Experimental results showing phase voltages of the source and the inverter V_{Sa} and V_{Can} , and the line current I_{Ca} at +1 kvar output.

 Fig. 14. Experimental results showing phase voltages of the inverter V_{Can} , V_{Cbn} , and V_{Ccn} , and the line current I_{Ca} at -1 kvar output.

 Fig. 12. Experimental results showing line-to-line voltages of the source and the inverter V_{Sab} and V_{Cab} , and the line current I_{Ca} at +1 kvar output.

 Fig. 15. Experimental results showing line-to-line voltages of the source and the inverter V_{Sab} and V_{Cab} , and the line current I_{Ca} at -1 kvar output.

In the experimental system of Fig. 8, a proportional and integral (PI) controller was used for the dc voltage control loops. The PI gains of the controllers were $K_P = 0$ and $K_I = 0.1$ rad/V.

Figs. 10–12 show that the inverter output phase voltage is an 11-level step-like waveform, and the line-to-line voltage is a 21-level step-like waveform over one half cycle. Each step has the same span, indicating that the voltage of each



(a)



(b)

Fig. 16. Simulation results of an SVG using a 21-level Delta-connected cascade inverter. (a) Source voltage, inverter voltage, and inverter current. (b) Voltage of each dc capacitor of phase *ab*.

dc capacitor is well controlled and balanced. The command dc voltage V_{dc}^* was 40 V, $\alpha_C = 0.08$ rad, $\Delta\alpha_{C1} = 0.002$ rad, $\Delta\alpha_{C5} = -0.003$ rad, and the modulation index was the maximum, $MI = 0.915$, in this case.

As is well known, to regulate the output voltage one can simultaneously and independently control either the modulation index or the dc voltage. Fig. 13 shows the experimental waveforms that generate zero reactive power or zero current

with the same modulation index as in Figs. 10–12, but with a different dc voltage. In this case the dc voltage of each dc capacitor was controlled to be 34 V, that is, $V_{dc}^* = 34$ V. Lowering the dc voltage can reduce the inverter losses. However, a step change of the dc voltage is impossible. Therefore, the *MI* regulation is usually used to get a desired step change of the output voltage, whereas the dc voltage control is suitable for slow response to improve the inverter efficiency.

In Figs. 14 and 15, MI was 0.615, and V_{dc}^* was 40 V. The inverter generates -1 kvar of reactive power, that is, the current I_{Ca} lags the voltage V_{Sa} by 90° .

The above experimental results show that voltages of all the dc capacitors are well balanced even with only two sensed voltages, although each dc voltage can be independently controlled by detecting all the dc voltages. The results also show that a pure sinusoidal current can be obtained with only a total 23% (0.23 p.u.) impedance on the ac side.

From the structures of the multilevel cascade inverter, Figs. 4–6, we can see that each phase can be controlled independently. Therefore, each phase of the inverter behaves just like an actively controlled inductance or capacitance as long as its voltage and current have a 90° phase difference. This feature makes it possible for the Delta structure of Fig. 6 to furnish both positive- and negative-sequence reactive power [14], [15], thus behaving like a controlled ideal source of reactive power. Negative-sequence reactive power is necessary for phase balancing and power-factor correction of unbalanced (unsymmetrical) loads.

Fig. 16 shows simulation results of an SVG, in which a 21-level Delta structure cascade inverter is used to connect directly to a 13-kV power line. The corresponding parameters have been mentioned in Section III-C. The capacitances for the ten FBI units' dc capacitors are $[C_1, C_2, \dots, C_{10}] = [23.2, 19.6, 18.1, 15.8, 14.0, 11.7, 9.11, 5.91, 4.01, 1.98]$ mF, respectively. In Fig. 16(a), $V(ca, cb)$ is the output voltage of phase ab of the inverter. It shows a step-like waveform with 21 levels over a half cycle. It is seen that the current I_{cab} leads the phase voltage by 90° and is purely sinusoidal, and the source voltage V_{sab} is almost distortion-free even with a small interface inductance ($L_S = 3.5\%$, $L_C = 3\%$, and L_C is placed between phases ab , bc , and ca of the inverter). Fig. 16(b) shows waveforms of dc capacitor voltages of phase ab , where the voltages are maintained at a constant value, 2 kV, within $\pm 5\%$ ripples.

V. CONCLUSIONS

A new multilevel voltage-source cascade inverter has been proposed. The new inverter has many features, including the least component count, as well as easy modularity and packaging, which solve the major problems of the conventional multipulse inverter, the diode-clamped multi-level inverter, and the flying-capacitor multilevel inverter. The cascade inverter is specially suitable for FACTS applications including static var generation, power-line conditioning, series compensation, phase shift, and voltage balancing because each dc capacitor voltage can be self-maintained and independently controlled without additional dc sources. The superiority and validity have been demonstrated through experimental and simulated results. It has also been shown that the required capacitance of dc capacitors is almost the same as that of the conventional inverter for practical SVG applications.

This cascade inverter topology can be easily adapted to other applications such as fuel cell and photovoltaic utility interface systems where the sources are originally isolated dc sources. For these niched applications, it is expected that the cascade inverter will become widespread.

ACKNOWLEDGMENT

The authors would like to thank G. Ott, L. Tolbert, and C. White for their assistance with the experiment.

REFERENCES


- [1] C. Schauder *et al.*, "Development of a ± 100 MVAR static condenser for voltage control of transmission systems," in *IEEE PES Summer Power Meeting*, paper no. 94SM479-6PWRD, 1994.
- [2] S. Mori *et al.*, "Development of large static var generator using self-commutated inverters for improving power system stability," in *IEEE PES Winter Power Meeting*, paper no. 92WM165-1, 1992.
- [3] J. Van Wyk, D. A. Marshall, and S. Boshoff, "Simulation and experimental study of a reactively loaded PWM converter as a fast source of reactive power," *IEEE Trans. Ind. Applicat.*, vol. IA-22, pp. 1082–1090, 1986.
- [4] L. H. Walker, "Force-commutated reactive power compensator," *IEEE Trans. Ind. Applicat.*, vol. IA-22, pp. 1091–1104, Nov./Dec. 1986.
- [5] L. T. Moran, P. D. Ziogas, and G. Joos, "Analysis and design of a three-phase current source solid-state var compensator," *IEEE Trans. Ind. Applicat.*, vol. 25, pp. 356–365, Mar./Apr. 1989.
- [6] N. S. Choi, G. C. Cho, and G. H. Cho, "Modeling and analysis of a static var compensator using multilevel voltage source inverter," in *Conf. Rec. IEEE/IAS Annual Meeting*, 1993, pp. 901–908.
- [7] F. Z. Peng and J. S. Lai, "A static var generator using a staircase waveform multilevel voltage-source converter," in *USA Official Proc. Seventh Intl. Power Quality Conf. (Power Quality'94)*, Dallas/Ft. Worth, TX, Sept. 17–22, 1994, pp. 58–66.
- [8] N. Seki *et al.*, "Which is better at a high-power reactive power compensation system, high PWM frequency or multiple connection?," in *Conf. Rec. IEEE/IAS'94 Annual Meeting*, 1994, pp. 946–953.
- [9] C. Hochgraf, R. Lasseter, D. Divan, and T. A. Lipo, "Comparison of multilevel inverters for static var compensation," in *Conf. rec. IEEE/IAS Annual Meeting*, 1994, pp. 921–928.
- [10] M. Carpita and S. Teconi, "A novel multilevel structure for voltage source inverter," *EPE 1991*, pp. 90–94.
- [11] M. Maresoni, "High-performance current control techniques for applications to multilevel high-power voltage source inverters," *IEEE Trans. Power Electron.*, vol. 7, pp. 189–204, Jan. 1992.
- [12] D. A. Woodford and R. W. Menzies, "Controlling a back-to-back DC link to operate as a phase shift transformer," *GIGRE*, paper no. 14-202, 1994.
- [13] J. S. Lai and F. Z. Peng, "Multilevel converters: A new breed of power converters," in *Conf. Rec. IEEE/IAS Annual Meeting*, 1995.
- [14] L. Gyugyi, R. A. Otto, and T. H. Putman, "Principles and applications of static-controlled shunt compensators," *IEEE Trans. Power Apparatus and Syst.*, vol. PAS-97, no. 5, pp. 1935–1945, Sept./Oct. 1978.
- [15] T. J. E. Miller, *Reactive Power Control in Electric Systems*. New York: Wiley-Interscience, 1982.
- [16] S. Nakama and K. Omori, "About static var generators (SVG's) installed at Shin-Biwashima substation" (in Japanese), *Railway and Electrical Tech.*, vol. 5, no. 6, pp. 41–45, 1994.



Fang Zheng Peng (M'93-SM'96) was born in Hubei Province, China. He received the B.S. degree in electrical engineering from Wuhan University of Hydraulic and Electrical Engineering, China, in 1983 and the M.S. and Ph.D. degrees in electrical engineering from Nagaoka University of Technology, Nagaoka, Japan, in 1987 and 1990, respectively.

He joined Toyo Electric Manufacturing Company, Ltd., from 1990–1992. From 1992–1994, he worked with Tokyo Institute of Technology as a Research Associate. Since 1994, he has been a Research Assistant Professor at University of Tennessee, Knoxville, working with Oak Ridge National Laboratory.


Jih-Sheng Lai (S'84-M'87-SM'93), for a photograph and biography, see this issue, p. 1025.



John W. McKeever received the B.S. degree in physics from Case Institute of Technology and the M.S. and Ph.D. degrees in physics from the University of Tennessee, Knoxville.

He has 35 years work experience serving in both technical and project management capacities. From 1960 to 1970, he helped develop the barrier material used in the gaseous diffusion process. From 1970 to 1982, he designed and tested rotating machine components for the gas centrifuge, which was developed at Oak Ridge for the DOE. From 1982 until the end of the Gas Centrifuge Project in 1985, he led a materials group. During this time, he chaired an advanced component development team and developed theory and hardware that provided the basis for mechanical evaluation and qualification of components prior to their use in the advanced machine. From 1985 to the present, he has been a part of the Engineering Technology Division. His development activities included supporting work on such projects as the University of Texas Compulsator, refabricating the rotor of the axial-gap superconducting motor used in the ORNL research facility for evaluating superconducting wire, designing molecular seals for a gas

centrifuge and for an early model of the centrifugal gas separator, investigating the use of thermoplastics for building space structures, supporting thermal hydraulic calculations for the High Flux Isotope Reactor, managing the lab-directed project that evaluated the axial-gap superconducting motor, managing the lab-directed project that developed the Resonant Snubber Inverter, and managing the project to reduce the cost of high-voltage dc transmission converter stations.



James VanCoevering (M'74) received the B.S. degree in electrical engineering from the University of Arizona, Tempe, in 1970, and the M.S.E.E. degree in electric power engineering from the Rensselaer Polytechnic Institute, Troy, NY, in 1975.

He is the Manager of the Power Systems Technology Program at Oak Ridge National Laboratory. He joined Oak Ridge National Laboratory in 1993 following a career in the utility industry which included Peace Corps service in rural electrification in Latin America as well as circuit breaker development for Allis Chalmers (now Siemens), system planning and transmission/substation engineering for Plains Electric in Albuquerque, NM, and transmission line research for General Electric in Lenox, MA. His research interests are power system analysis and transmission system design, especially the application of high-voltage dc transmission.