

## APPENDIX E SUPPLEMENTARY ACCESSIBILITY REQUIREMENTS

## SECTION E104 SPECIAL OCCUPANCIES

**E104.1 General.**

*Transient lodging* facilities shall be provided with accessible features in accordance with [Section E104.2](#). Group I-3 occupancies shall be provided with accessible features in accordance with [Section E104.2](#).

**E104.2 Communication features.**

Accessible communication features shall be provided in accordance with [Sections E104.2.1](#) through [E104.2.4](#).

**E104.2.1 Transient lodging.**

In *transient lodging* facilities, *sleeping units* with accessible communication features shall be provided in accordance with [Table E104.2.1](#). Units required to comply with [Table E104.2.1](#) shall be dispersed among the various classes of units.

**TABLE E104.2.1  
DWELLING OR SLEEPING UNITS WITH ACCESSIBLE COMMUNICATION FEATURES**

TOTAL NUMBER OF DWELLING OR SLEEPING UNITS PROVIDED	MINIMUM REQUIRED NUMBER OF DWELLING OR SLEEPING UNITS WITH ACCESSIBLE COMMUNICATION FEATURES
1	1
2 to 25	2
26 to 50	4
51 to 75	7
76 to 100	9
101 to 150	12
151 to 200	14
201 to 300	17
301 to 400	20
401 to 500	22
501 to 1,000	5% of total
1,001 and over	50 plus 3 for each 100 over 1,000

**E104.2.2 Group I-3.**

In Group I-3 occupancies at least 2 percent of the total number of general holding *cells* and general housing *cells* equipped with audible emergency notification systems, and not less than one cell, shall be provided with visual notification devices. Permanently installed telephones within the cell shall comply with [Section E104.2.4](#).

**E104.2.3 Dwelling units and sleeping units.**

Where *dwelling units* and *sleeping units* are altered or added, the requirements of [Section E104.2](#) shall apply only to the units being altered or added until the number of units with accessible communication features complies with the minimum number required for new construction.

**E104.2.4 Notification devices.**

Visual notification devices shall be provided to alert room occupants of incoming telephone calls and a door knock or bell. Notification devices shall not be connected to visual alarm signal appliances. Permanently installed telephones shall have volume controls and an electrical outlet complying with [ICC A117.1](#) located within 48 inches (1219 mm) of the telephone to facilitate the use of a TTY.