

CHAPTER 9 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

907.5.2.3.3 Group R-2.

In Group R-2 occupancies required by [Section 907](#) to have a fire alarm system, each *story* that contains *dwelling units* and *sleeping units* shall be provided with the capability to support future visible alarm notification appliances in accordance with [Chapter 11](#) of ICC A117.1. Such capability shall accommodate wired or wireless equipment.