

## CHAPTER 9 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

**907.5.2.3.2 Groups I-1 and R-1.**

Habitable spaces in dwelling units and sleeping units in Group I-1 and R-1 occupancies in accordance with Table 907.5.2.3.2 shall be provided with visible alarm notification. Visible alarms shall be activated by the in-room smoke alarm and the building fire alarm system.

**TABLE 907.5.2.3.2  
VISIBLE ALARMS**

<b>NUMBER OF SLEEPING UNITS</b>	<b>SLEEPING ACCOMMODATIONS WITH VISIBLE ALARMS</b>
6 to 25	2
26 to 50	4
51 to 75	7
76 to 100	9
101 to 150	12
151 to 200	14
201 to 300	17
301 to 400	20
401 to 500	22
501 to 1,000	5% of total
1,001 and over	50 plus 3 for each 100 over 1,000