

CHAPTER 9 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

907.5.2.1.3.1 Fire alarm system signal.

In sleeping rooms of Group R-1 and R-2 occupancies, the audible alarm activated by a fire alarm system shall be a 520-Hz low-frequency signal complying with [NFPA 72](#).