



Monument Academy PCS - Lead in Water Test Results



FY23 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Monument Academy PCS	WS-079-001	Cooler	1	In hallway adjacent to room 120	High	Left	WF-022023-079001-05	5/10/23	FT-FY23-022023-079001-A	<1	FT-FY23-022023-079001-B	<1
Monument Academy PCS	WS-079-002	Cooler	1	In hallway adjacent to room 120	Low	Right	WF-022023-079002-05	5/10/23	FT-FY23-022023-079002-A	<1	FT-FY23-022023-079002-B	<1
Monument Academy PCS	WS-079-003	Cooler	1	In hallway adjacent to gymnasium	High	Left	WF-022023-079003-05	5/10/23	FT-FY23-022023-079003-A	<1	FT-FY23-022023-079003-B	<1
Monument Academy PCS	WS-079-004	Cooler	1	In hallway adjacent to gymnasium	Low	Right	WF-022023-079004-05	5/10/23	FT-FY23-022023-079004-A	<1	FT-FY23-022023-079004-B	<1
Monument Academy PCS	WS-079-005	Break Room	1	In break room R02			WF-022023-079005-05	N/A	FT-FY23-022023-079005-A	Non-operational	FT-FY23-022023-079005-B	Non-operational
Monument Academy PCS	WS-079-006	Classroom Faucet	2	In classroom 201B			WF-022023-079006-05	N/A	FT-FY23-022023-079006-A	Non-operational	FT-FY23-022023-079006-B	Non-operational
Monument Academy PCS	WS-079-007	Classroom Faucet	3	In classroom 303			WF-022023-079007-05	5/10/23	FT-FY23-022023-079007-A	<1	FT-FY23-022023-079007-B	<1
Monument Academy PCS	WS-079-008	Food Prep Sink	1	In kitchen			WF-022023-079008-05	5/10/23	FT-FY23-022023-079008-A	<1	FT-FY23-022023-079008-B	<1
Monument Academy PCS	WS-079-009	Health Suite	1	In health suite 101		Left	WF-022023-079009-05	5/10/23	FT-FY23-022023-079009-A	<1	FT-FY23-022023-079009-B	<1
Monument Academy PCS	WS-079-011	Bottle Filler	1	In hallway adjacent to room 120			WF-022023-079011-03	5/10/23	FT-FY23-022023-079011-A	<1	FT-FY23-022023-079011-B	<1
Monument Academy PCS	WS-079-012	Bottle Filler	1	In hallway adjacent to gymnasium			WF-022023-079012-03	5/10/23	FT-FY23-022023-079012-A	<1	FT-FY23-022023-079012-B	<1