

This is sample data provided for CALIBER purposes only		ONE POINT LESSON (OPL)		OPL No: OPL-DC-3401A-05 Sheet 1 of 1
OPL Title	Cooling-Down & Catalyst Preservation	Discipline	Process / Operations	
Equipment	DC-3401A - CATALYST REDUCTION REACTOR	Area / Unit	3400 - CATALYST REDUCTION SYSTEM	
Related Interlock	SEQ-3401 (SIL 2)	P&ID Ref	TJC-LLD-PID-3401	
Classification:	☒ Basic Knowledge	☐ Improvement	☐ Trouble Case	Aspect: P-Q-C-D-S-M-E

1. PURPOSE / OBJECTIVE

This One Point Lesson explains **cooling-down & catalyst preservation** for DC-3401A (CATALYST REDUCTION REACTOR) in the CATALYST REDUCTION SYSTEM. After reduction the catalyst is pyrophoric; it must be cooled slowly and kept under a nitrogen blanket to prevent re-oxidation or fire. The lesson gives operators and technicians the key knowledge and the correct step-by-step method so the task is done safely, correctly and consistently every time.

2. SAFETY PRECAUTIONS

Hazard note: this equipment is **HIGH CRITICAL** handling **N2 / H2 / Pd catalyst** at up to 6 barg / FV / 250 degC. Observe the following before and during the task:

- Obtain the correct operating permit and brief the shift team before the task.
- Confirm hazardous fluids are isolated / inerted as required by procedure.
- Beware of flammable, hot, or high-pressure fluids; wear the correct PPE.
- Never defeat a safety interlock or trip without an authorised override permit.
- Have emergency actions and communications ready before starting.

3. TOOLS & MATERIALS REQUIRED

- Operating procedure & P&ID
- Radio / communication with panel
- Gas detector (O2 / LEL) as required
- Correct PPE for the fluid handled
- Sample containers & PPE for sampling
- Permit-to-work documentation

4. DETAILED PROCEDURE / STEPS

Step	Action	Check / Acceptance
1	Decrease TIC-17343 slowly, no faster than 0.5 degC/s	Permit valid & briefed
2	Cool all bed thermocouples below 29 degC (ambient)	Parameter within limit
3	Switch off heater EA-3401 (power off) once cool	Interlock status confirmed
4	Isolate the reactor and hold nitrogen pressure at 2 kg/cm2	Change logged on DCS
5	Never open the reactor to air while the catalyst is active	Handover to next shift

5. COMMON PROBLEMS & TROUBLESHOOTING

Symptom	Likely Cause	Action
Bed multipoint TC point 3 reading open circuit	Thermocouple element failed at the sheath junction	Replaced TC point 3 in the multipoint assembly, verified reading.
One heater bank drawing no current, slow heat-up	Electric heater element bank open circuit / element burnt	Replaced heater element bank, meggered, verified TIC-17343 response
Inerting O2 analyzer drift vs portable reference	Analyzer zero drift and sample dryer saturated	Recalibrated AI-3401 on span gas, replaced sample dryer

6. KEY LEARNING POINTS

- After reduction the catalyst is pyrophoric; it must be cooled slowly and kept under a nitrogen blanket to prevent re-oxidation or fire.
- Respect the interlock SEQ-3401: e.g. TSHH-3401 trips at > 230 degC - never defeat it without a permit.
- Always cross-check the Datasheet limits and the P&ID TJC-LLD-PID-3401 before working on DC-3401A.
- Record the work in the equipment history so the Knowledge Hub stays the single source of truth.

Prepared by	Reviewed by (Supervisor)	Approved by (Manager)	Date of Sharing
Panel Operator / Technician	Vino Ardiansyah (EMP-1102)	Arya Wibisono (EMP-0912)	Wednesday, 29 April 2026