

This is sample data provided for CALIBER purposes only	COOLING TOWER FAN & DRIVE DATA SHEET	DOC NO: TJC-LLD-DS-CT-7801 REV: 3
--	---	---

SDK Polyolefin Expansion Project

ITEM / TAG NO.	CT-7801	EQUIPMENT ID	EQ-1000078011
EQUIPMENT NAME	COOLING TOWER CELL FAN	TYPE	Induced Draft Cooling Tower Fan
PLANT / UNIT	LINEAR LOW DENSITY POLYETHYLENE (LLDPE) UNIT	AREA	7800 - COOLING WATER SYSTEM
FUNCTIONAL LOC.	TJC-LLD-7800-01	CRITICALITY	NON CRITICAL
SERVICE	Induced draft cooling of circulating water for LLDPE unit		

DESIGN & MECHANICAL DATA

TOWER TYPE	INDUCED DRAFT, COUNTERFLOW, CELL 1	BLADE MATERIAL	FRP (GRP)
ITEM NO.	CT-7801	HUB MATERIAL	CAST ALUMINIUM
FAN DIAMETER	7300 mm (24 ft)	DRIVE SHAFT	COMPOSITE FLOATING SHAFT
FAN TYPE	AXIAL, 6 FRP BLADES	WATER FLOW (CELL)	2200 m3/h
AIR FLOW	1,150,000 m3/h	RANGE / APPROACH	10 degC / 4 degC
FAN SPEED	128 rpm	DRIFT ELIMINATOR	PVC CELLULAR
GEARBOX RATIO	11.3 : 1 RIGHT ANGLE	FILL	PVC FILM FILL
GEARBOX OIL	ISO VG 220 (4.5 L)		

DRIVER / MOTOR / HEATER DATA

OUTPUT	55 kW	ENCLOSURE	TEFC IP56 (wet duty)
POLES	6 POLE	AREA CLASSIFICATION	NON-HAZARDOUS
SPEED	970 rpm	MOUNTING	IN-DUCT, WET
VOLTAGE	380 V / 3 Ph / 50 Hz	FRAME	IEC 250M
RATED CURRENT	104 A	WEIGHT (MOTOR)	410 kg
INSULATION CLASS	F		
VENDOR / MANUFACTURER	Vendor ABC	DRIVER SUPPLIER	Supplier XYZ
DRIVER TYPE	Electric Motor via Gearbox, TEFC	DATASHEET REV	Rev 3 - ISSUED FOR OPERATION

NOTES:

2. Cross-reference for tag CT-7801: GA Drawing, P&ID TJC-LLD-PID-7801, Interlock SEQ-7801, OPL sheets and Maintenance History.
3. Material of construction per WPN-MAT-001. Refer to interlock trip settings before operation.