



ELITE ELEVATOR INSPECTIONS, LLC

ELEVATOR INSPECTION REPORT

ROBERT LASSITER
OWNER/INSPECTOR
6217 Rambridge Drive
Oklahoma City, OK 73162
elite.elevator.ok@gmail.com
(405)-213-9779

DATE INSP MO/DAY/YR	CERT EXP. DATE MO/YEAR	OKLA NUMBER	SERIAL NUMBER	PERMIT #	TEMP CERT OF OPERATION ☐ 30 ☐ 60	INSP CYCLE ☐ Res. ☐ 1 ☐ 2 ☐ 3
LOCATION (BUILDING)			LOCATION ATTENTION		LOCATION COUNTY	
LOCATION PHYSICAL ADDRESS			LOCATION CITY	LOCATION ZIP	EMAIL ADDRESS	
OWNER -----			OWNER ATTENTION -----			
OWNER ADDRESS -----			OWNER CITY -----	OWNER STATE -----	OWNER ZIP -----	
BILLING CONTRACTOR NAME -----			BILLING CONTRACTOR CITY -----		BILLING CONTRACTOR ATTENTION -----	
NATURE OF BUSINESS			ENTITY TYPE ☐ PRIVATE ☐ CITY ☐ COUNTY ☐ STATE	HOISTWAY LOCATION		DEVICE LOCATION IN HOISTWAY
MANUFACTURER			CAPACITY (LBS)	SPEED (FPM)	RISE (FT IN)	OPENINGS # OF LANDINGS
DEVICE TYPE ☐ CONST/TEMP ☒ WHEELCHAIR LIFT ☐ ELEVATOR ☐ LU/LA ☐ ESCALATOR/MW ☐ PERSONNEL HOIST ☐ PLATFORM LIFT ☐ STAIRWAY CHAIR LIFT ☐ PASSENGER ☐ FREIGHT						INSTALLED YEAR _____ CODE YEAR _____
MACHINE TYPE ☐ CABLE ☐ HAND POWERED ☐ ROPED HYDRAULIC ☐ DIRECT PLUNGER HYDRAULIC ☐ OTHER _____				LATEST TEST DATES ONE YEAR TEST (MO/YR) _____ FIVE YEAR TEST (MO/YR) _____		
INSPECTION TYPE ☐ INITIAL ☐ PERIODIC ☐ REINSP ☐ FOLLOW-UP ☐ WITNESS ☐ ALTERATION		CERTIFICATE ISSUE: ☐ YES ☐ NO TEMP: ☐ YES ☐ NO TO: ☐ OWNER ☐ LOCATION		Inspection reports shall be submitted within thirty (30) days of the completion of the Inspection to: OKLAHOMA DEPARTMENT OF LABOR Safety Standards Division 3017 N Stiles, Suite 100 Oklahoma City, OK 73105 Upon successful Inspection, you will be invoiced \$25 for Certificate of Operation from the Oklahoma Department of Labor		
☐ NO ADVERSE CONDITIONS NOTED AT THIS INSPECTION						
CD For Office Use Only						
☐ RED TAG ☐ INACTIVE ☐ SCRAPPED # Violations _____ # Recommendations _____						
COMMENTS/VIOLATIONS/RECOMMENDATIONS V = Violations; must be corrected within 30 days. R = Recommendation C = Comments						

By signing this inspection report, neither the undersigned nor the Elite Elevator Inspections, LLC makes any warranty, expressed or implied, concerning this inspection report of the safety of the equipment inspected. Furthermore, neither the undersigned nor Elite Elevator Inspections, LLC shall be liable in anymanner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Company Name	Robert Lassiter	Date
Contact Person/Phone Number	Inspector Name (Print)	40012
	Inspector Signature	License #
	1234	
	QE#	

ROBERT LASSITER
OWNER/INSPECTOR
6217 Rambridge Drive
Oklahoma City, OK 73162
elite.elevator.ok@gmail.com
(405)-213-9779

OKLA NUMBER

This image shows a single sheet of white paper with horizontal blue or grey ruling lines. The lines are evenly spaced and run across the width of the page. There are approximately 20 lines visible. The paper appears to be a standard notebook page or a sheet of stationery. There is no handwriting or other markings on the page.

License #

Access keys shall be provided -- 17.1-8.6.11.3,-MR
Remove blockage to access machinery space, machine room -- 17.1-2.7.3,-MR
Machine Room Doors must be kept locked and closed -- 17.1-8.6.4.8.4,-MR
Machine room doors must be self-closing, spring type self-locking door knob -- 17.1-2.7.3.4.1,-MR
Provide permanent means to access elevator machine room -- 17.3-2.2.2,-MR
Provide machine rooms to be ventilated natural or mechanical -- 17.3-2.2.4 ,-MR
Install light switch located at point of entry -- 17.1-2.7.9.1,-MR
Machine room must have lighting minimum illumination (19fc) -- 17.1-2.7.9.1,-MR
Machine room lighting required to be permanent -- 17.3-2.2.3,-MR
Machine numbering required for more than one elevator in building -- 17.1-2.29.1,-MR
Elevator light disconnect must be installed -- NEC 620.22 / 53,-MR
Mainline disconnect must be installed within sight of elevator -- NEC620.51,-MR
Multiple power source warning sign installed on mainline disconnect -- NEC620.52,-MR
Provide power supply line disconnect means at each elevator motor, or motor generator set and controller equipment -- 17.3-3.10.5,-MR
Disconnect must be lockable -- NEC620.51,-MR
Install ground fault circuit interrupter (GFCI) in pit and machine room -- NEC620.85,-MR
Install protective covering on non-elevator related piping in machinery room -- 17.3-2.2.5,-MR
All elevator equipment shall be protected from weather -- 17.3-2.2.6,-MR
Provide written maintenance control program -- 17.1-8.6.1.2.1,-MR
All maintenance records shall be maintained to accurately reflect the frequency of service and items serviced -- 17.1-8.6.1.4.1,-MR
Maintenance record availability shall be kept on site -- 17.1-8.6.1.4.2,-MR
Oil Log shall be maintained and available of hydraulic fluid when added to system -- 17.1-8.6.5.7,-MR
Provide means to check minimum and maximum hydraulic oil level -- 17.1-8.6.5.4,-MR
Provide or maintain monthly firefighter test log -- 17.1-8.6.11.1,-MR
Elevator shall conform to the requirements of firefighter service Phase I & II -- 17.3-3.11.3,-
Electrical schematic shall be available -- 17.1-8.6.1.6.3a,-MR
Clean inside elevator controller -- 17.1-8.6.1.6.3b,-MR
Remove temporary wiring blocks from controller -- 17.1-8.6.1.6.3c,-MR
Jumper Wires not to be stored in controller -- 17.1-8.6.1.6.3d,-MR
“ABC” fire extinguisher required in machine room located near access door -- 17.1-8.6.1.6.5,-MR
Periodic test tags shall be installed -- 17.1-8.6.1.7.3,-DOC
Relief valve shall be sealed -- 17.1-8.6.5.9,-MR
Relief valve shall not exceed 150% of working pressure -- 17.1-8.6.5.14,-MR
Provide test documentation on site -- 17.1-8.11.1.1.1,-DOC
Witness inspector must provide signed test forms -- 17.1-8.11.1.1.2a,-DOC
Provide glass back elevators and hoistway cleaning procedure -- 17.1-8.6.11.4,-DOC
Provide written emergency evacuation procedure from a stalled elevator -- 17.1-8.6.11.5,-DOC
Provide escalator start up procedure -- 17.1-8.6.11.6,-DOC
Periodic (1) year test electric elevator -- 17.1-8.6.4.19,-DOC
Five (5) year test electric elevator -- 17.1-8.6.4.19.7,-DOC
Periodic hydraulic elevator test -- 17.1-8.6.5.,-DOC
Standby Power where provided elevator operation shall be tested -- 17.1-8.6.4.19.7,-DOC
Install code data plate -- 17.1-8.9,-MR
Replace a worn belt, and/or chain (entire set must be replaced) -- 17.1-8.6.3.5,-MR
Provide means to control the ambient temperature in the machine room -- 17.1-2.7.6.3.2,-MR
Replace expired flexible hose & fittings no more than every six (6) years from installation date -- 17.1-8.6.5.6,-MR
One suspension rope required to be replaced (entire set must be replaced) -- 17.1-8.6.3.2,-MR

Winding drum, no less than 1 complete turn on drum -- 17.3-3.12.7,-MR
Minimum 3 ropes (traction) 2 ropes (drum type) required -- 17.3-3.12.4,-MR
Wire ropes (suspension/governor) shall be kept clean for inspection purposes -- 17.1-8.6 4.1.1,-MR
Governor ropes shall not be lubricated -- 17.1-8.6.4.2.1,-MR
Suspension wire ropes shall be lightly lubricated -- 17.1-8.6.4.2.1,-MR
Clear floors, machinery room & control spaces of water, oil & debris -- 17.1-8.6.4.8.1,-MR
Remove non-elevator items in machine room -- 17.1-8.6.4.8.2,-MR
Flammable liquids with flash point of less than 110 degrees F, shall not be stored in machine room -- 17.1-8.6.4.8.3,-MR
STEP II Pit inspection – Check pit access device function, pit stop switch function and properly identified, buffers in place, pit access ladder securely mounted, pit dry free of debris, oil, water, elevator parts
Hoistway unlocking device shall be provided -- 17.3- 2.7.4,-PIT
Single receptacle for sump pump (non-GFCI) shall be installed -- NEC620.24,-PIT
Pit access doors shall be kept closed and locked -- 17.1-8.6.4.7.3,-PIT
Provide pit light switch, not connected to load side of GFCI receptacle, located next to pit access (10fc) -- NEC620.24,-PIT
Pit stop switch shall be located adjacent to the nearest point of access pits exceeds 67” in depth addition stop switch is required-17.1-2.2.6-PIT
Install pit stop switch, switch must be properly labeled -- 17.3-2.3.3,-PIT
Hydraulic packing shall be maintained to prevent excessive loss of fluid -- 17.1- 8.6.5.5.1,-PIT
Single Bottom Jacks requirements car safeties or plunger gripper -- 17.1-8.6.5.8,-PIT
Install car buffer -- 17.1- 8.11.3.1.5,-PIT
Counterweight metal guards shall be installed -- 17.3-2.1.5,-PIT
Maximum runby, car – 24 inches, counterweight – 36 inches -- 17.3-2.4.3,-PIT
Minimum and Maximum runby (see code requirements) -- 17.1-2.4.2,-PIT
Water & oil shall not be allowed to accumulate in pit -- 17.1-8.6.4.7.4,-PIT
Remove dirt and debris from pit -- 17.1-8.6.4.7.1,-PIT
Drains connected directly to sewer not allowed -- 17.3-2.3.2,-PIT
Install oil collection container -- 17.1-8.6.5.5.2,-PIT
Pit light protection -- 17.1-2.2.5.2,-PIT
Sump pump -- 17.1-2.2.2.5,-PIT
Sump cover -- 17.2-2.2.2.6,-PIT
Restore pit lighting -- 17.3-2.2.3,-PIT
STEP III Hoistway inspection- After taking control of elevator, check function hoistway door interlocks mechanism, door gibbs loose or missing, door restrictor function , hoistway door numbering, hoistway door self-closing, hoistway ledges more than 4”wide, condition of hoistway for penetrations, holes and cracks,
Hoistway unlocking devices shall be provide at all landing for emergency purposes -- 17.3-2.7.4,-HOIST
Hoistway construction shall be enclosed and all penetrations to be fire resistive sealed -- 17.3-2.1.1,-HOIST
Hoistway floor numbering on hoistway doors on hoistway side with 4” numbers -- 17.1-2.29.2 also 17.1-8.11.2.1.3(o),-HOIST
Hoistway enclosure using glass must be etched and visible on each panel with Z97.1/16CFR1201 -- 17.1- 2.1.1.2,-HOIST
Windows used for hoistway enclosure must be guarded -- 17.3-2.1.2,-HOIST
Ledges in hoistway more than 4” wide must be beveled 60 to 75 degree -- 17.3-2.1.3 also 17.1-2.1.6,-HOIST
Existing piping, ducts and wiring in hoistway that cannot be removed shall be secured and covered to prevent interference with elevator operation-17.3-2.1.4
Counter weights tie-rods shall have lock nuts at each end secured by cotter pins -- 17.1-4.3.17,-HOIST
Pipes and/or ducts in hoistway which if discharged into the hoistway could be hazardous shall not be permitted -- 17.3-2.1.4,-HOIST
Repair car top lighting -- 17.3-2.2.3,-CT
Install car top light guards -- 17.1-2.14.7.1.4,-CT
Clear car top of debris and or spare parts -- 17.1-8.6.4.8.9,-CT
Minimum car top clearance shall not be less 43”and no case less 24” from crosshead, -- 17.1-2.4.7,-CT
Install car top standard railing on all outside perimeter in access of 12” from hoistway walls -- 17.1-2.10.2,-CT

Install car top ground fault circuit interrupter (GFCI) -- NEC620.85,-CT
Provide car top emergency exit -- 17.3-3.4.4.1,-CT
Side emergency exit shall be lockable -- 17.3-3.4.4.2,-CT
Install car top operating device -- 17.3-3.10.3,-CT
Install wire rope data tag -- 17.3-3.12.2,-CT/MR
Install anti-rotation device (cable hobbles) -- 17.1-8.6.4.1.3,-CT
Perform rail lubrication maintenance according to crosshead, if applicable -- 17.1-8.6.4.3.1,-HOIST
Rails shall be free of lint and dirt -- 17.1-8.6.4.3.4,-HOIST
Shall be free of dirt and rubbish, no storage -- 17.1-8.6.4.7,-HOIST/PIT
Unenclosed hoistways, top emergency exits shall be permanently secured closed -- 17.3-3.4.4.1(b)1,-CT
Wire in hoistway shall be installed in conduit where required by NEC 620.21

STEP IV

Car Enclosure- check two-way communication, emergency alarm, illumination, door reopening device function, door closing pressure, control panel function,

Restore car emergency 2-way communication -- 17.1-8.6.11.2,-CAR
Restore car emergency alarm -- 17.3-3.11.1,-CAR
Capacity plate shall be installed -- 17.3- 3.7.4,-CAR
Freight elevator signage shall be installed -- 17.3-3.7.5,-CAR
Door closing force shall not be more than 30ft-lbs -- 17.3- 2.8.1,-CAR
Glass enclosures shall be etched on each panel visible with Z97.1, 16 CFR 1201 -- 17.1-2.1.1.2.2,-CAR
Restore or replace door reopening device -- 17.3- 2.8.2,-CAR
Horizontally sliding, multisection, and horizontally swinging doors must have door vision panel -- 17.3-2.6.3,-CAR
Freight door pull straps must be installed bottom of strap not more than 79"above landing(no length extensions to be added)-17.3-2.6.6,-CAR
Door restrictor shall prevent doors from opening outside unlocking zone no more than 4" -- 17.1-2.14.5.7,-CAR
Door restrictor shall be installed -- 17.3-2.7.5,-CAR
Car lighting passenger (5fc), freight 2.5 (fc) shall be installed no less than two lamps shall be provided -- 17.3-3.4.5,-CAR
In car light shall be protected in the event of accidental breakage -- 17.3-3.4.6,-CAR
Restore or install emergency auxiliary light (0.2 fc) -- 17.3-3.4.5,-CAR
Restore emergency alarm -- 17.3-3.11.1,-CAR
Car emergency signaling devices shall not be less than 80 dBA nor greater than 90 dBA -- 17.1-2.27.1,-CAR
In car stop switch change to keyed or behind locked panel -- 17.3-3.10.4 r,-CAR

STEP V

Miscellaneous requirements

Restore firefighter service Phase I & II -- 17.1-2.27.3,-FF
Fire alarm initiating devices shall recall elevator to proper landing when activated -- 17.1-2.27.3.2,-FF
Require signs and data plates damaged or illegible must be replaced -- 17.1-8.6.1.6.7,-MISC
Install sign to info passengers not to use elevator in case of fire -- 17.1-2.27.9,-MISC
Car Emergency Systems shall be maintained (lights, communication and ventilation) -- 17.1-8.6.4.15,-MISC
Installation of sprinklers in machine room or hoistway is an alteration -- 17.3-2.1.4,-MISC
Notice unusual noise, and or irregular motion during car ride -- 17.1-8.11.2.1.1,-MISC
Elevator shall be maintained to provide stopping accuracy at the landing -- 17.1-8.6.4.16,-MISC
To maintain machine room fire rating, all ceiling tiles must to be in their design position -- IBC 3001,-MISC
Certificate of Operation shall be posted, in the elevator car or main lobby near call station -- Ok 380:70-3-8,-OESA
All elevators and conveyances shall provide an written Maintenance Control Program -- OK380:70-11-13,-OESA

MR- Machine Room DOC- Documentation PIT –Pit HOIST- Hoistway CAR- Car Enclosure	FF- Firefighter Service MISC – Miscellaneous OESA – Oklahoma Elevator Safety Act CT- Car Top
---	---

[illegible]

[illegible]