

Life cycle impact assessment for a district heating project with seasonal storage

A case study analysis for a project based in Bracht, Hessen, Germany

Elke Michlmayr

1 Abstract

A Life Cycle Impact Assessment (LCIA) is performed for a solar district heating community project in Bracht, Rauschenberg, Germany.

2 Introduction

Heating is an important topic for energy consumption since it amounts to roughly half of the consumed energy in the EU. Currently, 60% of that energy is generated from fossil fuels as stated in Euroheat & Power [6]. District heating is a setup where one heating generator plant serves many households connected via pipes. District heating works in two ways: Either to utilise surplus heat from sources such as waste incineration plants for heating purposes in residential areas and service centres as described by Swiss Federal Office of Energy [18], or to use a dedicated source of energy, e.g. biomass or solar thermal collectors. There are 6000 existing district heating systems across the EU according to Euroheat & Power [6]. Process heating uses a similar setup but is targeted at industrial purposes, which usually require higher heat temperature.

Solar thermal collectors (STCs) are devices that absorb solar radiation and convert it into heat. There are different types of solar thermal collectors, including flat plate solar collectors, unglazed water collectors, and evacuated tube solar collectors. They are combined with heat pumps to bridge the gap between solar field produced water temperature and district heating delivery system required temperature as explained in Wikipedia [29]. According to Weiss and Spörk-Dür [26], there are more than 300 large scale district heating systems globally that are powered with STCs, and more than 1200 STC systems that provide industrial process heat.

STCs are a mature technology. In 2023, the total operational solar thermal capacity reached 560 GWth, which covers roughly 800 km² of collector area as stated by Weiss and Spörk-Dür

[26]. STC-provided capacity varies seasonally depending on available sunlight. Sometimes STCs are used only for parts of the year, e.g. to enable turning off a biomass-powered plant in the summer since it would run at extremely low capacity. STCs can be combined with a short term heat storage acting as buffer or a seasonal heat storage tank (e.g. underground hot water basin) to store extra heat from the hot season for the cold season, which incurs heat losses. If space restrictions require such a setup (or if land is cheaper), the geographical location of an STC can be remote from consumers and plants via pipelines (e.g., 4 km in Priština as described in Euroheat & Power [6]). However, there is a trade-off since the remote location required laying the necessary pipes underground.

In scientific literature, LCA case studies exist for the district heating system in Milan (see Famiglietti **and others** [8]) and Marseille (see Vauchez **and others** [21]). LCA, in particular the ReCiPe method, has been used to assess the environmental impact of different STC powered district heating configurations by Abokersh **and others** [1]. The outcome was that larger systems that serve many households have a lower environmental impact per energy unit served.

Solano **and others** [17] provide an LCA study of a STC plant connected to the Geneva district heat network and find that there is no LCA data available for the coupling of large scale solar thermal installations and district heating networks, and provides suggested numbers that could be used to complement district heat production routes in the KBOB database.

For the community project in Bracht, while the economic viability of the project in comparison to energetic renovation was analysed by Kelch **and others** [13], the environmental impact has not yet been studied in detail. This is the subject of the given study.

3 Methodology and research questions

The foreground data is collected from various online sources and combined with background data from the Ecoinvent v3 database by Wernet **and others** [28] and from the UVEK LCI database DQRv2:2025 database by Federal Office for the Environment (FOEN) [10]. The environmental impact is assessed using the mid-point level Environmental Footprint (EF) method recommended in European Commission [7], and the Ecological Scarcity 2021 v1.04 method defined in Federal Office for the Environment (FOEN) [9] at the single score level (with UVEK LCI weighting set). The LCIA is performed using the SimaPro 9.6.0.1 software provided by PRé Sustainability [15].

The research questions are formulated as follows:

- (1) How does the STC based system with seasonal heat storage compare to other heating technologies in terms of environmental impact? The comparison will include district heating from other sources that would be available in small communities (such as a heat pump or wood chips), and consumer side heating installations such as oil or gas

boilers. The hypothesis is that the STC based system will have a lower environmental impact compared to other district heating setups and to fossil energy based consumer installations.

- (2) What is the environmental impact contribution of the seasonal heat storage unit for the production, construction, and use stages in the life cycle? The benefits of the STC based system with a seasonal heat storage component included will be assessed in comparison to the same system without seasonal heat storage under several assumed loss coefficients for the storage component (sensitivity analysis). The hypothesis is that the seasonal storage component will lower the environmental impact.
- (3) What is the relevance of the additional electricity required in the setup (amounting to 6% of overall energy consumed) and the supplemental biomass boiler (amounting to 26% of overall energy consumed) with respect to the overall environmental impact? The hypothesis is that the additional electricity and biomass required will amount to a sizable part of the overall environmental impact.

4 Goal and scope

The goal and scope definition of an LCA provides a description of the product system and its system boundaries, and a functional unit.

The district heating project that is the topic of this analysis is led by a cooperative comprising future household consumers and the local council. The project setup consists of a solar thermal collector field, a seasonal storage unit also called Pit Thermal Energy Storage (PTES), a heat pump which is using power from the grid, a buffer storage unit, a backup biomass combustion unit that if required can be used as an alternative source of heat (for the cases where there is no availability of heat from neither the solar collector nor the storage), and a distribution network for the customer households (see Figure 1). A receiver unit is installed in each participating household. There are at least 180 consumer households expected, which is roughly 60% of all households in the community.

The functional unit is 1 MegaJoule (MJ) of thermal energy provided to the consumer directly at the consumer site during the heating period. Using MJ instead of kilowatt-hours of thermal energy (kWh_{th}) to be consistent with the processes in SimaPro that the comparison will be performed against.

The lifetime of the installation is assumed to be 50 years. The system diagram shown in Figure 2 describes the product system and its boundaries.

TBD: Simapro process uses MJ (like the ones used for comparison), doublecheck that this is correct




Figure 1: Overview of system setup for the Bracht district heating. Source: University of Kassel.




Figure 2: System diagram, with functional unit.

System deconstruction was modeled for the solar thermal collector field and the seasonal storage unit only. *TBD Is this acceptable? It's counted per weight, so the 15t of steel will be the majority, and that is covered.*

TBD Modelling deconstruction but not recycling (same as for OEBLM). I didn't find an entry for plastic recycling

5 Life Cycle Inventory

There is a lot of information available on the project website by City of Rauschenberg [5]. The website has been used as a resource to gather the life cycle inventory data for the five relevant components that are described in the following: solar thermal collector field, seasonal storage unit, heat preparation, distribution infrastructure, and consumer installations.

The planned lifetime for the Bracht plant is 50 years. The assumed individual component lifetimes and the resulting relevant multipliers are shown in Table 1. The assumed individual component lifetimes are in line with the assumptions used in Kelch **and others** [12].

Table 1

Component	Years	Multiplier	Source
Solar thermal collector	30	1.666667	[11]
Seasonal storage unit	30	1.666667	[12]
Heat pump	20	2.5	[30]
Heat buffer storage	20	2.5	[11]
Heat installation facility	50	1	[22]
Heat exchange station at consumer	20	2.5	[12]
Heat transport network	50	1	[12]

TBD Mostly in the supporting information and add a summary table here.

5.1 Electrical power requirements and loss coefficient assumptions

Several estimations of annual collector output can be found in the relevant performance data from TÜV Rheinland [20] for the solar thermal collectors used in this project. They are based on geographical location and on the desired output temperature. The geographically closest matching entry is 5283 kWh per collector per year for the Würzburg location and 75 degrees output. For the given 855 collectors this amounts to an estimated 4.517 MWh per year.

The Bracht documentation City of Rauschenberg [3] states that in total, 2.700 MWh per year are expected to reach consumer households. This means that the assumed loss coefficients for the storage unit and in the pipes together is estimated to amount to a significant factor of 40% loss. The electrical power that reaches consumer households is generated to 67% from what the solar thermal collectors generated for storage (2258 MWh), to 26% from biomass (904 MWh), and to 6% from the grid (209 MWh) using the percentage distribution given in Figure 1. There is no detailed information how the expected loss was estimated. However, based on the published numbers and an assumed 20% loss coefficient in the pipes, the resulting expected loss in the seasonal storage unit can be calculated at 50%. These assumptions were used in the modelling. Further discussion of loss coefficients and a related sensitivity analysis can be found in Section 7.1.

6 Results

The results for comparing the solar thermal based district network heat it to other forms of district heating (DH) that are available in small communities such as wood chips (biomass), geothermal heat pump, and also to the usually available consumer side heating installations (CI) such as a oil or gas boiler are shown in Figure 3 and Figure 4.

The relative influence of the district heating system components can be seen in Figure 5. TBD add for all midpoints (like for the lawns but with components instead of phases)

TBD expectation: heat storage should be 2x heat pump How much HDPE in kg? Compare with weight of heat pump

7 Discussion

As shown in Figure 3, the Bracht setup compares positively to other heating technologies in terms of environmental impact. Based on the analysis using the Ecological Scarcity 2021 v1.04 method with UVEK LCI weighting set, it shows a lower environmental impact compared to other relevant district heating setups and to fossil energy based consumer installations. The results visualize that the Bracht system fares better in the “Main air pollutants and Particulate Matter (PM)” category in comparison to a completely wood chips based energy source for district heating, while the impact from the biomass energy used in the Bracht system is still visible in the results. The geothermal based district heating would perform better if there wasn’t as much radioactive waste to deposit. The gas and oil based customer installations compare the least well in the selection because of the high impacts in the global warming category.

Related results are shown in Figure 4 when looking at the Environmental Footprint Method. Again the wood chips based energy source for district heating fares worst in the particulate




Figure 3: Comparison to other energy sources for district heating (wood chips, heatpump) and consumer installations (gas, oil), based on the Ecological Scarcity 2021 v1.04 method with UVEK LCI weighting set at the single score level.




Figure 4: Damage assessment using the Environmental Footprint Method, visualized as relative impacts in comparison.




Figure 5: Relative influence of the system components using the Ecological Scarcity 2021 v1.04 method with UVEK LCI weighting set at the single score level.

matter category. It is also returning the worst results for land use, eutrophication (marine and terrestrial), human toxicity (cancer), and photochemical ozone formation. The oil burner returns the worst results for acidification, climate change, freshwater ecotoxicity, human toxicity (non-cancer), and fossil resource use. The gas burner shows bad results for climate change and ozone depletion. The geothermal heat pump district heating is performing badly for eutrophication (freshwater) and for ionising radiation. The solar thermal based district heating returns the worst results for resource use (minerals and metals).

Figure 5 reveals that the environmental impact contribution of the seasonal heat storage unit are minimal. The only component that is listed is the Polystyrene from the floating cover of the seasonal heat storage unit, which amounts to 2% of the overall impact. The seasonal storage component lowers the environmental impact very significantly since it avoids using more heat from wood chips and electricity, which are the two biggest contributors to overall environmental impact. The plan for this research was to assess the impact of not using a seasonal storage component in the setup. However, the results shown in Figure 5 make it very clear that the seasonal storage component is essential for the overall system while its environmental impact is minimal. Therefore, the effects of not using a seasonal storage component in the setup were not analysed further.

The additional electricity and biomass required were expected to play a big role with respect to the overall environmental impact. But it is surprising to see that these two are the biggest contributors. The electricity use can not be avoided since it is required to run the heat pump. Its impact can be lowered by using green energy *TBD should it be assessed too? (It's clear that using green energy will make the results much better. Electricity modelling currently very simple, using "electricity mix, winter 2018/CH")*. The opportunities and effects of using less biomass by lowering heat loss coefficients is assessed in detail in Section 7.1.

7.1 Loss coefficients and sensitivity analysis

Heat is harder to transport than electrical power since even good insulation cannot avoid losses of radiating heat. There are two main areas where heat losses occur in the setup: in the pipes, and in the seasonal storage unit. Therefore, the loss coefficients assumed for the pipes and for the storage unit are highly relevant to the modelling.

As summarized by Werner [27], the relevant parameters affecting heat loss in the pipes are the length of the network which depends on the transmission distance relative to demand, the system age, and the operating temperature. The cited loss coefficient numbers for pipe loss range between 5% and 35%. The Bracht setup has a long transmission distance of 8800 meters because of the rural setup, and a planned operating temperature of 85 degrees Celsius. Both of these factors affect performance negatively. Therefore, even if the system is brand new and therefore modern, assuming a 20% heat loss is realistic. The open source modelling tool Energy Transition Model by Quintel [16] suggests 15% as a sensible default for modelling heat loss in the pipes of modern district heating networks based on real world numbers. Note

that in the comparison in Figure 3, the data for the other energy sources for district heating (wood chips, heatpump) used a 5% to 10% assumption which means that the solar thermal data with the 20% assumption is disadvantaged in the comparison.

If the heat loss in the Bracht pipes could be lowered to 10% by using a lower operating temperature, that would result in efficiency savings of 335 MWh per year which would in turn not require production from the biomass boiler. This is significant since it amounts to roughly one third of the energy coming from biomass. Figure 6 shows that this results in a reduction from 39 to 34 Ecopoints per MJ of district heat, which amounts to a 12% reduction. The main impact factor changed is in the “Main air pollutants and Particulate Matter (PM)” category.




Figure 6: Potential savings when halving heat loss in pipes.

Penttinen, Vimpari **and** Junnila [14] report a 26% loss of heat production in the storage unit amounted to of heat production. The Energy Transition Model by Quintel [16] suggests 30% as a sensible default for modelling heat loss in the storage unit. Xiang **and** others [31] provide a comprehensive review and find that 30% to 50% heat loss are common for Pit Thermal Energy Storage and that the majority of losses are caused by floating cover. The assumption for Bracht, which is 50% loss, seems to be on the conservative side. If it can be lowered to 30%, which seems feasible given the scientific results cited, that would cancel out the entirety of energy from biomass required. This would reduce the environmental impact from 39 to 26 Ecopoints per MJ of district heat, which is a reduction of 33%, as shown in Figure 7.




Figure 7: Potential savings when lowering heat loss in storage from 50% to 30%.

8 Conclusion

A case study life cycle assessment was performed for the solar district heating community project in Bracht, Rauschenberg, Germany. The results compare favorably to other heating technologies in terms of environmental impact. To further improve, the recommendations are (1) to consider a lower operating temperature for the system to achieve better overall efficiency through avoided heat losses, (2) to use green energy for running the heat pump, and (3) to lower or event completely remove the amount of biomass burnt by improving the heat loss coefficients for storage unit and transmission pipes.

9 Supporting information

In this section, the supporting information related to the life cycle inventory and to project organization is collected.

9.1 Life Cycle Inventory

TBD add the Simapro processed used

9.1.1 Solar thermal collector

The relevant data for the solar thermal collector can be found in Table 2.

Table 2

Dimension	Value	Source
Size	11'638 m^2 (855 x 13.6 m^2)	[23]
Type	Flat-plate collectors Vitosol 100-F XF13 Viessmann	[23] [24] [20]
Land use	23.500 m^2	[23]
Mounting infrastructure material	15 t steel	[5]
Collector weight	50 kg / m^2	Own assumption
Production country	China	Own assumption
Transport per container ship	8000 km	Own assumption
Transport per lorry	1000 km	Own assumption
Total transport km per container ship	$(11638 \text{ } m^2 * 50 \text{ kg / } m^2 * 1.666667 + 15000 \text{ kg}) / 1000 * 8000 \text{ km} = 7'878'668 \text{ tkm}$	Calculation

Dimension	Value	Source
Total transport km per lorry	$(11638 \text{ m}^2 * 50 \text{ kg} / \text{m}^2 * 1.666667 + 15000 \text{ kg}) / 1000 * 1000 \text{ km} = 984'834 \text{ tkm}$	Calculation

9.1.2 Seasonal storage unit (SSU)

The relevant data for the seasonal storage unit can be found in Table 3. A picture of the floating cover can be found in Figure 8.




Figure 8: Floating cover profile. Source: Bracht community.

Table 3

Dimension	Value	Source
Volume	$26'600 \text{ m}^3$	Figure 1
Resource: water	$26'600 \text{ m}^3$ filled from local source	[4]
Cover: layer 1 and 10	Polyethylen (HDPE) sealing membranes 1.5 mm, $0.5 \text{ kg} / \text{m}^2$	[4], weight own assumption
Cover: layer 2 and 9	Fleece ($0.1 \text{ kg} / \text{m}^2$) laminated plastic grid (HDPE, $0.25 \text{ kg} / \text{m}^2$)	[4], weight own assumption
Cover: layer 3	Foam glass, $8.33 \text{ kg} / \text{m}^2$	[4]
Cover: layer 4	Polyurethane (bauder foam): $3.125 \text{ kg} / \text{m}^2$	[4]
Cover: layer 5	Airing gap made of plastic grid, $0.25 \text{ kg} / \text{m}^2$	[4], weight own assumption
Cover: layer 6	Polystyrene (XPS), $3 \text{ kg} / \text{m}^2$	[4]

Dimension	Value	Source
Cover: layer 7+8	Airing gap made of plastic grid (HDPE), 0.5 kg / m^2	[4], weight own assumption
Floating cover dimensions	70 m x 70 m = 4900 m^2	[19]
Floating cover weight	2 * (0.5 + 0.1 + 0.25) + 8.33 + 3.125 + 0.25 + 3 + 0.5 = 16.905 kg / m^2	Calculation
Ground liner	Polyethylen (HDPE), 5 kg / m^2	[4], weight own assumption
Ground liner dimensions	Bottom 20 m x 20 m, vertical height ca. 12 m, surface area ca. 5400 m^2	[19]
Ground liner weight	5 kg / m^2	Calculation
Production country	China	Own assumption
Transport per container ship	8000 km	Own assumption
Transport per lorry	1000 km	Own assumption
Required construction process	Excavator 26.600 m^3	Own assumption
Total transport km per container ship	$((4900 \text{ } m^2 * 16.905 \text{ kg / } m^2) + (5400 \text{ } m^2 * 5 \text{ kg / } m^2)) * 1.666667) / 1000 * 8000 \text{ km} = 1'464'460 \text{ tkm}$	Calculation
Total transport km per lorry	$((4900 \text{ } m^2 * 16.905 \text{ kg / } m^2) + (5400 \text{ } m^2 * 5 \text{ kg / } m^2)) * 1.666667) / 1000 * 1000 \text{ km} = 183'058 \text{ tkm}$	Calculation

9.1.3 Heat preparation

The relevant data for the heat preparation unit can be found in Table 4.

Table 4

Dimension	Value	Source
Type of heat pump	2 Carrier Aquaforce 61XWH-ZE heat pump with 630 kW max electrical input power each	[23] [2]
Electricity requirements	209 MWh per year	Own calculation, see Section 5.1 for details
Buffer storage	ca. 200 m^3 = 200'000 l	Figure 1
Biomass boiler	Mawera boiler with 700 kW thermal power	[23]
Controller	Vitocontrol 200-M	[23] [25]

Dimension	Value	Source
Heat installation facility	50 m ²	Own assumption

9.2 SimaPro Data

9.3 Project organization

In this section, the time plan and the meeting notes are documented.

9.3.1 Time planning

Figure 10 documents the time plan that was followed for this project. The live version can be found [here](#). Access is given upon request.

9.3.2 Meeting notes

The notes for the meetings can be found [here](#). Access is given upon request.

References

- [1] Mohamed Hany Abokersh **and others**. “A framework for the optimal integration of solar assisted district heating in different urban sized communities: A robust machine learning approach incorporating global sensitivity analysis”. in *Applied Energy*: 267 (2020), **page** 114903.
- [2] Carrier Klimatisierungs- und Heizsysteme - Deutschland. *AquaForce - Hochtemperatur Wasser/Wasser-Wärmepumpe mit Kältemittel HFO R-1234ze*. <https://www.carrier.com/commercial/de/de/produkte/heizung/wasser-wasser-waermepumpen/61xwhze/>. Accessed: 2025-04-12. 2025.
- [3] City of Rauschenberg. *Solarwärme Bracht eG, FAQ und häufig gestellte Fragen*. <https://www.solarwaerme-bracht.de/faq/>. Accessed: 2025-04-12. 2025.
- [4] City of Rauschenberg. *Solarwärme Bracht eG, Genossenschaftsunterlagen: Floating Cover*. <https://www.solarwaerme-bracht.de/unterlagen-der-genossenschaft/>. Accessed: 2025-04-12. 2025.
- [5] City of Rauschenberg. *Solarwärme Bracht eG, Stadtteile Bracht und Bracht-Siedlung*. <https://www.solarwaerme-bracht.de/>. Accessed: 2025-04-12. 2025.

Resources		
Water, cooling, unspecified natural origin, DE	$26600 / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	m3
Land use II-III	$23500 * \text{Lifetime} / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	m2a
Materials/fuels		
flat plate collector for PVT, aluminium copper absorber, at plant/CH/I U	$(11638 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	m2
steel, electric, unalloyed, at plant/CH U	$15000 / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
transport, transoceanic freight ship/tkm/OCE U	$((11.638 * 50 * \text{Mult30To50} + 15000) / 1000 * 8000) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	tkm
transport, freight, lorry 40-50 metric ton, EURO 5/RER U	$((11.638 * 50 * \text{Mult30To50} + 15000) / 1000 * 1000) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	tkm
Polyethylene, HDPE, granulate, at plant/RER U	$(\text{SSUDimensionsM2} * 2 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
Fleece, polyethylene, at plant/RER U	$(\text{SSUDimensionsM2} * 0.2 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
Foam glass, at plant/RER U	$(\text{SSUDimensionsM2} * 6.33 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
Polyurethane, rigid foam, at plant/RER U	$(\text{SSUDimensionsM2} * 3.125 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
Polystyrene, extruded (XPS), at plant/RER U	$(\text{SSUDimensionsM2} * 3 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
Polyethylene, HDPE, granulate, at plant/RER U	$(\text{SSUGroundDimensionsM2} * 5 * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
transport, transoceanic freight ship/tkm/OCE U	$((\text{SSUDimensionsM2} * 16.905) + (\text{SSUGroundDimensionsM2} * 5)) * \text{Mult30To50} / 1000 * 8000 / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	tkm
transport, freight, lorry 40-50 metric ton, EURO 5/RER U	$((\text{SSUDimensionsM2} * 16.905) + (\text{SSUGroundDimensionsM2} * 5)) * \text{Mult30To50} / 1000 * 1000 / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	tkm
excavation, hydraulic digger, average/m3/CH U	$26600 / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	m3
heat pump, brine-water, 50kW/RER/I U	$(24 * \text{Mult20To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	p
electricity, production mix ENTSO/kWh/ENTSO U	$(209 * \text{Lifetime}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	MWh
Heat storage 2000l, at plant/CH/I U	$(100 * \text{Mult20To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	p
Building, hall/CH/I U	$(50) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	m2
heat, mixed chips from forest, at furnace 1000kW/MJ/CH U	$(904 * \text{Lifetime}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	MWh
Heat exchanger of Mini CHP plant/CH/I U	$(180 * \text{Mult20To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	p
transport, district heat, large area network, for warm water/MJ/CH/I U	$(\text{TotalAmountOfMWhPerYear} * \text{Lifetime}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	MWh
Waste to treatment		
deconstruction, average/CH U	$((11.638 * 50 * \text{Mult30To50} + 15000) + ((\text{SSUDimensionsM2} * 16.905) + (\text{SSUGroundDimensionsM2} * 5)) * \text{Mult30To50}) / (\text{TotalAmountOfMWhPerYear} * \text{Lifetime} * \text{MWhtoMJ})$	kg
Input parameters		
TotalAmountOfMWhPerYear		2700
Lifetime		50
MWhtoMJ		3600
Mult30To50		1.666666667
Mult20To50		2.5
SSUDimensionsM2		4900
SSUGroundDimensionsM2		5400

Figure 9: SimaPro data excerpt.




Figure 10: Gantt chart used for time planning.

- [6] Euroheat & Power. *28/03/2023: The Rise of Solar District Heating*. <https://www.youtube.com/watch?v=ngNgVxTT2y4>. Accessed: 2025-04-12. 2023.
- [7] European Commission. *Commission Recommendation (EU) 2021/2279 of 15 December 2021 on the use of the Environmental Footprint methods to measure and communicate the life cycle environmental performance of products and organisations*. <https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32021H2279>. Official Journal of the European Union, L 471, 1–16. 2021.
- [8] Jacopo Famiglietti **and others**. “Environmental Life Cycle Assessment scenarios for a district heating network. An Italian case study”. *in Energy Reports*: 7 (2021), **pages** 368–379.
- [9] Federal Office for the Environment (FOEN). *Swiss Eco-Factors 2021 According to the Ecological Scarcity Method: Methodological Fundamentals and Their Application in Switzerland*. Accessed: 2025-04-15. 2021. URL: <https://www.bafu.admin.ch/bafu/en/home/topics/economy-consumption/economy-and-consumption-publications/publications-economy-and-consumption/eco-factors-switzerland.html>.
- [10] Federal Office for the Environment (FOEN). *UVEK LCI database DQRv2:2025*. Supplied by Life Cycle Assessment Research Group, Institute of Natural Resource Sciences, ZHAW. 2025.
- [11] Robert Große **and others**. *Long term (2050) projections of techno-economic performance of large-scale heating and cooling in the EU*. techreport. Publications Office of the European Union, 2017.
- [12] Jan Kelch **and others**. *Abschlussbericht Weiterentwicklung und Optimierung des Konzepts einer solaren Nahwärmeverorgung für ländliche Gebiete am Beispiel von Bracht-Dorf*. Technical report EF960 0039/2021 20008503. Universität Kassel, 2022.
- [13] Jan Kelch **and others**. “Comparison of solar district heating and renovation of buildings as measures for decarbonization of heat supply in rural areas”. *in Solar Energy Advances*: 4 (2024), **page** 100060.
- [14] Petri Penttinen, Jussi Vimpari **and** Seppo Junnila. “Optimal seasonal heat storage in a district heating system with waste incineration”. *in Energies*: 14.12 (2021), **page** 3522.
- [15] PRé Sustainability. *SimaPro 9.6 Database Manual: Methods Library*. Accessed: 2025-04-15. 2024. URL: <https://simapro.com/wp-content/uploads/2024/04/DatabaseManualMethods.pdf>.
- [16] Quintel. *Energy Transition Model (ETM)*. https://energytransitionmodel.com/scenario/supply/heat_ht/transport-and-distribution-losses. Accessed: 2025-04-14. 2025.
- [17] J Solano **and others**. “Life cycle assessment of the new solar thermal power plant SolarCAD II connected to a district heating network in Geneva, Switzerland”. *in Journal of Physics: Conference Series*: **volume** 2600. 15. IOP Publishing. 2023, **page** 152005.
- [18] Swiss Federal Office of Energy. *District heat*. <https://www.bfe.admin.ch/bfe/en/home/supply/energy-efficiency/district-heat.html>. Accessed: 2025-04-12. 2020.

- [19] Top Agrar. *Hessisches Dorf baut riesiges Wasserbecken für eigene Solarthermieranlage*. <https://www.topagrar.com/energie/news/hessisches-dorf-baut-riesiges-wasserbecken-fur-eigene-solarthermieranlage-20010847.html>. Accessed: 2025-04-12. 2025.
- [20] TÜV Rheinland. *Annex to Solar Keymark Certificate*. <https://www.dincertco.de/logos/011-7S3003%20F.pdf>. Accessed: 2025-04-12. 2021.
- [21] Mahaut Vauchez **and others**. “Life Cycle Assessment of District Heating Infrastructures: A Comparison of Pipe Typologies in France”. *in Energies*: 16.9 (2023), **page** 3912.
- [22] VD VDI. *VDI 2067 Blatt 1” Wirtschaftlichkeit gebäudetechnischer Anlagen-Grundlagen und Kostenberechnung*. 2012.
- [23] Viessmann Climate Solutions. *Energiewende: Solarthermie und Erdspeicher decken rund 70 Prozent des Wärmebedarfs im hessischen Bracht*. <https://www.viessmann-climatesolutions.com/de/newsroom/unternehmen/erstes-klimaneutrales-mit-solarwaerme-versorgtes-dorf.html>. Accessed: 2025-04-12. 2024.
- [24] Viessmann Climate Solutions. *Großflächen-Solarthermie für die Nah- und Fernwärme*. <https://energiekonsens.de/media/pages/media/6a0997554c-1640096559/2-viessmann-nah-und-fernwaerme-mit-solarthermie.pdf>. Accessed: 2025-04-12. 2021.
- [25] Viessmann Climate Solutions. *Regelungsprogramm für Mittel- und Großkessel*. <https://www.viessmann.de/de/loesungen/gewerbe-und-industrie/regelung-mittelkessel-grosskessel.html>. Accessed: 2025-04-12. 2025.
- [26] Werner Weiss **and** Monika Spörk-Dür. *Solar Heat World Wide*. White paper DOI: 10.18777/ieashc-shww-2024-0001. Accessed: 2025-04-12. International Energy Agency, 2024. URL: <https://www.iea-shc.org/Data/Sites/1/publications/Solar-Heat-Worldwide-2024.pdf>.
- [27] Sven Werner. “International review of district heating and cooling”. *in Energy*: 137 (2017), **pages** 617–631.
- [28] Gregor Wernet **and others**. “The ecoinvent database version 3 (part I): overview and methodology”. *in The International Journal of Life Cycle Assessment*: 21 (2016), **pages** 1218–1230.
- [29] Wikipedia. *Solar thermal collector*. https://en.wikipedia.org/wiki/Solar_thermal_collector. Accessed: 2025-04-12. 2025.
- [30] Stefan Wolf. “Integration von Wärmepumpen in industrielle Produktionssysteme: Potenziale und Instrumente zur Potenzialerschließung”. *in* (2017).
- [31] Yutong Xiang **and others**. “A comprehensive review on pit thermal energy storage: Technical elements, numerical approaches and recent applications”. *in Journal of Energy Storage*: 55 (2022), **page** 105716.