

Compliance Report

Generated: 2025-12-18 11:13

Summary

PASS	19	FAIL	22
MISSING METRIC	0	CANNOT CHECK	0
OTHER	0	Total checks	41

How to read this report

PASS = the model value meets the rule. FAIL = the model value violates the rule. MISSING_METRIC = the required metric wasn't exported from Rhino. CANNOT_CHECK = unsupported operator/metric.

Building: SITE

Status	Measured	Rule	Citations
PASS	0.11219367866636597	site.coverage <= 0.6 ratio	chunk:C1
PASS	0.11219367866636597	site.coverage <= 0.4 ratio	chunk:C3
FAIL	3.2336383214562745	site.far <= 2 ratio	chunk:C2
PASS	0.11219367866636597	site.coverage <= 0.9 ratio	chunk:C2
FAIL	3.2336383214562745	site.far <= 1.6 ratio	chunk:C4
PASS	0.11219367866636597	site.coverage <= 0.7 ratio	chunk:C4
PASS	10879.971845133703	site.area_m2 >= 300 m2	chunk:C2
FAIL	3.2336383214562745	site.far <= 0.9 ratio	chunk:C7
FAIL	3.2336383214562745	site.far <= 2.2 ratio	chunk:C2

Building: BLDG_A

Status	Measured	Rule	Citations
FAIL	31.000000000000007	building.height_m <= 11.8 m	chunk:C3
FAIL	31.000000000000007	building.height_m <= 9 m	chunk:C2
FAIL	31.000000000000007	building.height_m <= 15 m	chunk:C4
PASS	105.8957501713128	building.min_setback_m >= 3 m	chunk:C8
PASS	105.8957501713128	building.min_setback_m >= 3 m	chunk:C8
PASS	0.08070284455193716	building.coverage <= 0.3 ratio	chunk:C2
PASS	105.8957501713128	building.min_setback_m >= 3 m	chunk:C8
PASS	0.08070284455193716	building.coverage <= 0.3 ratio	chunk:C2
FAIL	31.000000000000007	building.height_m <= 10.15 m	chunk:C5
PASS	105.8957501713128	building.min_setback_m >= 6 m	chunk:C5
PASS	105.8957501713128	building.min_setback_m >= 4 m	chunk:C5
FAIL	1.8772828003504056	building.far <= 1.6 ratio	chunk:C2
PASS	0.08070284455193716	building.coverage <= 0.7 ratio	chunk:C2
FAIL	31.000000000000007	building.height_m <= 9.15 m	chunk:C3

FAIL	31.0000000000000007	building.height_m <= 21.5 m	chunk:C3
PASS	0.0807028445519371	building.coverage <= 0.4 ratio	chunk:C3

Building: BLDG_B

Status	Measured	Rule	Citations
FAIL	46.0	building.height_m <= 11.8 m	chunk:C3
FAIL	46.0	building.height_m <= 9 m	chunk:C2
FAIL	46.0	building.height_m <= 15 m	chunk:C4
FAIL	7.1054273576010026	building.min_setback_m >= 3 m	chunk:C8
FAIL	7.1054273576010026	building.min_setback_m >= 3 m	chunk:C8
PASS	0.0314908341144287	building.coverage <= 0.3 ratio	chunk:C2
FAIL	7.1054273576010026	building.min_setback_m >= 3 m	chunk:C8
PASS	0.0314908341144287	building.coverage <= 0.3 ratio	chunk:C2
FAIL	46.0	building.height_m <= 10.15 m	chunk:C5
FAIL	7.1054273576010026	building.min_setback_m >= 6 m	chunk:C5
FAIL	7.1054273576010026	building.min_setback_m >= 4 m	chunk:C5
PASS	1.3563555211058689	building.far <= 1.6 ratio	chunk:C2
PASS	0.0314908341144287	building.coverage <= 0.7 ratio	chunk:C2
FAIL	46.0	building.height_m <= 9.15 m	chunk:C3
FAIL	46.0	building.height_m <= 21.5 m	chunk:C3
PASS	0.0314908341144287	building.coverage <= 0.4 ratio	chunk:C3