

# Muon induced secondary electrons at the KATRIN experiment

## Detector installation and setup and data analysis

Diploma Thesis of

**Philipp Rovedo**

At the Department of Informatics  
IKP - Institut fuer Kernphysik - KIT Karlsruhe

Reviewer: Prof. Dr. Guido Drexlin  
Second reviewer: Prof. Dr. Ulrich Husemann  
Advisor: Nancy Wandkowsky  
Second advisor: ?

Duration: September 27th 2012 – September 27th 2013

---

I declare that I have developed and written the enclosed thesis completely by myself, and have not used sources or means without declaration in the text.

**PLACE, DATE**

.....  
**(YOUR NAME)**

# Contents

<b>1. Introduction</b>	<b>5</b>
1.1. Neutrinos in the standard model . . . . .	5
1.1.1. Neutrino Oscillations . . . . .	6
1.1.2. Direct measurement of neutrino mass . . . . .	6
1.1.3. Indirect measurement of neutrino mass . . . . .	7
1.2. Cosmic muons and their interaction with matter . . . . .	7
<b>2. The KATRIN experiment</b>	<b>9</b>
2.1. Measurement principle . . . . .	9
2.2. Experimental Setup . . . . .	9
2.2.1. Source and Rear Section . . . . .	11
2.2.2. Transport and Pumping Section . . . . .	11
2.2.3. Pre-Spectrometer . . . . .	11
2.2.4. Main Spectrometer . . . . .	11
2.2.5. MAC-E Filter . . . . .	11
2.2.6. Focal Plane Detector System . . . . .	13
2.2.7. Solenoids, LFCS and EMCS system . . . . .	13
2.2.8. Background sources . . . . .	16
<b>3. The muon detection system</b>	<b>17</b>
3.1. Data aquistion crate . . . . .	17
3.1.1. First level trigger cards . . . . .	18
3.1.2. Second level triger cards . . . . .	18
3.2. Orca control . . . . .	18
3.2.1. Software Gains and Thresholds . . . . .	18
3.2.2. Run control . . . . .	19
3.2.3. Scripting . . . . .	19
3.2.4. File handling . . . . .	19
3.2.5. Orca Fit . . . . .	19
3.3. Scintillator modules . . . . .	19
3.4. Photomultipliers . . . . .	20
3.5. Gains, Thresholds and Acceleration Voltages . . . . .	20
<b>4. Analysis software</b>	<b>23</b>
4.1. Data structure . . . . .	23
4.2. Search Algorithms . . . . .	24
4.2.1. Frequency Search . . . . .	25
4.2.2. Incremental Search . . . . .	25
4.3. Member Functions of the class <b>run</b> . . . . .	25
<b>5. Comissioning measurements and analysis</b>	<b>29</b>
5.1. Rate instability due to charging effects . . . . .	29

5.2. Gain-, Threshold and Acceleration Voltage Settings . . . . .	30
5.3. Finding the best filter settings . . . . .	30
5.4. Moun module's rates . . . . .	30
5.5. Modules in high magnetic fields . . . . .	32
5.6. Module Stability . . . . .	32
5.7. Module Efficiency . . . . .	34
5.8. Photo Multiplier Tube Test with Sr source . . . . .	34
5.9. Synchronisation of moun module and FPD DAQs . . . . .	35
5.10. Coincidence Search between Muon- and Detector Events . . . . .	37
5.10.1. Monitor Spectrometer . . . . .	37
5.10.2. Main Spectrometer . . . . .	40
<b>6. Simulation of muon induced background</b>	<b>43</b>
6.1. Geant4 . . . . .	43
6.2. Geometry setup . . . . .	44
6.3. Muon generator . . . . .	44
6.4. Hit counter . . . . .	44
6.5. Visualisation - the vis.mac file . . . . .	44
<b>7. Conclusion</b>	<b>45</b>
<b>8. Outlook</b>	<b>47</b>
<b>Bibliography</b>	<b>49</b>
<b>Appendix</b>	<b>51</b>
A. First Appendix Section . . . . .	51

# List of Figures

1.1.	Neutrino mass hierarchy . . . . .	6
1.2.	Neutrino mass areas . . . . .	6
1.3.	Cosmic ray composition . . . . .	7
2.1.	Schematic tritium energy spectrum . . . . .	10
2.2.	KATRIN beam line . . . . .	10
2.3.	Main spectrometer and wire electrodes . . . . .	12
2.4.	MAC E Filter . . . . .	14
2.5.	Focal plane detector system . . . . .	15
2.6.	Detector wafer . . . . .	15
3.1.	Multiplug grounding . . . . .	18
3.2.	FLT back panel card . . . . .	18
3.3.	ORCA data object . . . . .	19
3.4.	Photomultiplier tube . . . . .	20
3.5.	Landau peak 1200 V acceleration voltage . . . . .	21
3.6.	Landau peak 1500 V acceleration voltage . . . . .	21
4.1.	Frequency search algorithm . . . . .	25
4.2.	Incremental search algorithm . . . . .	25
5.1.	Muon modules' rate: noise problems . . . . .	29
5.2.	6 channel energy Histogram with noise . . . . .	30
5.3.	Pulser and signal shape . . . . .	30
5.4.	Rate dependance on magnetic fields . . . . .	33
5.5.	Atmospheric density stability measurement . . . . .	34
5.6.	Rate scanning with cobalt source . . . . .	35
5.7.	Cobalt decay mechanisms . . . . .	36
5.8.	Testing of all modules with cobalt source . . . . .	36
5.9.	Synchronisation old firmware . . . . .	37
5.10.	Synchronisation new firmware . . . . .	37
5.11.	Asymmetric magnetic field flux tube . . . . .	38
5.12.	Non-axially symmetric magnetic flux tube . . . . .	39
5.13.	Time difference histogram . . . . .	39
5.14.	Non-axially symmetric magnetic flux tube monitor spectrometer . . . . .	39
5.15.	Time difference Histogram for all rings . . . . .	40
5.16.	Flux tube P12.M8 . . . . .	41
5.17.	Flux tube M12.8 . . . . .	41
5.18.	Inner electrode field emission . . . . .	41
6.1.	Muon rate dependance on zenith angle . . . . .	44
A.1.	A figure . . . . .	51

A.2. Scripting task through the example of a LFCS current ramping script. All currents are incremented in tenthths of the maximum current for the individual coil. . . . .	51
A.3. 50 A loops . . . . .	53
A.4. -50 A loops . . . . .	53
A.5. 25 A loops . . . . .	54
A.6. -25 A loops . . . . .	54
A.7. 50 A loops . . . . .	55
A.8. 50 A loops . . . . .	55

# List of Tables

3.1. Channel assignment . . . . .	17
5.1. Gains - thresholds - acceleration voltages . . . . .	31
5.2. Energy resolution dependant on filter setting . . . . .	31
5.3. LFCS settings stability measurement . . . . .	33
5.4. Asymmetric magnetic field measurements . . . . .	38
5.5. Non axially-symmetric magnetic field measurements . . . . .	39



# 1. Introduction

## 1.1. Neutrinos in the standard model

During the second part of the 20th century, a model stating 16 particles has been developed to describe a huge portion of known phenomena, the standard model. It contains six quarks, six leptons (both made up of three particle generations) and four types of Gauge Bosons. The latter are carriers of the standard models interactions of the former particles, meaning all interactions of matter are based on the exchange of one or more of the Gauge Bosons. For our universe, gravity, the graviton generated force, plays a major role for formation and stability of almost all larger structures. In particle physics however, it can mostly be neglected. Here, only the strong and weak as well as the electromagnetic interaction make for noticeable contributions to phenomena observed. That is why, in the standard model, gravity as well as its carrier, the graviton, are neglected. Most of what we can observe with our bare eyes or in basic experiments is attributable to the electromagnetic force or gravity, however, strong and weak interaction do play a major role when it comes to high energy physics. Here, the limited reach of the two is overcome by small distances between interacting particles. In case of the neutrino, detection and by that the study of its characteristics is even more difficult as it interacts only gravitationally and weakly. Now, as mentioned before, gravity is indeed long range, but very weak in force. And although weak interaction is a lot stronger compared to gravity, it is still weak compared to both electromagnetic and strong interactions. That is why the neutrino is considered elusive, detection efficiencies are low and only large scale detectors are able to detect statistically relevant amounts of neutrinos. One method used quite frequently is the Cherenkov radiation emitted while travelling through matter at speeds above the speed of light. This light, comparable to the supersonic cones planes cause in air, can be detected by standard photomultiplier tubes. The problem is that, as mentioned above, the volumes to be able to make dependable statements on directions and energies need to be large. This is why most experiments make use of “natural” detectors such as water (**cite** **ToDo** **MARE+ICE Cube**) or even ice. Other approaches are to catch neutrinos in reactions where those are required such as inverse beta decays:



In the standard model, neutrinos are considered massless. Many experiments though have shown that the weightless neutrino is a wrong assumption. Most of these were experiments proving neutrino oscillations with both reactor neutrinos and solar neutrinos




Figure 1.1.: The possible mass hierarchies for neutrinos.

Figure 1.2.: Possible mass areas

such as Kamiokande[Abe13] or SNO [MSTV03] (**add experiments**). Important for those experiments is the known source location making baseline analysis possible. ToDo

Up till now, only the differences of the squared masses are known. This leads to different relations depending on how masses are distributed between the flavours, 1.1, and how large they are absolutely 1.2. This problem is solved by the knowledge of one of the masses. KATRIN is on the verge of finding the  $\nu_e$ 's mass.[BKR09]

### 1.1.1. Neutrino Oscillations

If the neutrinos were without mass, its mass eigenstates would equal its flavour eigenstates:

$$\begin{aligned} |\nu_e\rangle &= |\nu_1\rangle \\ |\nu_\mu\rangle &= |\nu_2\rangle \\ |\nu_\tau\rangle &= |\nu_3\rangle \end{aligned} \tag{1.2}$$

First doubts concerning this assumption occurred as inconsistencies between the measured and the calculated solar  $\nu$ -flux occurred. As the count on  $\nu_e$  was too low, the theory of neutrino oscillations emerged, stating that a mixture of flavours was possible as the flavours were made up of all three of the mass eigenstates. The mixture is described by the so called Pontecorvo-Maki-Nakagawa-Sakata matrix:

$$\begin{pmatrix} |\nu_e\rangle \\ |\nu_\mu\rangle \\ |\nu_\tau\rangle \end{pmatrix} = \begin{pmatrix} \theta_{e,1} & \theta_{e,2} & \theta_{e,3} \\ \theta_{\mu,1} & \theta_{\mu,2} & \theta_{\mu,3} \\ \theta_{\tau,1} & \theta_{\tau,2} & \theta_{\tau,3} \end{pmatrix} \begin{pmatrix} |\nu_1\rangle \\ |\nu_2\rangle \\ |\nu_3\rangle \end{pmatrix} \tag{1.3}$$

### 1.1.2. Direct measurement of neutrino mass

Direct measurements of the neutrino mass require a reaction known to include neutrinos in its equation. There are both spectrometric and calorimetric approaches. While the scale of spectrometers is getting bigger and bigger, calorimetric approaches seem to be a reasonable alternative, although the slow detector response - the detector material itself is decaying - requires for large arrays of detectors leading to extensive space requirements as well at some point. The luminosity of spectrometer experiments though is unachieved by any other. That is why the KATRIN collaboration is working on a setup to measure electrons from Tritium decay to determine the neutrino mass.




Figure 1.3.: On the left, an artistic impression of various cosmic rays hitting the atmosphere [Sch13]. On the right, the measured composition for cosmic nuclei is shown: on top, the lightest particle, the proton. further down, all with orders of magnitude smaller rates, heavier ions.

### 1.1.3. Indirect measurement of neutrino mass

Another approach is using indirect ways of finding the neutrino mass. One possibility here is to search for neutrinoless double beta decay,  $0\nu\beta\beta$ , which can exist only if the neutrino is its own anti-particle, a so called majorana neutrino. Then, if two nuclei beta decay, the neutrino from one vertex can be absorbed in the second as an anti-neutrino - or vice versa. The decay would then not emit any neutrino and the rate would be dependant on the effective Majorana neutrino mass square" [DHMW13]:

$$\Gamma_{0\nu\beta\beta} \propto \left| \sum U_{ei}^2 m(\nu_i) \right|^2 \quad (1.4)$$

## 1.2. Cosmic muons and their interaction with matter

When high energy particles hit the upper parts of the atmosphere, a cascade of particles generated from the interaction with atmospheric molecules and atoms follows. Most primary particles are nucleons, most of which again are free protons, i.e. Hydrogen ions. Helium nucleons' fluxes are already about a order of magnitude below that, higher mass number nuclei show even lower rates[Sta04]. (insert right side graphic from TODOR) By different interactions, secondary particles are created. Any particle satisfying the inequation

$$E_{sec,kin} + m_{sec}c^2 < E_{prim,kin} + m_{prim} \quad (1.5)$$

can be created. Mostly pions at first, those cascade further. Often through intermediate photons muons emerge. These travel towards the earth's surface often close to the speed of light due to their small masses. Even at these high speeds, the muons' average decay time of around 2.2  $\mu$ s [Gor13] is too small for many muons to reach the earth's surface from our reference frame's point of view. In the most common production height of 2 km [DAAe08], the non relativistic time of flight for a 90 % speed of light particle would be

$$t_{class} = 2 \text{ km} / 0.9 \cdot c = \quad (1.6)$$

meaning only time dilation from special relativity makes the muon flux as large as it is:

$$t_{rel} = t_{class} / \sqrt{1 - 0.9^2} \quad (1.7)$$

meaning from our reference frame, the lifetime is prolonged by a factor of around 5, being already enough to reach the surface from heights of 3 km. Most muons have even higher energies, making it possible for them to reach surface from greater heights and under non perpendicular angles towards it. For KATRIN, this poses a problem. A smaller flux would be advantageous, as muons may, through different kinds of interaction, cause emission of electrons from the spectrometer vessels surface.

## 2. The KATRIN experiment

The KATRIN experiment is on its way to measure the neutrino mass or set new upper limits at precisions never achieved before. It will reach a sensitivity of  $200 \text{ meV}/c^2$  (90 % C.L.) excelling the previously best experiments of Mainz and Troisk by a factor of 10. Major challenges of the project are the requirement of ultra high vacuum, the exat knowledge of all magnetic and electric fields as well as external influences on those, the required high luminosity of the tritium source and the classification and reduction of background sources.

### 2.1. Measurement principle

A generally easy principle is used to find information on the neutrino mass: The energy of electrons from tritium decay is measured with high precision and compared to the standard model's presumption for a massless neutrino:



As the decay's energy is distributed between the constant neutrino's rest mass and its and the electron's kinetic energies respectively, the decay electrons will show a continous spectrum. The difference between the electron energy calculated by standard model presumptions to the extrapolated maximum electron energy from the spectrum then equals the neutrino rest mass as shown on figure 2.4 A different light is shed on the simplicity of the task when considering the needed accuracy of

### 2.2. Experimental Setup

The KATRIN experiment is made up of different section all fulfilling their own important purpose in the whole setup. We start off with the production of tritium electrons in the very south. These are guided magnetically northwards through pumping tracks removing hydrogen ions and other residual gases in the process on through the two spectrometers posing as a energetic high pass filter to the focal plane detector registering them. See figure 2.2 for a schematic overview. It follows a more detailed description of the single components.




Figure 2.1.: Schematic energy spectrum for electrons from tritium beta decay. On the left, the entire spectrum with the peak at the energy most emitted - around 5 eV - can be seen. On the right, a zoom-in on the endpoint showing both the calculations for a massless and a 1 eV neutrino. As described in the graph, rates in this region are extremely low and extrapolation through advanced software tools needs to be applied.




Figure 2.2.: The beam line of the KATRIN experiment with the different stages: Rear section and WGTS on the very left, followed by the transport section consisting of DPS and CPS. Energy analysis in pre- and main spectrometer of the spectrometer section and electron detection at the detector section.

### 2.2.1. Source and Rear Section

The required high luminosity is achieved by using a gaseous Tritium source. In a solid, most electrons from decays inside the structure would be resorbed quickly and be unavailable for analysis. The gase's large advantage is that not only the surface facing the detector emits electrons at the desired spectrum, but the whole volume covered by the magnetic flux tube arriving at the detector can be utilised. Of course, new challenges arise from the decision to use gas instead of solids: The spectrometers further downstream require for ultra high vacuum, for the main spectrometer in the order of  $10^{-11}$  mbar. As the Tritium pressure is in the order of  $10 \times 10^{-3}$  mbar and the source needs to be windowless - as no electron transparent window is known to stand such pressure differences - the pressure must be reduced to desired values without any physical barrier. For that purpose, after being allowed to decay inside the WGTS, the windowless gaseous tritium source, electrons fly on through DPS and CPS, the differential- and cryogenic pumping sections.

### 2.2.2. Transport and Pumping Section

In the DPS, pressure is actively reduced by the use of turbo pumps. These need to be tested thoroughly to withstand the constant radiation by tritium decays. Afterwards, the CPS uses strongly cooled walls to freeze residual gas, always keeping the information carrying electrons away from those by magnetic guidance.

### 2.2.3. Pre-Spectrometer

The pre-spectrometer was built in Munster and works on the same principle as the main spectrometer, although being a lot smaller. It is installed to reduce the flux to the main spectrometer, and by that the possible amount of stored electrons inside the main vessel. The pre-spectrometer has a single layer of wires as a inner electrode to shield against externally induced electrons. It is made to

### 2.2.4. Main Spectrometer

The largest component of all is the main spectrometer. With a diameter of 9 m and a length of over 24 m, it incorporates around  $1400 \text{ m}^3$  that need to be evacuated to extremely high vacuum of  $< 10^{-11}$  mbar. The vessel is equipped with two layers of electrodes on a comb-like structure. This setup reduces the number of secondary electrons from the spectrometer walls entering the flux tube's volume. Keeping that count low, the rate of those electrons not reflected magnetically due to imperfect symmetries is reduced to the sub-eV level. The layer made from thinner wires further to the inside shields the spectrometer volume from the one further towards the wall as cosmic rays may unleash electrons there as well. The main spectrometer as a whole is set to high voltage varied in the region below the endpoint of 18.6 kV. It constitutes the MAC-E filter from 2.2.5. The wire electrodes float on that voltage while being more negative to shield against electron background.

### 2.2.5. MAC-E Filter

A high luminosity is a major requirement for good statistics at the KATRIN experiment. This makes it impossible to use some kind of aperture to filter for electrons from Tritium decay with one momentum direction as they are emitted uniformly from the source volume and the largest amount of electrons would never reach the main spectrometer. That is why another strategy is used at KATRIN: The MAC-E filter - magnetic adiabatic collimation with electrostatic filter - which utilises the fact that, under small enough magnetic field changes, the magnetic momentum of a particle is constant; the particle can be considered




Figure 2.3.: On the left, the main spectrometer of the KATRIN experiment. It is divided into a central, cylindric shape to which two flat cones, disengaging in the steep cones, are attached. Also visible in this image are the 3 large pump ports on the lower right and the three-legged holding structures. On the right a image of the comb structure of the inner electrodes with both layers of wires visible.

adiabatic. The solenoid and coil system surrounding the main spectrometer are set up to create a strong, but smooth magnetic field gradient of several orders of magnitude. At entrance and exit of the vessel, solenoids generating fields of up to T are installed while in the central, widest part, the field strength reduces by a factor of (**factors and field strengths**). This area is called the analysing plane. According to

$$\mu = \frac{E_{\perp}}{B} = const \propto \frac{p_{\perp}}{B} \quad (2.2)$$

where  $\mu$  is the magnetic momentum,  $E_{\perp}$  the kinetic energy transversal to the field line and  $B$  is the magnetic fields magnitude, the momentum will align with the magnetic field lines as the field weakens. In the edge case of  $B \rightarrow 0$  in the analysing plane, the momentum would need to be exactly parallel to the field as the transversal motion would approach 0 as well. One can not differentiate between electrons emitted parallel to a magnetic field line and those emitted under the maximum angle towards it as the filter is not a perfect one. So, following

$$\mu_0 = \mu_{low} \longrightarrow \frac{E_{\perp 0}}{B_0} = \frac{E_{\perp low}}{B_{low}} \quad (2.3)$$

the energy resolution can be described by the field values, the electron's initial energy  $E_0$  and its maximum transversal energy  $E_{\perp max}$  to be accepted by the filter:

$$\Delta E = E_{\perp max} = E_{\perp 0} \frac{B_{low}}{B_0} \quad (2.4)$$

The main spectrometer reaches a resolution of 0.93 eV. To further filter out electrons with high starting angle, the source is set to lower fields than the maximum  $B_{max}$ . As with larger angles come longer paths, this reduces the probability of electrons taking part in scattering processes inside the source section being detected.

$$\theta_{s max} = \arcsin \sqrt{\frac{B_s}{B_{max}}} \quad (2.5)$$



graphics/katrinExperiment/macEFilter.jpg

Figure 2.4.: Functionality of a MAC E filter. The angular momentum of an electron not starting parallel to the magnetic field lines is converted mostly to linear kinetic energy up to the point of lowest fields. Here, the energy is analysed before the particle is guided towards the detector.

With the chosen settings This results in an angular acceptance of  $2\pi$ .

### 2.2.6. Focal Plane Detector System

The main detector is located at the very north of the experiment. It is made up of a silicon wafer divided into 148 pixels attached to the readout electronics by pin connectors. The pattern is dartboard-like, multiple pixels with the same distance to the center form rings. Every pixel has the same surface area, making rates more easily comparable - that is if the magnetic flux through the wafer is as homogenous as in this experiment. The detector system is roughly divided into two chambers: one connected to the ultra high vacuum of the main spectrometer and one with a lower grade vacuum on the detectors readout side. For background reduction, the detector system features both a passive shielding and an active veto system read out by the same data crate as the detector itself. It allows to discriminate externally triggered events. due to the high magnetic fields from detector and pinch magnet, semiconductor readout electronics had to be used instead of conventional photomultiplier tubes.




Figure 2.5.: The focal plane detector system including the flux tube (green). One can make out the different grade vacuum sections: extremely high vacuum (XHV) and medium high vacuum (MHV). The post acceleration electrode is visible left of the actual detector and ist signal feed trough on the very right. Multiple flanges and connectors are shown, not in this image are the calibration source holders.

Figure 2.6.: The detector wafer as installed in the FPD system. Note the “dartboard pattern” with the four pixel bullseye in the center on the left side.

### 2.2.7. Solenoids, LFCS and EMCS system

To achieve magnetic guidance in the way explained above, a sophisticated system of supraconducting solenoids, the low field correction system LFCS and the earth magnetic field compensation system EMCS have been installed [G<sup>+09</sup>]. These make sure that the path of flight is kept away from the wall and can be considered adiabatic, that penning traps are avoided as far as possible, that the earth magnetic field is compensated for and, most importantly, that the field drop to the analysis plane is of the order of (order?) so the spectrometers resolution will achieve desired values. ToDo

### 2.2.8. Background sources

Different sources contribute to the background of electrons arriving at the detector. First, there is background due to stored electrons. Penning traps cause electrons with fitting energies to be trapped in a potential cup. Discharges of those traps due to scattering processes with either residual gas or due to excessive filling of the trap can cause high-rate events at the detector. This can be both dangerous for the detector itself as it is harmful for data taking. Stored electrons can be both from external sources as from within the spectrometer. Decays of residual gas or wall absorbed molecules can contribute to the background. One large background source is radon, a neutral particle enabling it to move freely inside the vessel. Radon alpha decays, but shakeoff-, conversion- and auger electrons can then be guided to the detector [G<sup>10</sup>].

Another large background souce are cosmic rays interacting with the vessel hull and producing electrons like that. This background is reduced mainly by two factors, one: the symmetry of the magnetic field and two: the wire electrodes shielding the flux tube up to a certain threshold energy. To one: if the fields, both electric and magnetic, were perfectly symmetrical and parallel, only particles generated within the flux tube would be guided towards the detector. But through inhomogenities and alignment errors, electrons may enter the flux tube even if generated externally, e.g at the spectrometer wall through  $E \times B$  drifts. To keep this from happening, point two, the wire electrodes, were installed. They shield the flux tube against electrons with energies up to  $E_e = U_{wire}e$  depending on the wire electrodes voltage  $U_{wire}$ .



### 3. The muon detection system

The need for low background rates at the main detector requires for a good knowledge of background sources. Despite magnetic reflection and wire electrodes, cosmic ray and particularly cosmic muon induced background may be an issue for the KATRIN experiment. To gather and assess muon related data, scintillator modules have been installed at both the monitor spectrometer and the main spectrometer. While the monitor spectrometer is equipped with only two rather small modules, at the larger main spectrometer, 8 modules have been installed at different positions enabling the user to cover different regions of the vessel. This freedom is enlarged by installing the detection system on three independently movable trolleys. The modules have been connected to the DAQ one trolley per card, meaning modules one and two connect to card three, modules 3 through 5 to card six and modules 6 through 8 to card nine (3.1) All connections from modules to DAQ are made of coaxial cabling of equal length. This ensures comparable timestamps which are assigned only after the analogue signals arrive at the DAQ. High voltage is provided by two supplies, one on the east and one on the west side of the main hall. All devices of the muon detection system are connected to two multiplugs that are both overcurrent protected and feature mains filters. These multiplugs have been modified 3.1 to connect to a ground other than the outlet's. To ensure a common potential for all of the devices and the surrounding appliances this connection was made to the trough below the main vessel.

(insert photograph of multiplug)

**ToDo**

#### 3.1. Data aquisition crate

The Data acquisition crate, short DAQ, is the central part of event recording and by that the interface between hardware muon modules and software based ORCA machine. It

Module	1A	1B	2A	2B	3A	3B	4A	4B
Card	3	3	3	3	6	6	6	6
Channel	0	14	3	7	0	14	3	7
Module	5A	5B	6A	6B	7A	7B	8A	8B
Card	6	6	8	8	8	8	8	8
Channel	9	23	0	14	3	7	9	23

Table 3.1.: Assignment of module sides to cards and channels



Figure 3.1.: Added extension of the earthing contact to connect to any ground needed

Figure 3.2.: FLT back panel card with channel numbering scheme. Readout groups are 0,1,2,3,4,5,6,7 with 14 as the sum channel,

features first and second level trigger cards in version 4 that are described in detail in the following sections 3.1.1 and 3.1.2. The linux based system runs from an external hard drive connected to the second level trigger card via USB. Here, a screen and keyboard can be connected for network setup, then, access via secure shell is possible. The DAQ can be connected to and controlled by the ORCA software 3.

### 3.1.1. First level trigger cards

The FLT cards directly receive the signal output of the photomultiplier tubes via coaxial cabling. They then do first parts of data analysis to reduce data flow to the ORCA machine. In this case, only events with occur simultaneously on both sides of any module are passed on. This reduces the rate from (**look up non veto rate**) to around 250 Hz. The FLT cards are made up of a large main card and a smaller connector card entered at the back side. Every card has 28(**28?**) channels sectioned into three groups. Every group consist of one sum channel that can be read out in coincidence with any other or multiple other channels from the group. In case of the muon modules, 1-fold coincidence is sufficient. **(channel numbers)**3.2

**ToDo**  
**ToDo**  
**ToDo**

### 3.1.2. Second level trigger cards

Only one second level trigger card is installed on each DAQ. all the Signals from the FLT cards are stacked here and passed on to the the ORCA machine. Networking runs directly through the SLT card. Other connections, such as USB, a display port, and also the CAT 5 connectors for synchronisation to a clock can be attached to the back panel card.

## 3.2. Orca control

The orca software (Object-oriented Real-time Control and Acquisition) [How09] is the central software for data acquisition. It is able to control lots of different devices via various kinds of interfaces with ethernet connections being the most common.

### 3.2.1. Software Gains and Thresholds

All data registered by the DAQ is amplified and cut off at certain, software set values. Theses can be entered for every chanel of every card separately. Gains can vary from 0 to 4095 (12 bit), thresholds can be set to any value up to the maximum bin used. Depending on the filter settings, ore more precisely with rising shaping length, bin values will be shifted towards higher absolute values 5.3. Scripting of the values is possible and reasonable for large numbers of readout channels such as at the FPD.

Figure 3.3.: Data storage object in ORCA. Marked is the dropdown for setting paths for data, logs and ...

---

### 3.2.2. Run control

Runs are the basic element of data storage, every time data is recorded, a run is created. Inside every run can be a number of subruns (at least there is one) that will in turn contain data classes such as KaLi::KLVetoEvents, the most used event class in case of the muon modules. Runs and Subruns are started and stopped via the "Start Run", "Stop Run", "Start SubRun" and "Stop SubRun" buttons. While, from Run control, Runs can be set to end after a certain timespan and even repeat, Subruns can only be used on the go. This is different if scripting is utilised. 3.2.3.

### 3.2.3. Scripting

Scripts are useful for repetitive tasks or such that require short interaction only at certain points in time. One example for scripting is the ramping of LFCS coils that has been used to check the rate dependance on the LFCS currents. In that case, the script sends the values to be set to the ZEUS server, which passes them on to the **(company name)** ToDo boxes which in turn set the desired values at the power supplies. As this was supposed to be a stability measurement, every LFCS setting was kept constant for half an hour after which the script changed the currents. Scripting makes it possible to take these 5 h runs without human interaction making it much more comfortable A.2. Of course, much more sophisticated tasks can be handled through scripts as well.

### 3.2.4. File handling

All runs created are first saved to the local disc of the iMac machine as ORCA specific .orca files. Sorting in folders for year and month can be applied to quickly find what you are looking for. They are then uploaded to servers of the IPE via cronjobs, a feature of the Linux based MacOS. The crontab is set to upload only files from "/home/..../data/" **(add dirs)** ToDo - the folders in the data storage object should be set to that 3.3. Scripts on the servers convert the files to the .root format. Using the ROOT based KaLi software, the user can then access and analyse 4.1 this data from anywhere he has internet access.

### 3.2.5. Orca Fit

The Orca Fit function uses external servers to fit data aquired by the DAQ in user defined ways. Besides linear or gaussian fits, landau fitting can be used. This way, the user can receive an impression of the goodnes of the data via  $R^2$  values.

## 3.3. Scintillator modules

The central part of the detection system are the eight scintillator modules. They are made of the synthetic material BC-412 which is utilized in applications requiring large area coverage [Cry05]. These have previously been used at **(From Where?)** ToDo. Every scintillator cuboid is read out by two sets of four photomultiplier tubes. Photons arriving at the short ends of the module are guided to the photomultiplier tubes via non-scintillating material which, away from that, exhibits similar optical properties. All other sides of the scintillator are covered in reflective foil to push detection efficiency to the maximum. Of the eight photomultiplier tubes per scintillator module installed, 4 are read out via one FLT channel.




Figure 3.4.: Schematic view of a photomultiplier tube with incident photons and photoelectrons emerging. Note the nested dynode structure for cascading purposes.

The background of low energy events can be reduced significantly by recording only events occurring on both sides of the module at once. Only coincident signals should be recorded by the DAQ, though, on some occasions, quite a lot of single side signals occur. To account for those, every dataset is first analysed by a search algorithm (4.2.2) to filter them.

### 3.4. Photomultipliers

#### ToDo

Each Photomultiplier tube is made up of a layer of (**of what**) where photons from scintillation ionize the layers' atoms leaving electrons with their initial Energy less the ionization energy

$$E_{e^-} = E_{phot} - E_{ion}$$

The electron is then accellerated and guided by the electric field from dynode to dynode, cascading to more and more electrons, as each electron's energy rises by  $e \cdot U_{acc}$  between each pair of dynodes.

### 3.5. Gains, Thresholds and Acceleration Voltages

To achieve the best possible event detection, the photomultipliers' acceleration voltages as well as the software gains and thresholds in Orca had to be adjusted. The focus here was to obtain landau peaks with equal height and width, as the rates throughout the modules can be considered equal over large time intervals compared to the inverse rate. At first, the acceleration voltages were kept low to limit the signal peaks' heights to around 2 V. Carefully setting the mentioned parameters, one achieved the following, well aligned curves. A problem remaining at the time though was that the electronic noise set in pretty close to the peak position, only slightly shifted to lower energies. This meant that thresholds had to be set close to the peak bin as well, loosing low energy events in the process, observable in figure 3.5. This showed in rates of around 150 Hz that did not compare too well to literature values. The high energy region though was well fittable with landau distributions.

#### ToDo

(**mv co**) Later in the comissioning process, it got clear from the handbooks that the photomultiplier tubes had to be operated at accelleration voltages of 1.5 kV and above. To keep the singnals' height as small as possible, most of the tubes were limited to this minimal voltage,

#### ToDo

wheras the sides (**which ones**) were set to 1.6 kV over showing lower rates than the others. Following this procedure, the tubes seemed much more stable and comparable, as

#### ToDo

all the gains and thresholds could now be set to the same values of (**enter values**) and respectively, while still showing aligned peak positions 3.6. This is a huge advance to before when gains varied by a factor of up to almost four as it reduces potential non-linearities in amplification. Also, gains are left at lower values to begin with, leaving a larger part of the al in all amplification to the photomultiplier tubes known for their linear behaviour and relatively low noise.




Figure 3.5.: The landau peak at acceleration voltages around 1200 V. All channels show similar width and height. Note that the thresholds had to be set pretty close to the peak position as noise was a huge issue under the conditions.




Figure 3.6.: Landau peaks after raising acceleration voltages to 1.5 kV or else 1.6 kV. Note that this pattern was achieved solely by raising two module's side's acceleration voltages to 1.6 kV leaving gains and thresholds at the same low level for all channels.



## 4. Analysis software

To analyse the data recorded by DAQ and ORCA software, completely new data structures fit to the needs of muon detection and coincidence analysis have been created. Methods have been implemented to further investigate data stored inside those structures. A cmake file has been created making it possible to install the program on any machine used for analysis. All the sources including the main programs are available on the svn repository (**move program(s) to svn repository**). Doing so, external programs can be modified ToDo for custom analysis that shall include muon data making it very modular.

### 4.1. Data structure

All data from the IPE-servers arrives converted from ORCA-specific formatting to .root files compatible with CERN's analysis software ROOT. Hence, ROOT Methods are used to extract data from these structures, while most of these methods are implemented as part of the KaLi package in Kasper, which constitutes for a complete and closed data transfer protocol. Through those structures, data specified by the user will be cached locally and can be analysed afterwards.// For analysis with the classes described here, all data is transferred from the cached files to runtime storage. Here, the newly written class **event** with the following members comes into play.

event private class members

- fADCValue
- fTimeSec
- fTimeSubSec
- fPanel
- fSide

For each member, corresponding set- and get-methods have been implemented making them accessible to the programmer. Furthermore, the operators "<", "<=", ">", ">=", "==" and "-" have been overloaded to compare the timestamps of the event class. This

was useful especially since ADCValues are merely used for plausibility checking of the data but not for quantitative analysis. Doing so, events and the classes derived can easily be compared and searching becomes cleaner and clearer.

Derived from the base event class are two more storage classes:

**panelEvent** storing a second ADCValue

**coincidentEvent** additional member

- fADCValue2

and the common timestamp of events activating both panel sides and **coincidentEvent** storing ADCValues of simultaneous events in multiple modules and the number of modules involved:

**coincidentEvent** additional members

- std::vector fADCValues
- fnPanels

Every ORCA-run then utilizes the class **run** storing the data of the .root files in vectors of events. Recorded events should already be filtered - only simultaneously occurring events on the two sides of the same module should be recorded. As, under conditions not known, single sided events are recorded as well, a software workaround is needed. All events of one side of the modules are scanned to find whether a corresponding event with the same timestamp exists on the other side. If so, a coincidentEvent is created and pushed back into the run's vector of coincident events corresponding to the module it occurred in. Now, the user can decide on which modules to analyse with the setPanels() function. This can be done sequentially for multiple sets of modules without newly reading the run's data, as all the primary data is stored inside the event vector.

**run** class members

- std::vector events
- std::vector detectorEvents
- std::vector eventsByPanels
- std::vector coincidentEvents
- std::vector selectedPanels

## 4.2. Search Algorithms

To analyse data, at various points searches for events with a particular timestamp have to be performed. This was simplified by the time-sorted recording of events. A first implementation to search for coincident events was done on the base of average frequency and its standard deviation. This algorithm proved as fast and stable, though well applicable

Figure 4.1.: An illustration of the search algorithm utilising the average rate of the run analysed. Based on that, a guess is made (marked in). If that guess is wrong, the algorithm increments the guess in units of the rates standard deviation.

Figure 4.2.: All modules are stepped through, the one with the earliest time stamp is incremented. Then, all times are compared to each other.

only for two sets of timed events. That is why an advanced incremental method has been created. The number of modules is now limited only by the physically available memory and the speed is even higher.

#### 4.2.1. Frequency Search

As this algorithm was built to run on only two sets of data, it simply walks through one set incrementally and looks for corresponding data in the other. Latter is not done in a "dumb" way by incrementing through the second set as well, but by calculating the average frequency of events inside the set and performing an intelligent guess on that basis. If the guessed event shows a different timestamp, the algorithm will keep going forward or backward in time in steps of the frequency's standard deviation until the timestamp searched for is in between two steps. Lastly, simple incrementation is used to find out whether an event at the desired point in time exists or not.

#### 4.2.2. Incremental Search

While the frequency search increments solely one dataset, the incremental search steps through all the event trees, incrementing the one with the smallest timestamp. It then compares all events to each other, writes out the coincident ones, if any, and goes on incrementing the next smallest stamp. This assures the finding of all coincident events while keeping the speed very high.

### 4.3. Member Functions of the class **run**

#### Constructor **run()**

Whenever a new instance of "run" is created, the constructor is called. Arguments to be passed are a `KaLi::KLRIdentifier`, basically a string distinctively naming the run to be analysed, such as "myo00000001", `KaLi::KLDataManger`, a class handling the download of the files from IPE-servers and a toggle variable telling the constructor which data to read via the member function `getRun()` and what member functions to call afterwards:

#### Toggle Choices

- **0:** Data is downloaded and both muon data and detector data are stored
- **1:** Data is downloaded and only detector data is stored
- **2:** Data is downloaded and only muon data is stored
- **3:** Data is read from local file system, only muon data is stored

**Destructor run()**

The destructor deletes all the contents of the vectors of events and inherited classes and clears them afterwards before deleting the member RUN which in fact frees all the memory reserved by the KaLi classes.

**getRun()**

This sets the member KaLi::KLRUN through the KaLi::KLDataManager and then returns its KaLi::KLRUNEvents - these include all recorded events meaning also both the relevant KaLi::KLEnergyEvents and KaLi::KLVetoEvents. The getRun() function is used for example in the constructor to read the run's data.

**getLocalRun()**

It is not always possible to read data from the file servers, example given were files too big leading to timeouts at least in older KaLi versions. That is why the getLocalRun() function was introduced reading data from the local filesystem via the KaLi::KLRUNIdentifier. The path to the files needs to be adapted in the source code (**environment variable?**).

**ToDo****detectCoincidences()**

After calling the member function channelCoincidences(), panelCoincidences(nPanels) is returned where nPanels defines, how many modules have to show coincidences for the counter to increment.

**channelCoincidences()**

This **always** clears the vector eventsByPanels before filling it according to the current selectedPanels settings. To do so, it loops over all entries of selectedPanels, calling loopOverSides() of the current module.

**loopOverSides()**

Analysing only one of the modules for coincident events between the two sides, the function runs through all the events of one panel side using the operators "<" and "==" overloaded for the class run to compare event times. For the search itself, the "A" side's index is incremented step by step while the "B" side's index is pushed up as long as its event time is smaller than A's. Every time that condition changes, it checks whether the events occurred at the same time - pushing a coincidentEvent with both the events ADCValues and the timestamp into the vector for the corresponding module if so - and then going on incrementing A's index.

**ToDo****panelCoincidences()**

As mentioned above, the first algorithm to search for coincidences between different panels was based on the average event frequency and its standard deviation, soon being replaced by a simpler, more efficient incremental algorithm: This features a storage for the smallest timestamp in a group of events. (**change code to overl.ops**) This is set to the smallest timestamp of the first event of all the modules analysed. Now, all the events are compared to the smallest one. This has the advantage, that one does not need to cross check every event with every other one but can simply compare every event to the smallest in a linear way. If simultaneous events are found, they are pushed back into the coincidentEvents vector together with the timestamp and their ADC values, nPanels is risen by one. Subsequently, the index of the smallest event storage is incremented and the new smallest event in the

- **default/1:** Size of events returned
- **2:** Size of eventsByPanels returned
- **3:** Size of coincidentEvents returned
- **4:** Size of detectorEvents returned

changed pool is searched for via the member function `findSmallest()`. This is repeated until all the event storages have reached their last entry. The return value is the number of events fulfilling the requirement passed through `nPanels` to `panelCoincidences`: if it is zero, every coincident event with two or more modules involved is counted, for every other number, only the number of event with exactly this number of modules is counted.

### **findSmallest()**

Setting the smallest event's timestamp through references, the `findSmallest` function requires only the steppoints of the different modules and returns the one with the smallest timestamp.

### **TOFHist()**

Setting the modules to be analysed to one and two, this function was designed to analyse monitor spectrometer data. This also reflects in the fact, that both muon data and detector data are expected to be stored within the same mosxxxxxxxx run file. The function then runs `channelCoincidences()` and `panelCoincidences()` before shifting through all the muon events searching for following detector events in a certain time interval.

### **TOFMuonDet()**

In contrary to the `TOFHist` function, this one reads muon and detector data from different files as it is designed for the needs of the main spectrometer. Here, two DAQs record muon and electron detections to `myoxxxxxxxx` and `fpdxxxxxxxx` files respectively. That is why the function reads a muon run and requires a guess as to where corresponding detector data is located. It then loads on detector run after the other to check whether there's events inside a time window after each muon event. If so, a histogram is filled with the data acquired to inspect it for cumulation at particular times.

### **determineEfficiency**

Efficiencies of modules can be determined through three of them located coextensively in front of each other. Then, all events recognised in both the uppermost and the lowest module have to - leaving geometrical inaccuracies unaccounted for - pass the middle module as well. By comparing the counts one can determine an efficiency for the module:

$$\%_{\text{eff}} = \frac{\wedge_{68}}{\wedge_{678}} \quad (4.1)$$

### **getSize()**

The `getSize()` function returns the size of one of the vectors storing events or one of the inherited classes depending on the passed integer "what":

(**default nonsense, reimplement**)

**ToDo**

**readVetoEventData(), readDetectorData() and readMOSDetectorData()**

Depending on the toggle choice in the constructor, either one of the two or both of the functions are called. While the readDetectorData() function reads all recorded KaLi::KLEnergyEvents (only the FPD records those), the readVetoEventData() function reads all the KaLi::KLVetoEvents from cards three, six and nine. This can never interfere with veto data recorded directly around the FPD vor active vetoing of detector signals, as cards 15 and 16 are used here. For analysis of monitor spectrometer data, a function readMOSDetectorData() has been implemented reading all energy events of card one independent of channel, while of course single channels can easily be excluded. The pulser usually active at the monitor spectrometer creating KaLi::KLEnergyEvents at constant frequency is standardly excluded from analysis. All the member functions reading data require the passage of an instance of the KaLi::KLRunEvents, usually the member of the same class set in the getRun() function.<sup>4.3</sup>

## 5. Comissioning measurements and analysis

While the system was still under construction at the beginning of this thesis, first measurements were taken at the time with few modules under preliminary conditions to look into the behaviour of the modules. Step by step, the system was brought to completion and is now up and running. During this time, several measurements and test have been conducted to ensure the capabilities of the system meet the requirements for the KATRIN experiment. Starting at the setup of acceleration voltages, gains and thresholds, Using data obtained by the muon modules and the detector as well as other subsystems' data, the muon induced background rates and both spatial and energy distribution can be obtained. Before actual measurements, the modules had to be set up and calibrated, meaning high voltage and signal cabling needed to be installed and high voltage power supplies had to be found.

### 5.1. Rate instability due to charging effects

As the panels' rates were peaking over certain, short time intervals at some arbitrary frequency, it was not possible to set gains, thresholds and PMT voltages correctly as one had to be lucky to be able to identify the peak position in a calm period. It seemed there was some kind of electronic pileup. As this did not appear for all the modules it was not noticed until later into the commissioning process.

If the landau peaks were not identifiable due to prevalent electronic noise, the measurement was rendered useless as a lot of noise triggered events were recorded. As a countermeasure, in cooperation with Sascha Wuestling, potential equalisation by connecting the modules to the huge trough below the main spectrometer has been established. After the installation of the grounding, the peaking did not occur any more so the issue seems to be resolved. Now, one could make a start on setting gains, thresholds and acceleration voltages 5.2.




Figure 5.1.: Rate progression over the course of hours. Noticable raise in the cumulative rate of all panels in certain intervals




Figure 5.2.: Energy histogram of 6 channels, counts over ADC-Value. Two channels show a lot of noise around the peak position while four are developing into nice looking Landau Peaks

Figure 5.3.: Pulser shape on the left compared to actual signal shape on the right.

## 5.2. Gain-, Threshold and Acceleration Voltage Settings

A first amplification - linear with acceleration voltage - of the scintillation photons occurs in the photomultiplier tubes. As signals at first seemed too high for the DAQ to handle at nominal values of the datasheet, these were reduced to around 1200 V. Now, the software gains and thresholds in the ORCA software needed to be set.

## 5.3. Finding the best filter settings

As the PMT tubes are directly, without any preamplifiers, connected to the DAQ, the signal lengths arriving at the latter are in the order of 20 ns. This poses a problem for filters as the sampling rates need to be high and anti-aliasing is inevitable. To find the best settings, a pulser has been set up to create events at known frequency and peak height. The pulser's signal form (**what form**) was chosen as closely to the actual shape as possible, which is the "pin diode" form.

Now, to evaluate filter goodness, the width of the resulting energy histogram, which should, assuming perfect pulser signals and perfect filters, be monoenergetic, was analysed for each filter setting. This resulted in the following set of data:

On average, the boxcar filter at shaping lengths of 150 ns shows the most promising results, i.e. the sharpest peaks for any signal height. This concurs with the settings chosen for the active fpd veto; here slightly longer (around 30 ns) but comparable signals enter the DAQ, showing best results at the same filter settings [Wie13]. That is why, for any measurements after (**run & date**), the new filter settings were used, bringing up the need for new threshold and gain adaptions 5.2.

## 5.4. Moun module's rates

A simple first check into the data is possible simply by comparing the rates measured to literature values. Here, a flux of around 1 per min and cm<sup>2</sup> through an area parallel to the

**ToDo**

**ToDo**

Panel/Side	1/A	1/B	2/A	2/B		
Card	3	3	3	3		
Channel	0	14	3	7		
PMT Voltage	1150	1150	1250	1150		
Threshold	2110	2110	2110	2110		
Gains	2350	2400	1200	2850		
Panel/Side	3/A	3/B	4/A	4/B	5/A	5/B
Card	6	6	6	6	6	6
Channel	0	14	3	7		
PMT Voltage	1150	1150	1150	1150	1150	1150
Threshold	2110	2110	2110	2110	2110	2110
Gains	2450	2400	2150	2550	2100	2400
Panel/Side	6/A	6/B	7/A	7/B	8/A	8/B
Card	9	9	9	9	9	9
Channel	0	14	3	7		
PMT Voltage	1150	1150	1150	1150	1050	1100
Threshold	2110	2110	2110	2110	2110	2110
Gains	3400	2100	2400	2500	3950	2900

Table 5.1.: **Gains, thresholds and voltages:** These are the settings that appeared to be reasonable for each panel side; furthermore, the table displays the card and channel each side is associated with in the DAQ card system

Table 5.2.: Energy resolution at different filter settings  
50 ns gap, 0 s shaping time

	1	2	3
standard filter	1	2	3
	1	2	3
	1	2	3
	1	2	3
boxcar filter	1	2	3
	1	2	3
	1	2	3

ground is stated. Measured rates are in the order of 250 Hz. The muon modules' area is

$$315 \text{ cm} \cdot 65 \text{ cm} = 2.05 \text{ m}^2 \quad (5.1)$$

Considering the 45° tilt of the modules towards the horizontal, this area reduces to an effective area of

$$A_{\text{eff}} = \sin(45^\circ) A_{\text{real}} = 1.45 \text{ m}^2 \quad (5.2)$$

Further taking into account detection efficiencies  $\eta$  discussed in 5.7, we receive an estimation of effective rate of

$$\Phi_{\text{est}} = \eta \frac{1}{\text{cm}^2 \text{Hz}} A_{\text{eff}} = 225 \text{ Hz} \quad (5.3)$$

**ToDo**

It compares well to measured rates of (**calculate actual rates**) 250 Hz.

## 5.5. Modules in high magnetic fields

For there is the need of moving the muon modules as close to the spectrometer tank as possible to register mostly muons that indeed went through the vessel, they are aligned closely to the air coil system. This brought up the problem of photomultiplier tubes having to work in high magnetic fields. Photomultipliers, as mentioned before, use electrons cascading in electric fields to generate amplified signals. Additional magnetic fields can keep the electrons from reaching the dynodes stopping the cascade thus keeping single events from being registered. As rate decreases strongly under these conditions (**are there runs showing that? ask nancy**), a solution needed to be found. As a simple, yet efficient passive counter measurement, a layer of mu-metal was wrapped around the modules. Mu-metal is a magnetically highly permeable material (here,  $\mu_r \approx$ (**find out permeability**)) that guides the magnetic field lines inside itself. In doing so, the remaining flux inside a mu-metal surrounded volume, and with it the field strengths, drastically reduces. To test the improvement the mu metal coverage produces, measurements with rising aircoil currents have been performed. Steps in the size of tenths of the maximum current of mostly 100 A, in some cases only 70 A, were used to record rates over half an hour at each value. During the first run, due to a slow control problem, the current was not raised between two steps. Although displaying the expected behaviour - rates dropped much less than before - the measurement was repeated with the correct currents. Measurements show that the rate still drops at currents close to the maximum, though only to around 90 % of initial values 5.4. As, under normal measurement conditions, the coil currents are mostly around half the maximum value or less, the problem could be solved, as here, the reduction in rate is within the order errors' order.

## 5.6. Module Stability

If consistent factual statements on muon induced background are to be made, the modules need to work stable over the course of days, as rates are supposed to be comparable. For this reason, over the Christmas time 2012, a two-weekly measurement of half hourly runs has been taken, see 5.3 for air coil settings used. Runs myo00000051 to myo00000675 contain the data of this measurement.

The time slot was chosen for the lowly frequented spectrometer hall's sake to minimise external impacts on data taking. For analysis, a simple program to count events in variable time bins was written, creating a count histogram for all the runs in the measurement period. The result can be seen in 5.5. The observable fluctuation is well describable by fluctuations in atmospheric density, i.e. pressure and temperature, as ideally, air could be described by

$$\rho = \frac{R}{M} \frac{p}{T} \quad (5.4)$$




Figure 5.4.: Counts over air coil currents, with a maximum of 100 A. A clear decrease in rate is recognisable in the last 5 data points.

Coil #	1	2	3	4	5	6	7	EMCS h
Current [A]	10	10	14	25	42	39	54	50
Coil #	8	9	10	11	12	13	14	EMCS v
Current [A]	54	21	36	30	21	20	56	15

Table 5.3.: Runtime settings for air coils as proposed and for the commissioning measurements. These were kept static over the two weeks end 2012/beginning 2013

Figure 5.5.: Atmospheric density as a function of time over the course of two weeks the muon measurements took place. Note the

where  $\rho$  is the density, R is the gas constant, M is the molar mass of air and p and T are pressure and temperature respectively. If one looks at the data from **(find weather station data, see if it fits fluctuations, maybe cascade data to back it up?)**

## 5.7. Module Efficiency

The runs used for stability measurements, as well as any other run including modules six, seven and eight, can be used to check muon module seven for efficiency. For tests on other modules, the geometry would need to be changed so that the one to be checked is in between at least two other modules. For analysis, the function `determineEfficiency()` 4.3 has been written. The principle is the following: considering the small change in momentum direction high energy muons achieve through interaction with matter, one can assume straight-lined paths. From that follows, that if two parallel planes, that can be used to describe the scintillating volumes, are hit, any other, also parallel plane, in between those two will be hit as well. Keeping this in mind, one can analyse data for events registered in both modules 6 and 8 and cross check whether a event has been detected in module 7 as well. The quota of events in all three modules compared to those detected in 6 and 8 - but including the triple events - shows the efficiency of module 7. It shows that during the measurement period end of 2012, the efficiencies were at **(rerun)** 94 % which is less than one would expect at a scintillator thickness of 5 cm for muons perpendicular to the largest module surface, even more for any other. For that reason, the filter settings were checked and changed to the boxcar filter with a gap of 150 ns from the before used **(exact name)** filter. However, the expected efficiency increase was not observable, the average efficiencies before and after are within the margin of error of the other. To examine the problem further, another idea came up: modules 3, 4 and 5, that are located next to each other could be used for efficiency measurements as well considering they are stacked in an upright way. Using the program on those three modules resulted in even lower efficiencies of  $(50 \pm 3) \%$ . This raises the question whether this is not an effect of signal filtering, but a previously not considered physics effect. One thing coming to mind is deviation of the muon track from linear forms. This feature would comply with the seemingly lower efficiency at the upright stacked modules, where, at equal bending radii, the ratio of muons travelling around the middle module is higher due to the lower total area in stacking direction. This thesis should be tested. This can be done both by simulating the cosmic muons including magnetic fields and empirically by varying the distance between the single modules. The latter is difficult not only because the modules are heavy and not made for lifting (no designated carrying structures), but also because movement always means potential danger to the photomultiplier tubes and their connection to the scintillators. Furthermore, if all coils and solenoids were to be turned off simultaneously at some point, one could collect data then and see how efficiencies change during that (there have been runs taken when that was still the case, but only few modules were working properly at that point). If the dependence on module distance turns out to be true, but the efficiencies are still below expected values at the lowest possible distances, a possible improvement would be to use preamplifiers before signals arrive at the DAQ. These would widen the signals timewise leading to a more easily detectable signal for the filters.

## 5.8. Photo Multiplier Tube Test with Sr source

With sets of four photomultiplier tubes being read out over one cable, and, consequently, via one channel, the test of individual PMTs is not trivial. Nevertheless, a method using

**ToDo**

**ToDo**

**ToDo**




Figure 5.6.

a MBq  $^{90}\text{Sr}$  source to trigger events was used to check functionality. Of course, all tubes were able to see the source at any position but rates were expected to rise as the distance to any of the tubes shrank. A source holder was constructed from acrylic glass to shield the user from radiation and to attach the source to the modules, as a large dependence of rate on the position was found when the source was simply duct taped to the modules. As the foil mantling of the modules absorbs a non negligible part of the radiation emitted from the source, it had to be ensured that the number of layers was equal for all measurements. This was given only below the modules as the foil has been folded around them at the ends in a gift wrapping way. Thus, the source was pretty far away from the photomultiplier tubes making it more difficult to distinguish between them. A first measurement was then to check for exactly that distinguishability. (insert measurement for small steps over PMTs positions). ToDo

As one can see a rise in rate at the positions the tubes are located at, it was decided that four measurements per module and side were sufficient, especially as all measurements can afterwards be compared to each other. The tube positions at ( $\text{n,n,n,n cm}$ ) were used as measurement positions as well. For each side, a run has been taken containing five minute subruns for every position. Figure 5.8 shows the result of these measurements. One can see that the gerneral shape of each side compares very well to the others. Exceptions are (which ones different?) showing slight, but acceptable deviations off the norm. ToDo

## 5.9. Synchronisation of moun module and FPD DAQs

Measuring time differences on a  $\mu\text{s}$  scale requires exact synchronisation of the two different DAQs used for data acquisition. For this purpose, a clock has been designed sending signals at two frequencies: one at 1 Hz and one at  $10 \times 10^6$  Hz internally converted to a  $20 \times 10^6$  Hz signal by the DAQ. Those signals can be synchronised to the timestamps of GPS satellites if a GPS antenna is connected. This has not yet been done as relative synchronization




Figure 5.7.: Decay mechanism of  $^{90}\text{Sr}$ : first a lower energetic decay to  $^{90}\text{Y}$  emitting 544 keV/c<sup>2</sup> electrons, from that most probably a higher energetic decay to  $^{90}\text{Zr}$  ground state (2.29 MeV/c<sup>2</sup> electrons) or, with low probability, to one of two of its excited states.




Figure 5.8.: Measurements with source at different positions

---



---

Figure 5.9.: Subsecond time differences before firmware update: Large differences between the events,

between the two crates is sufficient for the purposes of finding correlations between muon and detector events. As the cable length for signal transmission is pretty extensive - around 50 m - it was decided to use optical fibers instead of CAT 5 cabling. As two signals need to be transmitted, paired (**connection type name**) fibers were used. The clock itself has optical outputs, the DAQ though needs converters from optical to electrical signals and a modified SLT back panel card to receive the converted signals via Cat 5 cable.

**ToDo**

To test the setup, the muon DAQ was moved to the detector platform. Both crates were fed by a pulser signal. Runs at different frequencies were recorded to test both the synchronisation and the detection of events. To synchronize timestamps to an external signal, the FLT cards drop down menu needs to be set to (**look up**) and the SLT needs to be set to (**lookup too**). At first, manually triggered signals were used in minute runs to check the timestamps equality. Several runs were taken, all showing that the events were shifted by several  $\mu$ s

**ToDo**  
**ToDo**

In close cooperation with the IPE it was found that this was merely a problem of firmware versioning as well as software settings in Orca resolving the problem quickly. After installing the latest firmware, more runs were taken now displaying the desired behaviour: Following the manually triggered events, runs with fixed frequency events were recorded, raising the frequency to up to (**find maximum**). All the test worked fine including starting one DAQ's run way ahead of the other. Those events recorded in both run files were always well synchronized. Afterwards, the muon DAQ was moved back to its original position and the optical fibers were stowed in wire-ways guiding it from the detector platform down to the basement where the muon detection system is located. Another problem occurred here, as signal transmission was impaired by a kink at one of the turns, but was quickly resolved by smooth rewiring. Concluding, it can be said that the clock runs continuously without any problems throughout all the measurements - including main spectrometer commissioning measurements.

**ToDo**

## 5.10. Coincidence Search between Muon- and Detector Events

If one wants to actually detect background induced by myonic events registered by the muon modules, those events need to be correlated to detector events time wise. For this purpose, the analysis code's class run was extended by the member functions TOFHist()4.3 and TOFMuonDet()4.3, where the former is used for monitor spectrometer analysis and the latter for the main spectrometer. The biggest difference is that, at the main spectrometer, two DAQs leading to runs with different starting times and of different lengths are created that need to be compared.

### 5.10.1. Monitor Spectrometer

Measurements at the monitor spectrometer are easily manageable due to the fast accessibility of all the components and the collection of data in a single run file through the mini crate.

---

Figure 5.10.: Time differences between events after firmware upgrades. Differences between the event times are within one 50 ns bin

Run	solenoid source	solenoid detector	inner aircoil	outer central aircoil	outer aircoil	emcs x	emcs y
mos00159395	0	25	0	-4	-4	2	-19.5
mos00159396-							
mos00159398	0	50	0	-8	-8	2	-19.5
mos00159399	0	50	0	-7	-7	2	-19.5
mos00159400	0	50	0	-6	-6	2	-19.5
mos00159401	0	10	0	-2	-2	2	-19.5
mos00160713-							
mos00160717	0.1	12.5	0	-2	-2	0	0
mos00160718-							
mos00160730	0.1	12.5	0	-2	-2	0	0
mos00161105-							
mos00161107	0.1	12.5	0	-2	-2	0	0
mos00161108-							
mos00161110	0.1	25	0	-2	-2	0	0

Table 5.4.: Measurements at asymmetric magnetic fields. The source side magnet was turned off for all measurements leaving the flux tube entering the spectrometer walls.

---

Figure 5.11.: Flux tube at asymmetric magnetic fields. Electrons from processes at the walls are guided directly towards the detector as the largest part of the flux tubes surface ends in the monitor spectrometer's vessel's wall

For measurements, high voltage supplies have been added to the (name of the rack) **ToDo** rack and the readout electronics were connected to a second FLT-card inserted into the mini DAQ and operated in veto mode. Gains and thresholds were easily set as only four sides had to be adjusted - compared to the 16 main spectrometer channels. The PMT tubes were operated at 1.5 kV. The detector gain and threshold settings for the 5 pixel detector have been kept, although the detector position has been shifted to the position at which the center pixel exhibited maximum rate and the pairs of east-west and top-bottom pixels showed comparable count rates. Furthermore, the recording mode was switched from histogram mode to energy mode as the timestamps for every single event were needed for analysis. Several hourly runs have been taken under different magnetic field compositions. Both asymmetric magnetic field (see table 5.4 and figure 5.11 and non-axially-symmetric field (see table 5.5 and figure 5.12 configurations have been investigated. **( )**)

The TOFHist4.3 function has been used to analyse the data. It browses through all the muon events detected and finds any detector event in a definable timespan after the muon event. This can be more than one detector event per muon event. In all of the settings, a clear peak is visible at around 7  $\mu$ s. As for count rates, they are a lot higher in the asymmetric magnetic field setup as secondary electrons are guided from their point of origin to the detector instead of mostly being magnetically shielded. In this setup, only the reflection through the rise in magnetic field on the electrons' paths takes its toll on the rate. A graphic of the flux tube configuration as well as the histograms for all of the settings can be found in the A, figures (**reference figures.**) The exact values are:

**ToDo** **(Do analysis for every measurement, insert peak positions + stdev)**

Run mos00...	<b>2 Horizontal loops</b>	soledon source	soleonid detector	inner aircoil	outer aircoil	outer cent. aircoil	EMCS x	EMCS y
161111-161125	0	25	25	6.8	7	5	0	-14
161126-161129	+50	12.5	12.5	3.5	-3.5	2.5	0	0
161130-161133	+25	12.5	12.5	1.75	-1.75	1.25	0	0
161134-161149	-25	12.5	12.5	1.75	-1.75	1.25	0	0
161150-161155	-50	12.5	12.5	3.5	-3.5	2.5	0	0
161156-161158	0	12.5	12.5	3.5	-3.5	2.5	0	0

Table 5.5.: Measurements in energy mode at non axially symmetric magnetic field. Both solenoid and air coil currents have bee changed, though always by a multiplication factor for all of them so that the ration remained the same.

---

Average	Standard Deviation
---------	--------------------

---

Figure 5.12.: Flux tube at non axially symmetric fields. Although no direct guidance from the wall to the detector is given (the flux tube never touches the wall in this configuration), by adding a magnetic component perpendicular to z-direction, the probability for entrance into the flux tube rises strongly.

---

Figure 5.13.: Time difference histogram for asymmetric magnetic fields.

---

Figure 5.14.: Flux tube at non axially symmetric fields. Although no direct guidance from the wall to the detector is given (the flux tube never touches the wall in this configuration), by adding a magnetic component perpendicular to z-direction, the probability for entrance into the flux tube rises strongly.

---




Figure 5.15.: Time differences of muon events followed by a detector event. From left to right and top down for every single detector ring, 0 being the innermost and 12 being the outermost ring.

### 5.10.2. Main Spectrometer

Monitor spectrometer results suggested that the time of flight was well measurable, even if on bigger scale, at the main spectrometer. So, during commissioning measurements, already parallel to measurement M1, some runs with asymmetric magnetic field have been taken with switched polarity or turned off pre spectrometer magnets compared to standard setup. The data was analysed for each single ring of the FPD. Search parameters were the time slot from 0 s to 15  $\mu$ s though remains inconclusive at the moment, see 5.15. Analysis for every single pixel was not possible due to much too low statistics, though it might be more conclusive as less different paths contribute to the single pixel. On the other hand, after the non-central alignment of the detector has been fixed using different settings for the LFCs-system, under asymmetric magnetic fields, the fields should be rotationally symmetric around the z axis disregarding small deviations. Assuming this, the path lengths for every pixel of one ring should be very comparable.

The failure to find a clear runtime for electrons induced by muonic events might be due to the combination of muon module position and the magnetic field setup as the wall area covered by the flux tubes and the volume surveilled by the muon modules did not overlap very much. Furthermore, due to the very low magnetic field at the wall compared to the volume inside the detector and pinch magnet, most of the induced electrons are magnetically reflected as the maximum polar angle towards magnetic field lines  $\theta_{max}$  is defined by

$$\frac{B_{min}}{B_{max}} \approx \frac{3\text{ G}}{4\text{ T}} = \sin(\theta_{max}) \quad (5.5)$$

meaning only angles satisfying the inequation

$$\theta < \arcsin \frac{B_{min}}{B_{max}} = \arcsin \frac{3\text{ G}}{4\text{ T}} = 0.004^\circ \quad (5.6)$$

---

Figure 5.16.: New flux tube

---

Figure 5.17.: Flux tube in field configuration M12.8

---

will be able to reach the detector. All others will be reflected and fly back to the wall to be absorbed in the conducting wall material. (**set real field values**) As a result, compared to the monitor spectrometer, where the ratio is a lot greater, less of the muon induced electrons arrive at the detector making long measurements a requirement for good statistics. This leads to detector rates of only around 2 cps, depending on the inner electrode voltages. At high inner electrode voltages, the rate increases strongly to 150 cps which is probably due to field emission from the electrodes. These measurements should be repeated when high voltage can be applied to the main vessel.

**ToDo**

Following that presumption, for M6 measurements, the setup was changed. The fluxtube was widened for its outer parts to hit the spectrometer wall in regions around combs n and n (**which combs**). This raises the probability of the muons detected being those inducing secondary electrons at the vessel as well. Also, the LFCS setup was changed in such fashion that the magnetic field at the spectrometer wall is higer by a factor of two, directly resulting in a higher angular acceptance of electrons. The resulting flux tube is shown in figure 5.16.

**ToDo**

(**flux tube including modules for horizontal and vertical view**) (**If data will be taken add to analysis.**)

**ToDo**  
**ToDo**

---

Figure 5.18.: Rate trend over inner electrode voltages

---



## 6. Simulation of muon induced background

To compare the data acquired to theoretically expected values, a Geant4 simulation of cosmic showers has been set up including the geometry of the main spectrometer as well as the muon modules. Using this software, any number of incidenting muons can be simulated and the effect on the main spectrometer and the muon modules can be evaluated. It was especially relevant to achieve estimations on which amount of the muons travelling through the main spectrometer would be registered by the muon modules. This would then make it possible to estimate the overall rate and probabilities for muons incidenting to also induce electrons entering the spectrometer.

### 6.1. Geant4

The Geant4 package is a powerful tool for simulation of particles. It has loads of possible interactions already integrated making it easy for the user to set up and run simulations. After setting up geometry and detectors, the user starts a run. Each run may consist of one or more events. During a single run, a loop of processes is called:

- Primary Generator Action
- Run action
- Event action
- Stacking action
- Tracking action
- Stepping action

For user interaction, for each item above, classes with the addition 'user' to the base classes name can be called before or after the standard action class. An example is the class G4UserEventAction invoked before and after each call of G4TrackingAction. It contains two member classes, namely BeginOfEventAction and EndOfEventAction that let the user decide what to do at this point. Through those, it is possible to change behaviour of the simulation or extract data needed. In this case, for every event, if more than one module has been hit, the copy numbers of those are pushed back to a vector of event data. Running the simulation, one can either interactively enter commands or write those to a .mac file, by default the vis.mac file, which are then sequentially executed.

Figure 6.1.: Dependance of muon rate on zenith angle.

## 6.2. Geometry setup

To set up a geometry, the class G4VUserDetectorConstruction is used. B1DetectorConstruction inherits from that as a base class and additionally contains all of the geometrical parameters needed for the setup such as radii of the main spectrometer cones or positions and extent of the muon modules. Every shape generated is made up of both a logical volume G4LogicalVolume and a physical volume G4PhysicalVolume. The logical volume describes the intrinsic properties of the geometric object added: its shape, its size and its material. The physical volume accepts a logical volume as input providing position and alignment of the previously defined. Inside the detector construction class, all of the materials used in the simulation need to be defined as well. These are the components of the air outside and inside the spectrometer including pressures and constitution, the stainless steel of the spectrometer wall and the scintillator material of the muon modules. The main spectrometer geometry was already (**written by who?**) existant but had to be modified as many border volumes were implemented. These were very flat volumes covering any area of the main spectrometer not needed for this simulation. Additionally, the muon modules have been added as sensitive volume. Keeping in mind that one wants to not only distinguish whether a module has been hit, but also which one. That is why the logical volume for every module is the same whereas the physical volume is a copy of the first at different world coordinates making them identifiable via their individual copy number.

## 6.3. Muon generator

Muon generation was realised through the primary generator action. The angular distribution suggested by Henrik Arlinghaus [Arl09] was implemented. The angular rate dependance is shown in 6.1. The energy was set to (**reasonable value**) disregarding the actual anergy distribution as this was mainly about flight paths that are not strongly dependant on energy at high energies. Starting positions were spherically distributed, with the direction towards the origin, which is in the center of the main spectrometer. Positions were then randomly moved in a volume surrounding the spectrometer to account for the non-point like structure of the detection system as a whole, while the distribution describes a single point in space.

## 6.4. Hit counter

For comparing the simulation to real data, of all the events generated, those hitting modules were counted. Each event containing at least one hit is written into a file for further analysis. To do so, the functions (**exact names**) are used handing the information up from function to function. This made it possible to compare the rates of the single modules, showing that the generator works fine. furthermore, it allowed for an estimation of muons hitting the modules compared to the total of inciding muons.

## 6.5. Visualisation - the vis.mac file

To display results of the calculations made, the tracks of all particles can be displayed as well as the geometry setup itself. This can be done interactively after running the program, though the faster approach is to use \*.mac files, standardly the vis.mac file. Here, different parameters can be changed and simple visualisation settings like viewing angles and zooms can be chosen.

**ToDo**

**ToDo**

**ToDo**

## 7. Conclusion

The whole muon detection system has been set up at the main- and readopted at the monitor spectrometer. Both systems are able to take data at rates that compare well to literature values. Most of the

It was shown that the muon induced electron rate is well shielded by axially symmetric magnetic fields and that, under circumstances differing from those, this rate increases strongly.



## **8. Outlook**

...



# Bibliography

- [Abe13] K. e. a. Abe, “Evidence for the appearance of atmospheric tau neutrinos in super-kamiokande,” *Phys. Rev. Lett.*, vol. 110, p. 181802, May 2013. [Online]. Available: <http://link.aps.org/doi/10.1103/PhysRevLett.110.181802>
- [Arl09] H. Arlinghaus, “Investigation of the muon-induced secondary electron background in the katrin experiment,” [http://www.uni-muenster.de/Physik.KP/AGWeinheimer/Files/theses/Diplom\\_Henrik\\_Arlinghaus.pdf](http://www.uni-muenster.de/Physik.KP/AGWeinheimer/Files/theses/Diplom_Henrik_Arlinghaus.pdf), 2009, [Online; accessed 21-08-2013].
- [BKR09] S. Becker, H. Koziolek, and R. Reussner, “The Palladio component model for model-driven performance prediction,” *JSS*, vol. 82, pp. 3–22, 2009. [Online]. Available: <http://dx.doi.org/10.1016/j.jss.2008.03.066>
- [Cry05] S.-G. Crystals, “Premium plastic scintillators,” [http://www.detectors.saint-gobain.com/uploadedFiles/SGdetectors/Documents/Product\\_Data\\_Sheets/BC400-404-408-412-416-Data-Sheet.pdf](http://www.detectors.saint-gobain.com/uploadedFiles/SGdetectors/Documents/Product_Data_Sheets/BC400-404-408-412-416-Data-Sheet.pdf), 2005, [Online; accessed 11-07-2013].
- [DAAe08] P. Doll, W. D. Apel, J. C. Arteaga, and et al., “Muon Production Height in the Air-Shower Experiment KASCADE-Grande,” in *International Cosmic Ray Conference*, ser. International Cosmic Ray Conference, vol. 4, 2008, pp. 115–118.
- [DHMW13] G. Drexlin, V. Hannen, S. Mertens, and C. Weinheimer, “Current Direct Neutrino Mass Experiments,” *ArXiv e-prints*, Jun. 2013. [Online]. Available: <http://arxiv.org/abs/1307.0101>
- [G<sup>+</sup>09] F. Glück *et al.*, “Air coil system & magnetic field sensor system,” <http://fuzzy.fzk.de/bscw/bscw.cgi/d530439/Air%20Coil%20System%20and%20Magnetic%20Field%20Sensor%20System.pdf>, 2009, [Online; accessed 24-08-2013].
- [Gö10] S. Görhardt, “Reduktion der durch radon induzierten untergrundprozesse in den katrin spektrometern,” <http://www.katrin.kit.edu/publikationen/dth-goerhardt.pdf>, 2010, [Online; accessed 27-08-2013].
- [Gor13] T. P. Gorringe, “MuLan Measurement of the Positive Muon Lifetime and Determination of the Fermi Constant,” *ArXiv e-prints*, Jan. 2013.
- [How09] Howe, M. A. *et al.*, *TUNL Progress Report*, vol. XLVIII, p. 179, 2009.
- [MSTV03] M. Maltoni, T. Schwetz, M. A. Tórtola, and J. W. F. Valle, “Status of three-neutrino oscillations after the sno-salt data,” *Phys. Rev. D*, vol. 68, p. 113010, Dec 2003. [Online]. Available: <http://link.aps.org/doi/10.1103/PhysRevD.68.113010>
- [Sch13] A. Schaeffer, [http://cds.cern.ch/record/1345733/files/Cosmic\\_image.jpg](http://cds.cern.ch/record/1345733/files/Cosmic_image.jpg), 2013, [Online; accessed 01-09-2013].
- [Sta04] T. Stanev, *High Energy Cosmic Rays*, 2004.
- [Wie13] K. Wierman, personal conversation, 2013.



# Appendix

## A. First Appendix Section

ein Bild

Figure A.1.: A figure

Figure A.2.: Scripting task through the example of a LFCS current ramping script. All currents are incremented in tenths of the maximum current for the individual coil.

...

**non-axially symmetric magnetic field**

solenoid source	solenoid detector	inner aircoil	outer aircoil	outer cent. aircoil	emcs x	emcs y
25	25	7	-7	5	0	-14
mos00159753- mos00159754	Two horizontal loops at 100 A					
mos00159755- mos00159758	Two horizontal loops at -100 A					
mos00159759- mos00159771	No current in horizontal loops - background measurement					
mos00159772- mos00159773	Two horizontal loops at 100 A					

solenoid source	solenoid detector	inner aircoil	outer aircoil	outer cent. aircoil	emcs x	emcs y
12.5	12.5	3.5	-3.5	2.5	0	0
mos00160661- mos00160666	Two horizontal loops at 50 A					
mos00160667- mos00160682	No current in horizontal loops - background measurement					
mos00160684- mos00160687	Two horizontal loops at -50 A					

solenoid source	solenoid detector	inner aircoil	outer aircoil	outer cent. aircoil	emcs x	emcs y
6.2	6.2	1.7	-1.7	1.2	0	0
mos00160688- mos00160691	Two horizontal loops at 25 A					
mos00160692- mos00160706	No current in horizontal loops - background measurement					
mos00160707- mos00160711	Two horizontal loops at -25 A					




Figure A.3.: Two horizontal loops at 50 A current. For all settings see 5.5, line 1.




Figure A.4.: Two horizontal loops at  $-50$  A current. For all settings see 5.5, line 3.




Figure A.5.: Two horizontal loops at 25 A current. For all settings see 5.5, line 2.




Figure A.6.: Two horizontal loops at  $-25$  A current. For all settings see 5.5, line 4.




Figure A.7.: Two horizontal loops at 0 A current. For all settings see 5.5, line 1.




Figure A.8.: Two horizontal loops at 0 A current. Both solenoids at 25 A for a comparison of the background at different field widening. For all settings see 5.5, line 1.