BRIK BY BRIK

DRAFT — PENDING JAMES APPROVAL

Property Deal Analysis & Evaluation Engine

Property Viewing & Condition Assessment Checklist (C01–C45 & V01–V13)

Document Reference: viewing-checklist-v1 (Final Draft) **Reviewer:** James Lake (Owner) **Date:** October 2026

Total Checks: 58 Items (45 Core + 13 Supplement)

OBSERVATION AID & PROFESSIONAL SURVEY DISCLAIMER

This checklist is an observation and due-diligence aid designed to structure visual appraisals during property viewings and video walkthrough reviews. It is **not** a building survey, structural appraisal, or statutory compliance certificate, and must **not** be used as a substitute for professional inspections by qualified specialists (including RICS chartered surveyors, Gas Safe registered engineers, NICEIC/NAPIT registered electricians, structural engineers, or UKAS-accredited testing laboratories). Defect diagnoses, repair decisions, statutory compliance conclusions, and lending/mortgageability determinations remain strictly conditional on qualified professional verification. All 58 items below are marked **PENDING JAMES APPROVAL**.

Evidence Mode: VIDEO + VISUAL Walkthrough video & visual observation | ON-SITE PHYSICAL Hands-on mechanical/operational testing | ON-SITE INQUIRY / DOC Verbal inquiry or physical document review

PART I: CORE PROPERTY INSPECTION (C01–C45)

Items C01–C10 of 45 Physical Condition Checks

ID	GROUP & EVIDENCE MODE	INSPECTION TITLE & OBSERVATION PROMPT	OWNER REVIEW APPR • MOD • REJ
C01	Roof VIDEO + VISUAL	**Main roof pitched covering** Inspect pitched slopes from ground vantage points; document slipped, broken or weathered slates or tiles; specialist high-level inspection required to confirm condition.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C02	Roof VIDEO + VISUAL	**Roof line ridge and pitch profile** Observe ridge lines and roof planes from front and rear vantage points; note noticeable sagging, dips or spread; structural engineer inspection required if deflection observed.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C03	Roof VIDEO + VISUAL	**Flat roof membranes and decks** Observe accessible flat roof coverings; record visible pooling water, blistering, cracking or edge detachment; specialist inspection required to assess decking and moisture beneath membrane.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C04	Chimneys VIDEO + VISUAL	**Chimney stack verticality** View chimney stacks from ground level against vertical reference points; record visible leaning or distortion; structural appraisal required if out of plumb.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C05	Chimneys VIDEO + VISUAL	**Chimney masonry, flaunching and pots** Inspect stack brickwork, mortar pointing, terminal pots, cowls and mortar flaunching from ground; document visible cracking, spalling or self-seeded vegetation; scaffold inspection required for full assessment.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C06	Rainwater goods VIDEO + VISUAL	**Gutters, downpipes and external drainage fittings** Check visible rainwater gutter runs, joints and downpipe connections; record staining on masonry, sagging sections or missing brackets; test during rainfall or water test if safe to do so.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C07	Rainwater goods VIDEO + VISUAL	**Eaves, fascias and bargeboards** Observe eaves timbers, PVC fascias, soffit boards and bargeboards; document timber decay, peeling paint, open joints or missing ventilation grilles; specialist access equipment required for high-level repairs.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C08	External walls VIDEO + VISUAL	**External masonry and wall finishes** Examine external brickwork, stone or rendered surfaces; document spalled brick faces, blown render patches or surface decay; invasive testing required to confirm structural substrate soundness.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C09	External walls VIDEO + VISUAL	**Mortar joint pointing** Check external wall mortar joints across all visible elevations; record recessed, powdery or missing pointing; assess whether weathered sections may warrant raking out and repointing subject to trade verification.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C10	External walls VIDEO + VISUAL	**Wall movement, cracking and lintel deflection** Identify visible cracks, diagonal stepped fractures or dropped window lintels; record width, direction and location with photographic scale; structural engineer investigation required to diagnose underlying movement.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:

PART I: CORE PROPERTY INSPECTION (CONTINUED)

Items C11–C23 of 45 Physical Condition Checks

ID	GROUP & EVIDENCE MODE	INSPECTION TITLE & OBSERVATION PROMPT	OWNER REVIEW APPR • MOD • REJ
C11	External glazing and doors ON-SITE PHYSICAL	**Window frames and opening sash operation** Inspect window frame materials, hinges and stays; test accessible opening sashes for smooth operation and closure with occupant consent; count defective units requiring overhaul or renewal.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C12	External glazing and doors VIDEO + VISUAL	**Insulated double glazing unit seals** Examine double or triple glazed panes for internal condensation, misting or scumming between panes; note visual indicators of potential perimeter hermetic seal failure warranting professional glazing appraisal.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C13	External glazing and doors VIDEO + VISUAL	**Glazing specification, safety markings and thermal profile** Record glazing type, safety glass kitemarks in low-level hazard areas, and thermal frame profile; statutory building regulation compliance to be verified against certified documentation.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C14	External glazing and doors ON-SITE PHYSICAL	**External entrance doors, frames and security hardware** Inspect external entrance door leaves, frames, weather seals and multi-point or cylinder locking assemblies; record binding, rot or warping; test lock operation with permission.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C15	External grounds VIDEO + VISUAL	**Paved pathways, steps and vehicular driveways** Walk external perimeter; document sunken flags, cracked tarmac, loose kerbs, step height variations or uneven surfaces creating trip hazards; evaluate vehicular and plant access for construction works.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C16	External grounds VIDEO + VISUAL	**Ground clearance and damp-proof course elevation** Locate external damp-proof course line and subfloor air grilles relative to finished external ground levels; record high ground or paving bridging DPC; specialist damp timber survey required for subfloor diagnosis.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C17	Ceilings VIDEO + VISUAL	**Ceiling linings, plaster condition and deflection** Inspect ceilings across every room; note sagging lath-and-plaster, plasterboard joints, water marks, or historical staining; concealed framing and ceiling void condition unknown without invasive opening.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C18	Ceilings VIDEO + VISUAL	**Textured decorative ceiling coatings** Identify textured or pattern coatings on ceiling surfaces; note age and surface profile; recommend UKAS-accredited laboratory sampling to verify presence or absence of asbestos prior to any planned disturbance or sanding.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C19	Ceilings VIDEO + VISUAL	**Fire compartmentation and ceiling resistance** Inspect ceiling integrity on escape routes and between separate occupancies or storeys; document penetrations or breaches; statutory fire resistance ratings require specialist building control sign-off.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C20	Internal walls VIDEO + VISUAL	**Internal wall layout and partition construction** Observe wall configurations and differentiate between solid masonry and timber stud partitions; look for signs of historical wall removal; structural engineering calculations required before removing loadbearing walls.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C21	Internal walls VIDEO + VISUAL	**Wall surface linings and suspect coatings** Examine internal wall plaster, boarding and decorative textured coatings; record loose plaster or hollow spots; flag suspect materials for certified testing prior to removal.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C22	Internal walls VIDEO + VISUAL	**Dampness signs, salt efflorescence and mould** Inspect wall bases, chimney breasts and external corners for visible tide marks, peeling paper, efflorescent salts or mould growth; note olfactory cues; record as visual indicators requiring specialist damp and timber survey to diagnose source (e.g. penetrating vs rising damp or condensation).	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C23	Internal walls VIDEO + VISUAL	**Services impacted by proposed wall modifications** Map electrical switchgear, sockets, gas/water pipework and radiators mounted on walls ear-marked for demolition or alteration; specialist trades required to isolate and reroute infrastructure.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:

PART I: CORE PROPERTY INSPECTION (CONTINUED)

Items C24–C36 of 45 Physical Condition Checks

ID	GROUP & EVIDENCE MODE	INSPECTION TITLE & OBSERVATION PROMPT	OWNER REVIEW APPR • MOD • REJ
C24	Floors ON-SITE PHYSICAL	**Suspended floor spring and structural bounce** Walk across floors in every accessible room to detect deflection, springiness or excessive movement; concealed joist ends and subfloor timbers require opening up to check for wet/dry rot or beetle attack.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C25	Floors ON-SITE PHYSICAL	**Floor surface levels and gradients** Check floor horizontal level with spirit level or digital angle gauge; record noticeable slopes, sudden level drops or steps between adjoining rooms; camera angles alone do not establish floor run.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C26	Floors VIDEO + VISUAL	**Floor deck construction and sub-floor access** Identify solid concrete ground floor slabs versus suspended timber joists; record presence and location of subfloor access hatches; check pipe and cable routing practicality.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C27	Floors VIDEO + VISUAL	**Existing floor covering condition and retention** Examine carpets, timber floorboards, laminates and tiles; document wear, stains, odors and water damage; record whether coverings are to be cleaned and retained or uplifted and disposed of.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C28	Internal doors ON-SITE PHYSICAL	**Internal doorsets, linings and ironmongery** Test internal doors for binding, latch engagement, squareness within linings, and ironmongery condition; count doors requiring overhaul, re-hanging or full set replacement.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C29	Internal doors VIDEO + VISUAL	**Fire-rated doorsets and smoke sealing** Check doors on protected escape corridors, kitchens and shared spaces; inspect for FD30/FD60 labels, intumescent strips, smoke seals and self-closing devices; specialist fire risk assessor verification required.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C30	Wall tiling ON-SITE PHYSICAL	**Wall tiling integrity and backing substrates** Inspect wall tile surfaces in bathrooms and kitchens; tap for hollow-sounding adhesion, loose tiles or perished grout; prepare for substrate reboarding where tiling has leaked.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C31	Drainage VIDEO + VISUAL	**Above-ground soil stacks and waste pipework** Trace internal and external soil vent stacks, waste branch connections, falls and pipe brackets; note any planned appliance relocations requiring new discharge connections.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C32	Drainage VIDEO + VISUAL	**Below-ground drainage inspection chambers and gullies** Locate external manhole covers, rainwater gullies and soil outlet discharges; note standing water or silt buildup without lifting hazardous covers; commission CCTV drainage survey if blockage suspected.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C33	Heating VIDEO + VISUAL	**Radiator emitters, pipe distribution and valves** Count heat emitters room by room; inspect panel surfaces for rust, bottom-edge corrosion, valve leaks and presence of thermostatic radiator valves (TRVs); heating functional test required to confirm flow.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C34	Heating VIDEO + VISUAL	**Boiler model, appliance type and flue discharge** Photograph boiler data badge showing manufacturer, model number, serial number and output rating without dismantling casing; observe visible flue termination location relative to openings; note that operational safety and statutory flue compliance require Gas Safe registered engineer certification.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C35	Heating ON-SITE DOCUMENT	**Gas heating commissioning and maintenance records** Request and photograph Gas Safe certificate, annual boiler maintenance log, and benchmark commissioning documentation; Gas Safe registered engineer inspection required to verify operational safety.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C36	Heating VIDEO + VISUAL	**Heating system capacity and thermal suitability** Review heating emitter sizes and system design against current property layout and proposed extensions; qualified heating engineer assessment required to certify adequate heat output and pipework sizing.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:

PART I: CORE PROPERTY INSPECTION (CONCLUDED)

Items C37–C45 of 45 Physical Condition Checks

ID	GROUP & EVIDENCE MODE	INSPECTION TITLE & OBSERVATION PROMPT	OWNER REVIEW APPR • MOD • REJ
C37	Electrical VIDEO + VISUAL	**Consumer unit intake and circuit protection** Photograph main incoming electrical service fuse, meter, metal or plastic consumer unit casing, and residual current devices (RCDs); formal Electrical Installation Condition Report (EICR) by registered electrician required.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C38	Electrical VIDEO + VISUAL	**Electrical socket provision and lighting points** Count socket outlets and light switches by room; document single sockets, trailing leads or outdated surface trunking; determine additional circuits and outlets needed for proposed occupation.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C39	Kitchen VIDEO + VISUAL	**Kitchen base and wall cabinetry carcasses** Open kitchen cabinet doors and drawers; inspect internal melamine carcasses, shelves and hinges for structural swelling, grease or water degradation; assess viability of retention versus replacement.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C40	Kitchen VIDEO + VISUAL	**Kitchen worktops, fascias and appliances** Inspect laminate, stone or timber worktops, sink unit, mixer tap, unit fascias and built-in appliances; separate cosmetic facelift options from full strip-out; verify extract hood vents externally.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C41	Bathroom VIDEO + VISUAL	**Sanitary appliances and bath/basin condition** Inspect bath, shower enclosure, wash hand basin and WC pan; check for enamel chipping, hairline porcelain cracks, limescale and secure mountings; determine replacement scope and layout changes.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C42	Bathroom ON-SITE PHYSICAL	**Bathroom taps, water delivery and mechanical extract** Test water flow rate from taps and shower head with permission; note presence and operation of mechanical extract ventilation fan and external vent ducting; concealed supply/waste pipes remain unverified.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C43	Decoration VIDEO + VISUAL	**Decorative wall and ceiling finishes** Assess decorative surface finishes, wood trim gloss work, paint condition, and peeling or multi-layered wallpaper; evaluate extent of skimming, plaster repairs and surface preparation before redecorating.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C44	Garden VIDEO + VISUAL	**Boundary fences, retaining walls, trees and garden waste** Inspect boundary fencing, retaining walls, external sheds, overgrown vegetation, large trees within influencing distance of foundations, and rubbish accumulation; separate site clearance and tree surgery works.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
C45	General VIDEO + VISUAL	**Miscellaneous property observations and space constraints** Document unusual features, low ceiling heights, restricted stair headroom, awkward access hatches, structural bulkheads, or room dimensional constraints not captured elsewhere.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:

PART II: SUPPLEMENTARY VIEWING QUESTIONS (V01–V13)

13 Transactional, Utility & Legal Inquiries

ID	GROUP & EVIDENCE MODE	INQUIRY TITLE & OBSERVATION PROMPT	OWNER REVIEW APPR • MOD • REJ
V01	Services ON-SITE PHYSICAL	**Mains water flow, pressure and delivery** Test cold and hot water delivery at multiple outlets simultaneously; record observed flow rate; verify vendor or agent assertions against independent pressure test.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V02	Services ON-SITE PHYSICAL	**Sanitary flushing and basic lighting circuits** Flush toilets and test accessible light switches in each room; record slow cistern refills or erratic switching; formal electrical/plumbing testing required for compliance.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V03	Connectivity ON-SITE PHYSICAL	**Cellular signal strength and broadband infrastructure** Check mobile phone reception on major networks across different floors; locate master Openreach/fibre telephone socket and cable TV intake point.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V04	Security ON-SITE INQUIRY	**Window lock operation and intruder alarm status** Check presence of key-operated locks on ground floor windows and inspect intruder alarm control panel; ask whether alarm is operational, serviced, or code is available.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V05	Bathroom VIDEO + VISUAL	**Sanitary silicone sealants and perimeter grouting** Inspect perimeter silicone bead around bath and shower tray for black mould, detachment or shrinkage; identify water leakage risk to timber floor structure below.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V06	Outside space VIDEO + VISUAL	**Vehicular parking, right of access and outdoor amenity** Inspect allocated parking space, dropped kerb authorization, shared access driveways, and proximity to green amenities; verify rights of way via title deeds.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V07	Sale context ON-SITE INQUIRY	**Marketing history, listing duration and previous sales** Query agent regarding property marketing timeframe, historical asking price reductions, and reasons for any previous sales falling through; corroborate with portal history.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V08	Sale context ON-SITE INQUIRY	**Vendor motivation, onward chain and completion timeline** Establish vendor reason for selling, onward chain dependencies, target exchange/completion dates, and whether vendor is in probate, liquidation or relocation.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V09	Legal information ON-SITE DOCUMENT	**Tenure classification, lease terms and vacant status** Confirm freehold versus leasehold tenure; where leasehold, note unexpired lease term, ground rent escalation clauses, service charges, and vacant possession on completion.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V10	Legal information ON-SITE DOCUMENT	**Planning permissions and building regulation approvals** Ask for copies of planning approvals, building control completion certificates, FENSA certificates, and sign-offs for historical extensions, loft rooms or chimney removals.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V11	Property details VIDEO + VISUAL	**Property orientation, fixture inventory and council tax** Determine rear garden aspect with compass (solar orientation); request draft fixture and fittings form (TA10); record local authority council tax band.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V12	Financing ON-SITE INQUIRY	**Mortgageability constraints and cash-buyer restrictions** Inquire regarding potential lending or mortgageability constraints (such as structural movement, missing essential amenities, invasive plants, or non-standard construction); note any reported down-valuations, while recognizing definitive lending decisions rest solely with prospective mortgage underwriters.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:
V13	Property details ON-SITE DOCUMENT	**Address verification, construction era and gross internal area** Confirm postal address matches Land Registry title; observe construction era and wall build type; check measured gross internal floor area against EPC and marketing brochure.	☐ Appr ☐ Mod ☐ Rej Notes / Changes:

PART III: OWNER FORMAL REVIEW & APPROVAL — JAMES LAKE

Please review the 58 checklist items (C01–C45 core inspection checks and V01–V13 supplementary viewing questions) presented across Pages 1 to 5. Every item has been rewritten to ensure independent authoring, conditional defect formulation, and explicit evidence-mode qualification. Indicate your formal decision below:

- ☐ **APPROVED AS WRITTEN:** I confirm that the 58 checklist items (C01–C45 and V01–V13) are approved as the official Brik by Brik property evaluation checklist. The working draft status and watermarks may be removed from the application.
- ☐ **APPROVED WITH MODIFICATIONS:** The checklist is approved subject to the specific line-item modifications marked in the tables above or recorded in the owner instructions below.
- ☐ **REVISIONS REQUIRED:** The checklist is returned for revision according to the instructions specified below.

JAMES LAKE SIGNATURE

Signed on behalf of Brik by Brik

DATE OF REVIEW

DD / MM / YYYY

OWNER COMMENTS / SPECIFIC LINE-ITEM INSTRUCTIONS