# SUMAN ELECTRONICS

**Updating Date: 13 / 06 / 2019**

## DIP SWITCH SETTING DOCUMENT (Document Version: 01/00)

**INPUT BOX DIP SWITCH SETTINGS:**

System could be configured as system with ODU and system without ODU using switch 3 as follows:

| Switch Position | SWITCH 3 |
|---|---|
| ON | System With ODU |
| OFF | System Without ODU |

Functionality of other switches is dependent on setting of switch 3. This is as mentioned below:

Functionality for system without ODU (**Switch 3 in OFF position**):

| Switch Position | SWITCH 4 | SWITCH 2 | SWITCH 1 |
|---|---|---|---|
| ON | Separate HP and LP Inputs (Carrier Machine) | External SPPR System | 1 Compressor System |
| OFF | Common HP and LP Inputs (Bluestar Machine) | In Built SPPR System | 2 Compressor System |

Functionality for system with ODU (**Switch 3 in ON position**):

| Switch Position | SWITCH 4 | SWITCH 2 | SWITCH 1 |
|---|---|---|---|
| ON | Unused | 3 Phase Blower Fan | 1 Compressor System |
| OFF | | Single Phase Blower Fan | 2 Compressor System |

**Note:** If 3 phase Blower Fan is configured, then it will have single Fan speed selection through Fan High terminal.

**ODU BOX DIP SWITCH SETTINGS:**

| Switch Position | SWITCH 4 | SWITCH 3 | SWITCH 2 | SWITCH 1 |
|---|---|---|---|---|
| ON | Separate HP and LP Inputs (Carrier Machine) | 3 Phase ODU | Unused | ODU Address: 2 |
| OFF | Common HP and LP Inputs (Bluestar Machine) | Single Phase ODU | | ODU Address: 1 |