

Nilai IKE Gedung A Luas Bangunan > 5.000 m2

Sangat efisien	$IKE < 99$
Efisien	$99 \leq IKE < 135$
Cukup Efisien	$135 \leq IKE \leq 173$
Boros	$IKE > 173$

LUAS BANGUNAN KESELURUHAN 10.250 m²
 LUAS BANGUNAN TERKONDISI 8.597 m²
 IKE = Kwh/m2/Tahun

<--- Berdasarkan Permen ESDM NO 3 Tahun 2025

Bulan Ke	22 Total Kwh digunakan
5	129664
2	129856
4	132144
3	144128
7	147888
9	151104
1	152896
6	157200
10	158528
11	163792
8	164432
12	170832

209.66
 IKE 22

Bulan Ke	23 Total Kwh digunakan
1	162000
2	142624
3	150912
4	109344
5	147200
6	115744
7	134368
8	152336
9	128768
10	140928
11	127040
12	123936

190.21
 IKE 23

Bulan Ke	24 Total Kwh digunakan
1	85,840.00
2	73,550.00
3	72,150.00
4	65,620.00
5	74,424.00
6	68,792.00
7	75,041.00
8	106,921.20
9	109,013.20
10	101,262.80
11	81,309.20
12	80,473.60

115.67
 IKE 24

Bulan Ke	Total Kwh digunakan
1	66,235.20
2	63,800.00
3	64,232.00
4	65,387.00
5	74,786.00
6	69,520.00
7	82,512.00
8	68,454.00
9	70,052.00
10	74,875.00
11	75,253.00
12	88,173.00

105.73
 IKE 25

Bulan Ke	26 Total Kwh digunakan
1	87893
4	80675
3	71439
2	70579
7	69913
8	67093
6	67027
5	66536
9	0
10	0
11	0
12	0

71.18
 IKE 26

Kategori IKE Berdasarkan tahun:

2022 = Boros
 2023 = Boros
 2024 = Efisien
 2025 = Efisien
 2026 = Berjalan