

# FIELDS SERVICE REPORT

Report No.: **578**

Date: **16/06/2021**

## ELEKRON POWER SOLUTIONS

Corp. Office : # 329, 1st Floor, 12th Cross  
1st Stage, Next to Motherhood Hospital  
Indiranagar, Bangalore - 560 038.

For any complaint and query / Write to us at :  
E-mail :- info@emot.co.in  
or call & Whatsup to us at  
+918095209948, 080- 41663297 / 080 - 40940860

Customer's Name & Address :

**INDUSIND BANK Ltd.**  
Ground Floor, 351, 1st Stage,  
8th main Road Basaveshwar  
Nagar Bangalore - 560079  
**BASAVESHWAR-Nagar**

Contact Person : **Vinayak Rudrakshi**

Designation : **DBM**

PH No. : **9538881399**

Cell No.:

E-mail :

Rating : **30 kVA**

DG Set Location	G. Floor	Basement ✓	Roof-top	DG set Operation	Auto	Manual ✓
Type of Service	Erection	Warranty	Paid Service	Commissioning	Courtesy	AMC ✓
Complaint Received on		Complaint Attended On				
Panel Make	Sudhis	Panel Model	Standard	Panel Sr. No		
Engine Make	Cummins	Engine Model	X27TAA-G2	Engine Sr. No.	1906A64982	
Alternator Make	Stamford	Alt Model	SOL2-P1	Alternator Sr. No.	G19F226325	
Battery Make	Cummins	Battery Model	95AH/12V	Battery Sr. No.	ADI3814T107243	
KWH Make	ELC	KWH Sr. No.		B. Charger Sr. no.		
Earthing Pits	Neutral	Two	Body	Two	With SS plate	
Engine Parameters		Alternator Parameters				
Engine RPM		Voltage	RY 412	Current Amp	R	7.6
Coolant Temp.	62°C		YB 412		Y	7.0
Lube Oil Pressure	458 kpa		BR 419		B	0.8
Lube Oil Temp.		PF :	Spares Used :			
Engine Hrs.	80.89	HZ :				

Visited the above site as per the preventive maintenance AMC Contract check the engine oil level, coolant level, Battery charger input/output voltage, all filter condition, V-Belt, and all Hose condition all is ok. D.G set testing on-load all parameters are found ok.

Customer Remarks :

Name : **BALVIR VERMA**

Designation :

Signature of Service Engineer

Cell No.: **9663579901**

Date : **16/06/2021**

Name : **Vinayak N Rudrakshi**

Designation : **DBM**

Signature of Customer's Rep:

Cell No.: **9538881399**

Date : **16/06/2021**



Our Branches Mumbai, Vapi, Hyderabad