TROUBLE REPORT

Unit No./System: 450 MW CCPP(North)

1. T.R. No. : 892 Date: 04-Feb-20 Time: 05:52 AM

2. Equipment: Gt generator seal oil supply Location : Turbine hall

3. Name of the Reporting Person: MD. Shah Alam Designation: Sub-Assistant Engineer

4. Description of Trouble:

DP SEAL OIL FILTER(20MKW21CP005) PRESSURE IS HIGH.NEED TO CLEAN FILTER.

Please take necessary action.

5. Referred to : Executive Engineer (Mechanical)

Sub-Assistant Engineer

Shift Charge Engineer

Executive Engineer (Shift)

Copy to:

01. CE/Project Director, 450 MW CCPP, North, APSCL.
02. SE (MMD, EMD, Operation), 450 MW CCPP, North, APSCL
03. XEN (Operation) 450 MW CCPP, North, APSCL.