

	ASHUGANJ POWER STATION COMPANY LIMITED	DOCUMENT NO.: SF-AUX-34
		REVISION NO.: 00
	FORMS	EFFECTIVE DATE: 19/03/2018
	TITLE: TROUBLE REPORT	PAGE: 1 OF 1

TROUBLE REPORT

Unit No./System: 450 MW CCPP(North)

- | | | |
|--|-----------------|-------------------------------------|
| 1. T.R. No. : 872 | Date: 20-Dec-19 | Time: 01:48 PM |
| 2. Equipment: Diverter damper | | Location : HRSG Area |
| 3. Name of the Reporting Person: Md. Jafrullah | | Designation: Sub-Assistant Engineer |
| 4. Description of Trouble: | | |
| Diverter damper oil level become less then minimum . | | |
| Please take necessary action. | | |

5. Referred to : Executive Engineer (Mechanical)



Sub-Assistant Engineer



Shift Charge Engineer



Executive Engineer (Shift)

Copy to:

01. CE/Project Director, 450 MW CCPP, North, APSCCL.
02. SE (MMD, EMD, Operation), 450 MW CCPP, North, APSCCL
03. XEN (Operation) 450 MW CCPP, North, APSCCL.