

SIDCT - Project Calculation Report

Project	SIDCT Project
Client	N/A
Site	N/A
Revision	A
Updated	2026-05-04T11:04:59+00:00
Routes	1
Lines	1

Status Summary

Status	Count
APPROVED	1

Line Results

project_name	line_tag	service	material	catalog	DN_governing_mm	velocity_ms	dp_total_bar	selected_schedule	checker_status	governing_issue
SIDCT Project	L-001	sanitary_drainage	PVC	PVC_EN1452	40	0.6161		PN10	APPROVED	

Warnings and Dataset Gaps

S

l class for buried loading and local fire/acoustic requirements.; temperature and fire/acoustic requirements; PVC pressure rating requires temperature derating above 20 C; verify manufacturer table for final design.; PVC-U dataset is for water and drainage services only.

Scope

Project report aggregates SIDCT line calculations. It does not replace final engineering review, licensed normative datasets, manufacturer derating tables, external pressure chart checks, support/flexibility stress analysis, or authority approval.

Audit events: 2