

SIDCT - Project Calculation Report

Project	SIDCT Project
Client	N/A
Site	N/A
Revision	A
Updated	2026-05-04T11:17:57+00:00
Routes	1
Lines	1

Status Summary

Status	Count
APPROVED	1

Line Results

Line Tag	Service	Material	Catalog	DN Governing [mm]	Governing Criterion	Velocity [m/s]	Pressure Drop [bar]	Flow Depth Ratio	Selected Schedule	Checker Status	Governing Issue
L-001	sanitary_drainage	PVC	PVC_EN1452	40	fill_ratio	0.616	N/A	0.595	PN10	APPROVED	N/A

Warnings and Dataset Gaps

Warning: PVC dataset is for water and drainage services only. Verify application class for buried loading and local fire/acoustic requirements.; temperature and fire/acoustic requirements; PVC pressure rating requires temperature derating above 20 C; verify manufacturer table for final design.; PVC-U dataset is for water and drainage services only.
--

Scope

Project report aggregates SIDCT line calculations. It does not replace final engineering review, licensed normative datasets, manufacturer derating tables, external pressure chart checks, support/flexibility stress analysis, or authority approval.

Audit events: 2