

NORME
INTERNATIONALE
INTERNATIONAL
STANDARD

CEI
IEC
185

1987

MODIFICATION 1
AMENDMENT 1

1990-07

Modification 1 à la Publication 185 (1987)

Transformateurs de courant

Amendment 1 to Publication 185 (1987)

Current transformers

© CEI 1990 Droits de reproduction réservés — Copyright — all rights reserved

Bureau Central de la Commission Electrotechnique Internationale 3, rue de Varembe Genève, Suisse



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

B

*Pour prix, voir catalogue en vigueur
For price, see current catalogue*

PREFACE

La présente modification a été établie par le Comité d'Etudes n° 38 de la CEI: Transformateurs de mesure.

Le texte de cette modification est issu des documents suivants:

Règle des Six Mois	Rapport de vote
38(BC)82	38(BC)85

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette modification.

Page 52

27. Limites de l'erreur de courant et du déphasage des transformateurs de courant pour mesures

Ajouter à la fin de cet article la note suivante:

Note.- En général, les limites prescrites pour l'erreur de courant et le déphasage sont valables pour n'importe quelle position d'un conducteur externe placé à une distance dans l'air non inférieure à celle qui est requise pour l'isolement dans l'air correspondant à la tension la plus élevée pour le matériel (U_m).

Il convient que les conditions spéciales d'application, y compris les gammes basses de tension de service associées à des valeurs élevées de courant, fassent l'objet d'un accord séparé entre le constructeur et l'acheteur.

185 Amend. 1 © IEC

- 3 -

PREFACE

This amendment has been prepared by IEC Technical Committee No. 38: Instrument transformers.

The text of this amendment is based on the following documents:

Six Months' Rule	Report on Voting
38(C0)82	38(C0)85

Full information on the voting for the approval of this amendment can be found in the Voting Report indicated in the above table.

Page 53

27. Limits of current error and phase displacement

Add the following note at the end of this clause:

Note.- In general the prescribed limits of current error and phase displacement are valid for any given position of an external conductor spaced at a distance in air not less than that required for insulation in air at the highest voltage for equipment (U_m).

Special conditions of application, including lower ranges of operation voltages associated with high current values, should be a matter of separate agreement between manufacturer and purchaser.

Imprimé en Suisse

Printed in Switzerland