

NOT TO SCALE


1. ALL ELECTRICAL/ELECTRONICS CODE WORKS INDICATED ARE IN ACCORDANCE WITH:

- = USE EMT SIZE NOT LARGER THAN 20mm DIAMETER FOR BRANCH CIRCUIT.
- = USE IMC WITH SIZE LARGER THAN 20mm DIAMETER FOR BRANCH CIRCUIT AND FEEDER.
6. ALL WIRING, CABLE AND EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST PECE AND PEE CODE.
7. ALL WIRING SHALL BE RUN IN DEDICATED CONDUIT AND NEVER IN THE SAME CONDUIT WITH AC LINE POWER.
8. POWER LIMITED AND NON POWER LIMITED CIRCUIT SHALL BE RUN IN SEPARATE CONDUIT.
9. HIGH AND LOW VOLTAGE CIRCUITS SHALL BE RUN ON SEPARATE CONDUIT.
10. ELECTRICAL METALLIC CONDUIT (EMT) CONNECTORS SHALL BE THE ALL-STEEL COMPRESSING TYPE, WITH INSULATING THROATS.
11. ALL JUNCTION BOXES THAT ARE VISIBLE OR ACCESSIBLE SHALL BE PAINTED RED.
12. ALL WORKS SHALL CONFORM TO THE PROVISIONS OF THE LATEST EDITION OF THE PHILIPPINE ELECTRONICS CODES AND THE RULES AND REGULATIONS OF THE LOCATION OF THE WORK.
13. WHERE THE PLANS DO NOT INDICATE THE MOUNTING HEIGHT FOR THE DEVICES/EQUIPMENT, THE FIRE ALARM CONTRACTOR SHALL INSTALL THEM IN ACCORDANCE WITH THE NFPA 72, NATIONAL FIRE ALARM CODE, AND LATEST PECE CODE UNLESS INSTRUCTED OTHERWISE BY THE LOCAL AUTHORITY HAVING JURISDICTION.
14. DETECTORS SHALL NOT BE INSTALLED IN DIRECT AIRFLOW NOR CLOSER 3 FEET FROM AN AIR SUPPLY DIFFUSER. THE FIRE ALARM CONTRACTOR SHALL FIELD VERIFY EXACT LOCATION FOR THE INSTALLATION OF ALL DETECTORS.
15. ALL JUNCTION BOXES THAT ARE VISIBLE OR ACCESSIBLE SHALL BE PAINTED RED.
16. CONTRACTOR SHALL SECURE ALL WIRING PERMIT AND ALL FEES REQUIRED FOR THE WORKS AND FURNISH THE OWNER THE CERTIFICATE OF FINAL INSPECTION.
17. T-TAPPING IS PERMITTED ON CLASS B WIRING ONLY
18. ALL UNDERGROUND PIPING AND CABLEING SHOULD CONFORM TO MINIMUM DEPTH REQUIREMENTS AS SPECIFIED BY THEIR OWN RESPECTIVE STANDARDS.

NOT TO SCALE

NOT TO SCALE

NOT TO SCALE:



NOT TO SCALE



NOT TO SCALE

---