

# NEW LEAK WORK ORDER

SECTION 1 PROJECT DATA						LEAK NUMBER
HOUSE 305	UNIT # Cooper Point Rd Nw	CITY Olympia			PLAT MAP 268.008	
REPORTED BY CO. HYDROMAX USA	NAME OR CONSULTANT NAME Genevieve Lavaud	DATE 02/15/2019	LEAK ORIGIN K	METHOD DETECTED A	PRESSURE P	
EQUIPMENT ID 9101551015	GRADE A	TIME 19:11	REPORT SOURCE O	FACILITY TYPE M	PSE GAS SYSTEM DISPLAYED ACCURATELY Yes	

## INSTRUCTIONS OR ORIGINAL LOC/CGI READS

(THIS INCLUDES LOCATION OF ALL ANODES INSTALLED, LEAK CLAMPS ETC.)

North district regulator vault 42 ft west of Cooper Pt Rd, 126 ft north of Harrison Ave. Spread is in south vault.  
Spread is 50' south.


Highest Gas Percentage: 3.00%    Latitude: 47.04747632738872    Longitude: -122.94138285457484

## Leak Work Order



### Gas Sample Location

-  Gas Box
-  Gas Vault
-  Manhole
-  Other
-  Storm Drain


### Highest Reading

-  Site of Highest Reading

### Gas Percentage

-  0.00%
-  Non Zero % Gas

### Phantom Leak

-  Phantom Leak

### Gas Services

-  Gas Services

### Gas Mains

-  Conduit
-  HP
-  IP
-  LP
-  NA
-  Transmission

