**EnvironmSafe for Engineering, Trading & Services Ltd.**
www.environmsafe.com | support@environmsafe.com
+967 78 340 2932 | Al Buraiqah, Aden, Yemen

| | | | |
|---|---|---|---|
| **Certificate number** | ES-R-12-001 | **Revision** | Rev. 00 |
| **Client** | DEMO – Sample Process Plant (not a real client) | **Site** | Demo Utilities Area |
| **Tag number** | PSV-101A | **Description** | Steam drum safety valve A |
| **Manufacturer** | Demo Valves | **Model** | SV-3 |
| **Serial number** | DV-1101 | **Date of test** | 09 Oct 2026 |

## 1. VALVE DATA

| | | | |
|---|---|---|---|
| **Valve type** | Conventional spring | **Protected equipment** | B-101 steam drum |
| **Inlet size** | 3 in | **Outlet size** | 4 in |
| **Orifice** | J | **Service** | Steam |

## 2. TEST RESULTS

| Parameter | Value | Result |
|---|---|---|
| Set pressure | 43 bar | |
| Tolerance | ± 0.689 bar | ASME I |
| Cold differential test pressure | 43 bar | |
| As-found pop pressure | 44.6 bar | Outside tolerance |
| As-left set pressure | 43.1 bar | Within tolerance |
| Reseat pressure | 40.5 bar | |
| Seat tightness (API 527) | | Pass |
| Test medium | Air | |
| Test bench / gauge | ES-TB-01 / G-114 (cal. due 2027-03) | |

## 3. PARTS CONDITION

| Part | Condition found | Action taken |
|---|---|---|
| Disc | Light wire drawing | Lapped |
| Seat | Light wire drawing | Lapped |
| Spring | Good | None |

**Final result: ACCEPTED. We certify that the valve was tested and set at 43.1 bar, found within the required tolerance, and sealed.**

| | |
|---|---|
| **Valid until / next test due** | 09 Oct 2027 |

| Tested / examined by | Witnessed by | Issued by |
|---|---|---|
| **Demo Inspector**<br>Senior Inspector · Cert. API 510 #00000<br>Date: 09 Oct 2026 | **Demo Plant Engineer**<br>Date: | **Demo Office Lead**<br>Date: 10 Oct 2026 |