

Site Installation Requirements - 2026 Deployment

1. Environmental Constraints

- **Temperature:** Operating environment must be maintained between 18°C and 25°C.
- **Power Supply:** Rack-mount units require dedicated 220V power circuits. Wall-mount units can operate on standard 110V/220V outlets.
- **Space:** A minimum clearance of 10cm is required on all sides of the equipment for adequate airflow.

2. Mounting Guidelines

- **Rack-Mount:** Must be installed in a standard 19-inch server rack. Use all 4 mounting screws provided in the kit.
- **Wall-Mount:** Ensure the wall material is load-bearing. Use drywall anchors for installations on non-concrete surfaces.

3. Safety Compliance

- All installations must be grounded. Do not bypass the grounding lug on the chassis.