

GAS PROCESSING & METHANOL COMPLEX PROJECT NO. 11998A

Project	FEED for Gas Gathering Pipelines & Associated Infrastructure
Client	Brass Fertilizer and Petrochemical Company Limited
Originating Company	Epic Atlantic Limited
Document Title	Instrument Point DataBase- BBOU,ELEPA,AKABEL
Document Number	EA-BFPCL-GPMC-GGPL-FEED-ICS-RPT-002
Document Revision	R02
Document Status	Issued For Review
Originator	KIRAN
Security Classification	Restricted
Issue Date	5 Aug 2022

Instrument Point DataBase

R02	05.08.22	Re-issued for Review	KIRAN	PAUL	A . Duru	
R01	05.07.22	Issued for review	KIRAN	PAUL	A . Duru	
Rev #	Issue Date	Status Description	Originator	Reviewer	Approver (Epic)	Approver (BFPCL)

Revision History

Rev No.	Date	Description of Revision
R01	05.07.22	Issued for review
R02	05.08.22	Re-issued for Review

Instrument Point DataBase- BBOU,ELEPA,AKABEL

Revision Philosophy:

- a. All documents for review shall be issued at R01, with subsequent R02, R03, etc as required.
- b. All documents approved for issue or approved for design shall be issued at A01 with subsequent A02, A03, etc. as required. (Management of Change is required for A02, A03, etc.).
for the subsequent project phases, post FEED, it is expected that:
- c. All Detailed Design documents for review shall be issued at D01, with subsequent D02, D03, etc. as required.
- d. All documents approved for construction shall be issued at C01 with subsequent C02, C03, etc. as required. (Management of Change is required for C02, C03, etc.)
- e. All approved "As-Built" documents shall be issued at Z01, with subsequent Z02, Z03, etc as required. (Use versions Z01.1, Z01.2, Z01.3, etc to review the "As-Built" document to Z02).

Restricted

This document is made available subject to the condition that the recipient will neither use nor disclose the contents except as agreed in writing with the copyright owner. Copyright is vested in Brass Fertilizer and Petrochemical Company Limited (BFPCL)
© All rights reserved.

Neither the whole nor any part of this document may be reproduced or distributed in any form or by any means (electronic, mechanical, reprographic, recording, or otherwise) without the prior written consent of the copyright owner.

SUMMARY PAGE

Client:	Brass Fertilizer & Petrochemical Company Limited	
Project:	Gas Processing & Methanol Complex	Project No. 11998A
Facility:	Gas Gathering Pipelines & Associated Infrastructure	Doc No. EA-BFPCL-GPMC-GGPL-FEED-ICS-RPT-002

The administration of this document is in respect of FEED for Gas Gathering Pipelines & Associated Infrastructure for the Gas Processing & Methanol Plant Project of BFPCL.

The Pipelines will be implemented in two phases, - starting with BBOU & ELEP as Phase 1 and followed by NUNR, SEIB & OPUG as Phase 2. The focus of the present FEED is on Phase 1, while Phase 2 will be implemented later.

It is also a precursor and accompaniment to the FEED study & report that will lead to the project's FID and implementation.

The report has relied on and used data and reference documents provided by the client, and if further documents and information become available, Epic Atlantic reserves the right to update the opinion set out in this report.

For better appreciation, this document should be read in conjunction with the references listed below, which are the Concept Select Study reports that constitute basis for the Conceptual Study.

KEYWORDS: BASIS OF DESIGN, PIPELINE, MANIFOLD, PLATFORM, GAS, PLANT, ROW, PTS

Instrument Point DataBase

Document No.	Description

Table of Contents

INSTRUMENT POINT DATA BASE -BBOU	5
INSTRUMENT POINT DATA BASE -ELEPA	7
INSTRUMENT POINT DATABASE -AKABEL	11

Instrument Point DataBase- BBOU,ELEPA,AKABEL

Instrument Point DataBase

EA | TCE | BFPCL 05 Aug 22 5 of 11

Notes

1. This point data base is tentative, subject to the finalisation of P&ID.
2. Interface signals from SPDC are not captured in this document as there is no input available.
3. Interface Signals for Pipeline Leak Detections shall be detailed out during detail engineering.
4. Communication interface and failure signals shall be detailed out during detail engineering.

Instrumentation Point Database-ELEP (Revision- R02)

Sr. No.	P&ID No.	Loop Reference	Tag No.	Application	Service	Location	Line No./Equipment No.	Piping Class	Pipe Material	Op. Press.	Design Press	Op. Temp.	Design Temp.	Type of Instruments	IO Type
1	PSE-DWG-003 Sh 4 of 8	ELEP-F-1001	ELEP-FE1-1001	Check Meter at the inlet manifold	Hydrocarbon	Field		CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Venturi Meter	-
2	PSE-DWG-003 Sh 4 of 8	ELEP-F-1001	ELEP-DPT-1001	Differential Pressure Measurement at the inlet across Venturi Meter	Hydrocarbon	Field		CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	DP Transmitter	AI
3	PSE-DWG-003 Sh 4 of 8	ELEP-F-1001	ELEP-FI-1001A	Flow Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
4	PSE-DWG-003 Sh 4 of 8	ELEP-F-1001	ELEP-FI-1001B	Flow Indication at Remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
5	PSE-DWG-003 Sh 4 of 8	ELEP-F-1001	ELEP-FIQ-1001A	Flow Totalizer at RTU		PLC-RTU								On PLC-RTU Screen	Soft
6	PSE-DWG-003 Sh 4 of 8	ELEP-F-1001	ELEP-FIQ-1001B	Flow Totalizer at Remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
7	PSE-DWG-003 Sh 4 of 8	ELEP-F-1002	ELEP-FE1-1002	Check Meter at the inlet manifold	Hydrocarbon	Field		CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Venturi Meter	-
8	PSE-DWG-003 Sh 4 of 8	ELEP-F-1002	ELEP-DPT-1002	Differential Pressure Measurement at the inlet across Venturi Meter	Hydrocarbon	Field		CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	DP Transmitter	AI
9	PSE-DWG-003 Sh 4 of 8	ELEP-F-1002	ELEP-FI-1002A	Flow Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
10	PSE-DWG-003 Sh 4 of 8	ELEP-F-1002	ELEP-FI-1002B	Flow Indication at Remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
11	PSE-DWG-003 Sh 4 of 8	ELEP-F-1002	ELEP-FIQ-1002A	Flow Totalizer at RTU		PLC-RTU								On PLC-RTU Screen	Soft
12	PSE-DWG-003 Sh 4 of 8	ELEP-F-1002	ELEP-FIQ-1002B	Flow Totalizer at Remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
13	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PI-1001	Battery Limit Pressure at the Inlet Manifold of ELEP	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-
14	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PI1-1001	Battery Limit Pressure at the Inlet Manifold of ELEP	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI
15	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PI-1001A	Battery Limit Pressure Indication at RTU-Inlet Manifold of ELEP		PLC-RTU								On PLC-RTU Screen	Soft
16	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PI-1001B	Battery Limit Pressure Indication at remote DCS-Inlet Manifold of ELEP		Remote DCS								On Remote DCS Screen	V-SAT/Serial
17	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PAI-1001	Flowline Pressure Low Alarm at RTU		PLC-RTU								On PLC-RTU Screen	Soft
18	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PAI-1001	Flowline Pressure High Alarm at RTU		Remote DCS								On Remote DCS Screen	V-SAT/Serial
19	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PAH-1001A	Flowline Pressure Low Alarm at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
20	PSE-DWG-003 Sh 4 of 8	ELEP-P-1001	ELEP-PAH-1001A	Flowline Pressure High Alarm at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
21	PSE-DWG-003 Sh 4 of 8	ELEP-T-1001	ELEP-TWI1-1001	Battery Limit Temperature at the Inlet Manifold of ELEP	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Temperature Gauge with Thermowell	-
22	PSE-DWG-003 Sh 4 of 8	ELEP-T-1001	ELEP-TWI1-1001	Battery Limit Temperature at the Inlet Manifold of ELEP		PLC-RTU								RTU with Thermowell	-
23	PSE-DWG-003 Sh 4 of 8	ELEP-T-1001	ELEP-TIT-1001	Battery Limit Temperature at the Inlet Manifold of ELEP	Hydrocarbon	Field		CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Temperature Transmitter	AI
24	PSE-DWG-003 Sh 4 of 8	ELEP-T-1001	ELEP-TI-1001A	Battery Limit Temperature at RTU-Inlet Manifold of ELEP		PLC-RTU								On PLC-RTU Screen	Soft
25	PSE-DWG-003 Sh 4 of 8	ELEP-T-1001	ELEP-TI-1001B	Battery Limit Temperature at Remote DCS-Inlet Manifold of ELEP		DCS								On Remote DCS Screen	V-SAT/Serial
26	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-PSV-1001	Inlet pressure reduction-ELEP Gathering Manifold	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Regulator	-
27	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-SOV-1001	Inlet Shutdown Valve-ELEP Gathering Manifold	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Shut-down Valve- Gas Over Liquid	-
28	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-SD-1001	ESD Command from RTU		PLC-RTU								Push Button	OI
29	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-SD-1001A	ESD Command from Remote DCS		DCS								Push Button	V-SAT/Serial
30	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-SOV-1001A	Inlet SDV Close Signal		Field	-							Solenoid Valve	DO
31	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-SOV-1001B	Inlet SDV Open Signal		Field	-							Solenoid Valve	DO
32	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-ZSC-1001	Inlet SDV Close Feedback Limit Switch		Field	-							Limit Switch- Close	OI
33	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-ZSO-1001	Inlet SDV Open Feedback Limit Switch		Field	-							Limit Switch-Open	OI
34	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-ZIC-1001	Inlet SDV Close Feedback at PLC-RTU		PLC-RTU								On PLC-RTU Screen	Soft
35	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-ZIO-1001	Inlet SDV Open Feedback at PLC-RTU		PLC-RTU								On PLC-RTU Screen	Soft
36	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-ZIC-1001A	Inlet SDV Close Feedback at remote DCS		DCS								On Remote DCS Screen	V-SAT/Serial
37	PSE-DWG-003 Sh 4 of 8	ELEP-S-1001	ELEP-ZIO-1001A	Inlet SDV Open Feedback at remote DCS		DCS								On Remote DCS Screen	V-SAT/Serial
38	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PI-1002	Flowline Pressure to ELEP-A-200 Launcher	Hydrocarbon	Field		CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-
39	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PI1-1002	Flowline Pressure for Interlock-ELEP Gathering Manifold	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI
40	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PI-1002A	Flowline Pressure Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
41	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PI-1002B	Flowline Pressure Indication at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
42	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PAI-1002	Flowline Pressure Low Alarm at RTU		PLC-RTU								On PLC-RTU Screen	Soft
43	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PAH-1002	Flowline Pressure High Alarm at RTU		Remote DCS								On Remote DCS Screen	V-SAT/Serial
44	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PAI-1002A	Flowline Pressure Low Alarm at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
45	PSE-DWG-003 Sh 4 of 8	ELEP-P-1002	ELEP-PAH-1002A	Flowline Pressure High Alarm at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
46	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PI1-1003	Flowline Pressure for Interlock-ELEP Gathering Manifold	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI
47	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PI-1003A	Flowline Pressure Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
48	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PI-1003B	Flowline Pressure Indication at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
49	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PAI-1003	Flowline Pressure Low Alarm at RTU		PLC-RTU								On PLC-RTU Screen	Soft
50	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PAH-1003	Flowline Pressure High Alarm at RTU		Remote DCS								On PLC-RTU Screen	Soft
51	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PAI-1003A	Flowline Pressure Low Alarm at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
52	PSE-DWG-003 Sh 4 of 8	ELEP-P-1003	ELEP-PAH-1003A	Flowline Pressure High Alarm at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
53	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PI1-1004	Flowline Pressure for Interlock-ELEP Gathering Manifold	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI
54	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PI-1004A	Flowline Pressure Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
55	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PI-1004B	Flowline Pressure Indication at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
56	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PAI-1004	Flowline Pressure Low Alarm at RTU		PLC-RTU								On PLC-RTU Screen	Soft
57	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PAH-1004	Flowline Pressure High Alarm at RTU		Remote DCS								On PLC-RTU Screen	Soft
58	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PAI-1004A	Flowline Pressure Low Alarm at remote DCS		Remote DCS								On PLC-RTU Screen	V-SAT/Serial
59	PSE-DWG-003 Sh 4 of 8	ELEP-P-1004	ELEP-PAH-1004A	Flowline Pressure High Alarm at remote DCS		Remote DCS								On PLC-RTU Screen	V-SAT/Serial
60	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-BDV-1002	Blowdown Valve to Vent	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Blowdown Valve- Gas Over Liquid	-
61	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-B-1002	ESD Command from RTU		PLC-RTU								Push Button	OI
62	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-B-1002A	ESD Command from Remote DCS		DCS								Push Button	V-SAT/Serial
63	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-SOV-1002A	BDV Close Signal		Field	-							Solenoid Valve	DO
64	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-SOV-1002B	BDV Open Signal		Field	-							Solenoid Valve	DO
65	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-ZSC-1002	BDV Close Feedback Limit Switch		Field	-							Limit Switch- Close	OI
66	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-ZSO-1002	BDV Open Feedback Limit Switch		Field	-							Limit Switch-Open	OI
67	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-ZIC-1002	BDV Close Feedback at PLC-RTU		PLC-RTU								On PLC-RTU Screen	Soft
68	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-ZIO-1002	BDV Open Feedback at PLC-RTU		PLC-RTU								On PLC-RTU Screen	Soft
69	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-ZIC-1002A	BDV Close Feedback at remote DCS		DCS								On Remote DCS Screen	V-SAT/Serial
70	PSE-DWG-003 Sh 4 of 8	ELEP-B-1002	ELEP-ZIO-1002A	BDV Open Feedback at remote DCS		DCS								On Remote DCS Screen	V-SAT/Serial
71	PSE-DWG-003 Sh 4 of 8	ELEP-P-1005	ELEP-PI1-1005	Instrument Gas Manifold Pressure Measurement	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI
72	PSE-DWG-003 Sh 4 of 8	ELEP-P-1005	ELEP-PI-1005A	Instrument Gas Manifold Pressure Measurement- RTU Indication		PLC-RTU								On PLC-RTU Screen	Soft
73	PSE-DWG-003 Sh 4 of 8	ELEP-P-1005	ELEP-PI-1005B	Instrument Gas Manifold Pressure Measurement- Remote DCS Indication		Remote DCS								On Remote DCS Screen	V-SAT/Serial
74	PSE-DWG-003 Sh 4 of 8	-	ELEP-RO-1001	Restriction Orifice to Vent-ELEP Vent Line Depressurization Orifice	Hydrocarbon	Field	ELEP-24"-P-004-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Restriction Orifice	-
75	PSE-DWG-003 Sh 4 of 8	-	ELEP-PSV-1001	Inlet Safety Valve-ELEP Vent Line	Hydrocarbon	Field	ELEP-24"-P-006-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Safety Valve	-
76	PSE-DWG-003 Sh 4 of 8	-	ELEP-PSV-1002	Inlet Safety Valve-ELEP Vent Line	Hydrocarbon	Field	ELEP-24"-P-007-CL900	CL 900	CS API SL	100 barg	110 barg	50-95 degC	100 degC	Safety Valve	-
77	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AE(IAT)-1001	Point Type Gas Detector		Field								IR Type HC Detector	AI
78	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AI-1001	Point Type Gas Detector Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
79	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AI-1001A	Point Type Gas Detector Indication at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
80	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AAH-1001	Point Type Gas Detector High Alarm at RTU		PLC-RTU								On PLC-RTU Screen	Soft
81	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AAHH-1001	Point Type Gas Detector High High Alarm at RTU		PLC-RTU								On Remote DCS Screen	V-SAT/Serial
82	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AAH-1001A	Point Type Gas Detector High Alarm at Remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
83	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1001	ELEP-AAHH-1001A	Point Type Gas Detector High High Alarm at Remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
84	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1002	ELEP-AE(IAT)-1002	Point Type Gas Detector		Field								IR Type HC Detector	AI
85	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1002	ELEP-AI-1002	Point Type Gas Detector Indication at RTU		PLC-RTU								On PLC-RTU Screen	Soft
86	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1002	ELEP-AI-1002A	Point Type Gas Detector Indication at remote DCS		Remote DCS								On Remote DCS Screen	V-SAT/Serial
87	PSE-DWG-003 Sh 4 of 8	ELEP-AI-1002	ELEP-AAH-1002	Point Type Gas Detector High Alarm at RTU		PLC-RTU									

207	PSE-DWG-003 Sh 6 of 8	ELEP-P-1014	ELEP-PI-1014	Pressure on the Pig Launcher ELEP-A-300	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-
208	PSE-DWG-003 Sh 6 of 8	ELEP-P-1015	ELEP-PI-1015	Pressure on the Pig Launcher ELEP-A-300	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-
209	PSE-DWG-003 Sh 6 of 8	ELEP-P-1016	ELEP-PI-1016	Pressure at the outlet of the Pig Launcher ELEP-A-300	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-
210	PSE-DWG-003 Sh 6 of 8	-	ELEP-PSV-1005	Pressure Safety Valve to Vent ELEP-A-300	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Safety Valve	-
211	PSE-DWG-003 Sh 6 of 8	-	ELEP-RO-1004	Restriction Orifice to Vent - ELEP-A-300	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Restriction Orifice	-
212	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PII-1018	Flowline Pressure for Interlock-ELEP-A-300 Launcher	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI
213	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PI-1018A	Flowline Pressure Indication at RTU- ELEP-A-300 Launcher		PLC-RTU								On PLC-RTU Screen	Soft

214	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PI-1018B	Flowline Pressure Indication at remote DCS -ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
215	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PAL-1018	Flowline Pressure Low Alarm at RTU -ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
216	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PAH-1018	Flowline Pressure High Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
217	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PAL-1018A	Flowline Pressure Low Alarm at remote DCS -ELEP-A-300 Launcher	Remote DCS												On PLC-RTU Screen	V-SAT/Serial
218	PSE-DWG-003 Sh 6 of 8	ELEP-P-1018	ELEP-PAH-1018A	Flowline Pressure High Alarm at remote DCS - ELEP-A-300 Launcher	Remote DCS												On PLC-RTU Screen	V-SAT/Serial
219	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PI-1019	Flowline Pressure for interlock-ELEP-A-300 Launcher	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Pressure Transmitter	AI
220	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PI-1019A	Flowline Pressure Indication at RTU- ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
221	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PI-1019B	Flowline Pressure Indication at remote DCS -ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
222	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PAL-1019	Flowline Pressure Low Alarm at RTU -ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
223	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PAH-1019	Flowline Pressure High Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
224	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PAL-1019A	Flowline Pressure Low Alarm at remote DCS -ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
225	PSE-DWG-003 Sh 6 of 8	ELEP-P-1019	ELEP-PAH-1019A	Flowline Pressure High Alarm at remote DCS - ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
226	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PI-1020	Flowline Pressure for interlock-ELEP-A-300 Launcher	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Pressure Transmitter	AI
227	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PI-1020A	Flowline Pressure Indication at RTU- ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
228	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PI-1020B	Flowline Pressure Indication at remote DCS -ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
229	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PAL-1020	Flowline Pressure Low Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
230	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PAH-1020	Flowline Pressure High Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU												On PLC-RTU Screen	Soft
231	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PAL-1020A	Flowline Pressure Low Alarm at remote DCS -ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
232	PSE-DWG-003 Sh 6 of 8	ELEP-P-1020	ELEP-PAH-1020A	Flowline Pressure High Alarm at remote DCS - ELEP-A-300 Launcher	Remote DCS												On Remote DCS Screen	V-SAT/Serial
233	PSE-DWG-003 Sh 7 of 8	ELEP-P-1021	ELEP-PI-1021	Pressure measurement of closed Drain Vessel ELEP-CDT-001	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Pressure Transmitter	AI
234	PSE-DWG-003 Sh 7 of 8	ELEP-P-1024	ELEP-PI-1024A	Pressure Indication at RTU	PLC-RTU												On PLC-RTU Screen	Soft
235	PSE-DWG-003 Sh 7 of 8	ELEP-P-1021	ELEP-PI-1021B	Pressure Indication at Remote DCS	Remote DCS												On Remote DCS Screen	V-SAT/Serial
236	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LIT-1001	Level for interlock-Closed Drain Vessel ELEP-CDT-001	Hydrocarbon	Field	ELEP-X"-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Guided Wave Radar Transmitter	AI
237	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LI-1001A	Level Indication at RTU- Closed Drain Vessel ELEP-CDT-001	PLC-RTU												On PLC-RTU Screen	Soft
238	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LI-1001B	Level Indication at remote DCS -Closed Drain Vessel ELEP-CDT-001	Remote DCS												On Remote DCS Screen	V-SAT/Serial
239	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LAL-1001	Level Low Alarm at RTU -Closed Drain Vessel ELEP-CDT-001	PLC-RTU												On PLC-RTU Screen	Soft
240	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LAH-1001	Level High Alarm at RTU - Closed Drain Vessel ELEP-CDT-001	PLC-RTU												On PLC-RTU Screen	Soft
241	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LAL-1001A	Level Low Alarm at remote DCS -Closed Drain Vessel ELEP-CDT-001	Remote DCS												On PLC-RTU Screen	V-SAT/Serial
242	PSE-DWG-003 Sh 7 of 8	ELEP-L-1001	ELEP-LAH-1001A	Level High Alarm at remote DCS - Closed Drain Vessel ELEP-CDT-001	Remote DCS												On PLC-RTU Screen	V-SAT/Serial
243	PSE-DWG-003 Sh 7 of 8	-	ELEP-LIG-1001	Level Indication at Closed Drain Vessel ELEP-CDT-001	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Level Gauge	-
244	PSE-DWG-003 Sh 7 of 8	-	ELEP-TWT/TI-1003	Temperature on the Closed Drain Vessel ELEP-CDT-001	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				RTD with Thermowell	-
245	PSE-DWG-003 Sh 7 of 8	ELEP-T-1004	ELEP-TIT-1004	Temperature on the Closed Drain Vessel ELEP-CDT-001	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Temperature Transmitter	AI
246	PSE-DWG-003 Sh 7 of 8	ELEP-T-1004	ELEP-TI-1004A	Temperature indication at RTU	PLC-RTU												On PLC-RTU Screen	Soft
247	PSE-DWG-003 Sh 7 of 8	ELEP-T-1004	ELEP-TI-1004B	Temperature indication at Remote DCS	Remote DCS												On Remote DCS Screen	V-SAT/Serial
248	PSE-DWG-003 Sh 7 of 8	ELEP-L-1002	ELEP-LIT-1002	Level at ELEP-CDT-001	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC				Guided Wave Radar Transmitter	AI
249	PSE-DWG-003 Sh 7 of 8	ELEP-L-1002	ELEP-LI-1002A	Level Indication at RTU- ELEP-CDT-001	PLC-RTU												On PLC-RTU Screen	Soft
250	PSE-DWG-003 Sh 7 of 8	ELEP-L-1002	ELEP-LI-1002B	Level Indication at remote DCS -ELEP-CDT-001	Remote DCS												On Remote DCS Screen	V-SAT/Serial
251	PSE-DWG-003 Sh 7 of 8	ELEP-LD-1001	ELEP-LDG-1001	Leak Detection System	PLC-RTU												On PLC-RTU Screen	Serial

Notes

1. This point data base is tentative, subject to the finalisation of P&ID.
2. Interface signals from SPDC are not captured in this document as there is no input available.
3. Interface Signals for Pipeline Leak Detections shall be detailed out during detail engineering.
4. Communication interface and failure signals shall be detailed out during detail engineering.

Instrumentation Point Database-AKAB | Revision: R02|

Sr. No.	Tag No.	Loop Reference	Tag No.	Application	Service	Location	Line No./Equipment No.	Piping Class	Pipe Material	Op. Press.	Design Press	Op. Temp.	Design Temp.	Type of Instruments	IO Type	Range	Set Point	Unit	Alarm	Trip	Signal from / to	Supply Voltage	Remarks	Revision
1	PSE-DWG-003 Sh B of B	-	AKAB-P-1001	Battery Limit Pressure at the Inlet of Pig Receiver AKAB-A-100	Hydrocarbon	Field	ELEP-X'-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	AI	0-150		barg						
2	PSE-DWG-003 Sh B of B	-	AKAB-P-1001	Battery Limit Pressure at the Inlet of Pig Receiver AKAB-A-100	Hydrocarbon	Field	ELEP-X'-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI	0-150		barg						
3	PSE-DWG-003 Sh B of B	-	AKAB-P-1001	Battery Limit Pressure Indication at RTU/Pig Receiver AKAB-A-100	-	PLC-RTU								On PLC-RTU Screen	Soft	010-								
4	PSE-DWG-003 Sh B of B	-	AKAB-P-1001B	Battery Limit Pressure Indication at remote DCS/Pig Receiver AKAB-A-100	Remote DCS	Field								On Remote DCS Screen	Serial									
5	PSE-DWG-003 Sh B of B	-	AKAB-T-1001	Battery Limit Temperature/Pig Receiver AKAB-A-100	Hydrocarbon	Field	ELEP-P'-P-002-CL1000	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Temperature Gauge with Thermowell	AI									
6	PSE-DWG-003 Sh B of B	-	AKAB-T-1001	Battery Limit Temperature/Pig Receiver AKAB-A-100	Hydrocarbon	Field								RTD with Thermowell	AI									
7	PSE-DWG-003 Sh B of B	-	AKAB-T-1001	Battery Limit Temperature/Pig Receiver AKAB-A-100	Hydrocarbon	Field								Temperature Transmitter	AI	150		degC						
8	PSE-DWG-003 Sh B of B	-	AKAB-T-1001A	Battery Limit Temperature at RTU/Pig Receiver AKAB-A-100	Hydrocarbon	Field								On PLC-RTU Screen	Soft									
9	PSE-DWG-003 Sh B of B	-	AKAB-T-1001B	Battery Limit Temperature at remote DCS/Pig Receiver AKAB-A-100	DCS	Field								On Remote DCS Screen	Serial									
10	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-SOV-1001	Instrument Point Database- BBOU/ELEPA/AKABEL	Hydrocarbon	Field	ELEP-X'-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Shutdown Valve- Gas Over Liquid	DI								
11	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-SOV-1001	ESD Command From RTU	PLC-RTU								Push Button	DI									
12	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-SOV-1001A	ESD Command from Remote DCS	DCS								Push Button	Serial									
13	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-SOV-1001A	Inlet SOV Close Signal	Field								Solenoid Valve	DO									
14	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-SOV-1001B	Inlet SOV Open Signal	Field								Solenoid Valve	DO									
15	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-ZSC-1001	Inlet SOV Close Feedback Limit Switch	Field								Limit Switch- Close	DI									
16	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-ZSO-1001	Inlet SOV Open Feedback Limit Switch	Field								Limit Switch-Open	DI									
17	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-ZSC-1001	Inlet SOV Close Feedback at PLC-RTU	PLC-RTU								On PLC-RTU Screen	Soft									
Next Point On	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-ZSO-1001	Inlet SOV Open Feedback at PLC-RTU	PLC-RTU								On PLC-RTU Screen	Soft									
	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-ZSC-1001A	Inlet SOV Close Feedback at remote DCS	DCS								On Remote DCS Screen	Serial									
20	PSE-DWG-003 Sh B of B	-	AKAB-S-1001	AKAB-ZSO-1001A	Inlet SOV Open Feedback at remote DCS	DCS								On Remote DCS Screen	Serial									
21	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PI-1002	Flowline Pressure for Interlock-AKAB Gathering Manifold	Hydrocarbon	Field	AKAB-X'-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI	0-150		barg					
22	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PI-1002A	Flowline Pressure Indication at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
23	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PI-1002B	Flowline Pressure Indication at remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
24	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PAH-1002	Flowline Pressure Low Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
25	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PAH-1002	Flowline Pressure High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
26	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PAL-1002A	Flowline Pressure Low Alarm at remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
27	PSE-DWG-003 Sh B of B	-	AKAB-P-1002	AKAB-PAH-1002A	Flowline Pressure High Alarm at remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
28	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PI-1003	Flowline Pressure for Interlock-AKAB Gathering Manifold	Hydrocarbon	Field	AKAB-X'-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI	0-150		barg					
29	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PI-1003A	Flowline Pressure Indication at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
30	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PI-1003B	Flowline Pressure Indication at remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
31	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PAL-1003	Flowline Pressure Low Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
32	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PAH-1003	Flowline Pressure High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
33	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PAL-1003A	Flowline Pressure Low Alarm at remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
34	PSE-DWG-003 Sh B of B	-	AKAB-P-1003	AKAB-PAH-1003A	Flowline Pressure High Alarm at remote DCS	Remote DCS								On PLC-RTU Screen	V-SAT/Serial									
35	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PI-1004	Flowline Pressure for Interlock-AKAB Gathering Manifold	Hydrocarbon	Field	AKAB-X'-P-002-CL900	CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Transmitter	AI	0-150		barg					
36	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PI-1004A	Flowline Pressure Indication at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
37	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PI-1004B	Flowline Pressure Indication at remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
38	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PAL-1004	Flowline Pressure Low Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
39	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PAH-1004	Flowline Pressure High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
40	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PAL-1004A	Flowline Pressure Low Alarm at remote DCS	Remote DCS								On PLC-RTU Screen	V-SAT/Serial									
41	PSE-DWG-003 Sh B of B	-	AKAB-P-1004	AKAB-PAH-1004A	Flowline Pressure High Alarm at remote DCS	Remote DCS								On PLC-RTU Screen	V-SAT/Serial									
42	PSE-DWG-003 Sh B of B	-	-	AKAB-B-1003	Pig Indicator at the Inlet of the Pig Receiver AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Local Pig Signaller	AI								
43	PSE-DWG-003 Sh B of B	-	AKAB-B-1004	Pig Indicator on the Pig Receiver AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Local Pig Signaller	-									
44	PSE-DWG-003 Sh B of B	-	AKAB-P-1011	AKAB-PI-1011	Pressure at the Pig Receiver AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-								
45	PSE-DWG-003 Sh B of B	-	AKAB-P-1012	AKAB-PI-1012	Pressure on the Pig Receiver AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-								
46	PSE-DWG-003 Sh B of B	-	AKAB-P-1013	AKAB-PI-1013	Pressure on the Pig Receiver AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Pressure Gauge	-								
47	PSE-DWG-003 Sh B of B	-	AKAB-PV-1004	AKAB-PV-1004	Pressure Safety Valve to Vent AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Safety Valve	-								
48	PSE-DWG-003 Sh B of B	-	AKAB-RO-1003	AKAB-RO-1003	Restriction Orifice to Vent - AKAB-A-100	Hydrocarbon	Field		CL 900	CS API 5L	100 barg	110 barg	50-95 degC	100 degC	Restriction Orifice	AI								
49	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AE/AT-1001	Point Type Gas Detector	Field								RT Type HC Detector	AI									
50	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AE-1001	Point Type Gas Detector Indication at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
51	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AE-1001A	Point Type Gas Detector Indication at remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
52	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AAH-1001	Point Type Gas Detector High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
53	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AAH-1001	Point Type Gas Detector High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
54	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AAH-1001A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
55	PSE-DWG-003 Sh B of B	-	AKAB-A-1001	AKAB-AAH-1001A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
56	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AE/AT-1002T	Open Path Gas Detector (Transmitter)	Field								RT Type Open Path HC Detector-Transmitter	24V Power									
57	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AE/AT-1002R	Open Path Gas Detector (Receiver)	Field								RT Type Open Path HC Detector-Receiver	AI									
58	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AE-1002	Open Path Gas Detector Indication at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
59	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AE-1002A	Open Path Gas Detector Indication at remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
60	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AAH-1002	Open Path Gas Detector High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
61	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AAH-1002	Open Path Gas Detector High Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
62	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AAH-1002A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
63	PSE-DWG-003 Sh B of B	-	AKAB-A-1002	AKAB-AAH-1002A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
64	PSE-DWG-003 Sh B of B	-	AKAB-M-1001	AKAB-MAC-1001A	Manual Alarm Call Point (Field ESD)	Field								Manual Call Point	DI									
65	PSE-DWG-003 Sh B of B	-	AKAB-M-1001	AKAB-MAA-1001A	Manual Alarm Call Point Alarm at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
66	PSE-DWG-003 Sh B of B	-	AKAB-M-1001	AKAB-MAA-1001B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS								On Remote DCS Screen	Radio/Serial									
67	PSE-DWG-003 Sh B of B	-	AKAB-H-1003	ELEP-HB-1003	Hoster and Reason combine	Field								Hoster-Reason	DO									
68	PSE-DWG-003 Sh B of B	-	AKAB-H-1003	ELEP-HB-1003A	Hoster-Reason Display at RTU	PLC-RTU								On PLC-RTU Screen	Soft									
69	PSE-DWG-003 Sh B of B	-	AKAB-H-1003	ELEP-HB-1003B	Hoster Reason Display at Remote DCS	Remote DCS								On Remote DCS Screen	V-SAT/Serial									
70	PSE-DWG-003 Sh B of B	-	AKAB-LD-1001	AKAB-LDS-1001	Leak Detection System	PLC-RTU								On PLC-RTU Screen	Serial									

Notes

- This point data base is tentative, subject to the finalization of P&ID.
- Interface signals from SPDC are not captured in this document as there is no input available.
- Interface Signals for Pipeline Leak Detections shall be detailed out during detail engineering.
- Communication interface and failure signals shall be detailed out during detail engineering.