

Instrumentation Point Database-BBOU (Revision- R03)

Sr. No.	Tag No.	Application	Location	Type of Instruments	IO Type
1	BBOU-FE/FT-1001	Check Meter at the inlet manifold	Field	Venturi Meter	-
2	BBOU-DPT-1001	Differential Pressure Measurement at the inlet across Ve	Field	DP Transmitter	AI
3	BBOU-FI-1001A	Flow Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
4	BBOU-FI-1001B	Flow Indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
5	BBOU-FQI-1001A	Flow Totalizer at RTU	PLC-RTU	On PLC-RTU Screen	Soft
6	BBOU-FQI-1001B	Flow Totalizer at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
7	BBOU-FE/FT-1002	Check Meter at the inlet manifold	Field	Venturi Meter	-
8	BBOU-DPT-1002	Differential Pressure Measurement at the inlet across Ve	Field	DP Transmitter	AI
9	BBOU-FI-1002A	Flow Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
10	BBOU-FI-1002B	Flow Indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
11	BBOU-FQI-1002A	Flow Totalizer at RTU	PLC-RTU	On PLC-RTU Screen	Soft
12	BBOU-FQI-1002B	Flow Totalizer at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
13	BBOU-PI-1001	Battery Limit Pressure at the Inlet Manifold of BBOU	Field	Pressure Gauge	-
14	BBOU-PIT-1001	Battery Limit Pressure at the Inlet Manifold of BBOU	Field	Pressure Transmitter	AI
15	BBOU-PI-1001A	Battery Limit Pressure indication at RTU-Inlet Manifold d	PLC-RTU	On PLC-RTU Screen	Soft
16	BBOU-PI-1001B	Battery Limit Pressure indication at remote DCS-Inlet Ma	Remote DCS	On Remote DCS Screen	V-SAT/Serial
17	BBOU-PAL-1001	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
18	BBOU-PAH-1001	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
19	BBOU-PAL-1001A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
20	BBOU-PAH-1001A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
21	BBOU-TW/TI-1001	Battery Limit Temperature at the Inlet Manifold of BBOU	Field	Temperature Gauge with Thermowell	-
22	BBOU-TW/TE-1001	Battery Limit Temperature at the Inlet Manifold of BBOU	Field	RTD with Thermowell	-
23	BBOU-TIT-1001	Battery Limit Temperature at the Inlet Manifold of BBOU	Field	Temperature Transmitter	AI
24	BBOU-TI-1001A	Battery Limit Temperature at RTU-Inlet Manifold of BBO	PLC-RTU	On PLC-RTU Screen	Soft
25	BBOU-TI-1001B	Battery Limit Temperature at remote DCS-Inlet Manifold	DCS	On Remote DCS Screen	V-SAT/Serial
26	BBOU-PCV-1001	Inlet pressure reduction-BBOU Gathering Manifold	Field	Pressure Regulator	-
27	BBOU-SDV-1001	Inlet Shutdown Valve-BBOU Gathering Manifold	Field	Shutdown Valve- Gas Over Liquid	-
28	BBOU-SD-1001	ESD Command from RTU	PLC-RTU	Push Button	DI
29	BBOU-SD-1001A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
30	BBOU-SOV-1001A	Inlet SDV Close Signal	Field	Solenoid Valve	DO
31	BBOU-SOV-1001B	Inlet SDV Open Signal	Field	Solenoid Valve	DO
32	BBOU-ZSC-1001	Inlet SDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
33	BBOU-ZSO-1001	Inlet SDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
34	BBOU-ZIC-1001	Inlet SDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
35	BBOU-ZIO-1001	Inlet SDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
36	BBOU-ZIC-1001A	Inlet SDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
37	BBOU-ZIO-1001A	Inlet SDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
38	BBOU-PI-1002	Flowline Pressure to BBOU-A-200 Launcher	Field	Pressure Gauge	-
39	BBOU-PIT-1002	Flowline Pressure for interlock-BBOU Gathering Manifold	Field	Pressure Transmitter	AI

40	BBOU-PI-1002A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
41	BBOU-PI-1002B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
42	BBOU-PAL-1002	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
43	BBOU-PAH-1002	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
44	BBOU-PAL-1002A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
45	BBOU-PAH-1002A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
46	BBOU-PIT-1003	Flowline Pressure for interlock-BBOU Gathering Manifold	Field	Pressure Transmitter	AI
47	BBOU-PI-1003A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
48	BBOU-PI-1003B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
49	BBOU-PAL-1003	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
50	BBOU-PAH-1003	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
51	BBOU-PAL-1003A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
52	BBOU-PAH-1003A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
53	BBOU-PIT-1004	Flowline Pressure for interlock-BBOU Gathering Manifold	Field	Pressure Transmitter	AI
54	BBOU-PI-1004A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
55	BBOU-PI-1004B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
56	BBOU-PAL-1004	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
57	BBOU-PAH-1004	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
58	BBOU-PAL-1004A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
59	BBOU-PAH-1004A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
60	BBOU-BDV-1002	Blowdown Valve to Vent	Field	Blowdown Valve- Gas Over Liquid	-
61	BBOU-SD-1002	ESD Command from RTU	PLC-RTU	Push Button	DI
62	BBOU-SD-1002A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
63	BBOU-SOV-1002A	BDV Close Signal	Field	Solenoid Valve	DO
64	BBOU-SOV-1002B	BDV Open Signal	Field	Solenoid Valve	DO
65	BBOU-ZSC-1002	BDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
66	BBOU-ZSO-1002	BDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
67	BBOU-ZIC-1002	BDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
68	BBOU-ZIO-1002	BDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
69	BBOU-ZIC-1002A	BDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
70	BBOU-ZIO-1002A	BDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
71	BBOU-PIT-1005	Instrument Gas Manifold Pressure Measurement	Field	Pressure Transmitter	AI
72	BBOU-PI-1005A	Instrument Gas Manifold Pressure Measurement- RTU Indication	PLC-RTU	On PLC-RTU Screen	Soft
73	BBOU-PI-1005B	Instrument Gas Manifold Pressure Measurement- Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
74	BBOU-RO-1001	Restriction Orifice to Vent-BBOU Vent Line Depressurisation	Field	Restriction Orifice	-
75	BBOU-PSV-1001	Inlet Safety Valve-BBOU Vent Line	Field	Safety Valve	-
76	BBOU-PSV-1002	Inlet Safety Valve-BBOU Vent Line	Field	Safety Valve	-
77	BBOU-AE/AT-1001	Point Type Gas Detector	Field	IR Type HC Detector	AI
78	BBOU-AI-1001	Point Type Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
79	BBOU-AI-1001A	Point Type Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
80	BBOU-AAH-1001	Point Type Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft

81	BBOU-AAHH-1001	Point Type Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
82	BBOU-AAH-1001A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
83	BBOU-AAHH-1001A	Point Type Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
84	BBOU-AE/AT-1002	Point Type Gas Detector	Field	IR Type HC Detector	AI
85	BBOU-AI-1002	Point Type Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
86	BBOU-AI-1002A	Point Type Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
87	BBOU-AAH-1002	Point Type Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
88	BBOU-AAHH-1002	Point Type Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
89	BBOU-AAH-1002A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
90	BBOU-AAHH-1002A	Point Type Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
91	BBOU-AE/AT-1003T	Open Path Gas Detector (Transmitter)	Field	IR Type Open Path HC Detector-Transmit	24V Power
92	BBOU-AE/AT-1003R	Open Path Gas Detector (Receiver)	Field	IR Type Open Path HC Detector-Receiver	AI
93	BBOU-AI-1003	Open Path Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
94	BBOU-AI-1003A	Open Path Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
95	BBOU-AAH-1003	Open Path Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
96	BBOU-AAHH-1003	Open Path Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
97	BBOU-AAH-1003A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
98	BBOU-AAHH-1003A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
99	BBOU-AE/AT-1004T	Open Path Gas Detector (Transmitter)	Field	IR Type Open Path HC Detector-Transmit	24V Power
100	BBOU-AE/AT-1004R	Open Path Gas Detector (Receiver)	Field	IR Type Open Path HC Detector-Receiver	AI
101	BBOU-AI-1004	Open Path Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
102	BBOU-AI-1004A	Open Path Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
103	BBOU-AAH-1004	Open Path Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
104	BBOU-AAHH-1004	Open Path Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
105	BBOU-AAH-1004A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
106	BBOU-AAHH-1004A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
107	BBOU-MAC-1001A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
108	BBOU-MAA-1001A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
109	BBOU-MAA-1001B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
110	BBOU-MAC-1002A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
111	BBOU-MAA-1002A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
112	BBOU-MAA-1002B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
113	BBOU-MAC-1003A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
114	BBOU-MAA-1003A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
115	BBOU-MAA-1003B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
116	BBOU-MAC-1004A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
117	BBOU-MAA-1004A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
118	BBOU-MAA-1004B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
119	BBOU-HB-1004	Hooter and beacon combine	Field	Hooter-Beacon	DO
120	BBOU-HBI-1004A	Hooter-Beacon Display at RTU	PLC-RTU	On PLC-RTU Screen	Soft
121	BBOU-HBI-1004B	Hooter Beacon Display at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial

122	BBOU-PI-1006	Battery Limit Pressure at the Inlet of Pig Receiver BBOU-	Field	Pressure Gauge	-
123	BBOU-PIT-1006	Battery Limit Pressure at the Inlet of Pig Receiver BBOU-	Field	Pressure Transmitter	AI
124	BBOU-PI-1006A	Battery Limit Pressure indication at RTU-Pig Receiver BBOU-	PLC-RTU	On PLC-RTU Screen	Soft
125	BBOU-PI-1006B	Battery Limit Pressure indication at remote DCS-Pig Receiver BBOU-	Remote DCS	On Remote DCS Screen	V-SAT/Serial
126	BBOU-TW/TI-1002	Battery Limit Temperature-Pig Receiver BBOU-A-100- Future	Field	Temperature Gauge with Thermowell	-
127	BBOU-TW/TE-1002	Battery Limit Temperature-Pig Receiver BBOU-A-100- Future	Field	RTD with Thermowell	-
128	BBOU-TIT-1002	Battery Limit Temperature-Pig Receiver BBOU-A-100- Future	Field	Temperature Transmitter	AI
129	BBOU-TI-1002A	Battery Limit Temperature at RTU-Pig Receiver BBOU-A-100	PLC-RTU	On PLC-RTU Screen	Soft
130	BBOU-TI-1002B	Battery Limit Temperature at remote DCS-Pig Receiver BBOU-A-100	DCS	On Remote DCS Screen	V-SAT/Serial
131	BBOU-SDV-1002	Inlet Shutdown Valve-OPUGBENE Pig Receiver BBOU-A-100	Field	Shutdown Valve- Gas Over Liquid	-
132	BBOU-SD-1002	ESD Command from RTU- Future	PLC-RTU	Push Button	DI
133	BBOU-SD-1002A	ESD Command from Remote DCS- Future	DCS	Push Button	V-SAT/Serial
134	BBOU-SOV-1002A	Inlet SDV Close Signal- Future	Field	Solenoid Valve	DO
135	BBOU-SOV-1002B	Inlet SDV Open Signal- Future	Field	Solenoid Valve	DO
136	BBOU-ZSC-1002	Inlet SDV Close Feedback Limit Switch- Future	Field	Limit Switch- Close	DI
137	BBOU-ZSO-1002	Inlet SDV Open Feedback Limit Switch- Future	Field	Limit Switch-Open	DI
138	BBOU-ZIC-1002	Inlet SDV Close Feedback at PLC-RTU- Future	PLC-RTU	On PLC-RTU Screen	Soft
139	BBOU-ZIO-1002	Inlet SDV Open Feedback at PLC-RTU- Future	PLC-RTU	On PLC-RTU Screen	Soft
140	BBOU-ZIC-1002A	Inlet SDV Close Feedback at remote DCS- Future	DCS	On Remote DCS Screen	V-SAT/Serial
141	BBOU-ZIO-1002A	Inlet SDV Open Feedback at remote DCS- Future	DCS	On Remote DCS Screen	V-SAT/Serial
142	BBOU-ZI-1001	Pig Indicator at the Inlet of the Pig Receiver BBOU-A-100	Field	Local Pig Signaller	-
143	BBOU-ZI-1002	Pig Indicator on the Pig Receiver BBOU-A-100 Future	Field	Local Pig Signaller	-
144	BBOU-PI-1007	Pressure at the Pig Receiver BBOU-A-100 Future	Field	Pressure Gauge	-
145	BBOU-PI-1008	Pressure on the Pig Receiver BBOU-A-100 Future	Field	Pressure Gauge	-
146	BBOU-PI-1009	Pressure on the Pig Receiver BBOU-A-100 Future	Field	Pressure Gauge	-
147	BBOU-PSV-1002	Pressure Safety Valve to Vent BBOU-A-100 Future	Field	Safety Valve	-
148	BBOU-RO-1002	Restriction Orifice to Vent - BBOU-A-100 Future	Field	Restriction Orifice	-
149	BBOU-SDV-1003	Outlet Shutdown Valve- Pig Launcher BBOU-A-200	Field	Shutdown Valve- Gas Over Liquid	-
150	BBOU-SD-1003	ESD Command from RTU	PLC-RTU	Push Button	DI
151	BBOU-SD-1003A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
152	BBOU-SOV-1003A	Outlet SDV Close Signal	Field	Solenoid Valve	DO
153	BBOU-SOV-1003B	Outlet SDV Open Signal	Field	Solenoid Valve	DO
154	BBOU-ZSC-1003	Outlet SDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
155	BBOU-ZSO-1003	Outlet SDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
156	BBOU-ZIC-1003	Outlet SDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
157	BBOU-ZIO-1003	Outlet SDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
158	BBOU-ZIC-1003A	Outlet SDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
159	BBOU-ZIO-1003A	Outlet SDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
160	BBOU-ZI-1003	Pig Indicator at the outlet of the Pig Launcher BBOU-A-200	Field	Local Pig Signaller	-
161	BBOU-ZI-1004	Pig Indicator on the Pig Launcher BBOU-A-200	Field	Local Pig Signaller	-
162	BBOU-PI-1010	Pressure on the Pig Launcher BBOU-A-200	Field	Pressure Gauge	-

163	BBOU-PI-1011	Pressure on the Pig Launcher BBOU-A-200	Field	Pressure Gauge	-
164	BBOU-PI-1012	Pressure at the outlet of the Pig Launcher BBOU-A-200	Field	Pressure Gauge	-
165	BBOU-PSV-1004	Pressure Safety Valve to Vent BBOU-A-200	Field	Safety Valve	-
166	BBOU-RO-1003	Restriction Orifice to Vent - BBOU-A-200	Field	Restriction Orifice	-
167	BBOU-PIT-1013	Flowline Pressure for interlock-BBOU-A-200 Launcher	Field	Pressure Transmitter	AI
168	BBOU-PI-1013A	Flowline Pressure Indication at RTU- BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
169	BBOU-PI-1013B	Flowline Pressure Indication at remote DCS -BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
170	BBOU-PAL-1013	Flowline Pressure Low Alarm at RTU -BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
171	BBOU-PAH-1013	Flowline Pressure High Alarm at RTU - BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
172	BBOU-PAL-1013A	Flowline Pressure Low Alarm at remote DCS -BBOU-A-200	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
173	BBOU-PAH-1013A	Flowline Pressure High Alarm at remote DCS - BBOU-A-200	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
174	BBOU-PIT-1014	Flowline Pressure for interlock-BBOU-A-200 Launcher	Field	Pressure Transmitter	AI
175	BBOU-PI-1014A	Flowline Pressure Indication at RTU- BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
176	BBOU-PI-1014B	Flowline Pressure Indication at remote DCS -BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
177	BBOU-PAL-1014	Flowline Pressure Low Alarm at RTU -BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
178	BBOU-PAH-1014	Flowline Pressure High Alarm at RTU - BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
179	BBOU-PAL-1014A	Flowline Pressure Low Alarm at remote DCS -BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
180	BBOU-PAH-1014A	Flowline Pressure High Alarm at remote DCS - BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
181	BBOU-PIT-1015	Flowline Pressure for interlock-BBOU-A-200 Launcher	Field	Pressure Transmitter	AI
182	BBOU-PI-1015A	Flowline Pressure Indication at RTU- BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
183	BBOU-PI-1015B	Flowline Pressure Indication at remote DCS -BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
184	BBOU-PAL-1015	Flowline Pressure Low Alarm at RTU -BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
185	BBOU-PAH-1015	Flowline Pressure High Alarm at RTU - BBOU-A-200 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
186	BBOU-PAL-1015A	Flowline Pressure Low Alarm at remote DCS -BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
187	BBOU-PAH-1015A	Flowline Pressure High Alarm at remote DCS - BBOU-A-200	Remote DCS	On Remote DCS Screen	V-SAT/Serial
188	BBOU-PIT-1016	Pressure measurement of closed Drain Vessel BBOU-CDT-001	Field	Pressure Transmitter	AI
189	BBOU-PI-1016A	Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
190	BBOU-PI-1016B	Pressure Indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
191	BBOU-LIT-1001	Level for interlock-Closed Drain Vessel BBOU-CDT-001	Field	Guided Wave Radar Transmitter	AI
192	BBOU-LI-1001A	Level Indication at RTU- Closed Drain Vessel BBOU-CDT-001	PLC-RTU	On PLC-RTU Screen	Soft
193	BBOU-LI-1001B	Level Indication at remote DCS -Closed Drain Vessel BBOU-CDT-001	Remote DCS	On Remote DCS Screen	V-SAT/Serial
194	BBOU-LAL-1001	Level Low Alarm at RTU -Closed Drain Vessel BBOU-CDT-001	PLC-RTU	On PLC-RTU Screen	Soft
195	BBOU-LAH-1001	Level High Alarm at RTU - Closed Drain Vessel BBOU-CDT-001	PLC-RTU	On PLC-RTU Screen	Soft
196	BBOU-LAL-1001A	Level Low Alarm at remote DCS -Closed Drain Vessel BBOU-CDT-001	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
197	BBOU-LAH-1001A	Level High Alarm at remote DCS - Closed Drain Vessel BBOU-CDT-001	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
198	BBOU-LG-1001	Level Indication at Closed Drain Vessel BBOU-CDT-001	Field	Level Gauge	-
199	BBOU-TW/TE-1003	Temperature on the Closed Drain Vessel BBOU-CDT-001	Field	RTD with Thermowell	-
200	BBOU-TIT-1003	Temperature on the Closed Drain Vessel BBOU-CDT-001	Field	Temperature Transmitter	AI
201	BBOU-TI-1003A	Temperature indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
202	BBOU-TI-1003B	Temperature indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
203	BBOU-LIT-1002	Level at BBOU-ODT-001	Field	Guided Wave Radar Transmitter	AI

204	BBOU-LI-1002A	Level Indication at RTU- BBOU-ODT-001	PLC-RTU	On PLC-RTU Screen	Soft
205	BBOU-LI-1002B	Level Indication at remote DCS -BBOU-ODT-001	Remote DCS	On Remote DCS Screen	V-SAT/Serial
206	BBOU-LDS-1001	Leak Detection System	PLC-RTU	On PLC-RTU Screen	Serial

Notes

1. This point data base is tentative, subject to the finalisation of P&ID.
2. Interface signals from SPDC are not captured in this document as there is no input available.
3. Interface Signals for Pipeline Leak Detections shall be detailed out during detail engineering
4. Communication interface and failure signals shall be detailed out during detail engineering.

Instrumentation Point Database-ELEP (Revision- R03)

Sr. No.	Tag No.	Application	Location	Type of Instruments	IO Type
1	ELEP-FE/FT-1001	Check Meter at the inlet manifold	Field	Venturi Meter	-
2	ELEP-DPT-1001	Differential Pressure Measurement at the inlet across V	Field	DP Transmitter	AI
3	ELEP-FI-1001A	Flow Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
4	ELEP-FI-1001B	Flow Indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
5	ELEP-FQI-1001A	Flow Totalizer at RTU	PLC-RTU	On PLC-RTU Screen	Soft
6	ELEP-FQI-1001B	Flow Totalizer at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
7	ELEP-FE/FT-1002	Check Meter at the inlet manifold	Field	Venturi Meter	-
8	ELEP-DPT-1002	Differential Pressure Measurement at the inlet across V	Field	DP Transmitter	AI
9	ELEP-FI-1002A	Flow Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
10	ELEP-FI-1002B	Flow Indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
11	ELEP-FQI-1002A	Flow Totalizer at RTU	PLC-RTU	On PLC-RTU Screen	Soft
12	ELEP-FQI-1002B	Flow Totalizer at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
13	ELEP-PI-1001	Battery Limit Pressure at the Inlet Manifold of ELEP	Field	Pressure Gauge	-
14	ELEP-PIT-1001	Battery Limit Pressure at the Inlet Manifold of ELEP	Field	Pressure Transmitter	AI
15	ELEP-PI-1001A	Battery Limit Pressure indication at RTU-Inlet Manifold	PLC-RTU	On PLC-RTU Screen	Soft
16	ELEP-PI-1001B	Battery Limit Pressure indication at remote DCS-Inlet M	Remote DCS	On Remote DCS Screen	V-SAT/Serial
17	ELEP-PAL-1001	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
18	ELEP-PAH-1001	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
19	ELEP-PAL-1001A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
20	ELEP-PAH-1001A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
21	ELEP-TW/TI-1001	Battery Limit Temperature at the Inlet Manifold of ELEP	Field	Temperature Gauge with Thermowell	-
22	ELEP-TW/TE-1001	Battery Limit Temperature at the Inlet Manifold of ELEP	Field	RTD with Thermowell	-
23	ELEP-TIT-1001	Battery Limit Temperature at the Inlet Manifold of ELEP	Field	Temperature Transmitter	AI
24	ELEP-TI-1001A	Battery Limit Temperature at RTU-Inlet Manifold of ELEP	PLC-RTU	On PLC-RTU Screen	Soft
25	ELEP-TI-1001B	Battery Limit Temperature at remote DCS-Inlet Manifo	DCS	On Remote DCS Screen	V-SAT/Serial
26	ELEP-PCV-1001	Inlet pressure reduction-ELEP Gathering Manifold	Field	Pressure Regulator	-
27	ELEP-SDV-1001	Inlet Shutdown Valve-ELEP Gathering Manifold	Field	Shutdown Valve- Gas Over Liquid	-
28	ELEP-SD-1001	ESD Command from RTU	PLC-RTU	Push Button	DI
29	ELEP-SD-1001A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
30	ELEP-SOV-1001A	Inlet SDV Close Signal	Field	Solenoid Valve	DO
31	ELEP-SOV-1001B	Inlet SDV Open Signal	Field	Solenoid Valve	DO
32	ELEP-ZSC-1001	Inlet SDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
33	ELEP-ZSO-1001	Inlet SDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
34	ELEP-ZIC-1001	Inlet SDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
35	ELEP-ZIO-1001	Inlet SDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
36	ELEP-ZIC-1001A	Inlet SDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
37	ELEP-ZIO-1001A	Inlet SDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
38	ELEP-PI-1002	Flowline Pressure to ELEP-A-200 Launcher	Field	Pressure Gauge	-
39	ELEP-PIT-1002	Flowline Pressure for interlock-ELEP Gathering Manifo	Field	Pressure Transmitter	AI
40	ELEP-PI-1002A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
41	ELEP-PI-1002B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
42	ELEP-PAL-1002	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft

43	ELEP-PAH-1002	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
44	ELEP-PAL-1002A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
45	ELEP-PAH-1002A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
46	ELEP-PIT-1003	Flowline Pressure for interlock-ELEP Gathering Manifold	Field	Pressure Transmitter	AI
47	ELEP-PI-1003A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
48	ELEP-PI-1003B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
49	ELEP-PAL-1003	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
50	ELEP-PAH-1003	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
51	ELEP-PAL-1003A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
52	ELEP-PAH-1003A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
53	ELEP-PIT-1004	Flowline Pressure for interlock-ELEP Gathering Manifold	Field	Pressure Transmitter	AI
54	ELEP-PI-1004A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
55	ELEP-PI-1004B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
56	ELEP-PAL-1004	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
57	ELEP-PAH-1004	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
58	ELEP-PAL-1004A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
59	ELEP-PAH-1004A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
60	ELEP-BDV-1002	Blowdown Valve to Vent	Field	Blowdown Valve- Gas Over Liquid	-
61	ELEP-SD-1002	ESD Command from RTU	PLC-RTU	Push Button	DI
62	ELEP-SD-1002A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
63	ELEP-SOV-1002A	BDV Close Signal	Field	Solenoid Valve	DO
64	ELEP-SOV-1002B	BDV Open Signal	Field	Solenoid Valve	DO
65	ELEP-ZSC-1002	BDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
66	ELEP-ZSO-1002	BDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
67	ELEP-ZIC-1002	BDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
68	ELEP-ZIO-1002	BDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
69	ELEP-ZIC-1002A	BDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
70	ELEP-ZIO-1002A	BDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
71	ELEP-PIT-1005	Instrument Gas Manifold Pressure Measurement	Field	Pressure Transmitter	AI
72	ELEP-PI-1005A	Instrument Gas Manifold Pressure Measurement- RTU Indication	PLC-RTU	On PLC-RTU Screen	Soft
73	ELEP-PI-1005B	Instrument Gas Manifold Pressure Measurement- Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
74	ELEP-RO-1001	Restriction Orifice to Vent-ELEP Vent Line Depressurisation	Field	Restriction Orifice	-
75	ELEP-PSV-1001	Inlet Safety Valve-ELEP Vent Line	Field	Safety Valve	-
76	ELEP-PSV-1002	Inlet Safety Valve-ELEP Vent Line	Field	Safety Valve	-
77	ELEP-AE/AT-1001	Point Type Gas Detector	Field	IR Type HC Detector	AI
78	ELEP-AI-1001	Point Type Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
79	ELEP-AI-1001A	Point Type Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
80	ELEP-AAH-1001	Point Type Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
81	ELEP-AAHH-1001	Point Type Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
82	ELEP-AAH-1001A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
83	ELEP-AAHH-1001A	Point Type Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
84	ELEP-AE/AT-1002	Point Type Gas Detector	Field	IR Type HC Detector	AI
85	ELEP-AI-1002	Point Type Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
86	ELEP-AI-1002A	Point Type Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial

87	ELEP-AAH-1002	Point Type Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
88	ELEP-AAHH-1002	Point Type Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
89	ELEP-AAH-1002A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
90	ELEP-AAHH-1002A	Point Type Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
91	ELEP-AE/AT-1003T	Open Path Gas Detector (Transmitter)	Field	IR Type Open Path HC Detector-Transmitter	24V Power
92	ELEP-AE/AT-1003R	Open Path Gas Detector (Receiver)	Field	IR Type Open Path HC Detector-Receiver	AI
93	ELEP-AI-1003	Open Path Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
94	ELEP-AI-1003A	Open Path Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
95	ELEP-AAH-1003	Open Path Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
96	ELEP-AAHH-1003	Open Path Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
97	ELEP-AAH-1003A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
98	ELEP-AAHH-1003A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
99	ELEP-AE/AT-1004T	Open Path Gas Detector (Transmitter)	Field	IR Type Open Path HC Detector-Transmitter	24V Power
100	ELEP-AE/AT-1004R	Open Path Gas Detector (Receiver)	Field	IR Type Open Path HC Detector-Receiver	AI
101	ELEP-AI-1004	Open Path Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
102	ELEP-AI-1004A	Open Path Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
103	ELEP-AAH-1004	Open Path Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
104	ELEP-AAHH-1004	Open Path Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
105	ELEP-AAH-1004A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
106	ELEP-AAHH-1004A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
107	ELEP-MAC-1001A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
108	ELEP-MAA-1001A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
109	ELEP-MAA-1001B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
110	ELEP-MAC-1002A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
111	ELEP-MAA-1002A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
112	ELEP-MAA-1002B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
113	ELEP-MAC-1003A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
114	ELEP-MAA-1003A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
115	ELEP-MAA-1003B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
116	ELEP-MAC-1004A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
117	ELEP-MAA-1004A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
118	ELEP-MAA-1004B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
119	ELEP-HB-1004	Hooter and beacon combine	Field	Hooter-Beacon	DO
120	ELEP-HBI-1004A	Hooter-Beacon Display at RTU	PLC-RTU	On PLC-RTU Screen	Soft
121	ELEP-HBI-1004B	Hooter Beacon Display at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
122	ELEP-PI-1006	Battery Limit Pressure at the Inlet of Pig Receiver ELEP-	Field	Pressure Gauge	-
123	ELEP-PIT-1006	Battery Limit Pressure at the Inlet of Pig Receiver ELEP-	Field	Pressure Transmitter	AI
124	ELEP-PI-1006A	Battery Limit Pressure indication at RTU-Pig Receiver ELEP-	PLC-RTU	On PLC-RTU Screen	Soft
125	ELEP-PI-1006B	Battery Limit Pressure indication at remote DCS-Pig Receiver ELEP-	Remote DCS	On Remote DCS Screen	V-SAT/Serial
126	ELEP-TW/TI-1002	Battery Limit Temperature-Pig Receiver ELEP-A-100- Fuel	Field	Temperature Gauge with Thermowell	-
127	ELEP-TW/TE-1002	Battery Limit Temperature-Pig Receiver ELEP-A-100- Fuel	Field	RTD with Thermowell	-
128	ELEP-TIT-1002	Battery Limit Temperature-Pig Receiver ELEP-A-100- Fuel	Field	Temperature Transmitter	AI
129	ELEP-TI-1002A	Battery Limit Temperature at RTU-Pig Receiver ELEP-A-100- Fuel	PLC-RTU	On PLC-RTU Screen	Soft
130	ELEP-TI-1002B	Battery Limit Temperature at remote DCS-Pig Receiver ELEP-A-100- Fuel	DCS	On Remote DCS Screen	V-SAT/Serial

131	ELEP-SDV-1002	Inlet Shutdown Valve-OPUGBENE Pig Receiver ELEP-A-100	Field	Shutdown Valve- Gas Over Liquid	-
132	ELEP-SD-1002	ESD Command from RTU- Future	PLC-RTU	Push Button	DI
133	ELEP-SD-1002A	ESD Command from Remote DCS- Future	DCS	Push Button	V-SAT/Serial
134	ELEP-SOV-1002A	Inlet SDV Close Signal- Future	Field	Solenoid Valve	DO
135	ELEP-SOV-1002B	Inlet SDV Open Signal- Future	Field	Solenoid Valve	DO
136	ELEP-ZSC-1002	Inlet SDV Close Feedback Limit Switch- Future	Field	Limit Switch- Close	DI
137	ELEP-ZSO-1002	Inlet SDV Open Feedback Limit Switch- Future	Field	Limit Switch-Open	DI
138	ELEP-ZIC-1002	Inlet SDV Close Feedback at PLC-RTU- Future	PLC-RTU	On PLC-RTU Screen	Soft
139	ELEP-ZIO-1002	Inlet SDV Open Feedback at PLC-RTU- Future	PLC-RTU	On PLC-RTU Screen	Soft
140	ELEP-ZIC-1002A	Inlet SDV Close Feedback at remote DCS- Future	DCS	On Remote DCS Screen	V-SAT/Serial
141	ELEP-ZIO-1002A	Inlet SDV Open Feedback at remote DCS- Future	DCS	On Remote DCS Screen	V-SAT/Serial
142	ELEP-ZI-1001	Pig Indicator at the Inlet of the Pig Receiver ELEP-A-100	Field	Local Pig Signaller	-
143	ELEP-ZI-1002	Pig Indicator on the Pig Receiver ELEP-A-100 Future	Field	Local Pig Signaller	-
144	ELEP-PI-1007	Pressure at the Pig Receiver ELEP-A-100 Future	Field	Pressure Gauge	-
145	ELEP-PI-1008	Pressure on the Pig Receiver ELEP-A-100 Future	Field	Pressure Gauge	-
146	ELEP-PI-1009	Pressure on the Pig Receiver ELEP-A-100 Future	Field	Pressure Gauge	-
147	ELEP-PSV-1003	Pressure Safety Valve to Vent ELEP-A-100 Future	Field	Safety Valve	-
148	ELEP-RO-1002	Restriction Orifice to Vent - ELEP-A-100 Future	Field	Restriction Orifice	-
149	ELEP-PI-1010	Battery Limit Pressure at the Inlet of Pig Receiver ELEP-A-100	Field	Pressure Gauge	-
150	ELEP-PIT-1010	Battery Limit Pressure at the Inlet of Pig Receiver ELEP-A-100	Field	Pressure Transmitter	AI
151	ELEP-PI-1010A	Battery Limit Pressure indication at RTU-Pig Receiver ELEP-A-100	PLC-RTU	On PLC-RTU Screen	Soft
152	ELEP-PI-1010B	Battery Limit Pressure indication at remote DCS-Pig Receiver ELEP-A-100	Remote DCS	On Remote DCS Screen	V-SAT/Serial
153	ELEP-TW/TI-1003	Battery Limit Temperature-Pig Receiver ELEP-A-200	Field	Temperature Gauge with Thermowell	-
154	ELEP-TW/TE-1003	Battery Limit Temperature-Pig Receiver ELEP-A-200	Field	RTD with Thermowell	-
155	ELEP-TI-1003	Battery Limit Temperature-Pig Receiver ELEP-A-200	Field	Temperature Transmitter	AI
156	ELEP-TI-1003A	Battery Limit Temperature at RTU-Pig Receiver ELEP-A-200	PLC-RTU	On PLC-RTU Screen	Soft
157	ELEP-TI-1003B	Battery Limit Temperature at remote DCS-Pig Receiver ELEP-A-200	DCS	On Remote DCS Screen	V-SAT/Serial
158	ELEP-SDV-1003	Inlet Shutdown Valve-OPUGBENE Pig Receiver ELEP-A-200	Field	Shutdown Valve- Gas Over Liquid	-
159	ELEP-SD-1003	ESD Command from RTU	PLC-RTU	Push Button	DI
160	ELEP-SD-1003A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
161	ELEP-SOV-1003A	Inlet SDV Close Signal	Field	Solenoid Valve	DO
162	ELEP-SOV-1003B	Inlet SDV Open Signal	Field	Solenoid Valve	DO
163	ELEP-ZSC-1003	Inlet SDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
164	ELEP-ZSO-1003	Inlet SDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
165	ELEP-ZIC-1003	Inlet SDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
166	ELEP-ZIO-1003	Inlet SDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
167	ELEP-ZIC-1003A	Inlet SDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
168	ELEP-ZIO-1003A	Inlet SDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
169	ELEP-ZI-1003	Pig Indicator at the Inlet of the Pig Receiver ELEP-A-200	Field	Local Pig Signaller	-
170	ELEP-ZI-1004	Pig Indicator on the Pig Receiver ELEP-A-200	Field	Local Pig Signaller	-
171	ELEP-PI-1011	Pressure at the Pig Receiver ELEP-A-200	Field	Pressure Gauge	-
172	ELEP-PI-1012	Pressure on the Pig Receiver ELEP-A-200	Field	Pressure Gauge	-
173	ELEP-PI-1013	Pressure on the Pig Receiver ELEP-A-200	Field	Pressure Gauge	-
174	ELEP-PSV-1004	Pressure Safety Valve to Vent ELEP-A-200	Field	Safety Valve	-

175	ELEP-RO-1003	Restriction Orifice to Vent - ELEP-A-200	Field	Restriction Orifice	-
176	ELEP-AE/AT-1005	Point Type Gas Detector	Field	IR Type HC Detector	AI
177	ELEP-AI-1005	Point Type Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
178	ELEP-AI-1005A	Point Type Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
179	ELEP-AAH-1005	Point Type Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
180	ELEP-AAHH-1005	Point Type Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
181	ELEP-AAH-1005A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
182	ELEP-AAHH-1005A	Point Type Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
183	ELEP-AE/AT-1006T	Open Path Gas Detector (Transmitter)	Field	IR Type Open Path HC Detector-Transmitter	24V Power
184	ELEP-AE/AT-1006R	Open Path Gas Detector (Receiver)	Field	IR Type Open Path HC Detector-Receiver	AI
185	ELEP-AI-1006	Open Path Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
186	ELEP-AI-1006A	Open Path Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
187	ELEP-AAH-1006	Open Path Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
188	ELEP-AAHH-1006	Open Path Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
189	ELEP-AAH-1006A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
190	ELEP-AAHH-1006A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
191	ELEP-MAC-1005A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
192	ELEP-MAA-1005A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
193	ELEP-MAA-1005B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
194	ELEP-SDV-1004	Outlet Shutdown Valve- Pig Launcher ELEP-A-300	Field	Shutdown Valve- Gas Over Liquid	-
195	ELEP-SD-1004	ESD Command from RTU	PLC-RTU	Push Button	DI
196	ELEP-SD-1004A	ESD Command from Remote DCS	DCS	Push Button	V-SAT/Serial
197	ELEP-SOV-1004A	Outlet SDV Close Signal	Field	Solenoid Valve	DO
198	ELEP-SOV-1004B	Outlet SDV Open Signal	Field	Solenoid Valve	DO
199	ELEP-ZSC-1004	Outlet SDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
200	ELEP-ZSO-1004	Outlet SDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
201	ELEP-ZIC-1004	Outlet SDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
202	ELEP-ZIO-1004	Outlet SDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
203	ELEP-ZIC-1004A	Outlet SDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
204	ELEP-ZIO-1004A	Outlet SDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	V-SAT/Serial
205	ELEP-ZI-1005	Pig Indicator at the outlet of the Pig Launcher ELEP-A-300	Field	Local Pig Signaller	-
206	ELEP-ZI-1006	Pig Indicator on the Pig Launcher ELEP-A-300	Field	Local Pig Signaller	-
207	ELEP-PI-1014	Pressure on the Pig Launcher ELEP-A-300	Field	Pressure Gauge	-
208	ELEP-PI-1015	Pressure on the Pig Launcher ELEP-A-300	Field	Pressure Gauge	-
209	ELEP-PI-1016	Pressure at the outlet of the Pig Launcher ELEP-A-300	Field	Pressure Gauge	-
210	ELEP-PSV-1005	Pressure Safety Valve to Vent ELEP-A-300	Field	Safety Valve	-
211	ELEP-RO-1004	Restriction Orifice to Vent - ELEP-A-300	Field	Restriction Orifice	-
212	ELEP-PIT-1018	Flowline Pressure for interlock-ELEP-A-300 Launcher	Field	Pressure Transmitter	AI
213	ELEP-PI-1018A	Flowline Pressure Indication at RTU- ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft

214	ELEP-PI-1018B	Flowline Pressure Indication at remote DCS -ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
215	ELEP-PAL-1018	Flowline Pressure Low Alarm at RTU -ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
216	ELEP-PAH-1018	Flowline Pressure High Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
217	ELEP-PAL-1018A	Flowline Pressure Low Alarm at remote DCS -ELEP-A-300	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
218	ELEP-PAH-1018A	Flowline Pressure High Alarm at remote DCS - ELEP-A-300	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
219	ELEP-PIT-1019	Flowline Pressure for interlock-ELEP-A-300 Launcher	Field	Pressure Transmitter	AI
220	ELEP-PI-1019A	Flowline Pressure Indication at RTU- ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
221	ELEP-PI-1019B	Flowline Pressure Indication at remote DCS -ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
222	ELEP-PAL-1019	Flowline Pressure Low Alarm at RTU -ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
223	ELEP-PAH-1019	Flowline Pressure High Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
224	ELEP-PAL-1019A	Flowline Pressure Low Alarm at remote DCS -ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
225	ELEP-PAH-1019A	Flowline Pressure High Alarm at remote DCS - ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
226	ELEP-PIT-1020	Flowline Pressure for interlock-ELEP-A-300 Launcher	Field	Pressure Transmitter	AI
227	ELEP-PI-1020A	Flowline Pressure Indication at RTU- ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
228	ELEP-PI-1020B	Flowline Pressure Indication at remote DCS -ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
229	ELEP-PAL-1020	Flowline Pressure Low Alarm at RTU -ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
230	ELEP-PAH-1020	Flowline Pressure High Alarm at RTU - ELEP-A-300 Launcher	PLC-RTU	On PLC-RTU Screen	Soft
231	ELEP-PAL-1020A	Flowline Pressure Low Alarm at remote DCS -ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
232	ELEP-PAH-1020A	Flowline Pressure High Alarm at remote DCS - ELEP-A-300	Remote DCS	On Remote DCS Screen	V-SAT/Serial
233	ELEP-PIT-1021	Pressure measurement of closed Drain Vessel ELEP-CDT-001	Field	Pressure Transmitter	AI
234	ELEP-PI-1021A	Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
235	ELEP-PI-1021B	Pressure Indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
236	ELEP-LIT-1001	Level for interlock-Closed Drain Vessel ELEP-CDT-001	Field	Guided Wave Radar Transmitter	AI
237	ELEP-LI-1001A	Level Indication at RTU- Closed Drain Vessel ELEP-CDT-001	PLC-RTU	On PLC-RTU Screen	Soft
238	ELEP-LI-1001B	Level Indication at remote DCS -Closed Drain Vessel ELEP-CDT-001	Remote DCS	On Remote DCS Screen	V-SAT/Serial
239	ELEP-LAL-1001	Level Low Alarm at RTU -Closed Drain Vessel ELEP-CDT-001	PLC-RTU	On PLC-RTU Screen	Soft
240	ELEP-LAH-1001	Level High Alarm at RTU - Closed Drain Vessel ELEP-CDT-001	PLC-RTU	On PLC-RTU Screen	Soft
241	ELEP-LAL-1001A	Level Low Alarm at remote DCS -Closed Drain Vessel ELEP-CDT-001	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
242	ELEP-LAH-1001A	Level High Alarm at remote DCS - Closed Drain Vessel ELEP-CDT-001	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
243	ELEP-LG-1001	Level Indication at Closed Drain Vessel ELEP-CDT-001	Field	Level Gauge	-
244	ELEP-TW/TE-1003	Temperature on the Closed Drain Vessel ELEP-CDT-001	Field	RTD with Thermowell	-
245	ELEP-TIT-1004	Temperature on the Closed Drain Vessel ELEP-CDT-001	Field	Temperature Transmitter	AI
246	ELEP-TI-1004A	Temperature indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
247	ELEP-TI-1004B	Temperature indication at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
248	ELEP-LIT-1002	Level at ELEP-ODT-001	Field	Guided Wave Radar Transmitter	AI
249	ELEP-LI-1002A	Level Indication at RTU- ELEP-ODT-001	PLC-RTU	On PLC-RTU Screen	Soft
250	ELEP-LI-1002B	Level Indication at remote DCS -ELEP-ODT-001	Remote DCS	On Remote DCS Screen	V-SAT/Serial
251	ELEP-LDS-1001	Leak Detection System	PLC-RTU	On PLC-RTU Screen	Serial

Notes

1. This point data base is tentative, subject to the finalisation of P&ID.
2. Interface signals from SPDC are not captured in this document as there is no input available.
3. Interface Signals for Pipeline Leak Detections shall be detailed out during detail engineering
4. Communication interface and failure signals shall be detailed out during detail engineering.

Instrumentation Point Database-AKAB (Revision- R03)

Sr. No.	Tag No.	Application	Location	Type of Instruments	IO Type
1	AKAB-PI-1001	Battery Limit Pressure at the Inlet of Pig Receiver AKAB-A-100	Field	Pressure Gauge	-
2	AKAB-PIT-1001	Battery Limit Pressure at the Inlet of Pig Receiver AKAB-A-100	Field	Pressure Transmitter	AI
3	AKAB-PI-1001A	Battery Limit Pressure indication at RTU-Pig Receiver AKAB-A-100	PLC-RTU	On PLC-RTU Screen	Soft
4	AKAB-PI-1001B	Battery Limit Pressure indication at remote DCS-Pig Receiver AKAB-A-100	Remote DCS	On Remote DCS Screen	Serial
5	AKAB-TW/TI-1001	Battery Limit Temperature-Pig Receiver AKAB-A-100	Field	Temperature Gauge with Thermowell	-
6	AKAB-TW/TE-1001	Battery Limit Temperature-Pig Receiver AKAB-A-100	Field	RTD with Thermowell	-
7	AKAB-TIT-1001	Battery Limit Temperature-Pig Receiver AKAB-A-100	Field	Temperature Transmitter	AI
8	AKAB-TI-1001A	Battery Limit Temperature at RTU-Pig Receiver AKAB-A-100	PLC-RTU	On PLC-RTU Screen	Soft
9	AKAB-TI-1001B	Battery Limit Temperature at remote DCS-Pig Receiver AKAB-A-100	DCS	On Remote DCS Screen	Serial
10	AKAB-SDV-1001	Inlet Shutdown Valve-OPUGBENE Pig Receiver AKAB-A-100	Field	Shutdown Valve- Gas Over Liquid	-
11	AKAB-SD-1001	ESD Command from RTU	PLC-RTU	Push Button	DI
12	AKAB-SD-1001A	ESD Command from Remote DCS	DCS	Push Button	Serial
13	AKAB-SOV-1001A	Inlet SDV Close Signal	Field	Solenoid Valve	DO
14	AKAB-SOV-1001B	Inlet SDV Open Signal	Field	Solenoid Valve	DO
15	AKAB-ZSC-1001	Inlet SDV Close Feedback Limit Switch	Field	Limit Switch- Close	DI
16	AKAB-ZSO-1001	Inlet SDV Open Feedback Limit Switch	Field	Limit Switch-Open	DI
17	AKAB-ZIC-1001	Inlet SDV Close Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
18	AKAB-ZIO-1001	Inlet SDV Open Feedback at PLC-RTU	PLC-RTU	On PLC-RTU Screen	Soft
19	AKAB-ZIC-1001A	Inlet SDV Close Feedback at remote DCS	DCS	On Remote DCS Screen	Serial
20	AKAB-ZIO-1001A	Inlet SDV Open Feedback at remote DCS	DCS	On Remote DCS Screen	Serial
21	AKAB-PIT-1002	Flowline Pressure for interlock-AKAB Gathering Manifold	Field	Pressure Transmitter	AI
22	AKAB-PI-1002A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
23	AKAB-PI-1002B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
24	AKAB-PAL-1002	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
25	AKAB-PAH-1002	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
26	AKAB-PAL-1002A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
27	AKAB-PAH-1002A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
28	AKAB-PIT-1003	Flowline Pressure for interlock-AKAB Gathering Manifold	Field	Pressure Transmitter	AI
29	AKAB-PI-1003A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
30	AKAB-PI-1003B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
31	AKAB-PAL-1003	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
32	AKAB-PAH-1003	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
33	AKAB-PAL-1003A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
34	AKAB-PAH-1003A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
35	AKAB-PIT-1004	Flowline Pressure for interlock-AKAB Gathering Manifold	Field	Pressure Transmitter	AI
36	AKAB-PI-1004A	Flowline Pressure Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
37	AKAB-PI-1004B	Flowline Pressure Indication at remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
38	AKAB-PAL-1004	Flowline Pressure Low Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
39	AKAB-PAH-1004	Flowline Pressure High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
40	AKAB-PAL-1004A	Flowline Pressure Low Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial
41	AKAB-PAH-1004A	Flowline Pressure High Alarm at remote DCS	Remote DCS	On PLC-RTU Screen	V-SAT/Serial

42	AKAB-ZI-1003	Pig Indicator at the Inlet of the Pig Receiver AKAB-A-100	Field	Local Pig Signaller	-
43	AKAB-ZI-1004	Pig Indicator on the Pig Receiver AKAB-A-100	Field	Local Pig Signaller	-
44	AKAB-PI-1011	Pressure at the Pig Receiver AKAB-A-100	Field	Pressure Gauge	-
45	AKAB-PI-1012	Pressure on the Pig Receiver AKAB-A-100	Field	Pressure Gauge	-
46	AKAB-PI-1013	Pressure on the Pig Receiver AKAB-A-100	Field	Pressure Gauge	-
47	AKAB-PSV-1004	Pressure Safety Valve to Vent AKAB-A-100	Field	Safety Valve	-
48	AKAB-RO-1003	Restriction Orifice to Vent - AKAB-A-100	Field	Restriction Orifice	-
49	AKAB-AE/AT-1001	Point Type Gas Detector	Field	IR Type HC Detector	AI
50	AKAB-AI-1001	Point Type Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
51	AKAB-AI-1001A	Point Type Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
52	AKAB-AAH-1001	Point Type Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
53	AKAB-AAHH-1001	Point Type Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
54	AKAB-AAH-1001A	Point Type Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
55	AKAB-AAHH-1001A	Point Type Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
56	AKAB-AE/AT-1002T	Open Path Gas Detector (Transmitter)	Field	IR Type Open Path HC Detector-Transmitter	24V Power
57	AKAB-AE/AT-1002R	Open Path Gas Detector (Receiver)	Field	IR Type Open Path HC Detector-Receiver	AI
58	AKAB-AI-1002	Open Path Gas Detector Indication at RTU	PLC-RTU	On PLC-RTU Screen	Soft
59	AKAB-AI-1002A	Open Path Gas Detector Indication at remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
60	AKAB-AAH-1002	Open Path Gas Detector High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
61	AKAB-AAHH-1002	Open Path Gas Detector High High Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
62	AKAB-AAH-1002A	Open Path Gas Detector High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
63	AKAB-AAHH-1002A	Open Path Gas Detector High High Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
64	AKAB-MAC-1001A	Manual Alarm Call Point (Field ESD)	Field	Manual Call Point	DI
65	AKAB-MAA-1001A	Manual Alarm Call Point Alarm at RTU	PLC-RTU	On PLC-RTU Screen	Soft
66	AKAB-MAA-1001B	Manual Alarm Call Point Alarm at Remote DCS	Remote DCS	On Remote DCS Screen	Radio/Serial
67	ELEP-HB-1003	Hooter and beacon combine	Field	Hooter-Beacon	DO
68	ELEP-HBI-1003A	Hooter-Beacon Display at RTU	PLC-RTU	On PLC-RTU Screen	Soft
69	ELEP-HBI-1003B	Hooter Beacon Display at Remote DCS	Remote DCS	On Remote DCS Screen	V-SAT/Serial
70	AKAB-LDS-1001	Leak Detection System	PLC-RTU	On PLC-RTU Screen	Serial

Notes

1. This point data base is tentative, subject to the finalisation of P&ID.
2. Interface signals from SPDC are not captured in this document as there is no input available.
3. Interface Signals for Pipeline Leak Detections shall be detailed out during detail engineering.
4. Communication interface and failure signals shall be detailed out during detail engineering.